



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/22/2023
Received: 12/15/2023
Sampled By: Jose Godinez
Work Order: 3349017

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Bridgeport

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3349017-01	Sample Name: B-01 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-02	Sample Name: B-02 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-03	Sample Name: B-03 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	40	ppb	4	15 ppb	12/20/23 16:35 MCLE
3349017-04	Sample Name: B-04 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	22	ppb	2	15 ppb	12/20/23 16:35 MCLE
3349017-05	Sample Name: B-05 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	31	ppb	2	15 ppb	12/20/23 16:35 MCLE
3349017-06	Sample Name: B-06 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	30	ppb	2	15 ppb	12/20/23 16:35 MCLE
3349017-07	Sample Name: B-07 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	12	ppb	1	15 ppb	12/20/23 16:35
3349017-08	Sample Name: B-08 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-09	Sample Name: B-09 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-10	Sample Name: B-10 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/22/2023
Received: 12/15/2023
Sampled By: Jose Godinez
Work Order: 3349017

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Bridgeport

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3349017-11	Sample Name: B-11 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-12	Sample Name: B-12 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-13	Sample Name: B-13 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	10	ppb	1	15 ppb	12/20/23 16:35
3349017-14	Sample Name: B-14 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-15	Sample Name: B-15 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/20/23 16:35
3349017-16	Sample Name: B-16 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/20/23 16:35
3349017-17	Sample Name: B-17 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	14	ppb	1	15 ppb	12/20/23 16:35
3349017-18	Sample Name: B-18 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	11	ppb	1	15 ppb	12/20/23 16:35
3349017-19	Sample Name: B-19 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/20/23 16:35
3349017-20	Sample Name: B-20 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/20/23 16:35



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/22/2023
Received: 12/15/2023
Sampled By: Jose Godinez
Work Order: 3349017

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Bridgeport

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3349017-21	Sample Name: B-21 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	8	ppb	1	15 ppb	12/20/23 16:35
3349017-22	Sample Name: B-22 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/20/23 16:35
3349017-23	Sample Name: B-23 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/20/23 16:35
3349017-24	Sample Name: B-24 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/20/23 16:35
3349017-25	Sample Name: B-25 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/20/23 16:35
3349017-26	Sample Name: B-26 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	12	ppb	1	15 ppb	12/20/23 16:35
3349017-27	Sample Name: B-27 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	10	ppb	1	15 ppb	12/20/23 16:35
3349017-28	Sample Name: B-28 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	9	ppb	1	15 ppb	12/20/23 16:35
3349017-29	Sample Name: B-29 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/20/23 16:35
3349017-30	Sample Name: B-30 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	12/20/23 16:35



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/22/2023
Received: 12/15/2023
Sampled By: Jose Godinez
Work Order: 3349017

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Bridgeport

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3349017-31	Sample Name: B-31 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/20/23 16:35
3349017-32	Sample Name: B-32 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/20/23 16:35
3349017-33	Sample Name: B-33 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/20/23 16:35
3349017-34	Sample Name: B-34 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/20/23 16:35
3349017-35	Sample Name: B-35 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-36	Sample Name: B-36 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/20/23 16:35
3349017-37	Sample Name: B-37 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/20/23 16:35
3349017-38	Sample Name: B-38 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	12/20/23 16:35
3349017-39	Sample Name: B-39 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/20/23 16:35
3349017-40	Sample Name: B-40 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	12	ppb	1	15 ppb	12/20/23 16:35



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/22/2023
Received: 12/15/2023
Sampled By: Jose Godinez
Work Order: 3349017

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Bridgeport

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3349017-41	Sample Name: B-41 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/20/23 16:35
3349017-42	Sample Name: B-42 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	12/20/23 16:35
3349017-43	Sample Name: B-43 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	9	ppb	1	15 ppb	12/20/23 16:35
3349017-44	Sample Name: B-44 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	15	ppb	1	15 ppb	12/20/23 16:35 MCLE
3349017-45	Sample Name: B-45 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	12	ppb	1	15 ppb	12/20/23 16:35
3349017-46	Sample Name: B-46 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	14	ppb	1	15 ppb	12/20/23 16:35
3349017-47	Sample Name: B-47 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	10	ppb	1	15 ppb	12/20/23 16:35
3349017-48	Sample Name: B-48 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	26	ppb	2	15 ppb	12/20/23 16:35 MCLE
3349017-49	Sample Name: B-49 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	23	ppb	2	15 ppb	12/20/23 16:35 MCLE
3349017-50	Sample Name: B-50 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	21	ppb	2	15 ppb	12/20/23 16:35 MCLE



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/22/2023
Received: 12/15/2023
Sampled By: Jose Godinez
Work Order: 3349017

C Apex Environmental
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Bridgeport

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3349017-51	Sample Name: B-51 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	12/20/23 16:35
3349017-52	Sample Name: B-52 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/20/23 16:35
3349017-53	Sample Name: B-53 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-54	Sample Name: B-54 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-55	Sample Name: B-55 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/20/23 16:35
3349017-56	Sample Name: B-56 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	12/20/23 16:35
3349017-57	Sample Name: B-57 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-58	Sample Name: B-58 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/20/23 16:35
3349017-59	Sample Name: B-59 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	12/20/23 16:35
3349017-60	Sample Name: B-60 Sampled: 12/9/23 6:00		Matrix: Water				
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	12/20/23 16:35



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/22/2023
Received: 12/15/2023
Sampled By: Jose Godinez
Work Order: 3349017

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project #: N/A
Sample Type:

Sampling Location: Bridgeport

Lab Number

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: [Signature]
Adriana Gonzalez-Gray
Laboratory Director

Sample #	Date	Location	TIME
B-01	01	12/9/2023 outside gym	0600
B-02	02	12/9/2023 outside gym	0600
B-03	03	12/9/2023 kitchen	0600
B-04	04	12/9/2023 kitchen	0600
B-05	05	12/9/2023 kitchen	0600
B-06	06	12/9/2023 kitchen	0600
B-07	07	12/9/2023 kitchen	0600
B-08	08	12/9/2023 cafeteria	0600
B-09	09	12/9/2023 cafeteria	0600
B-10	10	12/9/2023 health room	0600
B-11	11	12/9/2023 staff room	0600
B-12	12	12/9/2023 staff room	0600
B-13	13	12/9/2023 3	0600
B-14	14	12/9/2023 3	0600
B-15	15	12/9/2023 4	0600
B-16	16	12/9/2023 4	0600
B-17	17	12/9/2023 5	0600
B-18	18	12/9/2023 5	0600
B-19	19	12/9/2023 6	0600
B-20	20	12/9/2023 6	0600
B-21	21	12/9/2023 25	0600
B-22	22	12/9/2023 25	0600
B-23	23	12/9/2023 26	0600
B-24	24	12/9/2023 21	0600
B-25	25	12/9/2023 21	0600
B-26	26	12/9/2023 22	0600
B-27	27	12/9/2023 22	0600
B-28	28	12/9/2023 17	0600
B-29	29	12/9/2023 17	0600
B-30	30	12/9/2023 18	0600
B-31	31	12/9/2023 18	0600
B-32	32	12/9/2023 28	0600
B-33	33	12/9/2023 28	0600
B-34	34	12/9/2023 24	0600
B-35	35	12/9/2023 24	0600
B-36	36	12/9/2023 23	0600
B-37	37	12/9/2023 23	0600
B-38	38	12/9/2023 19	0600
B-39	39	12/9/2023 19	0600
B-40	40	12/9/2023 20	0600
B-41	41	12/9/2023 20	0600
B-42	A2	12/9/2023 7	0600

B-43	43	12/9/2023	7	0600
B-44	44	12/9/2023	8	0600
B-45	45	12/9/2023	8	0600
B-46	46	12/9/2023	9	0600
B-47	47	12/9/2023	9	0600
B-48	48	12/9/2023	12	0600
B-49	49	12/9/2023	12	0600
B-50	50	12/9/2023	11	0600
B-51	51	12/9/2023	11	0600
B-52	52	12/9/2023	10	0600
B-53	53	12/9/2023	10	0600
B-54	54	12/9/2023	13b	0600
B-55	55	12/9/2023	13b	0600
B-56	56	12/9/2023	room adjacent to 13a	0600
B-57	57	12/9/2023	14a	0600
B-58	58	12/9/2023	14a	0600
B-59	59	12/9/2023	14b	0600
B-60	60	12/9/2023	14b	0600