



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>3346032-01</b>	<b>Sample Name:</b> C-01 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-02</b>	<b>Sample Name:</b> C-02 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-03</b>	<b>Sample Name:</b> C-03 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-04</b>	<b>Sample Name:</b> C-04 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-05</b>	<b>Sample Name:</b> C-05 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-06</b>	<b>Sample Name:</b> C-06 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-07</b>	<b>Sample Name:</b> C-07 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-08</b>	<b>Sample Name:</b> C-08 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-09</b>	<b>Sample Name:</b> C-09 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-10</b>	<b>Sample Name:</b> C-10 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>3346032-11</b>	<b>Sample Name:</b> C-11 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-12</b>	<b>Sample Name:</b> C-12 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	9	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-13</b>	<b>Sample Name:</b> C-13 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-14</b>	<b>Sample Name:</b> C-14 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-15</b>	<b>Sample Name:</b> C-15 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-16</b>	<b>Sample Name:</b> C-16 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>21</b>	ppb	10	15 ppb	12/18/23 17:26 <b>MCLE</b>
<b>3346032-17</b>	<b>Sample Name:</b> C-17 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-18</b>	<b>Sample Name:</b> C-18 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-19</b>	<b>Sample Name:</b> C-19 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-20</b>	<b>Sample Name:</b> C-20 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	9	ppb	1	15 ppb	12/18/23 17:26



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>3346032-21</b>	<b>Sample Name:</b> C-21 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-22</b>	<b>Sample Name:</b> C-22 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-23</b>	<b>Sample Name:</b> C-23 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-24</b>	<b>Sample Name:</b> C-24 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-25</b>	<b>Sample Name:</b> C-25 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-26</b>	<b>Sample Name:</b> C-26 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-27</b>	<b>Sample Name:</b> C-27 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-28</b>	<b>Sample Name:</b> C-28 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-29</b>	<b>Sample Name:</b> C-29 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-30</b>	<b>Sample Name:</b> C-30 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>3346032-31</b>	<b>Sample Name:</b> C-31 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-32</b>	<b>Sample Name:</b> C-32 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-33</b>	<b>Sample Name:</b> C-33 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-34</b>	<b>Sample Name:</b> C-34 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-35</b>	<b>Sample Name:</b> C-35 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-36</b>	<b>Sample Name:</b> C-36 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-37</b>	<b>Sample Name:</b> C-37 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-38</b>	<b>Sample Name:</b> C-38 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-39</b>	<b>Sample Name:</b> C-39 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-40</b>	<b>Sample Name:</b> C-40 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>3346032-41</b>	<b>Sample Name:</b> C-41 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-42</b>	<b>Sample Name:</b> C-42 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-43</b>	<b>Sample Name:</b> C-43 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-44</b>	<b>Sample Name:</b> C-44 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-45</b>	<b>Sample Name:</b> C-45 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-46</b>	<b>Sample Name:</b> C-46 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-47</b>	<b>Sample Name:</b> C-47 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-48</b>	<b>Sample Name:</b> C-48 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-49</b>	<b>Sample Name:</b> C-49 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-50</b>	<b>Sample Name:</b> C-50 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>3346032-51</b>	<b>Sample Name:</b> C-51 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-52</b>	<b>Sample Name:</b> C-52 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-53</b>	<b>Sample Name:</b> C-53 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-54</b>	<b>Sample Name:</b> C-54 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-55</b>	<b>Sample Name:</b> C-55 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-56</b>	<b>Sample Name:</b> C-56 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-57</b>	<b>Sample Name:</b> C-57 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-58</b>	<b>Sample Name:</b> C-58 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-59</b>	<b>Sample Name:</b> C-59 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-60</b>	<b>Sample Name:</b> C-60 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>3346032-61</b>	<b>Sample Name:</b> C-61 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-62</b>	<b>Sample Name:</b> C-62 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-63</b>	<b>Sample Name:</b> C-63 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-64</b>	<b>Sample Name:</b> C-64 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-65</b>	<b>Sample Name:</b> C-65 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-66</b>	<b>Sample Name:</b> C-66 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-67</b>	<b>Sample Name:</b> C-67 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-68</b>	<b>Sample Name:</b> C-68 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-69</b>	<b>Sample Name:</b> C-69 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/18/23 17:26
<b>3346032-70</b>	<b>Sample Name:</b> C-70 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/18/23 17:26



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>3346032-71</b>	<b>Sample Name: C-71</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-72</b>	<b>Sample Name: C-72</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-73</b>	<b>Sample Name: C-73</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-74</b>	<b>Sample Name: C-74</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-75</b>	<b>Sample Name: C-75</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-76</b>	<b>Sample Name: C-76</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-77</b>	<b>Sample Name: C-77</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-78</b>	<b>Sample Name: C-78</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-79</b>	<b>Sample Name: C-79</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-80</b>	<b>Sample Name: C-80</b>		<b>Matrix: Water</b>				
	<b>Sampled: 12/2/23 16:00</b>						
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/19/23 17:21





**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>3346032-81</b>	<b>Sample Name:</b> C-81 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-82</b>	<b>Sample Name:</b> C-82 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-83</b>	<b>Sample Name:</b> C-83 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-84</b>	<b>Sample Name:</b> C-84 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-85</b>	<b>Sample Name:</b> C-85 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-86</b>	<b>Sample Name:</b> C-86 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-87</b>	<b>Sample Name:</b> C-87 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/19/23 17:21
<b>3346032-88</b>	<b>Sample Name:</b> C-88 <b>Sampled:</b> 12/2/23 16:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	12/19/23 17:21

**MCL** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.



Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

Reported: 12/21/2023  
Received: 12/08/2023  
Sampled By: Jose Godinez  
Work Order: 3346032

**C** **Apex Environmental**  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: CFT

---

## Lab Number

**Note:** Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director



Sample #	Date	Location	TIME
C-01	01	12/2/2023 Cafeteria	1600
C-02	02	12/2/2023 Cafeteria	1600
C-03	03	12/2/2023 Kitchen	1600
C-04	04	12/2/2023 Kitchen	1600
C-05	05	12/2/2023 Kitchen	1600
C-06	06	12/2/2023 Hallway outside gym	1600
C-07	07	12/2/2023 Hallway outside gym	1600
C-08	08	12/2/2023 Music	1600
C-09	09	12/2/2023 Work Room	1600
C-10	10	12/2/2023 Main office	1600
C-11	11	12/2/2023 Staff room	1600
C-12	12	12/2/2023 Work room	1600
C-13	13	12/2/2023 114	1600
C-14	14	12/2/2023 114	1600
C-15	15	12/2/2023 101	1600
C-16	16	12/2/2023 101	1600
C-17	17	12/2/2023 113	1600
C-18	18	12/2/2023 113	1600
C-19	19	12/2/2023 Outside 112	1600
C-20	20	12/2/2023 Outside 112	1600
C-21	21	12/2/2023 Outside 112	1600
C-22	22	12/2/2023 112	1600
C-23	23	12/2/2023 112	1600
C-24	24	12/2/2023 111	1600
C-25	25	12/2/2023 111	1600
C-26	26	12/2/2023 110	1600
C-27	27	12/2/2023 110	1600
C-28	28	12/2/2023 102	1600
C-29	29	12/2/2023 102	1600
C-30	30	12/2/2023 103	1600
C-31	31	12/2/2023 103	1600
C-32	32	12/2/2023 outside 103	1600
C-33	33	12/2/2023 outside 103	1600
C-34	34	12/2/2023 outside 103	1600
C-35	35	12/2/2023 104	1600
C-36	36	12/2/2023 104	1600
C-37	37	12/2/2023 105	1600
C-38	38	12/2/2023 105	1600
C-39	39	12/2/2023 outside 108	1600
C-40	40	12/2/2023 outside 108	1600
C-41	41	12/2/2023 outside 108	1600
C-42	42	12/2/2023 109	1600

C-43	43	12/2/2023	109	1600
C-44	44	12/2/2023	108	1600
C-45	45	12/2/2023	108	1600
C-46	46	12/2/2023	107	1600
C-47	47	12/2/2023	107	1600
C-48	48	12/2/2023	106	1600
C-49	49	12/2/2023	106	1600
C-50	50	12/2/2023	201	1600
C-51	51	12/2/2023	201	1600
C-52	52	12/2/2023	202	1600
C-53	53	12/2/2023	202	1600
C-54	54	12/2/2023	outside 203	1600
C-55	55	12/2/2023	outside 203	1600
C-56	56	12/2/2023	203	1600
C-57	57	12/2/2023	203	1600
C-58	58	12/2/2023	204	1600
C-59	59	12/2/2023	204	1600
C-60	60	12/2/2023	205	1600
C-61	61	12/2/2023	205	1600
C-62	62	12/2/2023	214	1600
C-63	63	12/2/2023	214	1600
C-64	64	12/2/2023	213	1600
C-65	65	12/2/2023	213	1600
C-66	66	12/2/2023	outside 212	1600
C-67	67	12/2/2023	outside 212	1600
C-68	68	12/2/2023	212	1600
C-69	69	12/2/2023	212	1600
C-70	70	12/2/2023	211	1600
C-71	71	12/2/2023	211	1600
C-72	72	12/2/2023	210	1600
C-73	73	12/2/2023	210	1600
C-74	74	12/2/2023	outside 211	1600
C-75	75	12/2/2023	outside 211	1600
C-76	76	12/2/2023	outside 202	1600
C-77	77	12/2/2023	outside 202	1600
C-78	78	12/2/2023	outside 207	1600
C-79	79	12/2/2023	outside 207	1600
C-80	80	12/2/2023	outside 207	1600
C-81	81	12/2/2023	206	1600
C-82	82	12/2/2023	206	1600
C-83	83	12/2/2023	207	1600
C-84	84	12/2/2023	207	1600
C-85	85	12/2/2023	208	1600

C-86	86	12/2/2023 208	1600
C-87	87	12/2/2023 209	1600
C-88	88	12/2/2023 209	1600