



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/26/2023
Received: 12/15/2023
Sampled By: Jose Godinez
Work Order: 3349022

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Hazelbrook

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3349022-01	Sample Name: H-100 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/22/23 12:30
3349022-02	Sample Name: H-101 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/22/23 12:30
3349022-03	Sample Name: H-102 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/22/23 12:30
3349022-04	Sample Name: H-103 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	12/22/23 12:30
3349022-05	Sample Name: H-104 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/22/23 12:30
3349022-06	Sample Name: H-105 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/22/23 12:30
3349022-07	Sample Name: H-106 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	12/22/23 12:30
3349022-08	Sample Name: H-107 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	12/22/23 12:30
3349022-09	Sample Name: H-108 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	10	ppb	1	15 ppb	12/22/23 12:30
3349022-10	Sample Name: H-109 Sampled: 12/8/23 5:00		Matrix: Water				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	12/22/23 12:30



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/26/2023
Received: 12/15/2023
Sampled By: Jose Godinez
Work Order: 3349022

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Hazelbrook

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
3349022-11	Sample Name: H-110 Sampled: 12/8/23 5:00		Matrix: Water				
†Lead	1030	EPA 200.9	13	ppb	1	15 ppb	12/22/23 12:30
3349022-12	Sample Name: H-111 Sampled: 12/8/23 5:00		Matrix: Water				
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	12/22/23 12:30

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

Sample #	Date	Location	TIME
H-01	12/8/2023	health room	0500
H-02	12/8/2023	main office sink	0500
H-03	12/8/2023	kitchen	0500
H-04	12/8/2023	kitchen	0500
H-05	12/8/2023	kitchen	0500
H-06	12/8/2023	kitchen	0500
H-07	12/8/2023	kitchen	0500
H-08	12/8/2023	female locker room	0500
H-09	12/8/2023	male locker room	0500
H-10	12/8/2023	hallway outside art	0500
H-11	12/8/2023	art	0500
H-12	12/8/2023	art	0500
H-13	12/8/2023	art	0500
H-14	12/8/2023	art	0500
H-15	12/8/2023	Home EC	0500
H-16	12/8/2023	Home EC	0500
H-17	12/8/2023	Home EC	0500
H-18	12/8/2023	Home EC	0500
H-19	12/8/2023	Home EC	0500
H-20	12/8/2023	Home EC	0500
H-21	12/8/2023	Home EC	0500
H-22	12/8/2023	Home EC	0500
H-23	12/8/2023	between band & choir	0500
H-24	12/8/2023	between band & choir	0500
H-25	12/8/2023	cafeteria	0500
H-26	12/8/2023	cafeteria	0500
H-27	12/8/2023	staff room	0500
H-28	12/8/2023	e8	0500
H-29	12/8/2023	e8	0500
H-30	12/8/2023	outside e1	0500
H-31	12/8/2023	e1	0500
H-32	12/8/2023	e1	0500
H-33	12/8/2023	e2	0500
H-34	12/8/2023	e2	0500
H-35	12/8/2023	e3	0500
H-36	12/8/2023	e3	0500
H-37	12/8/2023	e4	0500
H-38	12/8/2023	e4	0500
H-39	12/8/2023	e5	0500
H-40	12/8/2023	e5	0500
H-41	12/8/2023	e6	0500
H-42	12/8/2023	e6	0500

on WC

3349021

H-43	12/8/2023 e7	0500
H-44	12/8/2023 e7	0500
H-45	12/8/2023 mutli b	0500
H-46	12/8/2023 multi b	0500
H-47	12/8/2023 w1	0500
H-48	12/8/2023 w1	0500
H-49	12/8/2023 w2	0500
H-50	12/8/2023 w2	0500
H-51	12/8/2023 w11	0500
H-52	12/8/2023 w11	0500
H-53	12/8/2023 w12	0500
H-54	12/8/2023 w12	0500
H-55	12/8/2023 outside w10	0500
H-56	12/8/2023 outside w10	0500
H-57	12/8/2023 w10	0500
H-58	12/8/2023 w10	0500
H-59	12/8/2023 w3	0500
H-60	12/8/2023 w3	0500
H-61	12/8/2023 w4	0500
H-62	12/8/2023 w4	0500
H-63	12/8/2023 w8	0500
H-64	12/8/2023 w8	0500
H-65	12/8/2023 w9	0500
H-66	12/8/2023 w9	0500
H-67	12/8/2023 w5	0500
H-68	12/8/2023 w5	0500
H-69	12/8/2023 w6	0500
H-70	12/8/2023 w6	0500
H-71	12/8/2023 w7	0500
H-72	12/8/2023 w7	0500
H-73	12/8/2023 w13	0500
H-74	12/8/2023 w13	0500
H-75	12/8/2023 w14	0500
H-76	12/8/2023 w14	0500
H-77	12/8/2023 w15	0500
H-78	12/8/2023 w15	0500
H-79	12/8/2023 w16	0500
H-80	12/8/2023 w16	0500
H-81	12/8/2023 outside w12	0500
H-82	12/8/2023 d10	0500
H-83	12/8/2023 d10	0500
H-84	12/8/2023 d1	0500
H-85	12/8/2023 d1	0500

ON WO

334 9021

H-86	12/8/2023 d2	0500
H-87	12/8/2023 d2	0500
H-88	12/8/2023 d5	0500
H-89	12/8/2023 d5	0500
H-90	12/8/2023 d6	0500
H-91	12/8/2023 d6	0500
H-92	12/8/2023 d3	0500
H-93	12/8/2023 d4	0500
H-94	12/8/2023 d4	0500
H-95	12/8/2023 d4	0500
H-96	12/8/2023 d4	0500
H-97	12/8/2023 d4	0500
H-98	12/8/2023 d4	0500
H-99	12/8/2023 d4	0500
H-100	01 12/8/2023 d4	0500
H-101	02 12/8/2023 d4	0500
H-102	03 12/8/2023 d4	0500
H-103	04 12/8/2023 d7	0500
H-104	05 12/8/2023 d7	0500
H-105	06 12/8/2023 d8	0500
H-106	07 12/8/2023 d8	0500
H-107	08 12/8/2023 d9	0500
H-108	09 12/8/2023 room adjacent to d9	0500
H-109	10 12/8/2023 custodial room	0500
H-110	11 12/8/2023 multi a	0500
H-111	12 12/9/2023 multi a	0500

on WC
3349021