Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/01/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022017

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022017-01	**Sample Name:** D-67A **Sampled:** 1/13/24 14:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**94**	ppb	20	15 ppb	01/31/24 12:25 **MCLE**
4022017-02	**Sample Name:** D-67B **Sampled:** 1/13/24 14:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	01/26/24 16:58

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

***** The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibilty to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 4022017-01-02

Page 1 of 2

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Same
Address: Po Box 1445	Mailing Address: Same	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip:	City/State/Zip:
phone: 503 789 4185	phone:	phone:
fax or email: Tulla.stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Durham		P.O. #:	PWSID #:
Sampled By: Jose Gutierrez	Project Name:	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes No

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested** Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
01-02	Please see attached spreadsheet D-67AB	01/13		Water		X	X	

Relinquished By (print): Jose Gutierrez	Company: Apex Environmental	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: AK 1/22/24 Date/Time: 10:5 11:54 1/22/24 Temp. on receipt: / °C Containers Intact? Y N On ice? Y N ID: TRM-10-

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

Sample #	Date	Location		TIME
D-67A	1/13/2024	Room 4	C1	1400
D-67B	1/13/2024	Room 4	C2	1400