Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/01/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022016

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022016-01	**Sample Name:** B-59A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**21**	ppb	2	15 ppb	01/24/24 17:04 **MCLE**
4022016-02	**Sample Name:** B-59B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**18**	ppb	1	15 ppb	01/24/24 17:04 **MCLE**
4022016-03	**Sample Name:** B-61A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**36**	ppb	2	15 ppb	01/24/24 17:04 **MCLE**
4022016-04	**Sample Name:** B-61B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	01/24/24 17:04
4022016-05	**Sample Name:** B-62A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**54**	ppb	4	15 ppb	01/24/24 17:04 **MCLE**
4022016-06	**Sample Name:** B-62B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5	ppb	1	15 ppb	01/24/24 17:04
4022016-07	**Sample Name:** B-63A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**19**	ppb	1	15 ppb	01/31/24 17:42 **MCLE**
4022016-08	**Sample Name:** B-63B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	9	ppb	1	15 ppb	01/24/24 17:04
4022016-09	**Sample Name:** B-64A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**20**	ppb	2	15 ppb	01/31/24 17:42 **MCLE**
4022016-10	**Sample Name:** B-64B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8	ppb	1	15 ppb	01/24/24 17:04

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/01/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022016

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022016-11	**Sample Name:** B-65A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**23**	ppb	2	15 ppb	01/24/24 17:04 **MCLE**
4022016-12	**Sample Name:** B-65B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	13	ppb	1	15 ppb	01/24/24 17:04
4022016-13	**Sample Name:** B-66A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**122**	ppb	10	15 ppb	01/31/24 17:42 **MCLE**
4022016-14	**Sample Name:** B-66B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7	ppb	1	15 ppb	01/24/24 17:04
4022016-15	**Sample Name:** B-67A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**27**	ppb	2	15 ppb	01/24/24 17:04 **MCLE**
4022016-16	**Sample Name:** B-67B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5	ppb	1	15 ppb	01/24/24 17:04
4022016-17	**Sample Name:** B-68A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**35**	ppb	2	15 ppb	01/31/24 17:42 **MCLE**
4022016-18	**Sample Name:** B-68B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8	ppb	1	15 ppb	01/24/24 17:04
4022016-19	**Sample Name:** B-69A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**81**	ppb	10	15 ppb	01/31/24 17:42 **MCLE**
4022016-20	**Sample Name:** B-69B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	10	ppb	1	15 ppb	01/24/24 17:04

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/01/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022016

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022016-21	**Sample Name:** B-70A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**60**	ppb	4	15 ppb	01/24/24 17:04 **MCLE**
4022016-22	**Sample Name:** B-70B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8	ppb	1	15 ppb	01/24/24 17:04
4022016-23	**Sample Name:** B-71A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**16**	ppb	1	15 ppb	01/24/24 17:04 **MCLE**
4022016-24	**Sample Name:** B-71B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6	ppb	1	15 ppb	01/24/24 17:04
4022016-25	**Sample Name:** B-72A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**76**	ppb	4	15 ppb	01/24/24 17:04 **MCLE**
4022016-26	**Sample Name:** B-72B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	01/24/24 17:04
4022016-27	**Sample Name:** B-73A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**20**	ppb	2	15 ppb	01/24/24 17:04 **MCLE**
4022016-28	**Sample Name:** B-73B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	01/24/24 17:04
4022016-29	**Sample Name:** B-74A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**98**	ppb	10	15 ppb	01/24/24 17:04 **MCLE**
4022016-30	**Sample Name:** B-74B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3	ppb	1	15 ppb	01/24/24 17:04

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/01/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022016

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022016-31	**Sample Name:** B-75A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**33**	ppb	2	15 ppb	01/24/24 17:04 **MCLE**
4022016-32	**Sample Name:** B-75B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	01/24/24 17:04
4022016-33	**Sample Name:** B-76A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	11	ppb	1	15 ppb	01/24/24 17:04
4022016-34	**Sample Name:** B-76B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	01/24/24 17:04
4022016-35	**Sample Name:** B-77A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**451**	ppb	40	15 ppb	01/31/24 17:42 **MCLE**
4022016-36	**Sample Name:** B-77B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**17**	ppb	1	15 ppb	01/24/24 17:04 **MCLE**
4022016-37	**Sample Name:** B-78A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**16**	ppb	1	15 ppb	01/24/24 17:04 **MCLE**
4022016-38	**Sample Name:** B-78B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7	ppb	1	15 ppb	01/24/24 17:04
4022016-39	**Sample Name:** B-79A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**322**	ppb	20	15 ppb	01/31/24 17:42 **MCLE**
4022016-40	**Sample Name:** B-79B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**81**	ppb	10	15 ppb	01/24/24 17:04 **MCLE**

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/01/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022016

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022016-41	**Sample Name:** B-80A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**38**	ppb	20	15 ppb	01/31/24 17:42 **MCLE**
4022016-42	**Sample Name:** B-80B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5	ppb	1	15 ppb	01/24/24 17:04
4022016-43	**Sample Name:** B-81A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**47**	ppb	4	15 ppb	01/24/24 17:04 **MCLE**
4022016-44	**Sample Name:** B-81B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	12	ppb	1	15 ppb	01/24/24 17:04
4022016-45	**Sample Name:** B-82A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**28**	ppb	2	15 ppb	01/24/24 17:04 **MCLE**
4022016-46	**Sample Name:** B-82B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5	ppb	1	15 ppb	01/24/24 17:04
4022016-47	**Sample Name:** B-83A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**230**	ppb	20	15 ppb	01/31/24 17:42 **MCLE**
4022016-48	**Sample Name:** B-83B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	12	ppb	1	15 ppb	01/31/24 17:42
4022016-49	**Sample Name:** B-84A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**36**	ppb	2	15 ppb	01/26/24 16:58 **MCLE**
4022016-50	**Sample Name:** B-84B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8	ppb	1	15 ppb	01/26/24 16:58

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/01/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022016

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022016-51	**Sample Name:** B-85A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**23**	ppb	20	15 ppb	01/31/24 17:42 **MCLE**
4022016-52	**Sample Name:** B-85B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**23**	ppb	2	15 ppb	01/26/24 16:58 **MCLE**
4022016-53	**Sample Name:** B-86A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**52**	ppb	4	15 ppb	01/31/24 17:42 **MCLE**
4022016-54	**Sample Name:** B-86B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	01/26/24 16:58
4022016-55	**Sample Name:** B-87A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**841**	ppb	80	15 ppb	01/31/24 17:42 **MCLE**
4022016-56	**Sample Name:** B-87B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5	ppb	1	15 ppb	01/26/24 16:58
4022016-57	**Sample Name:** B-88A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	12	ppb	1	15 ppb	01/26/24 16:58
4022016-58	**Sample Name:** B-88B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3	ppb	1	15 ppb	01/26/24 16:58
4022016-59	**Sample Name:** B-89A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**238**	ppb	20	15 ppb	01/31/24 17:42 **MCLE**
4022016-60	**Sample Name:** B-89B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8	ppb	1	15 ppb	01/26/24 16:58

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/01/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022016

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022016-61	**Sample Name:** B-90A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**32**	ppb	2	15 ppb	01/26/24 16:58 **MCLE**
4022016-62	**Sample Name:** B-90B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7	ppb	1	15 ppb	01/26/24 16:58
4022016-63	**Sample Name:** B-91A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	14	ppb	1	15 ppb	01/26/24 16:58
4022016-64	**Sample Name:** B-91B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7	ppb	1	15 ppb	01/26/24 16:58
4022016-65	**Sample Name:** B-92A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**20**	ppb	1	15 ppb	01/26/24 16:58 **MCLE**
4022016-66	**Sample Name:** B-92B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3	ppb	1	15 ppb	01/26/24 16:58
4022016-67	**Sample Name:** B-93A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**16**	ppb	1	15 ppb	01/26/24 16:58 **MCLE**
4022016-68	**Sample Name:** B-93B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	9	ppb	1	15 ppb	01/26/24 16:58
4022016-69	**Sample Name:** B-60A **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**399**	ppb	20	15 ppb	01/31/24 17:42 **MCLE**
4022016-70	**Sample Name:** B-60B **Sampled:** 1/13/24 10:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	01/26/24 16:58

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/01/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022016

CLIENT

Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

***** The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibilty to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Chain of Custody Record

Laboratory Job Number: ~~4022016-01-68~~ 4022016-01-70

Page 1 of 2

Alexin Analytical LABORATORIES, INC. Professional Laboratory Services
13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Same
Address: Po Box 1445	Mailing Address: Same	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip:	City/State/Zip:
phone: 503 789 4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Byron		P.O. #:	PWSID #:
Sampled By: Josh Godinez	Project Name:	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes No

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested**: Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
	Please see attached spreadsheet B-59AB → B-93AB	01/13		Water		X	X	

Relinquished By (print): Josh Godinez	Company: Apex Environmental	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: DC 12224 Date/Time: 11:54 Temp. on receipt: ___ °C Containers Intact? (Y) N On ice? (Y) N ID: TRM-10-___

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

4022016-01-42

	Sample #	Date	Location	TIME
01	B-59A	1/13/2024	Kitchen	1000
02	B-59B	1/13/2024	Kitchen	1000
03	B-61A	1/13/2024	Kitchen	1000
04	B-61B	1/13/2024	Kitchen	1000
05	B-62A	1/13/2024	Kitchen	1000
06	B-62B	1/13/2024	Kitchen	1000
07	B-63A	1/13/2024	Room 24	1000
08	B-63B	1/13/2024	Room 24	1000
09	B-64A	1/13/2024	Room 22	1000
10	B-64B	1/13/2024	Room 22	1000
11	B-65A	1/13/2024	Room 22	1000
12	B-65B	1/13/2024	Room 22	1000
13	B-66A	1/13/2024	Room 21	1000
14	B-66B	1/13/2024	Room 21	1000
15	B-67A	1/13/2024	Room 20	1000
16	B-67B	1/13/2024	Room 20	1000
17	B-68A	1/13/2024	Room 19	1000
18	B-68B	1/13/2024	Room 19	1000
19	B-69A	1/13/2024	Room 18	1000
20	B-69B	1/13/2024	Room 18	1000
21	B-70A	1/13/2024	Room 17	1000
22	B-70B	1/13/2024	Room 17	1000
23	B-71A	1/13/2024	Room 15	1000
24	B-71B	1/13/2024	Room 15	1000
25	B-72A	1/13/2024	Room 14	1000
26	B-72B	1/13/2024	Room 14	1000
27	B-73A	1/13/2024	Room 14	1000
28	B-73B	1/13/2024	Room 14	1000
29	B-74A	1/13/2024	Room 13	1000
30	B-74B	1/13/2024	Room 13	1000
31	B-75A	1/13/2024	Room 12	1000
32	B-75B	1/13/2024	Room 12	1000
33	B-76A	1/13/2024	Room 12	1000
34	B-76B	1/13/2024	Room 12	1000
35	B-77A	1/13/2024	Room 11	1000
36	B-77B	1/13/2024	Room 11	1000
37	B-78A	1/13/2024	Room 11	1000
38	B-78B	1/13/2024	Room 11	1000
39	B-79A	1/13/2024	Room 10	1000
40	B-79B	1/13/2024	Room 10	1000
41	B-80A	1/13/2024	Room 10	1000
42	B-80B	1/13/2024	Room 10	1000

4022016-43-70

43	B-81A	1/13/2024	Room 9	1000
44	B-81B	1/13/2024	Room 9	1000
45	B-82A	1/13/2024	Room 9	1000
46	B-82B	1/13/2024	Room 9	1000
47	B-83A	1/13/2024	Room 8	1000
48	B-83B	1/13/2024	Room 8	1000
49	B-84A	1/13/2024	Room 8	1000
50	B-84B	1/13/2024	Room 8	1000
51	B-85A	1/13/2024	Room 7	1000
52	B-85B	1/13/2024	Room 7	1000
53	B-86A	1/13/2024	Room 7	1000
54	B-86B	1/13/2024	Room 7	1000
55	B-87A	1/13/2024	Room 3	1000
56	B-87B	1/13/2024	Room 3	1000
57	B-88A	1/13/2024	Room 3	1000
58	B-88B	1/13/2024	Room 3	1000
59	B-89A	1/13/2024	Room 4	1000
60	B-89B	1/13/2024	Room 4	1000
61	B-90A	1/13/2024	Room 5	1000
62	B-90B	1/13/2024	Room 5	1000
63	B-91A	1/13/2024	Room 5	1000
64	B-91B	1/13/2024	Room 5	1000
65	B-92A	1/13/2024	Room 6	1000
66	B-92B	1/13/2024	Room 6	1000
67	B-93A	1/13/2024	Room 6	1000
68	B-93B	1/13/2024	Room 6	1000
69	B-60A	1/13/2024	Kitchen	1000
70	B-60B	1/13/2024	Kitchen	1000