



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/02/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022019

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Bridgeport

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022019-01	Sample Name: BR-61A Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	202	ppb	20	15 ppb	01/26/24 16:58 MCLE
4022019-02	Sample Name: BR-61B Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	16	ppb	1	15 ppb	01/26/24 16:58 MCLE
4022019-03	Sample Name: BR-62A Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	2340	ppb	200	15 ppb	02/01/24 17:19 MCLE
4022019-04	Sample Name: BR-62B Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	10	ppb	1	15 ppb	01/26/24 16:58
4022019-05	Sample Name: BR-63A Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	240	ppb	20	15 ppb	02/01/24 17:19 MCLE
4022019-06	Sample Name: BR-63B Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	8	ppb	1	15 ppb	01/26/24 16:58
4022019-07	Sample Name: BR-64A Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	247	ppb	20	15 ppb	02/01/24 17:19 MCLE
4022019-08	Sample Name: BR-64B Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	01/26/24 16:58
4022019-09	Sample Name: BR-65A Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	33	ppb	2	15 ppb	01/26/24 16:58 MCLE
4022019-10	Sample Name: BR-65B Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	01/26/24 16:58



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/02/2024
Received: 01/22/2024
Sampled By: Jose Godinez
Work Order: 4022019

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Bridgeport

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
4022019-11	Sample Name: BR-66A Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	19	ppb	1	15 ppb	01/26/24 16:58 MCLE
4022019-12	Sample Name: BR-66B Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	01/26/24 16:58
4022019-13	Sample Name: BR-67A Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	01/26/24 16:58
4022019-14	Sample Name: BR-67B Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	01/26/24 16:58
4022019-15	Sample Name: BR-68A Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	36	ppb	2	15 ppb	01/26/24 16:58 MCLE
4022019-16	Sample Name: BR-68B Sampled: 1/13/24 8:00		Matrix: Water				
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	01/26/24 16:58

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

Sample #	Date	Location	TIME
BR-61A	1/13/2024	Room 8	01 0800
BR-61B	1/13/2024	Room 8	02 0800
BR-62A	1/13/2024	Room 11	03 0800
BR-62B	1/13/2024	Room 11	04 0800
BR-63A	1/13/2024	Room 12	05 0800
BR-63B	1/13/2024	Room 12	06 0800
BR-64A	1/13/2024	Room 12	07 0800
BR-64B	1/13/2024	Room 12	08 0800
BR-65A	1/13/2024	Kitchen	09 0800
BR-65B	1/13/2024	Kitchen	10 0800
BR-66A	1/13/2024	Kitchen	11 0800
BR-66B	1/13/2024	Kitchen	12 0800
BR-67A	1/13/2024	Kitchen	13 0800
BR-67B	1/13/2024	Kitchen	14 0800
BR-68A	1/13/2024	Kitchen	15 0800
BR-68B	1/13/2024	Kitchen	16 0800