

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
RPES-01-DW-P-154	6/13/2024 05:10	6/19/2024 16:37	70301624001	Lead	<1.0	5	ug/L
RPES-01-FS-P-155	6/13/2024 05:11	6/19/2024 16:42	70301624002	Lead	<1.0	5	ug/L
RPES-01-CF-P-156	6/13/2024 05:12	6/19/2024 16:45	70301624003	Lead	2.1	5	ug/L
RPES-01-DW-P-157	6/13/2024 05:13	6/19/2024 16:59	70301624004	Lead	5.4	5	ug/L
RPES-01-CF-P-158	6/13/2024 05:14	6/19/2024 17:05	70301624005	Lead	3.6	5	ug/L
RPES-01-DW-P-159	6/13/2024 05:15	6/19/2024 17:10	70301624006	Lead	2.9	5	ug/L
RPES-01-CF-P-160	6/13/2024 05:16	6/19/2024 17:14	70301624007	Lead	2.2	5	ug/L
RPES-01-DW-P-161	6/13/2024 05:17	6/19/2024 17:16	70301624008	Lead	4.2	5	ug/L
RPES-01-NS1-P-162	6/13/2024 05:18	6/19/2024 17:17	70301624009	Lead	2.5	5	ug/L
RPES-01-NS2-P-163	6/13/2024 05:19	6/19/2024 17:19	70301624010	Lead	14.0	5	ug/L
RPES-01-NS3-P-164	6/13/2024 05:20	6/19/2024 17:20	70301624011	Lead	3.0	5	ug/L
RPES-01-CF-P-165	6/13/2024 05:21	6/19/2024 17:22	70301624012	Lead	4.5	5	ug/L
RPES-01-DW-P-166	6/13/2024 05:22	6/19/2024 17:24	70301624013	Lead	1.1	5	ug/L
RPES-01-CF-P-167	6/13/2024 05:23	6/19/2024 17:28	70301624014	Lead	3.2	5	ug/L
RPES-01-DW-P-168	6/13/2024 05:24	6/19/2024 17:30	70301624015	Lead	<1.0	5	ug/L
RPES-01-CF-P-169	6/13/2024 05:25	6/19/2024 17:31	70301624016	Lead	2.9	5	ug/L
RPES-01-DW-P-170	6/13/2024 05:26	6/19/2024 17:33	70301624017	Lead	3.3	5	ug/L
RPES-01-CF-P-171	6/13/2024 05:27	6/19/2024 17:34	70301624018	Lead	3.0	5	ug/L
RPES-01-DW-P-172	6/13/2024 05:28	6/19/2024 17:36	70301624019	Lead	2.3	5	ug/L
RPES-01-CF-P-173	6/13/2024 05:29	6/19/2024 17:41	70301624020	Lead	3.2	5	ug/L
RPES-01-DW-P-174	6/13/2024 05:30	6/19/2024 17:48	70301624021	Lead	1.6	5	ug/L
RPES-01-CF-P-175	6/13/2024 05:31	6/19/2024 17:53	70301624022	Lead	4.1	5	ug/L
RPES-01-DW-P-176	6/13/2024 05:32	6/19/2024 17:54	70301624023	Lead	2.4	5	ug/L
RPES-01-CF-P-177	6/13/2024 05:33	6/19/2024 17:56	70301624024	Lead	5.9	5	ug/L
RPES-01-CF-P-178	6/13/2024 05:34	6/19/2024 17:57	70301624025	Lead	1.3	5	ug/L
RPES-01-DW-P-179	6/13/2024 05:35	6/19/2024 17:59	70301624026	Lead	<1.0	5	ug/L
RPES-01-CF-P-180	6/13/2024 05:36	6/19/2024 18:01	70301624027	Lead	6.2	5	ug/L
RPES-01-DW-P-181	6/13/2024 05:37	6/19/2024 18:05	70301624028	Lead	1.9	5	ug/L
RPES-02-DW-P-184	6/13/2024 06:10	6/19/2024 18:07	70301624029	Lead	4.4	5	ug/L
RPES-02-CF-P-185	6/13/2024 06:08	6/19/2024 18:08	70301624030	Lead	2.5	5	ug/L
RPES-02-DW-P-186	6/13/2024 06:09	6/19/2024 18:10	70301624031	Lead	1.3	5	ug/L
RPES-02-CF-P-187	6/13/2024 06:06	6/19/2024 18:11	70301624032	Lead	3.3	5	ug/L
RPES-02-DW-P-188	6/13/2024 06:07	6/19/2024 18:13	70301624033	Lead	5.4	5	ug/L
RPES-02-CF-P-189	6/13/2024 06:04	6/19/2024 18:15	70301624034	Lead	6.7	5	ug/L
RPES-02-DW-P-190	6/13/2024 06:05	6/19/2024 18:16	70301624035	Lead	<1.0	5	ug/L
RPES-02-CF-P-191	6/13/2024 06:01	6/19/2024 18:18	70301624036	Lead	4.7	5	ug/L
RPES-02-DW-P-192	6/13/2024 06:02	6/19/2024 18:19	70301624037	Lead	4.4	5	ug/L
RPES-02-DW-P-193	6/13/2024 06:00	6/19/2024 18:24	70301624038	Lead	5.6	5	ug/L
RPES-02-CF-P-194	6/13/2024 05:50	6/19/2024 18:25	70301624039	Lead	4.9	5	ug/L
RPES-02-DW-P-195	6/13/2024 05:51	6/19/2024 18:30	70301624040	Lead	6.2	5	ug/L
RPES-02-CF-P-196	6/13/2024 05:52	6/19/2024 18:35	70301624041	Lead	19.6	5	ug/L
RPES-02-DW-P-197	6/13/2024 05:53	6/19/2024 18:42	70301624042	Lead	<1.0	5	ug/L
RPES-02-CF-P-198	6/13/2024 05:54	6/19/2024 18:44	70301624043	Lead	3.5	5	ug/L
RPES-02-DW-P-199	6/13/2024 05:55	6/19/2024 18:45	70301624044	Lead	3.6	5	ug/L
RPES-02-CF-P-200	6/13/2024 05:56	6/19/2024 18:47	70301624045	Lead	5.4	5	ug/L
RPES-02-DW-P-201	6/13/2024 05:57	6/19/2024 18:48	70301624046	Lead	3.9	5	ug/L
RPES-02-CF-P-202	6/13/2024 05:58	6/19/2024 18:50	70301624047	Lead	13.4	5	ug/L
RPES-02-DW-P-203	6/13/2024 05:59	6/19/2024 18:52	70301624048	Lead	2.5	5	ug/L

RPES-02-CF-P-204	6/13/2024 05:44	6/19/2024 18:53	70301624049	Lead	7.3	5	ug/L
RPES-02-DW-P-205	6/13/2024 05:45	6/19/2024 18:55	70301624050	Lead	2.8	5	ug/L
RPES-02-CF-P-206	6/13/2024 05:38	6/19/2024 18:56	70301624051	Lead	8.7	5	ug/L
RPES-02-DW-P-207	6/13/2024 05:39	6/19/2024 19:01	70301624052	Lead	2.6	5	ug/L
RPES-02-CF-P-208	6/13/2024 05:42	6/19/2024 19:02	70301624053	Lead	4.8	5	ug/L
RPES-02-DW-P-209	6/13/2024 05:43	6/19/2024 19:04	70301624054	Lead	6.7	5	ug/L
RPES-02-CF-P-210	6/13/2024 05:40	6/19/2024 19:06	70301624055	Lead	2.5	5	ug/L
RPES-02-DW-P-211	6/13/2024 05:41	6/19/2024 19:07	70301624056	Lead	<1.0	5	ug/L
RPES-02-DW-P-212	6/13/2024 06:18	6/19/2024 19:09	70301624057	Lead	4.0	5	ug/L
RPES-02-GS1-P-213	6/13/2024 06:11	6/19/2024 19:10	70301624058	Lead	4.3	5	ug/L
RPES-02-GS1-P-214	6/13/2024 06:12	6/19/2024 19:12	70301624059	Lead	6.2	5	ug/L
RPES-02-GS1-P-215	6/13/2024 06:13	6/19/2024 19:19	70301624060	Lead	2.4	5	ug/L
RPES-02-GS1-P-216	6/13/2024 06:14	6/19/2024 19:24	70301624061	Lead	3.7	5	ug/L
RPES-02-GS1-P-217	6/13/2024 06:15	6/19/2024 19:29	70301624062	Lead	<1.0	5	ug/L
RPES-02-GS1-P-218	6/13/2024 06:19	6/19/2024 19:30	70301624063	Lead	7.7	5	ug/L
RPES-02-DW-P-219	6/13/2024 06:20	6/19/2024 19:32	70301624064	Lead	4.2	5	ug/L
RPES-02-CF-P-220	6/13/2024 06:21	6/19/2024 19:33	70301624065	Lead	16.6	5	ug/L
RPES-02-DW-P-221	6/13/2024 06:22	6/19/2024 19:38	70301624066	Lead	2.3	5	ug/L
RPES-02-CF-P-222	6/13/2024 06:23	6/19/2024 19:40	70301624067	Lead	3.8	5	ug/L
RPES-02-DW-P-223	6/13/2024 06:24	6/20/2024 12:22	70301624068	Lead	3.0	5	ug/L
RPES-01-HC-P-224	6/13/2024 06:27	6/20/2024 12:24	70301624069	Lead	6.2	5	ug/L
RPES-01-HC-P-226	6/13/2024 06:37	6/20/2024 12:28	70301624070	Lead	7.6	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb