

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
TES-01-DW-P-69	6/13/2024 05:30	6/18/2024 14:05	70301619001	Lead	2.3	5	ug/L
TES-01-FS-P-70	6/13/2024 05:17	6/18/2024 14:06	70301619002	Lead	1.5	5	ug/L
TES-01-CF-P-71	6/13/2024 05:19	6/18/2024 14:11	70301619003	Lead	2.1	5	ug/L
TES-01-DW-P-72	6/13/2024 05:21	6/18/2024 14:23	70301619004	Lead	2.4	5	ug/L
TES-01-CF-P-73	6/13/2024 05:23	6/18/2024 14:31	70301619005	Lead	1.3	5	ug/L
TES-01-DW-P-74	6/13/2024 05:24	6/18/2024 14:32	70301619006	Lead	<1.0	5	ug/L
TES-01-CF-P-75	6/13/2024 05:24	6/18/2024 14:43	70301619007	Lead	2.7	5	ug/L
TES-01-DW-P-76	6/13/2024 05:25	6/18/2024 14:46	70301619008	Lead	9.9	5	ug/L
TES-01-NS1-P-77	6/13/2024 05:27	6/18/2024 14:49	70301619009	Lead	5.5	5	ug/L
TES-01-NS2-P-78	6/13/2024 05:28	6/18/2024 14:51	70301619010	Lead	7.1	5	ug/L
TES-01-CF-P-79	6/13/2024 06:06	6/18/2024 14:56	70301619011	Lead	2.1	5	ug/L
TES-01-DW-P-80	6/13/2024 06:07	6/18/2024 14:57	70301619012	Lead	1.4	5	ug/L
TES-01-CF-P-81	6/13/2024 06:08	6/18/2024 14:59	70301619013	Lead	1.9	5	ug/L
TES-01-DW-P-82	6/13/2024 06:09	6/18/2024 15:00	70301619014	Lead	<1.0	5	ug/L
TES-01-CF-P-83	6/13/2024 06:09	6/18/2024 15:05	70301619015	Lead	2.4	5	ug/L
TES-01-DW-P-84	6/13/2024 06:10	6/18/2024 15:09	70301619016	Lead	1.2	5	ug/L
TES-01-CF-P-85	6/13/2024 06:11	6/18/2024 15:17	70301619017	Lead	1.4	5	ug/L
TES-01-DW-P-86	6/13/2024 06:12	6/18/2024 15:26	70301619018	Lead	1.4	5	ug/L
TES-01-CF-P-87	6/13/2024 06:12	6/18/2024 15:33	70301619019	Lead	1.5	5	ug/L
TES-01-DW-P-88	6/13/2024 06:13	6/18/2024 15:36	70301619020	Lead	1.5	5	ug/L
TES-01-CF-P-89	6/13/2024 06:14	6/18/2024 15:40	70301619021	Lead	1.4	5	ug/L
TES-01-DW-P-90	6/13/2024 06:15	6/18/2024 15:42	70301619022	Lead	<1.0	5	ug/L
TES-01-CF-P-91	6/13/2024 05:58	6/18/2024 15:47	70301619023	Lead	<1.0	5	ug/L
TES-01-DW-P-92	6/13/2024 05:59	6/18/2024 15:59	70301619024	Lead	<1.0	5	ug/L
TES-01-DW-P-93	6/13/2024 06:00	6/18/2024 16:04	70301619025	Lead	5.5	5	ug/L
TES-01-CF-P-94	6/13/2024 05:54	6/18/2024 16:14	70301619026	Lead	4.1	5	ug/L
TES-01-DW-P-95	6/13/2024 05:55	6/18/2024 16:16	70301619027	Lead	1.1	5	ug/L
TES-01-NF-P-96	6/13/2024 05:56	6/18/2024 16:21	70301619028	Lead	<1.0	5	ug/L
TES-01-NF-P-97	6/13/2024 05:57	6/18/2024 16:24	70301619029	Lead	<1.0	5	ug/L
TES-01-DW-P-98	6/13/2024 05:51	6/18/2024 16:32	70301619030	Lead	<1.0	5	ug/L
TES-01-DW-P-99	6/13/2024 05:52	6/18/2024 16:33	70301619031	Lead	<1.0	5	ug/L
TES-01-KF-P-100	6/13/2024 05:36	6/18/2024 16:36	70301619032	Lead	<1.0	5	ug/L
TES-01-KF1-P-101	6/13/2024 05:34	6/18/2024 16:48	70301619033	Lead	1.7	5	ug/L
TES-01-KF2-P-102	6/13/2024 05:35	6/18/2024 16:55	70301619034	Lead	1.7	5	ug/L
TES-01-DW-P-104	6/13/2024 05:38	6/19/2024 13:55	70301619035	Lead	<1.0	5	ug/L
TES-01-DW-P-105	6/13/2024 05:39	6/19/2024 13:58	70301619036	Lead	<1.0	5	ug/L
TES-01-DW-P-106	6/13/2024 05:40	6/19/2024 14:01	70301619037	Lead	<1.0	5	ug/L
TES-01-DW-P-107	6/13/2024 05:41	6/19/2024 14:09	70301619038	Lead	<1.0	5	ug/L
TES-01-DW-P-108	6/13/2024 05:42	6/19/2024 14:12	70301619039	Lead	<1.0	5	ug/L
TES-02-DW-P-109	6/13/2024 07:09	6/19/2024 14:16	70301619040	Lead	36.6	5	ug/L
TES-02-CF-P-110	6/13/2024 07:04	6/19/2024 14:19	70301619041	Lead	6.5	5	ug/L
TES-02-DW-P-111	6/13/2024 07:05	6/19/2024 14:26	70301619042	Lead	7.4	5	ug/L
TES-02-DW-P-112	6/13/2024 07:00	6/19/2024 14:35	70301619043	Lead	14.4	5	ug/L
TES-02-DW-P-113	6/13/2024 07:01	6/19/2024 14:42	70301619044	Lead	6.3	5	ug/L
TES-02-DW-P-114	6/13/2024 06:58	6/19/2024 14:45	70301619045	Lead	9.8	5	ug/L
TES-02-DW-P-115	6/13/2024 06:59	6/19/2024 14:48	70301619046	Lead	11.8	5	ug/L
TES-02-DW-P-116	6/13/2024 06:34	6/19/2024 14:51	70301619047	Lead	5.5	5	ug/L
TES-02-DW-P-117	6/13/2024 06:40	6/19/2024 14:53	70301619048	Lead	<1.0	5	ug/L

TES-02-DW-P-118	6/13/2024 06:41	6/19/2024 14:54	70301619049	Lead	<1.0	5	ug/L
TES-02-CF-P-119	6/13/2024 06:47	6/19/2024 15:02	70301619050	Lead	1.0	5	ug/L
TES-02-DW-P-120	6/13/2024 06:46	6/19/2024 15:04	70301619051	Lead	5.3	5	ug/L
TES-02-CF-P-121	6/13/2024 06:44	6/19/2024 15:05	70301619052	Lead	5.4	5	ug/L
TES-02-DW-P-122	6/13/2024 06:45	6/19/2024 15:07	70301619053	Lead	9.0	5	ug/L
TES-02-CF-P-123	6/13/2024 06:31	6/19/2024 15:10	70301619054	Lead	3.6	5	ug/L
TES-02-DW-P-124	6/13/2024 06:32	6/19/2024 15:19	70301619055	Lead	4.4	5	ug/L
TES-02-CF-P-125	6/13/2024 06:43	6/19/2024 15:24	70301619056	Lead	5.7	5	ug/L
TES-02-DW-P-126	6/13/2024 06:44	6/19/2024 15:28	70301619057	Lead	5.5	5	ug/L
TES-02-CF-P-127	6/13/2024 06:26	6/19/2024 15:31	70301619058	Lead	10.1	5	ug/L
TES-02-DW-P-128	6/13/2024 06:27	6/19/2024 15:42	70301619059	Lead	5.4	5	ug/L
TES-02-CF-P-129	6/13/2024 06:19	6/19/2024 15:44	70301619060	Lead	6.0	5	ug/L
TES-02-DW-P-130	6/13/2024 06:20	6/19/2024 15:45	70301619061	Lead	4.4	5	ug/L
TES-02-CF-P-131	6/13/2024 06:24	6/19/2024 15:47	70301619062	Lead	8.7	5	ug/L
TES-02-DW-P-132	6/13/2024 06:25	6/19/2024 15:48	70301619063	Lead	9.4	5	ug/L
TES-02-CF-P-133	6/13/2024 06:21	6/19/2024 15:50	70301619064	Lead	17.0	5	ug/L
TES-02-DW-P-134	6/13/2024 06:22	6/19/2024 15:51	70301619065	Lead	27.7	5	ug/L
TES-02-DW-P-135	6/13/2024 06:23	6/19/2024 15:56	70301619066	Lead	3.0	5	ug/L
TES-02-DW-P-136	6/13/2024 06:48	6/19/2024 15:59	70301619067	Lead	3.3	5	ug/L
TES-02-CF-P-137	6/13/2024 06:49	6/19/2024 16:01	70301619068	Lead	4.5	5	ug/L
TES-02-DW-P-138	6/13/2024 06:50	6/19/2024 16:10	70301619069	Lead	8.0	5	ug/L
TES-02-CF-P-139	6/13/2024 06:51	6/19/2024 16:20	70301619070	Lead	8.4	5	ug/L
TES-02-DW-P-140	6/13/2024 06:57	6/19/2024 16:22	70301619071	Lead	3.5	5	ug/L
TES-02-CF-P-141	6/13/2024 06:52	6/19/2024 16:23	70301619072	Lead	2.5	5	ug/L
TES-02-DW-P-142	6/13/2024 06:53	6/19/2024 16:25	70301619073	Lead	2.4	5	ug/L
TES-02-CF-P-143	6/13/2024 06:54	6/19/2024 16:27	70301619074	Lead	7.8	5	ug/L
TES-02-DW-P-144	6/13/2024 06:55	6/19/2024 16:28	70301619075	Lead	2.9	5	ug/L
TES-01-FS-P-145	6/13/2024 05:44	6/19/2024 16:33	70301619076	Lead	<1.0	5	ug/L
TES-02-FS-P-146	6/13/2024 05:45	6/19/2024 16:34	70301619077	Lead	<1.0	5	ug/L
TES-01-HC1-P-147	6/13/2024 07:06	6/19/2024 16:36	70301619078	Lead	3.5	5	ug/L
TES-01-HC2-P-148	6/13/2024 07:11	6/19/2024 16:39	70301619079	Lead	10.9	5	ug/L
TES-01-HC3-P-149	6/13/2024 07:21	6/19/2024 16:40	70301619080	Lead	<1.0	5	ug/L
TES-01-HC4-P-150	6/13/2024 07:18	6/19/2024 16:44	70301619081	Lead	1.6	5	ug/L
TES-01-HC5-P-151	6/13/2024 07:19	6/19/2024 16:47	70301619082	Lead	6.2	5	ug/L
TES-01-HC6-P-152	6/13/2024 07:16	6/19/2024 16:54	70301619083	Lead	1.8	5	ug/L
TES-01-HC7-P-153	6/13/2024 07:25	6/19/2024 17:03	70301619084	Lead	25.3	5	ug/L
TES-02-CF-P-153A	6/13/2024 06:28	6/19/2024 17:11	70301619085	Lead	15.8	5	ug/L
TES-02-DW-P-153B	6/13/2024 06:29	6/19/2024 17:13	70301619086	Lead	13.4	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb