

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
KMS-BM-IM-P-01	6/13/2024 07:40	6/18/2024 14:00	70301618001	Lead	<1.0	5	ug/L
KMS-BM-FS-P-2	6/13/2024 05:03	6/18/2024 14:03	70301618002	Lead	5.3	5	ug/L
KMS-01-DW-P-3	6/13/2024 05:08	6/18/2024 14:08	70301618003	Lead	3.9	5	ug/L
KMS-01-DW-P-4	6/13/2024 05:10	6/18/2024 14:09	70301618004	Lead	1.9	5	ug/L
KMS-01-NF1-P-5	6/13/2024 05:12	6/18/2024 14:19	70301618005	Lead	5.6	5	ug/L
KMS-01-NF2-P-6	6/13/2024 05:13	6/18/2024 14:28	70301618006	Lead	3.6	5	ug/L
KMS-01-DW-P-7	6/13/2024 05:15	6/18/2024 14:38	70301618007	Lead	<1.0	5	ug/L
KMS-01-DW-P-8	6/13/2024 05:15	6/18/2024 14:42	70301618008	Lead	<1.0	5	ug/L
KMS-01-DW-P-9	6/13/2024 05:17	6/18/2024 14:45	70301618009	Lead	2.0	5	ug/L
KMS-01-DW-P-10	6/13/2024 05:18	6/18/2024 14:48	70301618010	Lead	3.3	5	ug/L
KMS-02-DW-P-11	6/13/2024 05:22	6/18/2024 15:19	70301618011	Lead	7.8	5	ug/L
KMS-02-DW-P-12	6/13/2024 05:23	6/18/2024 15:22	70301618012	Lead	<1.0	5	ug/L
KMS-02-DW-P-13	6/13/2024 05:24	6/18/2024 15:25	70301618013	Lead	<1.0	5	ug/L
KMS-02-CF-P-14	6/13/2024 05:26	6/18/2024 15:34	70301618014	Lead	4.2	5	ug/L
KMS-02-DW-P-15	6/13/2024 05:28	6/18/2024 15:39	70301618015	Lead	3.3	5	ug/L
KMS-03-CF1-P-16	6/13/2024 05:32	6/18/2024 15:45	70301618016	Lead	5.9	5	ug/L
KMS-03-DW-P-17	6/13/2024 05:33	6/18/2024 15:54	70301618017	Lead	4.3	5	ug/L
KMS-03-DW-P-18	6/13/2024 05:35	6/18/2024 16:10	70301618018	Lead	<1.0	5	ug/L
KMS-03-DW-P-19	6/13/2024 05:36	6/18/2024 16:13	70301618019	Lead	<1.0	5	ug/L
KMS-03-KS-P-20	6/13/2024 05:38	6/18/2024 16:18	70301618020	Lead	1.2	5	ug/L
KMS-03-KS1-P-21	6/13/2024 05:39	6/18/2024 16:22	70301618021	Lead	1.8	5	ug/L
KMS-03-KS2-P-22	6/13/2024 05:40	6/18/2024 16:30	70301618022	Lead	1.8	5	ug/L
KMS-03-KPS-P-23	6/13/2024 05:41	6/18/2024 16:41	70301618023	Lead	<1.0	5	ug/L
KMS-03-KHS-P-24	6/13/2024 05:42	6/18/2024 16:56	70301618024	Lead	1.2	5	ug/L
KMS-03-DW-P-25	6/13/2024 05:43	6/19/2024 13:56	70301618025	Lead	1.2	5	ug/L
KMS-03-CF-P-26	6/13/2024 05:46	6/19/2024 14:05	70301618026	Lead	16.6	5	ug/L
KMS-03-CF-P-27	6/13/2024 05:46	6/19/2024 14:07	70301618027	Lead	2.2	5	ug/L
KMS-03-CF1-P-28	6/13/2024 05:47	6/19/2024 14:10	70301618028	Lead	19.5	5	ug/L
KMS-03-CF2-P-29	6/13/2024 05:48	6/19/2024 14:15	70301618029	Lead	1.7	5	ug/L
KMS-03-DW-P-30	6/13/2024 05:50	6/19/2024 14:18	70301618030	Lead	4.9	5	ug/L
KMS-03-CF-P-31	6/13/2024 05:51	6/19/2024 14:30	70301618031	Lead	12.2	5	ug/L
KMS-03-CF-P-32	6/13/2024 05:53	6/19/2024 14:44	70301618032	Lead	1.5	5	ug/L
KMS-03-CF-P-33	6/13/2024 05:53	6/19/2024 14:50	70301618033	Lead	3.4	5	ug/L
KMS-01-HC-P-33A	6/13/2024 05:59	6/19/2024 14:56	70301618034	Lead	246	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb