

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
271 Belvidere	101	1/22/2024	8:27:00 AM	514	0.6	65.8	15.8	0	
271 Belvidere	1001	1/22/2024	9:28:00 AM	762	0.4	73.6	13.4	4	
271 Belvidere	1002	1/22/2024	9:29:00 AM	754	0.5	73	14	0	
271 Belvidere	1103	1/22/2024	9:17:00 AM	657	0.5	71.5	13.6	18	
271 Belvidere	1104	1/22/2024	9:27:00 AM	766	0.5	74.1	13.6	0	
271 Belvidere	1105	1/22/2024	9:19:00 AM	660	0.5	71.4	13.4	0	Plants: Kept Away From Return And Supply Vents
271 Belvidere	1106	1/22/2024	9:25:00 AM	529	0.3	73.5	12.7	0	
271 Belvidere	1107	1/22/2024	9:20:00 AM	852	0.5	72	16.9	9	
271 Belvidere	1109	1/22/2024	9:21:00 AM	565	0.5	72.3	11.8	0	
271 Belvidere	1111	1/22/2024	9:22:00 AM	558	0.5	73.5	12.2	0	Bubbling/Peeling Paint
271 Belvidere	1113	1/22/2024	9:24:00 AM	880	0.5	73.8	15.4	20	
271 Belvidere	1202	1/22/2024	9:15:00 AM	687	0.4	70.5	13	0	
271 Belvidere	1205	1/22/2024	9:14:00 AM	673	0.5	70.9	12.1	0	
271 Belvidere	1206	1/22/2024	9:12:00 AM	522	0.6	71.6	11.8	0	Stained Ceiling Tiles
271 Belvidere	1301	1/22/2024	9:11:00 AM	526	0.5	72.1	14.1	1	
271 Belvidere	1302	1/22/2024	9:09:00 AM	593	0.5	72.1	13.2	0	
271 Belvidere	1305	1/22/2024	9:08:00 AM	547	0.5	70.2	12.5	0	Stained Ceiling Tiles
271 Belvidere	1306	1/22/2024	9:05:00 AM	481	0.5	69.6	12.4	2	
271 Belvidere	1307	1/22/2024	9:07:00 AM	482	0.5	69.6	13	0	Stained Ceiling Tiles
271 Belvidere	1310	1/22/2024	9:04:00 AM	473	0.6	69.4	12.5	0	
271 Belvidere	1313	1/22/2024	9:03:00 AM	470	0.6	69.6	12.5	0	
271 Belvidere	1314	1/22/2024	9:03:00 AM	537	0.6	69.6	13.3	0	
271 Belvidere	1315	1/22/2024	9:02:00 AM	1137	0.6	69.4	14.6	0	
271 Belvidere	1401	1/22/2024	9:01:00 AM	596	0.7	69.3	15.9	0	
271 Belvidere	1402	1/22/2024	8:56:00 AM	711	0.8	68.7	14.5	0	
271 Belvidere	2103	1/22/2024	8:55:00 AM	506	0.9	72.3	11.6	0	
271 Belvidere	2105	1/22/2024	8:54:00 AM	512	0.8	72.3	12.2	0	
271 Belvidere	2106	1/22/2024	8:53:00 AM	607	0.9	71.8	13.4	3	
271 Belvidere	2107	1/22/2024	8:54:00 AM	515	0.8	72.3	11.7	2	
271 Belvidere	2108	1/22/2024	8:51:00 AM	632	0.9	71.6	13.3	3	Food Odor
271 Belvidere	2109	1/22/2024	8:51:00 AM	548	0.9	72	13.4	1	
271 Belvidere	2110	1/22/2024	8:50:00 AM	517	0.9	72	12.2	0	
271 Belvidere	2111	1/22/2024	8:48:00 AM	524	0.7	72.7	12.5	1	
271 Belvidere	2112	1/22/2024	8:49:00 AM	510	0.9	72.3	11.8	0	
271 Belvidere	2113	1/22/2024	8:47:00 AM	576	0.7	72	12.2	0	
271 Belvidere	2115	1/22/2024	8:39:00 AM	498	0.7	70.9	12	0	
271 Belvidere	1306A	1/22/2024	9:06:00 AM	508	0.5	69.6	13	1	
271 Belvidere	OUTDOORS	1/22/2024		486	0.9	19	78		
Adams Spanish Immersion	1000	12/12/2023	11:15:00 AM	624		70.8	13.3	0	
Adams Spanish Immersion	1001	12/12/2023	11:18:00 AM	605		71.8	13	1	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	1002	12/12/2023	11:17:00 AM	586		71.6	13	1	
Adams Spanish Immersion	1003	12/12/2023	11:16:00 AM	613		71.5	13.6	2	Fragrance Odor
Adams Spanish Immersion	1004	12/12/2023	11:14:00 AM	616		70	14.1	0	
Adams Spanish Immersion	1006	12/12/2023	11:13:00 AM	541		69.2	12.7	0	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	1007	12/12/2023	11:12:00 AM	551	0.1	69.5	13.5	0	
Adams Spanish Immersion	1008	12/12/2023	11:10:00 AM	525		69.5	13.1	0	
Adams Spanish Immersion	1009	12/12/2023	11:11:00 AM	536		69.6	12.8	0	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Adams Spanish Immersion	1010	12/12/2023	11:09:00 AM	548	0.3	69.4	14.8	0	
Adams Spanish Immersion	1011	12/12/2023	11:19:00 AM	673	0.1	71.5	14.5	2	
Adams Spanish Immersion	1103	12/12/2023	11:34:00 AM	848		68.8	19	20	
Adams Spanish Immersion	1201	12/12/2023	11:02:00 AM	967	0.1	68.9	23.9	22	
Adams Spanish Immersion	1202	12/12/2023	11:01:00 AM	888		68.1	23.5	28	
Adams Spanish Immersion	1203	12/12/2023	11:03:00 AM	1091		69.7	24.3	20	
Adams Spanish Immersion	1301	12/12/2023	11:04:00 AM	882	0.1	69.5	21	20	
Adams Spanish Immersion	1302	12/12/2023	11:05:00 AM	785	0.1	69.8	19.2	28	
Adams Spanish Immersion	1303	12/12/2023	11:08:00 AM	590	0.1	69.2	15.9	0	
Adams Spanish Immersion	1306	12/12/2023	10:52:00 AM	733		66.5	20.7	1	
Adams Spanish Immersion	1400	12/12/2023	11:31:00 AM	889		68.8	19.7	20	
Adams Spanish Immersion	1401	12/12/2023	11:38:00 AM	791		69.2	20.7	20	Food Odor
Adams Spanish Immersion	1402	12/12/2023	12:59:00 PM	741		69.8	17.9	15	
Adams Spanish Immersion	1403	12/12/2023	12:03:00 PM	770		68.8	19.4	20	
Adams Spanish Immersion	1404	12/12/2023	11:41:00 AM	768	0.1	68.9	19.6	22	Food Odor, Taxidermy
Adams Spanish Immersion	1405	12/12/2023	11:44:00 AM	738		68.9	19.6	20	Food Odor
Adams Spanish Immersion	1406	12/12/2023	12:07:00 PM	688	0.1	68.8	17.2	20	
Adams Spanish Immersion	1503	12/12/2023	1:03:00 PM	625	0.1	69	17.7	10	Aquariums (fish), Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	1504	12/12/2023	11:26:00 AM	812	0.1	68.8	17.1	20	
Adams Spanish Immersion	1505	12/12/2023	11:30:00 AM	776		68.5	18	1	Fragrance Odor
Adams Spanish Immersion	1509	12/12/2023	11:28:00 AM	652		68.3	16.8	0	
Adams Spanish Immersion	1520	12/12/2023	11:21:00 AM	809	1.1	69.9	22.8	100	Food Odor
Adams Spanish Immersion	2201	12/12/2023	12:22:00 PM	1096		70.6	24.1	30	
Adams Spanish Immersion	2202	12/12/2023	1:17:00 PM	866	0.2	71	20.4	25	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2203	12/12/2023	12:50:00 PM	618		69.3	18.5	2	
Adams Spanish Immersion	2302	12/12/2023	12:45:00 PM	503	0.1	69	16.1	0	
Adams Spanish Immersion	2303	12/12/2023	1:16:00 PM	575		69.9	16.7	1	
Adams Spanish Immersion	2304	12/12/2023	1:05:00 PM	679		69.5	17.8	25	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2306	12/12/2023	12:09:00 PM	791		70	19.4	20	
Adams Spanish Immersion	2307	12/12/2023	12:26:00 PM	546		69.4	15.5	0	
Adams Spanish Immersion	2308	12/12/2023	12:16:00 PM	789	0.1	70.4	17.8	0	
Adams Spanish Immersion	2310	12/12/2023	12:19:00 PM	617	0.1	70.1	16	0	
Adams Spanish Immersion	2403	12/12/2023	12:30:00 PM	669		67.9	19.9	1	Food Odor
Adams Spanish Immersion	2404	12/12/2023	12:33:00 PM	544		67.6	16.7	0	Fragrance Odor
Adams Spanish Immersion	2501	12/12/2023	12:23:00 PM	665		69.9	14.3	0	
Adams Spanish Immersion	2502	12/12/2023	12:28:00 PM	1002		69.1	23.4	25	
Adams Spanish Immersion	2503	12/12/2023	1:21:00 PM	563		68.8	16.8	0	
Adams Spanish Immersion	2504	12/12/2023	12:29:00 PM	953	0.1	69	21.6	22	
Adams Spanish Immersion	2505	12/12/2023	12:34:00 PM	625	0.1	67.7	17.5	1	Fragrance, Food Odor
Adams Spanish Immersion	2601	12/12/2023	1:18:00 PM	519		69.8	17.4	0	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	2602	12/12/2023	12:37:00 PM	753	0.1	69	19.2	30	
Adams Spanish Immersion	2603	12/12/2023	12:38:00 PM	881		69.1	21.7	25	
Adams Spanish Immersion	2604	12/12/2023	12:39:00 PM	764		70	19.1	25	
Adams Spanish Immersion	2605	12/12/2023	12:42:00 PM	814		69.6	20.4	25	
Adams Spanish Immersion	2801	12/12/2023	12:40:00 PM	882	0.1	69.5	19.2	22	Fragrance Odor
Adams Spanish Immersion	2802	12/12/2023	12:43:00 PM	596	0.1	69.1	16	0	
Adams Spanish Immersion	2803	12/12/2023	1:23:00 PM	773		69.1	18.5	30	Fragrance Odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Adams Spanish Immersion	3201	12/12/2023	11:52:00 AM	1015		69.4	25.9	18	
Adams Spanish Immersion	3202	12/12/2023	11:51:00 AM	830		69	22.7	25	
Adams Spanish Immersion	3203	12/12/2023	12:57:00 PM	653		70.2	17.8	0	
Adams Spanish Immersion	3301	12/12/2023	11:45:00 AM	781		68.1	19	1	
Adams Spanish Immersion	3302	12/12/2023	11:53:00 AM	616	0.1	69.5	17.5	0	Fragrance Odor
Adams Spanish Immersion	3303	12/12/2023	11:55:00 AM	641	0.1	69.7	17.3	0	
Adams Spanish Immersion	3304	12/12/2023	11:56:00 AM	626		69.7	17	0	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	3305	12/12/2023	12:54:00 PM	729	0.1	69.9	18.4	15	
Adams Spanish Immersion	3306	12/12/2023	11:57:00 AM	670		70	18.9	0	Fragrance Odor
Adams Spanish Immersion	3307	12/12/2023	12:55:00 PM	834	0.1	69.8	20.2	18	
Adams Spanish Immersion	3308	12/12/2023	12:56:00 PM	721	0.1	69.7	17.8	20	
Adams Spanish Immersion	3309	12/12/2023	12:51:00 PM	712	0.1	69.4	18.3	18	
Adams Spanish Immersion	1011A	12/12/2023	11:21:00 AM	586		71.7	12.5	0	
Adams Spanish Immersion	1103D	12/12/2023	11:35:00 AM	875	0.1	69.1	18.8	0	
Adams Spanish Immersion	1510A	12/12/2023	11:25:00 AM	790	0.9	70.7	18.4	1	Food Odor
Adams Spanish Immersion	2803A	12/12/2023	12:44:00 PM	620		69.5	17.4	1	Plants: Kept Away From Return And Supply Vents
Adams Spanish Immersion	KITCHEN	12/12/2023	11:24:00 AM	827	1.3	70.8	21.5	2	Food Odor
Adams Spanish Immersion	OUTDOORS	12/12/2023		458	0.7	23	15		
Administration Building	100	1/12/2024	9:01:00 AM	665		71.2	8.7	2	
Administration Building	105	1/12/2024	9:08:00 AM	563		69.3	8.5	1	
Administration Building	106	1/12/2024	9:09:00 AM	518		69.1	7.3	0	
Administration Building	107	1/12/2024	9:06:00 AM	598		69.4	7.8	2	
Administration Building	109	1/12/2024	9:10:00 AM	759		69.1	8.6	3	
Administration Building	110	1/12/2024	9:14:00 AM	536		70	7.1	0	
Administration Building	111	1/12/2024	9:21:00 AM	741		69.6	10.2	3	
Administration Building	112	1/12/2024	9:11:00 AM	514		69.6	6.9	0	
Administration Building	113	1/12/2024	9:05:00 AM	581		69.6	7.8	2	
Administration Building	114	1/12/2024	9:03:00 AM	599		69.8	8.9	1	Plants: Kept Away From Return And Supply Vents
Administration Building	115	1/12/2024	9:20:00 AM	963		69.1	11.9	10	Stained Ceiling Tiles
Administration Building	116	1/12/2024	8:58:00 AM	629		71.4	10	30	
Administration Building	117	1/12/2024	8:57:00 AM	599		71.1	9.7	30	
Administration Building	118	1/12/2024	9:00:00 AM	642		71.6	9.2	10	
Administration Building	118	1/12/2024	9:17:00 AM	568		70	7.6	1	
Administration Building	123	1/12/2024	9:50:00 AM	503		71.4	8.1	0	
Administration Building	124	1/12/2024	9:01:00 AM	614		70.9	8.5	2	
Administration Building	124	1/12/2024	9:49:00 AM	534		70.9	8.8	1	
Administration Building	128	1/12/2024	9:51:00 AM	521		71.4	8.3	0	
Administration Building	131	1/12/2024	9:40:00 AM	556		70.7	8.9	1	
Administration Building	133	1/12/2024	9:48:00 AM	546		71.2	7.8	0	
Administration Building	136	1/12/2024	9:38:00 AM	589		70.5	8.9	1	
Administration Building	138	1/12/2024	9:39:00 AM	605		70.5	8.7	1	
Administration Building	139	1/12/2024	9:41:00 AM	565		71.1	8.8	1	
Administration Building	140	1/12/2024	9:37:00 AM	598		70.3	8.8	1	
Administration Building	141	1/12/2024	9:36:00 AM	540		70.5	7.5	6	
Administration Building	207	1/12/2024	9:59:00 AM	572		70.3	6.9	0	
Administration Building	211	1/12/2024	10:10:00 AM	522		72	6.2	0	Plants: Kept Away From Return And Supply Vents
Administration Building	212	1/12/2024	10:06:00 AM	511		70.5	6.4	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Administration Building	213	1/12/2024	10:11:00 AM	507		71.8	5.8	0	
Administration Building	214	1/12/2024	10:12:00 AM	526		71.1	6.3	1	
Administration Building	215	1/12/2024	10:07:00 AM	508		70.7	6.4	4	Plants: Kept Away From Return And Supply Vents
Administration Building	217	1/12/2024	10:30:00 AM	568		72.1	6.7	1	
Administration Building	218	1/12/2024	10:33:00 AM	573		70.9	6.5	1	
Administration Building	219	1/12/2024	10:34:00 AM	524		70.2	6.6	1	
Administration Building	221	1/12/2024	10:16:00 AM	517		72.1	6.6	0	
Administration Building	222	1/12/2024	10:15:00 AM	509		71.6	5.9	1	Stained Ceiling Tiles
Administration Building	223	1/12/2024	10:14:00 AM	511		70.9	6.5	1	Plants: Kept Away From Return And Supply Vents
Administration Building	224	1/12/2024	10:21:00 AM	522		70.9	6.2	0	Plants: Kept Away From Return And Supply Vents
Administration Building	230	1/12/2024	10:17:00 AM	511		71.4	5.8	0	
Administration Building	231	1/12/2024	10:19:00 AM	599		70.2	7.3	2	
Administration Building	232	1/12/2024	10:23:00 AM	633		70.9	7.1	2	
Administration Building	233	1/12/2024	10:24:00 AM	516		71.2	6.1	0	
Administration Building	234	1/12/2024	10:26:00 AM	506		71.4	6.5	0	Plants: Kept Away From Return And Supply Vents
Administration Building	235	1/12/2024	10:27:00 AM	523		71.2	6.1	3	Plants: Kept Away From Return And Supply Vents
Administration Building	236	1/12/2024	10:29:00 AM	522		71.4	6.3	1	
Administration Building	237	1/12/2024	10:28:00 AM	520		71.2	6.3	1	
Administration Building	238	1/12/2024	10:24:00 AM	548		71.1	6.4	1	Plants: Kept Away From Return And Supply Vents
Administration Building	239	1/12/2024	10:31:00 AM	519		71.6	6.1	0	
Administration Building	243	1/12/2024	10:20:00 AM	525		71.1	6.2	1	
Administration Building	244	1/12/2024	10:22:00 AM	528		70.7	6.5	2	Plants: Kept Away From Return And Supply Vents
Administration Building	308	1/12/2024	10:56:00 AM	510		71.1	6	0	Plants: Kept Away From Return And Supply Vents
Administration Building	309	1/12/2024	10:55:00 AM	514		71.4	6.3	0	
Administration Building	310	1/12/2024	10:54:00 AM	569		71.1	7.3	3	
Administration Building	311	1/12/2024	10:58:00 AM	580		71.1	7.2	1	Plants: Kept Away From Return And Supply Vents
Administration Building	313	1/12/2024	10:57:00 AM	584		71.1	7.1	5	Fragrance Odor
Administration Building	314	1/12/2024	11:00:00 AM	596		71.6	7.2	1	Fragrance Odor
Administration Building	315	1/12/2024	11:01:00 AM	642		72.9	7.5	3	Fragrance Odor
Administration Building	322	1/12/2024	11:03:00 AM	527		71.6	6.2	0	Plants: Kept Away From Return And Supply Vents
Administration Building	323	1/12/2024	11:02:00 AM	651		72.7	8.2	1	Fragrance Odor
Administration Building	324	1/12/2024	11:04:00 AM	592		70.7	7	1	
Administration Building	325	1/12/2024	11:07:00 AM	504		69.4	6.3	0	
Administration Building	326	1/12/2024	11:08:00 AM	501		68.2	6.7	0	
Administration Building	328	1/12/2024	11:04:00 AM	538		70.2	6.9	1	
Administration Building	330	1/12/2024	11:11:00 AM	547		68.9	7.4	1	
Administration Building	331	1/12/2024	11:32:00 AM	515		69.3	6.6	0	
Administration Building	332	1/12/2024	11:12:00 AM	600		69.3	7.6	3	
Administration Building	333	1/12/2024	11:31:00 AM	631		68.5	7.1	0	
Administration Building	337	1/12/2024	11:16:00 AM	500		67.8	6.9	0	
Administration Building	338	1/12/2024	11:30:00 AM	510		68.7	6.7	0	
Administration Building	339	1/12/2024	11:27:00 AM	506		68.9	6.8	0	
Administration Building	340	1/12/2024	11:15:00 AM	598		68.5	7.9	1	Fragrance Odor
Administration Building	341	1/12/2024	11:23:00 AM	545		68	7.8	0	
Administration Building	342	1/12/2024	11:22:00 AM	507		68.4	6.8	0	
Administration Building	343	1/12/2024	11:20:00 AM	547		68.7	7.5	1	
Administration Building	344	1/12/2024	11:26:00 AM	660		68.9	7.1	1	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Administration Building	345	1/12/2024	11:18:00 AM	515		67.5	6.9	0	
Administration Building	346	1/12/2024	11:10:00 AM	617		68.5	8	3	
Administration Building	347	1/12/2024	11:35:00 AM	512		69.4	6.6	0	
Administration Building	348	1/12/2024	11:36:00 AM	707		70	9.3	2	
Administration Building	349	1/12/2024	11:37:00 AM	527		71.1	6.5	0	
Administration Building	350	1/12/2024	11:40:00 AM	548		71.2	6.6	0	
Administration Building	352	1/12/2024	11:05:00 AM	529		70.3	7.2	1	
Administration Building	407	1/12/2024	11:48:00 AM	595		73.8	6.4	6	
Administration Building	409	1/12/2024	11:44:00 AM	583		73	6.1	0	Stained Ceiling Tiles
Administration Building	410	1/12/2024	11:49:00 AM	616		73.2	6.8	2	
Administration Building	411	1/12/2024	11:50:00 AM	538		72.7	6	2	Stained Ceiling Tiles
Administration Building	413	1/12/2024	11:51:00 AM	573		72.3	6.6	2	
Administration Building	414	1/12/2024	11:51:00 AM	567		72.3	7.2	1	Plants: Kept Away From Return And Supply Vents
Administration Building	415	1/12/2024	11:52:00 AM	498		72	5.8	1	Plants: Kept Away From Return And Supply Vents
Administration Building	417	1/12/2024	11:54:00 AM	507		71.4	9.3	0	Plants: Kept Away From Return And Supply Vents
Administration Building	418	1/12/2024	11:55:00 AM	548		70.9	7.1	1	
Administration Building	419	1/12/2024	11:55:00 AM	526		70.9	7.1	1	
Administration Building	420	1/12/2024	11:56:00 AM	553		70.5	7.8	0	Plants: Kept Away From Return And Supply Vents
Administration Building	421	1/12/2024	12:00:00 PM	575		70.2	7.3	2	
Administration Building	423	1/12/2024	11:59:00 AM	540		70	8.1	1	
Administration Building	424	1/12/2024	12:00:00 PM	546		70.3	7	1	
Administration Building	425	1/12/2024	12:01:00 PM	503		70.3	6.5	0	
Administration Building	426	1/12/2024	12:03:00 PM	584		70	7.5	3	
Administration Building	427	1/12/2024	12:04:00 PM	585		71.1	7.3	6	Plants: Kept Away From Return And Supply Vents
Administration Building	433	1/12/2024	12:05:00 PM	542		71.6	6.6	0	
Administration Building	435	1/12/2024	12:06:00 PM	571		72	7	1	Plants: Kept Away From Return And Supply Vents
Administration Building	436	1/12/2024	12:07:00 PM	544		71.2	6.5	2	Plants: Kept Away From Return And Supply Vents
Administration Building	437	1/12/2024	12:08:00 PM	503		70.3	6.7	0	
Administration Building	438	1/12/2024	12:10:00 PM	579		70.7	7.4	2	Plants: Kept Away From Return And Supply Vents
Administration Building	439	1/12/2024	12:11:00 PM	547		71.2	6.9	1	
Administration Building	440	1/12/2024	12:12:00 PM	500		70.2	6.4	0	
Administration Building	441	1/12/2024	12:13:00 PM	531		70.2	7	0	
Administration Building	442	1/12/2024	12:14:00 PM	680		70.5	8.1	2	
Administration Building	443	1/12/2024	12:16:00 PM	980		70.9	11.2	6	
Administration Building	446	1/12/2024	12:15:00 PM	563		70.2	7.5	1	
Administration Building	447	1/12/2024	11:58:00 AM	552		70.2	7.3	1	
Administration Building	508	1/12/2024	12:45:00 PM	548		71.8	6.7	1	
Administration Building	509	1/12/2024	12:44:00 PM	572		71.8	6.8	2	
Administration Building	511	1/12/2024	12:21:00 PM	522		71.8	6.2	0	
Administration Building	513	1/12/2024	12:25:00 PM	573		71.8	7	1	Plants: Kept Away From Return And Supply Vents
Administration Building	514	1/12/2024	12:26:00 PM	527		72	6.6	0	Plants: Kept Away From Return And Supply Vents
Administration Building	515	1/12/2024	12:27:00 PM	534		71.2	6.6	0	Plants: Kept Away From Return And Supply Vents
Administration Building	516	1/12/2024	12:31:00 PM	541		72.5	6.8	2	Plants: Kept Away From Return And Supply Vents
Administration Building	517	1/12/2024	12:32:00 PM	530		72.5	6.6	0	
Administration Building	524	1/12/2024	12:33:00 PM	516		72.3	6.4	0	
Administration Building	525	1/12/2024	12:35:00 PM	529		73.2	6.2	0	
Administration Building	526	1/12/2024	12:37:00 PM	531		72.7	6.7	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Administration Building	527	1/12/2024	12:38:00 PM	551		73	6.5	1	
Administration Building	528	1/12/2024	12:39:00 PM	532		73.2	6.2	0	Plants: Kept Away From Return And Supply Vents
Administration Building	529	1/12/2024	12:40:00 PM	549		73.2	6.4	1	
Administration Building	530	1/12/2024	12:41:00 PM	551		73.4	6.5	0	Plants: Kept Away From Return And Supply Vents
Administration Building	531	1/12/2024	12:39:00 PM	544		73.2	6.3	2	
Administration Building	532	1/12/2024	12:36:00 PM	536		72.9	6.5	0	
Administration Building	533	1/12/2024	12:28:00 PM	541		71.6	7.1	0	
Administration Building	534	1/12/2024	12:24:00 PM	521		71.1	6.7	2	Plants: Kept Away From Return And Supply Vents
Administration Building	535	1/12/2024	12:23:00 PM	528		70.9	6.6	0	
Administration Building	536	1/12/2024	12:22:00 PM	531		71.2	6.6	1	Stained Ceiling Tiles
Administration Building	102A	1/12/2024	9:16:00 AM	601		69.6	8	0	
Administration Building	118 OFFICE	1/12/2024	9:18:00 AM	517		70.2	7	0	
Administration Building	210A	1/12/2024	10:09:00 AM	521		71.4	6.4	1	Plants: Kept Away From Return And Supply Vents
Administration Building	329A	1/12/2024	11:14:00 AM	521		69.1	6.8	0	
Administration Building	329B	1/12/2024	11:38:00 AM	540		71.8	6.1	0	
Administration Building	346 CUBICLE	1/12/2024	11:34:00 AM	551		69.6	7.2	1	
Administration Building	524A	1/12/2024	12:34:00 PM	529		72.7	6.3	0	Plants: Kept Away From Return And Supply Vents
Administration Building	532 CUBICLE	1/12/2024	12:30:00 PM	545		71.8	6.7	1	
Administration Building	B108	1/12/2024	9:32:00 AM	798		72	10.1	15	
Administration Building	B109	1/12/2024	9:30:00 AM	684		71.6	10.3	10	
Administration Building	B110	1/12/2024	9:31:00 AM	698		71.8	10.1	12	
Administration Building	B111	1/12/2024	9:28:00 AM	609		71.1	9	1	
Administration Building	B112	1/12/2024	9:56:00 AM	702		71.1	10.2	5	
Administration Building	B113	1/12/2024	9:24:00 AM	531		70.2	8.7	1	
Administration Building	B114	1/12/2024	9:27:00 AM	508		70.5	8.6	1	
Administration Building	B115	1/12/2024	9:26:00 AM	547		70.5	8.9	0	
Administration Building	B121	1/12/2024	9:55:00 AM	539		72	8	1	
Administration Building	B129	1/12/2024	9:53:00 AM	506		71.8	7.7	0	
Administration Building	B203	1/12/2024	10:36:00 AM	537		70.7	7.7	0	Stained Ceiling Tiles
Administration Building	B206	1/12/2024	10:38:00 AM	539		72	8.1	3	Plants: Kept Away From Return And Supply Vents
Administration Building	B207	1/12/2024	10:40:00 AM	565		72.9	7.8	1	
Administration Building	B207A	1/12/2024	10:39:00 AM	583		72.3	8	1	
Administration Building	B208	1/12/2024	10:41:00 AM	532		71.4	7.8	0	Plants: Kept Away From Return And Supply Vents
Administration Building	B208A	1/12/2024	10:42:00 AM	548		71.2	8.4	1	Plants: Kept Away From Return And Supply Vents
Administration Building	B211	1/12/2024	10:49:00 AM	535		72.3	7.6	0	Stained Ceiling Tiles
Administration Building	B212	1/12/2024	10:47:00 AM	583		72.1	8.6	1	
Administration Building	B213	1/12/2024	10:46:00 AM	533		72.1	8.2	0	Plants: Kept Away From Return And Supply Vents
Administration Building	B214	1/12/2024	10:44:00 AM	537		71.2	8.4	1	
Administration Building	L006	1/12/2024	12:47:00 PM	706		71.2	9.1	2	
Administration Building	OUTDOORS	1/12/2024							
AGAPE High School	1000	1/19/2024	11:17:00 AM	524		68.7	6.1	1	
AGAPE High School	1001	1/19/2024	11:19:00 AM	533		69.4	5.9	0	
AGAPE High School	1003	1/19/2024	11:12:00 AM	565		65.8	8	1	
AGAPE High School	1005	1/19/2024	11:15:00 AM	533		67.8	6.5	1	
AGAPE High School	1006	1/19/2024	11:16:00 AM	579		68.2	6.7	2	
AGAPE High School	1007	1/19/2024	11:22:00 AM	526		70.7	5.7	1	
AGAPE High School	1009	1/19/2024	11:14:00 AM	527		67.3	6.7	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
AGAPE High School	1011	1/19/2024	12:15:00 PM	597		72	4.8	0	
AGAPE High School	1012	1/19/2024	12:17:00 PM	493		71.2	4.9	0	
AGAPE High School	1013	1/19/2024	12:15:00 PM	508		72.3	4.9	1	
AGAPE High School	1014	1/19/2024	12:13:00 PM	501	0.1	72.1	4.9	0	
AGAPE High School	1018	1/19/2024	12:12:00 PM	516	0.1	72.9	5	1	Plants: Kept Away From Return And Supply Vents
AGAPE High School	1019	1/19/2024	12:11:00 PM	514	0.1	73.6	4.4	1	
AGAPE High School	1020	1/19/2024	12:05:00 PM	570		71.2	6.2	1	Stained Ceiling Tiles
AGAPE High School	1021	1/19/2024	12:09:00 PM	525		74.1	4.9	0	
AGAPE High School	1023	1/19/2024	12:06:00 PM	554		72.3	5.7	1	Stained Ceiling Tiles
AGAPE High School	1024	1/19/2024	12:08:00 PM	566		73.4	4.7	0	
AGAPE High School	1025	1/19/2024	12:03:00 PM	502		70	5.4	0	
AGAPE High School	1026	1/19/2024	12:01:00 PM	513		68.5	5.8	1	
AGAPE High School	1027	1/19/2024	11:58:00 AM	734		67.8	18	6	
AGAPE High School	1028	1/19/2024	11:56:00 AM	746		67.8	12.8	5	
AGAPE High School	1029	1/19/2024	11:54:00 AM	610		67.5	8.6	1	
AGAPE High School	1030	1/19/2024	11:48:00 AM	945		69.8	14.9	15	
AGAPE High School	1031	1/19/2024	11:53:00 AM	750		67.6	11.9	5	
AGAPE High School	1032	1/19/2024	12:00:00 PM	603		66.9	9.7	0	Aquariums (fish)
AGAPE High School	1033	1/19/2024	11:50:00 AM	786		68	25.9	10	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
AGAPE High School	1035	1/19/2024	11:46:00 AM	609		70.7	6.8	0	
AGAPE High School	1038	1/19/2024	12:19:00 PM	572		71.2	5.8	1	
AGAPE High School	1040	1/19/2024	11:44:00 AM	633		70.9	7.7	1	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
AGAPE High School	1041	1/19/2024	11:43:00 AM	664		71.2	7.8	3	
AGAPE High School	1043	1/19/2024	11:39:00 AM	538		71.1	6.2	1	
AGAPE High School	1045	1/19/2024	11:36:00 AM	475		70.5	5.4	1	Plants: Kept Away From Return And Supply Vents
AGAPE High School	1045	1/19/2024	11:42:00 AM	627		72.1	7.4	4	
AGAPE High School	1046	1/19/2024	11:24:00 AM	490		70.9	5.4	0	Stained Ceiling Tiles
AGAPE High School	1048	1/19/2024	12:20:00 PM	496		70.7	6.2	0	
AGAPE High School	1053	1/19/2024	11:28:00 AM	417		69.1	8.5	1	
AGAPE High School	1206	1/19/2024	11:25:00 AM	470		70.9	5.8	0	
AGAPE High School	OUTDOORS	1/19/2024		412		4	68		
American Indian Magnet	1003	12/11/2023	12:27:00 PM	864	0.7	69.4	25.7	1	Food Odor, Plants: Kept Away From Return And Supply Vents
American Indian Magnet	1004	12/11/2023	12:30:00 PM	791	0.6	69.6	23.5	0	Plants: Kept Away From Return And Supply Vents
American Indian Magnet	1007	12/11/2023	12:38:00 PM	862	0.7	70.2	23	1	Fragrance Odor
American Indian Magnet	1008	12/11/2023	12:37:00 PM	832	0.5	70.1	22.9	2	Plants: Kept Away From Return And Supply Vents
American Indian Magnet	1009	12/11/2023	12:35:00 PM	839	0.4	70	22.5	0	Plants: Kept Away From Return And Supply Vents
American Indian Magnet	1010	12/11/2023	12:34:00 PM	896	0.7	70	23.9	0	
American Indian Magnet	1012	12/11/2023	12:32:00 PM	902	0.3	69.9	22.6	0	
American Indian Magnet	1013	12/11/2023	12:26:00 PM	848	0.3	68.4	24.5	0	
American Indian Magnet	1101	12/11/2023	11:36:00 AM	677	0.1	66.3	21	0	
American Indian Magnet	1201	12/11/2023	11:40:00 AM	749	0.1	67.4	23.2	3	
American Indian Magnet	1203	12/11/2023	11:42:00 AM	1052	0.1	68.7	27.4	18	
American Indian Magnet	1205	12/11/2023	11:44:00 AM	983	0.2	69.2	25	15	
American Indian Magnet	1206	12/11/2023	9:04:00 AM	735	0.9	64.4	29.6	1	
American Indian Magnet	1502	12/11/2023	11:38:00 AM	829	0.1	66	23.9	0	Food Odor
American Indian Magnet	1600	12/11/2023	11:45:00 AM	678		70.5	22.6	30	Food Odor
American Indian Magnet	2201	12/11/2023	10:51:00 AM	760	0.1	68.8	21.6	15	Musty Odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
American Indian Magnet	2203	12/11/2023	11:15:00 AM	744		69.6	21.3	25	
American Indian Magnet	2205	12/11/2023	10:49:00 AM	843		69.8	22	30	
American Indian Magnet	2207	12/11/2023	11:24:00 AM	906		70	25.2	22	Fragrance Odor
American Indian Magnet	2209	12/11/2023	10:44:00 AM	700	0.1	69.9	20.4	6	
American Indian Magnet	2210	12/11/2023	10:46:00 AM	728	0.2	70.4	20.6	0	
American Indian Magnet	2301	12/11/2023	10:43:00 AM	922	0.3	70.1	21.3	6	
American Indian Magnet	2303	12/11/2023	11:16:00 AM	792		70	21.3	1	
American Indian Magnet	2305	12/11/2023	10:41:00 AM	743	0.4	69.7	20.6	4	
American Indian Magnet	2307	12/11/2023	11:22:00 AM	829	0.1	68.9	22.4	5	Food Odor
American Indian Magnet	2309	12/11/2023	10:40:00 AM	741		70.2	21	1	Fragrance Odor
American Indian Magnet	2310	12/11/2023	10:38:00 AM	810	0.2	69.4	21.9	13	Fragrance Odor
American Indian Magnet	2315	12/11/2023	10:37:00 AM	810	0.1	69.3	22.1	15	Fragrance Odor
American Indian Magnet	2401	12/11/2023	10:36:00 AM	745	0.2	68.4	21.6	0	
American Indian Magnet	2403	12/11/2023	10:35:00 AM	821	0.1	69.1	23	15	
American Indian Magnet	2405	12/11/2023	10:34:00 AM	953	0.4	69	0.2	20	
American Indian Magnet	2407	12/11/2023	10:31:00 AM	863	0.1	68.7	23.3	2	
American Indian Magnet	2409	12/11/2023	11:21:00 AM	852		68.8	22.8	2	Food Odor
American Indian Magnet	2411	12/11/2023	11:20:00 AM	934	0.1	68.9	25.1	15	
American Indian Magnet	2413	12/11/2023	11:18:00 AM	1047	0.1	68.8	25.5	25	
American Indian Magnet	2414	12/11/2023	10:26:00 AM	776		67.7	21.5	0	
American Indian Magnet	3201	12/11/2023	10:02:00 AM	838	0.1	69.5	21.7	20	Musty Odor
American Indian Magnet	3203	12/11/2023	10:01:00 AM	685	0.2	70.1	19.8	15	
American Indian Magnet	3207	12/11/2023	10:00:00 AM	807	0.2	70.6	20.7	15	Fragrance, Food Odor
American Indian Magnet	3208	12/11/2023	9:59:00 AM	583		69.5	18.4	0	Fragrance Odor
American Indian Magnet	3301	12/11/2023	9:56:00 AM	901	0.2	69.5	22.8	7	
American Indian Magnet	3301	12/11/2023	10:23:00 AM	835	0.2	69.9	20.6	22	Live Animals
American Indian Magnet	3303	12/11/2023	10:04:00 AM	908	0.3	71.2	22.2	25	
American Indian Magnet	3305	12/11/2023	9:54:00 AM	788		69.8	22.2	7	
American Indian Magnet	3311	12/11/2023	9:53:00 AM	793	0.2	69.1	22.7	18	Odor Description: Incense Odor
American Indian Magnet	3313	12/11/2023	9:52:00 AM	860	0.3	68.9	22.9	25	
American Indian Magnet	3401	12/11/2023	9:51:00 AM	743	0.3	68.9	21.8	8	Odor Description: Incense Odor
American Indian Magnet	3403	12/11/2023	9:50:00 AM	812	0.5	69	22.8	18	
American Indian Magnet	3405	12/11/2023	9:49:00 AM	835	0.3	69.1	23.1	12	Odor Description: Incense Odor
American Indian Magnet	3407	12/11/2023	9:48:00 AM	763	0.1	69	22	4	
American Indian Magnet	3409	12/11/2023	9:47:00 AM	785	0.2	69.1	22.4	4	
American Indian Magnet	3411	12/11/2023	9:45:00 AM	851	0.4	68.7	23	15	
American Indian Magnet	3414	12/11/2023	9:41:00 AM	768	0.4	68.7	22.5	1	Food Odor
American Indian Magnet	3414	12/11/2023	9:44:00 AM	906	0.4	69.1	23.7	15	
American Indian Magnet	4204	12/11/2023	9:16:00 AM	716	0.3	67.7	23	1	
American Indian Magnet	4301	12/11/2023	9:40:00 AM	700	0.4	72.5	19.4	8	
American Indian Magnet	4303	12/11/2023	9:21:00 AM	644	0.4	70.4	21.6	1	
American Indian Magnet	4305	12/11/2023	9:38:00 AM	766		72.8	20.8	15	
American Indian Magnet	4307	12/11/2023	9:22:00 AM	886	0.4	71.4	23.4	18	Fragrance Odor
American Indian Magnet	4309	12/11/2023	9:37:00 AM	708	0.1	70.6	20.8	10	
American Indian Magnet	4403	12/11/2023	9:36:00 AM	748	0.6	69.8	21.8	12	
American Indian Magnet	4405	12/11/2023	9:35:00 AM	818	0.3	70.1	23.3	10	
American Indian Magnet	4407	12/11/2023	9:34:00 AM	779	0.3	70	22.9	6	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
American Indian Magnet	4409	12/11/2023	9:24:00 AM	780	0.7	70.3	22.4	12	
American Indian Magnet	4413	12/11/2023	9:33:00 AM	806	0.3	69.5	23.4	15	
American Indian Magnet	4414	12/11/2023	9:31:00 AM	773	0.1	69.1	22.6	0	Food Odor
American Indian Magnet	1103A	12/11/2023	11:32:00 AM	780	0.2	67.8	23.5	1	Food Odor
American Indian Magnet	1303 (CONSTRUCTION)	12/11/2023	12:16:00 PM	750	0.7	59.7	31.6	2	
American Indian Magnet	1305 (CONSTRUCTION)	12/11/2023	12:15:00 PM	759	0.6	59.6	31.4	0	
American Indian Magnet	1307 (CONSTRUCTION)	12/11/2023	12:12:00 PM	753		59.2	31.8	0	
American Indian Magnet	1309 (CONSTRUCTION)	12/11/2023	12:09:00 PM	743		57.5	31.9	0	Moisture Impacted Materials Location: Floor
American Indian Magnet	1310 (CONSTRUCTION)	12/11/2023	12:11:00 PM	762		59	31.8	0	
American Indian Magnet	1403 (CONSTRUCTION)	12/11/2023	12:08:00 PM	669		56.1	29.3	1	
American Indian Magnet	1405 (CONSTRUCTION)	12/11/2023	12:07:00 PM	642	0.1	56.5	27.8	1	
American Indian Magnet	1407 (CONSTRUCTION)	12/11/2023	12:04:00 PM	676	0.2	59.8	25.7	2	
American Indian Magnet	1507 (CONSTRUCTION)	12/11/2023	12:06:00 PM	626	0.1	57.8	25.6	0	
American Indian Magnet	1509 (CONSTRUCTION)	12/11/2023	12:18:00 PM	753	0.4	59.5	29.2	0	
American Indian Magnet	1517 OFFICE (CONSTRUCTION)	12/11/2023	11:57:00 AM	683	0.2	61.9	24.9	0	
American Indian Magnet	1706B	12/11/2023	11:55:00 AM	766	0.1	75.3	20.6	0	Food Odor
American Indian Magnet	2301A	12/11/2023	10:47:00 AM	803	0.1	69.4	69.2	2	
American Indian Magnet	4411A	12/11/2023	9:28:00 AM	650	0.5	69	22.4	0	Fragrance Odor
American Indian Magnet	4411B	12/11/2023	9:29:00 AM	618	0.5	68.4	21.9	0	Fragrance Odor
American Indian Magnet	GYMNASIUM	12/11/2023	11:34:00 AM	902		69.4	25.9	12	
American Indian Magnet	KITCHEN	12/11/2023	11:49:00 AM	1149	0.3	73.9	24	4	
American Indian Magnet	MAIN OFFICE	12/11/2023	12:20:00 PM	861	0.5	67.3	24.6	3	Fragrance Odor
American Indian Magnet	MEDIA CENTER	12/11/2023	11:25:00 AM	724	0.2	67.3	22.6	1	
American Indian Magnet	MOTOR ROOM (CONSTRUCTION)	12/11/2023	12:14:00 PM	786	0.3	59.5	32.5	0	
American Indian Magnet	OUTDOORS	12/11/2023		492	2.7	23	87		
American Indian Magnet	READING ROOM	12/11/2023	11:31:00 AM	701		67.5	22.3	0	
Area Learning Center	1001	1/18/2024	10:56:00 AM	446		68.8	6.8	1	
Area Learning Center	1002	1/18/2024	10:59:00 AM	421		69.2	5.3	0	
Area Learning Center	1003	1/18/2024	11:01:00 AM	491		67.1	6	1	
Area Learning Center	1004	1/18/2024	11:02:00 AM	416		68.4	3.8	0	
Area Learning Center	1101	1/18/2024	11:03:00 AM	418	0.1	68.5	4.2	1	Plants: Kept Away From Return And Supply Vents
Area Learning Center	1106	1/18/2024	11:04:00 AM	406	0.1	68.4	4.3	1	
Area Learning Center	1201	1/18/2024	11:11:00 AM	408		69.1	3.3	0	
Area Learning Center	1202	1/18/2024	11:07:00 AM	401		68.5	3.7	0	
Area Learning Center	1203	1/18/2024	11:16:00 AM	421		68.2	5.2	0	Stained Ceiling Tiles
Area Learning Center	1204	1/18/2024	11:09:00 AM	423		68.5	4.2	0	Stained Ceiling Tiles
Area Learning Center	1205	1/18/2024	11:19:00 AM	414		68.4	4.5	0	Stained Ceiling Tiles
Area Learning Center	1206	1/18/2024	11:14:00 AM	404		68.5	3.4	0	Stained Ceiling Tiles
Area Learning Center	2103	1/18/2024	11:55:00 AM	476		70.3	4.4	0	
Area Learning Center	2106	1/18/2024	11:59:00 AM	470		69.1	4.2	0	
Area Learning Center	2201	1/18/2024	11:54:00 AM	505		69.8	4.9	0	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Area Learning Center	2202	1/18/2024	11:41:00 AM	484		69.4	4.1	0	
Area Learning Center	2203	1/18/2024	11:52:00 AM	647		69.1	6.2	3	
Area Learning Center	2205	1/18/2024	11:51:00 AM	507		68.5	5.2	1	
Area Learning Center	2301	1/18/2024	11:40:00 AM	739		69.4	7.4	2	Fragrance Odor
Area Learning Center	2302	1/18/2024	11:30:00 AM	511		70.2	4.7	1	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Area Learning Center	2310	1/18/2024	11:25:00 AM	527	0.1	70.5	4.9	6	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Area Learning Center	2315	1/18/2024	11:27:00 AM	485		70.5	4.4	0	
Area Learning Center	2401	1/18/2024	11:38:00 AM	516		69.3	5.4	1	Stained Ceiling Tiles
Area Learning Center	2402	1/18/2024	11:39:00 AM	591		69.3	6.2	2	
Area Learning Center	2405	1/18/2024	11:37:00 AM	497		69.3	4.7	0	
Area Learning Center	2406	1/18/2024	11:35:00 AM	483		69.4	5	0	Stained Ceiling Tiles
Area Learning Center	2408	1/18/2024	11:33:00 AM	503		69.8	4.9	0	
Area Learning Center	2409	1/18/2024	11:32:00 AM	517		70	5.1	2	Plants: Kept Away From Return And Supply Vents
Area Learning Center	2204 MIDDLE	1/18/2024	11:45:00 AM	515		68.5	5	2	Plants: Kept Away From Return And Supply Vents
Area Learning Center	2204 NORTH	1/18/2024	11:49:00 AM	508		68.5	5	4	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Area Learning Center	2204 SOUTH	1/18/2024	11:44:00 AM	520		69.3	5	1	
Area Learning Center	OUTDOORS	1/18/2024		399	0.1	6	70		
Battle Creek Elementary	1001	1/19/2024	8:39:00 AM	575		72.3	7.7	2	
Battle Creek Elementary	1002	1/19/2024	8:42:00 AM	632		72.5	8.2	2	
Battle Creek Elementary	1003	1/19/2024	8:42:00 AM	580		72.3	8.9	1	
Battle Creek Elementary	1004	1/19/2024	8:38:00 AM	638		72.5	8.1	1	
Battle Creek Elementary	1005	1/19/2024	8:34:00 AM	614		72.1	8	1	Moisture Impacted Materials Location: West side ceiling, Further Assessment
Battle Creek Elementary	1006	1/19/2024	8:33:00 AM	666		70.7	8.8	2	
Battle Creek Elementary	1007	1/19/2024	8:40:00 AM	561		72.1	7.2	0	
Battle Creek Elementary	1009	1/19/2024	8:31:00 AM	566		68.7	13.3	0	
Battle Creek Elementary	1102	1/19/2024	8:24:00 AM	671		69.1	12.6	2	
Battle Creek Elementary	1103	1/19/2024	8:53:00 AM	917		70.5	11.1	8	
Battle Creek Elementary	1104	1/19/2024	8:51:00 AM	794		70.9	10.5	15	
Battle Creek Elementary	1105	1/19/2024	8:50:00 AM	797		70.3	11	15	Aquariums (fish), Plants: Kept Away From Return And Supply Vents, Taxidermy
Battle Creek Elementary	1106	1/19/2024	8:48:00 AM	725		70.3	9.9	15	
Battle Creek Elementary	1107	1/19/2024	8:29:00 AM	535		68.2	12.9	1	
Battle Creek Elementary	1108	1/19/2024	8:28:00 AM	550		69.3	13	5	
Battle Creek Elementary	1110	1/19/2024	8:26:00 AM	524		69.3	12.8	20	
Battle Creek Elementary	1111	1/19/2024	10:16:00 AM	745		71.1	8.9	0	
Battle Creek Elementary	1112	1/19/2024	8:45:00 AM	637		72	8	2	
Battle Creek Elementary	1113	1/19/2024	8:46:00 AM	644		71.1	8.2	1	
Battle Creek Elementary	1202	1/19/2024	8:56:00 AM	586		70.9	6.3	5	
Battle Creek Elementary	1203	1/19/2024	8:54:00 AM	448		70.7	3.2	2	
Battle Creek Elementary	1206	1/19/2024	10:24:00 AM	1239	0.1	71.1	16.3	20	
Battle Creek Elementary	1208	1/19/2024	8:59:00 AM	1299		70.2	12	25	Aquariums (fish)
Battle Creek Elementary	1210	1/19/2024	9:01:00 AM	1188		70.3	13.3	15	Plants: Kept Away From Return And Supply Vents
Battle Creek Elementary	1211	1/19/2024	10:22:00 AM	1233	0.1	71.1	13	20	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Battle Creek Elementary	1212	1/19/2024	10:18:00 AM	821	0.1	70.5	10.6	1	Plants: Kept Away From Return And Supply Vents
Battle Creek Elementary	1213	1/19/2024	10:20:00 AM	1147		70.7	16.2	20	Live Animals: Kept Away From Return And Supply Vents
Battle Creek Elementary	1215	1/19/2024	9:03:00 AM	569		69.8	8	2	
Battle Creek Elementary	1216	1/19/2024	9:05:00 AM	640		68.9	11	1	Fragrance Odor
Battle Creek Elementary	1217	1/19/2024	9:08:00 AM	861		68	12.3	1	
Battle Creek Elementary	1218	1/19/2024	9:10:00 AM	934		68.5	13	2	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Battle Creek Elementary	1219	1/19/2024	9:10:00 AM	749		68.9	11.1	1	
Battle Creek Elementary	1301	1/19/2024	9:53:00 AM	738	0.1	70.2	9.8	4	
Battle Creek Elementary	1302	1/19/2024	9:55:00 AM	625	0.1	69.3	9.3	0	
Battle Creek Elementary	1303	1/19/2024	9:50:00 AM	853		69.1	12.2	15	
Battle Creek Elementary	1304	1/19/2024	9:52:00 AM	735	0.1	70.3	10.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Battle Creek Elementary	1305	1/19/2024	9:47:00 AM	656	0.1	69.1	9.3	1	
Battle Creek Elementary	1306	1/19/2024	9:48:00 AM	653	0.1	67.3	9.9	0	
Battle Creek Elementary	1309	1/19/2024	10:05:00 AM	655		67.1	9.4	2	
Battle Creek Elementary	1310	1/19/2024	9:46:00 AM	740		69.6	10.4	10	Stained Ceiling Tiles
Battle Creek Elementary	1311	1/19/2024	9:57:00 AM	667		68.4	9	1	Plants: Kept Away From Return And Supply Vents
Battle Creek Elementary	1312	1/19/2024	9:44:00 AM	812		68.5	10.9	11	
Battle Creek Elementary	1313	1/19/2024	10:01:00 AM	657		68	9.1	0	
Battle Creek Elementary	1314	1/19/2024	9:40:00 AM	805		68.5	11.5	7	
Battle Creek Elementary	1315	1/19/2024	10:09:00 AM	681		66.7	9.7	1	
Battle Creek Elementary	1316	1/19/2024	9:38:00 AM	674	0.1	71.2	8.4	6	
Battle Creek Elementary	1317	1/19/2024	9:36:00 AM	747		71.2	9.9	20	
Battle Creek Elementary	1320	1/19/2024	10:10:00 AM	741		68.2	11.4	0	
Battle Creek Elementary	1321	1/19/2024	9:34:00 AM	764	0.1	72	8.8	20	
Battle Creek Elementary	1322	1/19/2024	9:33:00 AM	779		72.1	8.8	20	Plants: Kept Away From Return And Supply Vents
Battle Creek Elementary	1323	1/19/2024	9:30:00 AM	842		71.2	9.6	20	
Battle Creek Elementary	1324	1/19/2024	9:29:00 AM	806		69.6	10.1	20	
Battle Creek Elementary	1325	1/19/2024	9:27:00 AM	837	0.1	69.6	10.7	20	
Battle Creek Elementary	1326	1/19/2024	9:25:00 AM	881		71.1	10.5	20	
Battle Creek Elementary	1329	1/19/2024	9:13:00 AM	751	0.1	68.7	9.9	10	Live Animals: Kept Away From Return And Supply Vents, Plants: Kept Aw
Battle Creek Elementary	1330	1/19/2024	9:15:00 AM	880		69.1	11.1	20	
Battle Creek Elementary	1331	1/19/2024	9:17:00 AM	891		69.3	12.7	20	Plants: Kept Away From Return And Supply Vents, Taxidermy
Battle Creek Elementary	1332	1/19/2024	10:12:00 AM	731		69.4	9.4	0	
Battle Creek Elementary	1334	1/19/2024	9:19:00 AM	822		70.2	10.6	20	
Battle Creek Elementary	1335	1/19/2024	9:23:00 AM	1302	0.1	71.4	13.4	20	
Battle Creek Elementary	1336	1/19/2024	9:22:00 AM	1115		72.3	11.9	20	
Battle Creek Elementary	1337	1/19/2024	9:20:00 AM	1106		71.2	12.5	20	
Battle Creek Elementary	1309A	1/19/2024	10:08:00 AM	659		65.3	10	0	
Battle Creek Elementary	1309B	1/19/2024	10:07:00 AM	655		65.8	9.8	0	
Battle Creek Elementary	OUTDOORS	1/19/2024		412		2	74		
Battle Creek Middle School	213	1/10/2024	10:01:00 AM	570	0.4	69.1	17.9	0	
Battle Creek Middle School	1001	1/10/2024	11:35:00 AM	657		68.2	20.6	0	
Battle Creek Middle School	1003	1/10/2024	11:58:00 AM	752	0.2	71.1	19.4	2	Fragrance Odor
Battle Creek Middle School	1004	1/10/2024	11:38:00 AM	656	0.1	70	19.3	1	Fragrance Odor
Battle Creek Middle School	1005	1/10/2024	11:39:00 AM	784	0.1	70.3	19.1	1	Fragrance Odor
Battle Creek Middle School	1007	1/10/2024	11:35:00 AM	699	0.1	69.4	20.1	2	
Battle Creek Middle School	1008	1/10/2024	11:40:00 AM	665	0.1	70.3	19	2	
Battle Creek Middle School	1009	1/10/2024	11:41:00 AM	686	0.1	70.2	19.8	1	Stained Ceiling Tiles
Battle Creek Middle School	1010	1/10/2024	11:43:00 AM	686	0.1	70.3	19.5	2	
Battle Creek Middle School	1011	1/10/2024	11:45:00 AM	667	0.1	70	19.3	2	
Battle Creek Middle School	1013	1/10/2024	11:46:00 AM	659	0.1	71.2	19	0	
Battle Creek Middle School	1014	1/10/2024	11:48:00 AM	644	0.1	71.6	18.3	0	
Battle Creek Middle School	1015	1/10/2024	11:49:00 AM	652	0.2	71.2	18.4	0	
Battle Creek Middle School	1016	1/10/2024	11:50:00 AM	796	0.2	71.6	19.3	1	
Battle Creek Middle School	1017	1/10/2024	11:51:00 AM	720	0.2	71.6	18.8	0	
Battle Creek Middle School	1018	1/10/2024	11:52:00 AM	815		72.1	18.7	0	Food Odor
Battle Creek Middle School	1020	1/10/2024	11:57:00 AM	659	0.3	71.1	18.8	0	
Battle Creek Middle School	1021	1/10/2024	11:56:00 AM	693	0.3	71.8	18.9	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Battle Creek Middle School	1022	1/10/2024	11:55:00 AM	717	0.2	72.5	18.1	0	
Battle Creek Middle School	1103	1/10/2024	11:20:00 AM	508		67.3	17.8	0	
Battle Creek Middle School	1104	1/10/2024	11:22:00 AM	563		67.3	18.8	25	
Battle Creek Middle School	1106	1/10/2024	11:25:00 AM	534		68.5	17.5	1	
Battle Creek Middle School	1107	1/10/2024	11:32:00 AM	600		66.9	19	5	Fragrance Odor
Battle Creek Middle School	1108	1/10/2024	11:27:00 AM	504	0.1	66.6	18.4	2	
Battle Creek Middle School	1109	1/10/2024	11:29:00 AM	509		66.9	18.9	0	
Battle Creek Middle School	1113	1/10/2024	11:19:00 AM	580		67.5	19	10	Stained Ceiling Tiles
Battle Creek Middle School	1114	1/10/2024	11:17:00 AM	477	0.1	67.6	17.6	1	Stained Ceiling Tiles
Battle Creek Middle School	1201	1/10/2024	11:12:00 AM	729	0.1	68.9	21.3	20	Musty Odor
Battle Creek Middle School	1202	1/10/2024	11:13:00 AM	646		69.1	19.5	20	
Battle Creek Middle School	1203	1/10/2024	11:14:00 AM	518	0.1	68.5	18.3	0	
Battle Creek Middle School	1204	1/10/2024	11:15:00 AM	769	0.1	68.5	20.7	15	
Battle Creek Middle School	1205	1/10/2024	10:53:00 AM	695	0.2	68.7	19.6	22	
Battle Creek Middle School	1206	1/10/2024	10:56:00 AM	655	0.2	69.3	19.8	1	
Battle Creek Middle School	1208	1/10/2024	10:57:00 AM	713	0.1	69.8	19.9	1	
Battle Creek Middle School	1305	1/10/2024	9:31:00 AM	652	0.4	67.8	19.3	25	
Battle Creek Middle School	1307	1/10/2024	9:23:00 AM	712	0.4	68	18.3	1	
Battle Creek Middle School	1403	1/10/2024	9:32:00 AM	502	0.4	68	17.5	0	
Battle Creek Middle School	1407	1/10/2024	9:36:00 AM	471	0.5	68.2	18.1	0	
Battle Creek Middle School	1501	1/10/2024	9:40:00 AM	578	0.4	68.5	17.9	15	
Battle Creek Middle School	1504	1/10/2024	9:52:00 AM	562	0.4	69.8	17.3	0	Food Odor
Battle Creek Middle School	1505	1/10/2024	9:51:00 AM	524	0.4	70	16.5	0	Fragrance Odor
Battle Creek Middle School	1506	1/10/2024	9:49:00 AM	553	0.4	70.7	16.2	0	
Battle Creek Middle School	1507	1/10/2024	9:43:00 AM	591	0.4	70.5	17.8	1	
Battle Creek Middle School	1508	1/10/2024	9:48:00 AM	535	0.4	71.2	16.2	0	
Battle Creek Middle School	1509	1/10/2024	9:37:00 AM	589	0.4	68	17.8	11	
Battle Creek Middle School	1510	1/10/2024	9:41:00 AM	498	0.4	69.1	17.1	0	
Battle Creek Middle School	1601	1/10/2024	11:11:00 AM	738		68.7	20.7	16	
Battle Creek Middle School	1602	1/10/2024	11:09:00 AM	765	0.1	68.7	19.2	0	
Battle Creek Middle School	1603	1/10/2024	11:08:00 AM	717	0.1	68.5	19.8	15	
Battle Creek Middle School	1604	1/10/2024	11:07:00 AM	825	0.1	68.9	20.6	20	
Battle Creek Middle School	1605	1/10/2024	11:06:00 AM	657		68.9	19	1	
Battle Creek Middle School	1606	1/10/2024	11:05:00 AM	651	0.1	69.3	18.8	20	Fragrance Odor
Battle Creek Middle School	1607	1/10/2024	11:05:00 AM	683	0.1	68.5	19.3	20	
Battle Creek Middle School	1608	1/10/2024	11:03:00 AM	705	0.1	68.9	19	20	Fragrance Odor
Battle Creek Middle School	1609	1/10/2024	11:02:00 AM	685	0.1	68.9	19.2	20	Fragrance Odor
Battle Creek Middle School	1610	1/10/2024	11:00:00 AM	736	0.1	69.1	20.1	20	
Battle Creek Middle School	2104	1/10/2024	10:46:00 AM	735		68	19.8	80	
Battle Creek Middle School	2105	1/10/2024	10:43:00 AM	533	0.1	67.6	19	0	
Battle Creek Middle School	2106	1/10/2024	10:39:00 AM	532	0.1	67.8	19	5	
Battle Creek Middle School	2201	1/10/2024	10:15:00 AM	825	0.3	69.1	21.6	24	Food Odor, Stained Ceiling Tiles
Battle Creek Middle School	2204	1/10/2024	10:12:00 AM	625	0.3	69.6	18	15	
Battle Creek Middle School	2205	1/10/2024	9:53:00 AM	545	0.3	69.1	17.8	0	
Battle Creek Middle School	2206	1/10/2024	9:59:00 AM	561	0.3	69.3	18.6	0	Stained Ceiling Tiles
Battle Creek Middle School	2208	1/10/2024	10:13:00 AM	646	0.2	69.8	18.8	12	
Battle Creek Middle School	2303	1/10/2024	10:09:00 AM	572	0.2	69.6	17.4	10	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Battle Creek Middle School	2403	1/10/2024	10:02:00 AM	450	0.2	69.5	16.5	1	
Battle Creek Middle School	2502	1/10/2024	10:07:00 AM	651	0.2	69.3	18.9	15	
Battle Creek Middle School	2503	1/10/2024	10:06:00 AM	603	0.3	69.1	18	0	
Battle Creek Middle School	2504	1/10/2024	10:04:00 AM	638	0.2	69.3	18.5	25	
Battle Creek Middle School	2601	1/10/2024	10:28:00 AM	538	0.1	69.6	17.3	0	
Battle Creek Middle School	2602	1/10/2024	10:26:00 AM	741	0.1	69.8	19.2	15	
Battle Creek Middle School	2603	1/10/2024	10:25:00 AM	644	0.1	69.8	18.1	7	
Battle Creek Middle School	2604	1/10/2024	10:23:00 AM	526	0.1	69.6	17.6	0	
Battle Creek Middle School	2605	1/10/2024	10:08:00 AM	592	0.2	69.4	17.6	5	
Battle Creek Middle School	2606	1/10/2024	10:23:00 AM	782	0.3	69.1	20.2	25	
Battle Creek Middle School	2607	1/10/2024	10:21:00 AM	617	0.2	69.3	18.7	0	
Battle Creek Middle School	2608	1/10/2024	10:20:00 AM	772	0.2	69.4	19.7	15	
Battle Creek Middle School	2609	1/10/2024	10:19:00 AM	667	0.2	69.1	21.3	15	
Battle Creek Middle School	2610	1/10/2024	10:17:00 AM	695	0.2	68.9	19.2	15	
Battle Creek Middle School	2611	1/10/2024	10:35:00 AM	776	0.1	68.7	19.3	22	
Battle Creek Middle School	2612	1/10/2024	10:38:00 AM	928	0.1	68.5	19.9	0	
Battle Creek Middle School	2614	1/10/2024	10:33:00 AM	783	0.1	69.3	19.3	25	
Battle Creek Middle School	2615	1/10/2024	10:35:00 AM	675	0.1	69.1	18.5	0	
Battle Creek Middle School	2617	1/10/2024	10:29:00 AM	726	0.1	69.4	18.7	18	Fragrance Odor
Battle Creek Middle School	2618	1/10/2024	10:31:00 AM	713	0.2	69.6	19.5	0	Fragrance Odor
Battle Creek Middle School	2619	1/10/2024	10:32:00 AM	649	0.1	69.4	18.2	0	
Battle Creek Middle School	1018A	1/10/2024	11:53:00 AM	692	0.1	73.4	18	1	Food Odor
Battle Creek Middle School	1104C	1/10/2024	11:23:00 AM	471		68.4	17.5	0	
Battle Creek Middle School	1511A	1/10/2024	9:08:00 AM	510	0.2	68	20.3	1	
Battle Creek Middle School	2106C	1/10/2024	10:43:00 AM	740	0.1	69.3	19.2	2	
Battle Creek Middle School	OUTDOORS	1/10/2024		390	0.6	23	87		
Bridge View School	1001	1/12/2024		531		69.8	10	1	
Bridge View School	1003	1/12/2024	11:31:00 AM	661		70.9	9.3	1	
Bridge View School	1004	1/12/2024	11:32:00 AM	635		70.9	10.5	1	
Bridge View School	1005	1/12/2024	11:34:00 AM	556		71.1	12	1	Stained Ceiling Tiles
Bridge View School	1006	1/12/2024	11:33:00 AM	595		70.9	10.2	0	
Bridge View School	1007	1/12/2024	11:30:00 AM	612		70.3	9.8	0	
Bridge View School	1008	1/12/2024	11:29:00 AM	548		70.2	9.2	0	
Bridge View School	1009	1/12/2024	11:36:00 AM	654		71.2	10.6	1	
Bridge View School	1104	1/12/2024	11:39:00 AM	763	0.1	75.9	61.8	7	
Bridge View School	1105	1/12/2024	11:41:00 AM	566	0.2	75.2	12.6	0	
Bridge View School	1106	1/12/2024	11:43:00 AM	561	0.3	74.3	10.8	1	
Bridge View School	1111	1/12/2024	11:43:00 AM	715	0.2	73.2	14.9	0	
Bridge View School	1112	1/12/2024	11:47:00 AM	527	0.1	70.2	9.7	3	Food Odor
Bridge View School	1113	1/12/2024	11:48:00 AM	536	0.1	69.8	12.4	0	
Bridge View School	1201	1/12/2024	11:45:00 AM	529	0.1	71.1	12.4	9	
Bridge View School	1301	1/12/2024	12:21:00 PM	643		72	9.8	4	
Bridge View School	1302	1/12/2024	12:19:00 PM	659		71.8	9.1	0	
Bridge View School	1303	1/12/2024	12:15:00 PM	649		71.4	9.2	10	
Bridge View School	1306	1/12/2024	12:16:00 PM	585		71.6	8.6	0	
Bridge View School	1311	1/12/2024	12:06:00 PM	499		69.4	7.5	0	
Bridge View School	1315	1/12/2024	12:11:00 PM	550		69.3	8.5	10	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Bridge View School	1316	1/12/2024	12:08:00 PM	532		69.8	8.9	1	
Bridge View School	1317	1/12/2024	12:12:00 PM	550		70	8.3	0	
Bridge View School	1318	1/12/2024	12:13:00 PM	559		70.5	8.1	5	
Bridge View School	1320	1/12/2024	12:17:00 PM	553		71.8	8.1	10	
Bridge View School	1321	1/12/2024	12:20:00 PM	716		72.1	8.8	6	
Bridge View School	1401	1/12/2024	12:23:00 PM	564	0.1	69.8	9.3	1	
Bridge View School	1402	1/12/2024	12:26:00 PM	560		69.6	9.3	3	
Bridge View School	1403	1/12/2024	12:29:00 PM	741		68.9	10	0	
Bridge View School	1404	1/12/2024	12:30:00 PM	575		68.7	9.2	6	
Bridge View School	1405	1/12/2024	12:33:00 PM	566		68.2	8.7	2	
Bridge View School	1406	1/12/2024	12:31:00 PM	661		68.9	8.9	0	Food Odor
Bridge View School	1407	1/12/2024	12:28:00 PM	630		69.3	10.1	8	
Bridge View School	1408	1/12/2024	12:27:00 PM	686		69.4	10.4	8	Fragrance Odor
Bridge View School	1500	1/12/2024	11:49:00 AM	514		69.6	9.2	10	Stained Ceiling Tiles
Bridge View School	1501	1/12/2024	11:52:00 AM	598		70.9	12.2	1	
Bridge View School	1602	1/12/2024	12:05:00 PM	541		68.7	8.8	1	
Bridge View School	1603	1/12/2024	12:03:00 PM	506		67.8	8.6	0	Stained Ceiling Tiles
Bridge View School	1604	1/12/2024	12:02:00 PM	701		66.9	9.8	0	
Bridge View School	1605	1/12/2024	12:01:00 PM	479		66.9	8.7	0	
Bridge View School	1606	1/12/2024	12:00:00 PM	519		69.1	8.8	1	
Bridge View School	1607	1/12/2024	11:58:00 AM	719		69.3	9	15	
Bridge View School	1608	1/12/2024	11:57:00 AM	503		70.3	7.7	1	
Bridge View School	1609	1/12/2024	11:56:00 AM	531		71.1	8.7	5	
Bridge View School	1610	1/12/2024	11:53:00 AM	854	0.1	71.1	10.1	6	
Bridge View School	1009A	1/12/2024	11:38:00 AM	530		71.6	9.5	1	
Bridge View School	1009B	1/12/2024	11:37:00 AM	575		71.4	9.4	0	
Bridge View School	1301A	1/12/2024	12:23:00 PM	581		72.1	9.1	0	
Bridge View School	1600A	1/12/2024	11:59:00 AM	569		68.5	10.1	0	Stained Ceiling Tiles
Bridge View School	OUTDOORS	1/12/2024	12:53:00 PM	375	0.7	7	73		
Bruce F. Vento Elementary School	1000	1/23/2024	10:21:00 AM	502	0.1	70	19.6	2	
Bruce F. Vento Elementary School	1001	1/23/2024	10:15:00 AM	523	0.2	70	19.7	4	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Bruce F. Vento Elementary School	1002	1/23/2024	10:18:00 AM	499	0.1	69.4	20.1	1	
Bruce F. Vento Elementary School	1003	1/23/2024	10:20:00 AM	507	0.1	69.8	20	0	
Bruce F. Vento Elementary School	1004	1/23/2024	10:19:00 AM	523	0.1	69.6	20.3	0	Stained Ceiling Tiles
Bruce F. Vento Elementary School	1005	1/23/2024	10:17:00 AM	550	0.2	69.6	19.8	1	Plants: Kept Away From Return And Supply Vents
Bruce F. Vento Elementary School	1006	1/23/2024	10:15:00 AM	614	0.1	69.6	20.5	2	
Bruce F. Vento Elementary School	1007	1/23/2024	10:13:00 AM	570	0.1	69.4	20.6	1	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Bruce F. Vento Elementary School	1008	1/23/2024	10:08:00 AM	560	0.2	70.7	19.4	1	
Bruce F. Vento Elementary School	1009	1/23/2024	10:12:00 AM	686	0.2	69.4	20.8	1	
Bruce F. Vento Elementary School	1010	1/23/2024	10:11:00 AM	785	0.3	70	21.5	8	Plants: Kept Away From Return And Supply Vents
Bruce F. Vento Elementary School	1102	1/23/2024	10:52:00 AM	646	0.2	70.7	19.5	1	
Bruce F. Vento Elementary School	1103	1/23/2024	10:53:00 AM	635	0.2	71.1	19.3	0	
Bruce F. Vento Elementary School	1104	1/23/2024	10:54:00 AM	653	0.2	71.8	19.1	1	Aquariums (fish)
Bruce F. Vento Elementary School	1106	1/23/2024	10:55:00 AM	625	0.2	72.1	18.7	0	
Bruce F. Vento Elementary School	1107	1/23/2024	10:57:00 AM	703	0.2	72.3	18.9	20	
Bruce F. Vento Elementary School	1108	1/23/2024	10:58:00 AM	671	0.3	72.1	18.8	0	
Bruce F. Vento Elementary School	1110	1/23/2024	8:54:00 AM	813	0.1	71.6	18.3	20	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Bruce F. Vento Elementary School	1111	1/23/2024	8:55:00 AM	807	0.1	72	18.1	0	
Bruce F. Vento Elementary School	1112	1/23/2024	8:57:00 AM	812	0.1	72	18.1	2	
Bruce F. Vento Elementary School	1113	1/23/2024	8:58:00 AM	809	0.2	72.1	17.7	20	
Bruce F. Vento Elementary School	1114	1/23/2024	8:59:00 AM	808	0.1	72.3	18.3	1	
Bruce F. Vento Elementary School	1115	1/23/2024	8:53:00 AM	870	0.1	71.1	19.4	20	Stained Ceiling Tiles
Bruce F. Vento Elementary School	1202	1/23/2024	8:40:00 AM	807		73	17.7	24	
Bruce F. Vento Elementary School	1203	1/23/2024	8:38:00 AM	761		73	17.2	1	
Bruce F. Vento Elementary School	1204	1/23/2024	8:38:00 AM	765		72.9	17.3	15	
Bruce F. Vento Elementary School	1206	1/23/2024	8:37:00 AM	729		72.3	17.2	14	
Bruce F. Vento Elementary School	1207	1/23/2024	8:42:00 AM	781	0.1	73	17.3	1	
Bruce F. Vento Elementary School	1208	1/23/2024	8:41:00 AM	719	0.1	72.9	17.1	1	
Bruce F. Vento Elementary School	1210	1/23/2024	8:32:00 AM	694		72.1	16.7	1	
Bruce F. Vento Elementary School	1211	1/23/2024	8:31:00 AM	700		72	16.8	3	
Bruce F. Vento Elementary School	1212	1/23/2024	8:30:00 AM	677		71.8	16.9	1	
Bruce F. Vento Elementary School	1213	1/23/2024	8:35:00 AM	737		72	17.3	1	
Bruce F. Vento Elementary School	1214	1/23/2024	8:33:00 AM	720		72.1	17.2	4	
Bruce F. Vento Elementary School	1215	1/23/2024	8:34:00 AM	663		71.8	16.6	3	
Bruce F. Vento Elementary School	1301	1/23/2024	9:10:00 AM	625	0.1	69.4	19.7	5	Plants: Kept Away From Return And Supply Vents
Bruce F. Vento Elementary School	1302	1/23/2024	10:30:00 AM	660	0.2	69.4	21.4	3	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Bruce F. Vento Elementary School	1303	1/23/2024	8:46:00 AM	603	0.1	72.1	17	0	
Bruce F. Vento Elementary School	1304	1/23/2024	10:31:00 AM	661	0.2	69.8	21.3	9	
Bruce F. Vento Elementary School	1306	1/23/2024	8:44:00 AM	574	0.1	72	16.8	3	
Bruce F. Vento Elementary School	1307	1/23/2024	8:48:00 AM	567	0.1	73.6	15.6	2	Stained Ceiling Tiles
Bruce F. Vento Elementary School	1308	1/23/2024	8:50:00 AM	575	0.1	73.2	16.2	1	
Bruce F. Vento Elementary School	1310	1/23/2024	10:35:00 AM	814	0.2	69.1	22.1	4	
Bruce F. Vento Elementary School	1311	1/23/2024	10:36:00 AM	766	0.1	70.3	22.3	80	
Bruce F. Vento Elementary School	1312	1/23/2024	8:25:00 AM	669		68.9	20.5	5	
Bruce F. Vento Elementary School	1313	1/23/2024	8:27:00 AM	728		70.3	13.2	1	
Bruce F. Vento Elementary School	1317	1/23/2024	8:23:00 AM	647	0.3	68.5	19.4	1	
Bruce F. Vento Elementary School	1320	1/23/2024	8:26:00 AM	613		70	18	1	
Bruce F. Vento Elementary School	1402	1/23/2024	9:32:00 AM	1221	0.3	72	19.7	17	
Bruce F. Vento Elementary School	1403	1/23/2024	9:33:00 AM	1400	0.3	72.3	21.3	19	
Bruce F. Vento Elementary School	1404	1/23/2024	9:35:00 AM	1043	0.3	72.1	17.9	1	
Bruce F. Vento Elementary School	1406	1/23/2024	9:25:00 AM	1065	0.3	71.1	19.4	15	
Bruce F. Vento Elementary School	1407	1/23/2024	10:41:00 AM	1132	0.2	71.6	20	0	
Bruce F. Vento Elementary School	1408	1/23/2024	9:29:00 AM	988	0.2	71.1	18.6	1	
Bruce F. Vento Elementary School	1409	1/23/2024	10:44:00 AM	1071	0.4	72.3	18.3	0	
Bruce F. Vento Elementary School	1411	1/23/2024	9:18:00 AM	1055	0.3	71.8	18.7	2	
Bruce F. Vento Elementary School	1415	1/23/2024	9:19:00 AM	1052	0.3	71.4	17.8	1	
Bruce F. Vento Elementary School	1416	1/23/2024	9:16:00 AM	1115	0.3	71.8	18.7	4	
Bruce F. Vento Elementary School	1417	1/23/2024	9:21:00 AM	1101	0.3	71.6	19.2	15	
Bruce F. Vento Elementary School	1418	1/23/2024	9:23:00 AM	1064	0.3	71.4	19	13	Stained Ceiling Tiles
Bruce F. Vento Elementary School	1419	1/23/2024	9:15:00 AM	1197	0.2	71.8	20	18	
Bruce F. Vento Elementary School	1420	1/23/2024	9:13:00 AM	1368	0.2	70.3	21.4	20	
Bruce F. Vento Elementary School	1502	1/23/2024	10:06:00 AM	899	0.1	71.6	19.1	20	
Bruce F. Vento Elementary School	1503	1/23/2024	10:05:00 AM	862	0.1	70.5	19.2	1	
Bruce F. Vento Elementary School	1504	1/23/2024	10:04:00 AM	811	0.1	70.3	19	1	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Bruce F. Vento Elementary School	1505	1/23/2024	10:02:00 AM	906	0.2	70.5	19.6	15	
Bruce F. Vento Elementary School	1506	1/23/2024	10:00:00 AM	898	0.2	71.1	19.2	1	
Bruce F. Vento Elementary School	1507	1/23/2024	9:58:00 AM	870	0.2	71.1	19.3	19	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Bruce F. Vento Elementary School	1510	1/23/2024	9:46:00 AM	1095	0.2	72	19	5	Stained Ceiling Tiles
Bruce F. Vento Elementary School	1511	1/23/2024	10:49:00 AM	910	0.2	71.1	19.5	0	
Bruce F. Vento Elementary School	1512	1/23/2024	10:48:00 AM	1006	0.3	70.9	21.2	0	
Bruce F. Vento Elementary School	1513	1/23/2024	9:44:00 AM	1003	0.2	71.6	18.3	3	
Bruce F. Vento Elementary School	1514	1/23/2024	9:49:00 AM	978	0.3	72.3	19	15	Stained Ceiling Tiles
Bruce F. Vento Elementary School	1515	1/23/2024	9:42:00 AM	1204	0.3	72	20.3	20	Plants: Kept Away From Return And Supply Vents
Bruce F. Vento Elementary School	1516	1/23/2024	9:40:00 AM	1070	0.3	72	19	21	
Bruce F. Vento Elementary School	1517	1/23/2024	9:38:00 AM	1442	0.3	71.6	21.9	28	Stained Ceiling Tiles
Bruce F. Vento Elementary School	1601	1/23/2024	9:54:00 AM	612	0.2	71.8	20.6	22	
Bruce F. Vento Elementary School	1602	1/23/2024	10:27:00 AM	630	0.1	70	23	0	
Bruce F. Vento Elementary School	1604	1/23/2024	10:26:00 AM	579	0.1	68.7	20.2	0	Stained Ceiling Tiles
Bruce F. Vento Elementary School	1605	1/23/2024	10:24:00 AM	662	0.1	68.2	21.7	2	
Bruce F. Vento Elementary School	1606	1/23/2024	9:03:00 AM	828	0.1	71.2	17.6	3	
Bruce F. Vento Elementary School	1607	1/23/2024	9:05:00 AM	574	0.1	70.7	18	1	
Bruce F. Vento Elementary School	1608	1/23/2024	9:07:00 AM	624	0.2	70.2	18.5	2	
Bruce F. Vento Elementary School	1610	1/23/2024	9:01:00 AM	625	0.2	70.9	18.2	20	Plants: Kept Away From Return And Supply Vents
Bruce F. Vento Elementary School	OUTDOORS	1/23/2024		405	0.4	32	84		
Central Senior High School	101	2/1/2024	10:09:00 AM	516	0.8	72	25.5	1	
Central Senior High School	202	2/1/2024	10:18:00 AM	499	0.6	70.3	26.7	0	
Central Senior High School	401	2/1/2024	10:16:00 AM	515	0.6	70.3	26.9	0	
Central Senior High School	404	2/1/2024	10:12:00 AM	490	1	71.8	25	1	
Central Senior High School	1101	2/1/2024	10:55:00 AM	536	0.5	70.9	26.2	2	
Central Senior High School	1102	2/1/2024	10:57:00 AM	520	0.8	70.9	26	0	
Central Senior High School	1103	2/1/2024	11:00:00 AM	570	0.4	71.4	25.7	2	
Central Senior High School	1104	2/1/2024	10:59:00 AM	543	0.8	71.4	26	4	
Central Senior High School	1106	2/1/2024	10:58:00 AM	533	0.8	71.2	27	0	
Central Senior High School	1108	2/1/2024	11:03:00 AM	730	0.3	71.9	28.9	6	
Central Senior High School	1109	2/1/2024	11:05:00 AM	630	0.4	72.7	26.7	0	
Central Senior High School	1110	2/1/2024	11:06:00 AM	571	0.1	73.5	26	0	
Central Senior High School	1111	2/1/2024	11:08:00 AM	604	0.3	74	25.6	0	Fragrance Odor
Central Senior High School	1112	2/1/2024	11:09:00 AM	570	0.5	74.1	25	0	
Central Senior High School	1114	2/1/2024	11:11:00 AM	610	0.9	7.5	26.3	0	
Central Senior High School	1115	2/1/2024	11:13:00 AM	525	0.5	71.7	27.3	0	
Central Senior High School	1116	2/1/2024	11:16:00 AM	526	0.4	72.2	26.7	0	
Central Senior High School	1117	2/1/2024	11:17:00 AM	520		70.9	27.2	0	
Central Senior High School	1119	2/1/2024	11:19:00 AM	629	0.1	71.4	30.5	14	
Central Senior High School	1120	2/1/2024	11:28:00 AM	645	0.3	72.7	27	7	
Central Senior High School	1201	2/1/2024	10:53:00 AM	527	0.5	70.8	26.1	0	
Central Senior High School	1202	2/1/2024	10:52:00 AM	687	0.3	70.2	28.7	25	
Central Senior High School	1203	2/1/2024	10:49:00 AM	535	0.9	70.1	26.7	2	
Central Senior High School	1208	2/1/2024	9:47:00 AM	566	1.2	71.7	24.5	2	
Central Senior High School	1209	2/1/2024	9:45:00 AM	612	1.4	73	24.6	1	Stained Ceiling Tiles
Central Senior High School	1214	2/1/2024	11:40:00 AM	730	0.3	72	30.5	20	
Central Senior High School	1217	2/1/2024	11:44:00 AM	545	0.4	75.5	23.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Central Senior High School	1218	2/1/2024	11:47:00 AM	495	1	73	24.7	0	
Central Senior High School	1301	2/1/2024	10:48:00 AM	540	0.4	70.5	26.5	0	Fragrance Odor
Central Senior High School	1303	2/1/2024	10:28:00 AM	716	0.8	71.4	29.6	21	Plants
Central Senior High School	1304	2/1/2024	10:30:00 AM	677	0.8	70.8	28	31	
Central Senior High School	1308	2/1/2024	10:31:00 AM	623	0.6	70.8	29.4	18	Plants
Central Senior High School	1309	2/1/2024	10:33:00 AM	516	1.2	71.2	25.5	3	
Central Senior High School	1310	2/1/2024	10:41:00 AM	449	0.9	71	24.7	0	
Central Senior High School	1311	2/1/2024	10:38:00 AM	463	0.9	71.9	24	0	
Central Senior High School	1313	2/1/2024	10:34:00 AM	488	0.8	72	24.5	0	Fragrance Odor
Central Senior High School	1313	2/1/2024	10:37:00 AM	563	0.6	72.6	25.5	1	
Central Senior High School	1314	2/1/2024	10:42:00 AM	448	0.8	70.2	24.9	0	
Central Senior High School	1316	2/1/2024	10:44:00 AM	949	0.6	70.3	31.8	26	Stained Ceiling Tiles
Central Senior High School	1317	2/1/2024	10:47:00 AM	726	0.8	70.5	29.5	27	
Central Senior High School	1318	2/1/2024	10:20:00 AM	753	0.1	71	30.3	23	
Central Senior High School	1405	2/1/2024	9:52:00 AM	557	0.1	78.4	26.2	1	
Central Senior High School	1406	2/1/2024	12:13:00 PM	621	0.8	74.6	25.1	0	
Central Senior High School	1409	2/1/2024	9:51:00 AM	690	0.8	71	28.4	0	
Central Senior High School	1410	2/1/2024	9:48:00 AM	538	1	71.8	25	1	Plants
Central Senior High School	1412	2/1/2024	9:50:00 AM	532	0.9	69.9	24.9	0	
Central Senior High School	1414	2/1/2024	11:49:00 AM	632	0.5	72.6	26.1	23	
Central Senior High School	1415	2/1/2024	11:59:00 AM	554	0.8	72.6	25	0	
Central Senior High School	1501	2/1/2024	12:00:00 PM	591	0.9	71.3	25.5	3	
Central Senior High School	1503	2/1/2024	12:02:00 PM	634	0.3	71.5	27.4	0	
Central Senior High School	1505	2/1/2024	11:36:00 AM	530	0.8	71.3	25.1	0	
Central Senior High School	1506	2/1/2024	11:31:00 AM	687	0.5	73.5	25.8	0	
Central Senior High School	1512	2/1/2024	12:04:00 PM	525		82	31	1	
Central Senior High School	1513	2/1/2024	12:13:00 PM	600		80	25	0	
Central Senior High School	2001	2/1/2024	9:20:00 AM	646	0.1	69.4	27.3	2	
Central Senior High School	2002	2/1/2024	12:41:00 PM	762	0.1	75.2	24.8	3	
Central Senior High School	2003	2/1/2024	10:33:00 AM	564	0.1	72.9	24	0	Fragrance, Dirty Or Dusty Carpet Odor
Central Senior High School	2005	2/1/2024	10:29:00 AM	594	0.1	73.2	24	1	Fragrance, Dirty Or Dusty Carpet Odor
Central Senior High School	2006	2/1/2024	10:25:00 AM	562	0.1	73.6	23.3	0	Fragrance, Dirty Or Dusty Carpet Odor
Central Senior High School	2007	2/1/2024	10:21:00 AM	638	0.1	74.3	24.1	1	
Central Senior High School	2008	2/1/2024	10:18:00 AM	597	0.1	74.8	23	1	
Central Senior High School	2009	2/1/2024	10:15:00 AM	539	0.1	74.8	22.6	0	Plants: Kept Away From Return And Supply Vents
Central Senior High School	2012	2/1/2024	10:35:00 AM	604	0.1	72.9	24.3	1	Stained Ceiling Tiles
Central Senior High School	2013	2/1/2024	9:23:00 AM	501	0.1	71.1	25.3	0	
Central Senior High School	2014	2/1/2024	9:28:00 AM	506	0.1	72	24.5	0	
Central Senior High School	2015	2/1/2024	9:32:00 AM	543	0.1	72.9	24.2	2	
Central Senior High School	2016	2/1/2024	9:35:00 AM	606	0.1	73.6	24	1	Musty Odor, Moisture Impacted Materials Location: Ceiling mostly, Furt
Central Senior High School	2017	2/1/2024	9:40:00 AM	632	0.1	73.4	24.6	1	
Central Senior High School	2018	2/1/2024	9:45:00 AM	711	0.1	72.9	25.3	3	Dirty Or Dusty Carpet Odor
Central Senior High School	2019	2/1/2024	9:50:00 AM	563	0.1	73.6	23.7	1	Dirty Or Dusty Carpet Odor
Central Senior High School	2020	2/1/2024	9:55:00 AM	669	0.1	73.6	24.4	2	Dirty Or Dusty Carpet Odor
Central Senior High School	2021	2/1/2024	9:57:00 AM	665	0.1	73.9	24.4	2	Dirty Or Dusty Carpet Odor
Central Senior High School	2022	2/1/2024	10:01:00 AM	564	0.1	73.4	23.9	0	
Central Senior High School	2023	2/1/2024	10:05:00 AM	533	0.1	72.9	24.2	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Central Senior High School	2026	2/1/2024	9:45:00 AM	545	0.1	73.2	23.7	1	Stained Ceiling Tiles: Corner of room, Plants: Kept Away From Return And
Central Senior High School	2104	2/1/2024	10:50:00 AM	601	0.1	73.9	23.1	3	
Central Senior High School	2105	2/1/2024	11:08:00 AM	534	0.1	75.6	21.4	0	
Central Senior High School	2106	2/1/2024	10:59:00 AM	570	0.1	77.5	20.9	1	
Central Senior High School	2107	2/1/2024	10:39:00 AM	601	0.1	75.2	26	2	
Central Senior High School	2109	2/1/2024	10:45:00 AM	541	0.1	75.7	21.7	0	
Central Senior High School	2111	2/1/2024	10:56:00 AM	595	0.1	77	21.6	1	
Central Senior High School	2112	2/1/2024	11:00:00 AM	578	0.1	77.7	20.5	1	
Central Senior High School	2113	2/1/2024	11:07:00 AM	626	0.1	75.6	22.5	1	
Central Senior High School	2114	2/1/2024	11:01:00 AM	591	0.1	77.2	21	1	
Central Senior High School	2115	2/1/2024	11:03:00 AM	582	0.1	75.2	22.2	0	
Central Senior High School	2116	2/1/2024	11:06:00 AM	556	0.1	75	22	0	
Central Senior High School	2201	2/1/2024	11:42:00 AM	764	0.4	73	24.5	0	
Central Senior High School	2201	2/1/2024	11:28:00 AM	448	0.1	72	22.6	0	
Central Senior High School	2204	2/1/2024	11:37:00 AM	614	0.1	74.7	24.9	5	
Central Senior High School	2304	2/1/2024	11:38:00 AM	591	0.1	72.7	24.3	10	Moisture Impacted Materials Location: By the front white board on ceiling
Central Senior High School	2305	2/1/2024	11:43:00 AM	540	0.1	70.2	26.3	2	
Central Senior High School	2306	2/1/2024	11:41:00 AM	605	0.1	70.7	26.5	14	Stained Ceiling Tiles
Central Senior High School	2307	2/1/2024	11:45:00 AM	643	0.1	70.5	26.7	1	
Central Senior High School	2311	2/1/2024	11:48:00 AM	574	0.1	70	26.5	1	Plants: Kept Away From Return And Supply Vents, Taxidermy
Central Senior High School	2312	2/1/2024	11:46:00 AM	614	0.1	70.5	26.6	6	
Central Senior High School	2403	2/1/2024	11:50:00 AM	582	0.1	70.5	26.5	1	
Central Senior High School	2404	2/1/2024	11:51:00 AM	604	0.1	71.6	25	4	
Central Senior High School	2405	2/1/2024	11:54:00 AM	582	0.1	71.8	24.5	3	
Central Senior High School	2406	2/1/2024	11:57:00 AM	523	0.1	71.6	24.2	0	Live Animals: Kept Away From Return And Supply Vents, Taxidermy
Central Senior High School	2407	2/1/2024	12:04:00 PM	503	0.1	70.9	24.4	0	
Central Senior High School	2408	2/1/2024	12:05:00 PM	580	0.1	71.1	25.2	3	
Central Senior High School	2409	2/1/2024	12:08:00 PM	478	0.1	71.1	23.8	1	
Central Senior High School	2410	2/1/2024	11:53:00 AM	555	0.1	71.6	24.3	0	
Central Senior High School	2501	2/1/2024	11:10:00 AM	535	0.1	75.4	21.3	32	
Central Senior High School	2503	2/1/2024	11:15:00 AM	514	0.1	76.6	20.1	0	
Central Senior High School	2504	2/1/2024	11:21:00 AM	596	0.1	75.9	21.9	2	
Central Senior High School	2506	2/1/2024	11:19:00 AM	640	0.1	74.3	22.8	0	
Central Senior High School	2507	2/1/2024	11:16:00 AM	713	0.1	75.9	22.2	18	
Central Senior High School	3101	2/1/2024	12:08:00 PM	736	0.1	73.2	25.9	16	
Central Senior High School	3102	2/1/2024	12:52:00 PM	631	0.1	73	24.9	4	
Central Senior High School	3103	2/1/2024	12:54:00 PM	695	0.1	73.8	25.3	20	Plants: Kept Away From Return And Supply Vents
Central Senior High School	3104	2/1/2024	12:59:00 PM	689	0.1	74.1	24.8	12	
Central Senior High School	3105	2/1/2024	1:00:00 PM	702	0.1	73.8	25.2	15	
Central Senior High School	3106	2/1/2024	1:03:00 PM	700	0.1	74.5	24.8	24	
Central Senior High School	3107	2/1/2024	1:05:00 PM	833	0.1	74.5	26.1	30	Plants: Kept Away From Return And Supply Vents
Central Senior High School	3108	2/1/2024	1:07:00 PM	865	0.1	74.7	26.7	25	
Central Senior High School	3109	2/1/2024	1:08:00 PM	732	0.1	73.6	24.9	20	
Central Senior High School	3114	2/1/2024	1:10:00 PM	602	0.1	73.2	24.4	1	
Central Senior High School	3115	2/1/2024	1:12:00 PM	769	0.1	72.7	26.5	24	
Central Senior High School	3118	2/1/2024	1:16:00 PM	617	0.1	72.9	25.1	2	
Central Senior High School	3121	2/1/2024	1:15:00 PM	653	0.1	72.9	25.1	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Central Senior High School	3205	2/1/2024	12:28:00 PM	547	0.1	74.3	22.2	2	
Central Senior High School	3206	2/1/2024	12:30:00 PM	623	0.1	75.7	21.7	1	
Central Senior High School	3401	2/1/2024	12:33:00 PM	673	0.1	74.5	23.3	1	
Central Senior High School	3402	2/1/2024	12:33:00 PM	570	0.1	70.5	25.5	2	
Central Senior High School	3403	2/1/2024	12:36:00 PM	593	0.1	70.2	26.4	1	
Central Senior High School	3404	2/1/2024	12:37:00 PM	504	0.1	70.3	25.1	0	
Central Senior High School	3405	2/1/2024	1:47:00 PM	728	0.1	70.9	26.5	15	Plants: Kept Away From Return And Supply Vents
Central Senior High School	3406	2/1/2024	1:31:00 PM	641	0.1	71.6	25.1	22	
Central Senior High School	3407	2/1/2024	1:35:00 PM	521	0.1	70.5	25	2	
Central Senior High School	3408	2/1/2024	1:37:00 PM	562	0.1	70	26.1	5	
Central Senior High School	3409	2/1/2024	1:38:00 PM	545	0.1	70.5	25.2	3	Plants: Kept Away From Return And Supply Vents
Central Senior High School	3410	2/1/2024	1:45:00 PM	483	0.1	71.1	23.9	1	
Central Senior High School	3414	2/1/2024	1:43:00 PM	476	0.1	73.4	22	2	
Central Senior High School	3415	2/1/2024	1:41:00 PM	494	0.1	71.8	23.5	11	
Central Senior High School	3419	2/1/2024	1:25:00 PM	818	0.1	76.8	23.2	3	
Central Senior High School	3420	2/1/2024	1:18:00 PM	479	0.1	73.8	21.7	0	
Central Senior High School	4101	2/1/2024	1:00:00 PM	622	1	74	25	1	
Central Senior High School	4102	2/1/2024	1:02:00 PM	699	0.8	73.5	27.4	14	Plants
Central Senior High School	4103	2/1/2024	1:03:00 PM	616	0.6	72.8	26.6	0	
Central Senior High School	4104	2/1/2024	1:04:00 PM	601	0.8	71.7	27.6	3	
Central Senior High School	4105	2/1/2024	1:06:00 PM	678	0.3	72	27.6	2	Plants
Central Senior High School	4106	2/1/2024	1:11:00 PM	614	0.6	72.4	26.5	1	
Central Senior High School	4107	2/1/2024	1:13:00 PM	669	0.4	71.5	27.8	1	
Central Senior High School	4108	2/1/2024	1:16:00 PM	801	0.3	72.1	30.4	1	
Central Senior High School	4109	2/1/2024	1:19:00 PM	813		72.7	31.3	26	Plants
Central Senior High School	4110	2/1/2024	1:21:00 PM	625	0.1	72.3	27	1	Plants
Central Senior High School	4112	2/1/2024	1:22:00 PM	808		73.1	30.7	9	
Central Senior High School	4114	2/1/2024	1:10:00 PM	876	0.1	73.9	30.5	22	
Central Senior High School	4116	2/1/2024	1:09:00 PM	937	0.3	73.2	29.6	1	
Central Senior High School	4117	2/1/2024	1:08:00 PM	862	0.3	72.6	30.6	18	
Central Senior High School	4201	2/1/2024	12:41:00 PM	701	0.4	71.8	27.7	5	
Central Senior High School	4202	2/1/2024	12:50:00 PM	646	0.3	71.5	28.5	0	
Central Senior High School	4205	2/1/2024	12:44:00 PM	521	0.5	71	26.1	0	
Central Senior High School	4206	2/1/2024	12:44:00 PM	539	0.3	71.5	26.3	0	
Central Senior High School	4207	2/1/2024	12:51:00 PM	618	0.4	71.1	28	0	
Central Senior High School	4209	2/1/2024	12:46:00 PM	657	0.4	71.2	29	1	
Central Senior High School	4210	2/1/2024	12:48:00 PM	659	0.3	71.5	29	3	
Central Senior High School	4213	2/1/2024	12:52:00 PM	571	0.1	72.7	26.3	0	
Central Senior High School	4214	2/1/2024	12:54:00 PM	531		73.5	25	0	
Central Senior High School	4215	2/1/2024	12:59:00 PM	531		76.5	22.4	0	
Central Senior High School	4216	2/1/2024	12:58:00 PM	553		76	23.5	0	
Central Senior High School	4217	2/1/2024	12:57:00 PM	580	0.3	75.8	23.7	3	
Central Senior High School	4218	2/1/2024	12:56:00 PM	584	0.1	74.9	25.4	1	Plants
Central Senior High School	4219	2/1/2024	12:55:00 PM	517	0.3	74.1	24.5	1	
Central Senior High School	4222	2/1/2024	12:17:00 PM	803	0.1	74.8	25.3	0	
Central Senior High School	4401	2/1/2024	12:23:00 PM	612	0.3	73.8	24.8	2	
Central Senior High School	4402	2/1/2024	12:26:00 PM	83	1	72.8	27.9	20	Plants

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Central Senior High School	4403	2/1/2024	12:27:00 PM	786	0.9	72.9	29.2	22	
Central Senior High School	4404	2/1/2024	12:28:00 PM	806	0.8	72.2	28.1	26	
Central Senior High School	4405	2/1/2024	12:29:00 PM	764	0.6	72.9	28.6	30	
Central Senior High School	4406	2/1/2024	12:34:00 PM	836	0.6	73.7	27.9	25	
Central Senior High School	4407	2/1/2024	12:35:00 PM	741	1.2	72.7	28.3	24	
Central Senior High School	4408	2/1/2024	12:37:00 PM	704	0.9	71.6	27.6	24	Plants
Central Senior High School	4409	2/1/2024	12:38:00 PM	714	0.6	71.5	28.5	18	
Central Senior High School	4410	2/1/2024	12:39:00 PM	726	0.3	71.6	29.2	21	Taxidermy
Central Senior High School	4412	2/1/2024	12:39:00 PM	557	0.5	72	26	2	
Central Senior High School	4414	2/1/2024	12:32:00 PM	634	0.4	74.1	25.6	9	
Central Senior High School	4417	2/1/2024	12:31:00 PM	727		43.6	27.8	1	
Central Senior High School	1103A	2/1/2024	11:02:00 AM	537	0.4	71.1	25.5	0	
Central Senior High School	1119A	2/1/2024	11:25:00 AM	701	0.072	72	28.2	0	
Central Senior High School	1119C	2/1/2024	11:26:00 AM	740		72.8	29.1	4	
Central Senior High School	1120B	2/1/2024	11:30:00 AM	669	0.5	74.1	26.6	1	
Central Senior High School	119D	2/1/2024	11:27:00 AM	708	0.9	73.3	27.1	0	
Central Senior High School	1318A	2/1/2024	10:25:00 AM	779	0.6	71.1	29.2	0	
Central Senior High School	1505A	2/1/2024	11:39:00 AM	550	0.6	70.9	26.9	0	
Central Senior High School	1509A	2/1/2024	11:34:00 AM	624	1	73.3	26.1	0	
Central Senior High School	2001A	2/1/2024	9:30:00 AM	534	0.1	72.5	24.2	1	
Central Senior High School	2010A	2/1/2024	10:10:00 AM	603	0.1	73.8	23.9	0	Dirty Or Dusty Carpet Odor
Central Senior High School	2010B	2/1/2024	10:07:00 AM	535	0.1	73.6	23.3	0	
Central Senior High School	2201A	2/1/2024	11:23:00 AM	451	0.1	74.3	21.2	0	
Central Senior High School	2204A	2/1/2024	11:30:00 AM	602	0.1	72.9	24.4	1	Dirty Or Dusty Carpet Odor
Central Senior High School	2204C	2/1/2024	11:36:00 AM	1004	0.1	73.8	29.3	1	
Central Senior High School	2507C	2/1/2024	11:18:00 AM	643	0.1	73.8	23.3	0	
Central Senior High School	3420A	2/1/2024	1:20:00 PM	474	0.1	75.4	20.5	0	
Central Senior High School	CAFETERIA	2/1/2024	12:38:00 PM	973	0.1	71.6	33	200	
Central Senior High School	OUTDOORS	2/1/2024		533	1.3	37	23.1		
Central Service Station	CAR SHOP	12/1/2023	8:36:00 AM	583	1.4	65.5	20.4	2	Odor Description: Car gas, Comments
Central Service Station	CLASSROOM	12/1/2023	8:42:00 AM	965	0.9	69.1	20.9	9	
Central Service Station	OUTDOORS	12/1/2023		497	1.1	21	78		
Chelsea Heights Elementary School	205	12/13/2023	9:43:00 AM	1041		71.4	16.6	11	Fragrance Odor
Chelsea Heights Elementary School	206	12/13/2023	9:46:00 AM	985		71.4	16.2	27	Aquariums (fish), Live Animals, Plants
Chelsea Heights Elementary School	1001	12/13/2023	11:07:00 AM	800		70.2	15.3	1	
Chelsea Heights Elementary School	1101	12/13/2023	10:09:00 AM	880		69.8	15.6	3	Plants
Chelsea Heights Elementary School	1102	12/13/2023	10:08:00 AM	1113		69.6	17.4	20	Fragrance Odor
Chelsea Heights Elementary School	1103	12/13/2023	10:05:00 AM	1185		69.4	17.8	29	
Chelsea Heights Elementary School	1105	12/13/2023	10:03:00 AM	1000		69.3	15.6	1	
Chelsea Heights Elementary School	1108	12/13/2023	11:41:00 AM	830		69.6	16	0	
Chelsea Heights Elementary School	1117	12/13/2023	9:52:00 AM	640		69.3	12.4	0	
Chelsea Heights Elementary School	1118	12/13/2023	9:54:00 AM	727		69.1	13	1	
Chelsea Heights Elementary School	1119	12/13/2023	2:03:00 PM	745		71.4	17.5	30	Stained Ceiling Tiles
Chelsea Heights Elementary School	1120	12/13/2023	9:55:00 AM	760		69.8	13.4	0	Stained Ceiling Tiles
Chelsea Heights Elementary School	1202	12/13/2023	10:34:00 AM	1258		70.2	20	20	
Chelsea Heights Elementary School	1203	12/13/2023	10:31:00 AM	1117		69.8	19	16	
Chelsea Heights Elementary School	1203	12/13/2023	10:36:00 AM	834		71.2	14.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Chelsea Heights Elementary School	1204	12/13/2023	10:35:00 AM	902		70.9	15.7	1	
Chelsea Heights Elementary School	1208	12/13/2023	10:11:00 AM	797		70	14.6	0	
Chelsea Heights Elementary School	1209	12/13/2023	10:12:00 AM	802		70.5	14.9	0	Plants
Chelsea Heights Elementary School	1210	12/13/2023	10:13:00 AM	820		71.2	14.1	0	
Chelsea Heights Elementary School	1211	12/13/2023	10:15:00 AM	913		71.6	15	0	
Chelsea Heights Elementary School	1212	12/13/2023	10:18:00 AM	826		70.9	14.8	0	
Chelsea Heights Elementary School	1214	12/13/2023	10:16:00 AM	849		71.2	14.1	0	
Chelsea Heights Elementary School	1301	12/13/2023	10:37:00 AM	730		70.7	15.2	20	
Chelsea Heights Elementary School	1302	12/13/2023	10:18:00 AM	833		69.1	17.2	13	
Chelsea Heights Elementary School	1303	12/13/2023	10:23:00 AM	772		68.9	16.3	16	
Chelsea Heights Elementary School	1304	12/13/2023	10:24:00 AM	778		69.3	16.3	5	Stained Ceiling Tiles, Plants
Chelsea Heights Elementary School	1305	12/13/2023	10:26:00 AM	851		70.7	16.6	17	
Chelsea Heights Elementary School	1306	12/13/2023	10:28:00 AM	687		71.6	13.8	9	
Chelsea Heights Elementary School	1308	12/13/2023	11:44:00 AM	892		69.3	21.3	1	
Chelsea Heights Elementary School	2101	12/13/2023	11:21:00 AM	768		69.6	14.9	19	
Chelsea Heights Elementary School	2102	12/13/2023	11:22:00 AM	670		69.8	14.5	15	
Chelsea Heights Elementary School	2103	12/13/2023	11:28:00 AM	600		69.8	13.9	15	Plants
Chelsea Heights Elementary School	2104	12/13/2023	11:00:00 AM	637		68.7	13.3	0	
Chelsea Heights Elementary School	2106	12/13/2023	10:57:00 AM	673		69.4	13.2	0	
Chelsea Heights Elementary School	2107	12/13/2023	10:56:00 AM	705		69.1	14.2	0	
Chelsea Heights Elementary School	2109	12/13/2023	10:54:00 AM	727		69.4	12.9	1	
Chelsea Heights Elementary School	2110	12/13/2023	11:33:00 AM	899		70.5	15.5	16	Plants
Chelsea Heights Elementary School	2111	12/13/2023	10:53:00 AM	693		69.1	14	10	
Chelsea Heights Elementary School	2112	12/13/2023	10:51:00 AM	770		69.6	14	6	
Chelsea Heights Elementary School	2118	12/13/2023	10:59:00 AM	797		70	14.2	0	
Chelsea Heights Elementary School	2201	12/13/2023	10:50:00 AM	803		70	15	21	
Chelsea Heights Elementary School	2202	12/13/2023	10:49:00 AM	810		69.4	14.8	1	Plants
Chelsea Heights Elementary School	2203	12/13/2023	11:04:00 AM	913		69.6	15.1	17	
Chelsea Heights Elementary School	2204	12/13/2023	10:42:00 AM	678		69.6	13.6	0	
Chelsea Heights Elementary School	2205	12/13/2023	10:38:00 AM	763		69.8	12.5	0	
Chelsea Heights Elementary School	2208	12/13/2023	11:36:00 AM	602		70.7	13.7	16	
Chelsea Heights Elementary School	1102A	12/13/2023	10:09:00 AM	1059		69.6	16.2	0	
Chelsea Heights Elementary School	1118A	12/13/2023	10:00:00 AM	612		68.9	12.4	0	
Chelsea Heights Elementary School	1207A	12/13/2023	11:15:00 AM	867		71.6	18.2	0	
Chelsea Heights Elementary School	1207B	12/13/2023	11:14:00 AM	824		71.2	16.6	1	Fragrance Odor
Chelsea Heights Elementary School	1207D	12/13/2023	11:17:00 AM	790		70.9	15.7	0	
Chelsea Heights Elementary School	CAFETERIA	12/13/2023	10:29:00 AM	712		69.8	15.5	24	
Chelsea Heights Elementary School	GYMNASIUM	12/13/2023	9:49:00 AM	730		69.3	13.1	26	Stained Ceiling Tiles
Chelsea Heights Elementary School	OUTDOORS	12/13/2023		570		27	19.5		
Chelsea Heights Elementary School	PRINCIPAL	12/13/2023	11:11:00 AM	941		70.7	17.4	2	
Chelsea Heights Elementary School	RECEPTION	12/13/2023	11:13:00 AM	824		70.9	16.1	1	Plants
Cherokee Heights Elementary	1103	1/22/2024	8:43:00 AM	879	0.2	68.5	13	17	
Cherokee Heights Elementary	1104	1/22/2024	8:44:00 AM	747	0.2	68.5	11.9	4	
Cherokee Heights Elementary	1105	1/22/2024	8:45:00 AM	1150	0.2	68.4	16.5	9	
Cherokee Heights Elementary	1106	1/22/2024	8:47:00 AM	576	0.2	68.7	10.8	1	
Cherokee Heights Elementary	1107	1/22/2024	8:51:00 AM	677	0.2	69.4	12.7	2	
Cherokee Heights Elementary	1109	1/22/2024	8:49:00 AM	705	0.2	69.3	13.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Cherokee Heights Elementary	1201	1/22/2024	10:32:00 AM	646	0.2	71.2	13.9	48	
Cherokee Heights Elementary	1208	1/22/2024	11:11:00 AM	612	0.2	68.7	13.9	0	
Cherokee Heights Elementary	1210	1/22/2024	11:08:00 AM	599	0.2	70.5	12.7	1	
Cherokee Heights Elementary	2001	1/22/2024	9:14:00 AM	559	0.2	69.6	12	2	
Cherokee Heights Elementary	2002	1/22/2024	9:20:00 AM	547	0.2	68.7	12.1	1	
Cherokee Heights Elementary	2003	1/22/2024	9:19:00 AM	537	0.2	69.3	11.9	0	
Cherokee Heights Elementary	2004	1/22/2024	9:15:00 AM	550	0.2	69.8	11.7	0	
Cherokee Heights Elementary	2103	1/22/2024	8:58:00 AM	1477	0.2	68.5	16.8	16	
Cherokee Heights Elementary	2104	1/22/2024	8:56:00 AM	1388	0.2	68.5	16.7	12	
Cherokee Heights Elementary	2105	1/22/2024	8:54:00 AM	704	0.2	68.4	11	5	
Cherokee Heights Elementary	2106	1/22/2024	8:52:00 AM	805	0.2	68.4	11.6	8	
Cherokee Heights Elementary	2107	1/22/2024	11:12:00 AM	1294	0.2	70.3	16.6	14	
Cherokee Heights Elementary	2108	1/22/2024	11:15:00 AM	945	0.2	72.7	14	16	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary	2109	1/22/2024	10:28:00 AM	1070	0.2	67.6	18.1	13	
Cherokee Heights Elementary	2110	1/22/2024	10:31:00 AM	1287	0.2	68.7	18.1	16	
Cherokee Heights Elementary	2201	1/22/2024	9:13:00 AM	583	0.2	69.8	11.8	1	
Cherokee Heights Elementary	2202	1/22/2024	8:59:00 AM	576	0.2	68.9	12	2	
Cherokee Heights Elementary	2203	1/22/2024	10:25:00 AM	592	0.2	66.6	14	3	
Cherokee Heights Elementary	2206	1/22/2024	10:27:00 AM	574	0.2	66	13.9	1	
Cherokee Heights Elementary	2207	1/22/2024	10:23:00 AM	752	0.2	66.7	15.4	2	
Cherokee Heights Elementary	2208	1/22/2024	10:21:00 AM	614	0.2	65.5	13.8	0	
Cherokee Heights Elementary	2209	1/22/2024	10:19:00 AM	576	0.2	68	13.7	1	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary	2210	1/22/2024	10:18:00 AM	542	0.2	68.2	13.1	0	
Cherokee Heights Elementary	2211	1/22/2024	10:15:00 AM	759	0.2	68	13.7	3	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary	2213	1/22/2024	10:12:00 AM	710	0.2	68	13	2	
Cherokee Heights Elementary	2214	1/22/2024	10:09:00 AM	763	0.2	67.8	13.9	2	
Cherokee Heights Elementary	3103	1/22/2024	9:27:00 AM	537	0.2	67.5	12.1	0	
Cherokee Heights Elementary	3104	1/22/2024	9:29:00 AM	537	0.2	68.2	11.6	1	
Cherokee Heights Elementary	3105	1/22/2024	9:31:00 AM	847	0.2	68.9	13.5	16	
Cherokee Heights Elementary	3107	1/22/2024	9:32:00 AM	844	0.2	69.4	13.7	15	
Cherokee Heights Elementary	3109	1/22/2024	9:35:00 AM	794	0.2	66.7	13.7	1	
Cherokee Heights Elementary	3111	1/22/2024	9:57:00 AM	716	0.2	67.1	14	2	
Cherokee Heights Elementary	3113	1/22/2024	9:59:00 AM	784	0.2	68.2	14.8	1	
Cherokee Heights Elementary	3114	1/22/2024	9:52:00 AM	698	0.2	66	14.6	0	Musty Odor
Cherokee Heights Elementary	3201	1/22/2024	9:54:00 AM	597	0.2	65.5	13.9	3	
Cherokee Heights Elementary	3203	1/22/2024	9:25:00 AM	740	0.2	67.5	13.1	6	
Cherokee Heights Elementary	3204	1/22/2024	9:22:00 AM	712	0.2	67.6	13.6	2	
Cherokee Heights Elementary	3205	1/22/2024	9:50:00 AM	663	0.2	64.6	15.5	0	
Cherokee Heights Elementary	3206	1/22/2024	10:00:00 AM	720	0.2	70	14.2	6	Musty Odor, Moisture Impacted Materials Location: Far end of room cov
Cherokee Heights Elementary	4202	1/22/2024	9:43:00 AM	755	0.2	62.6	16.6	1	
Cherokee Heights Elementary	4203	1/22/2024	9:42:00 AM	680	0.2	66.7	13.8	2	Bubbling/Peeling Paint on ceiling
Cherokee Heights Elementary	4204	1/22/2024	9:37:00 AM	652	0.2	65.3	14.1	6	
Cherokee Heights Elementary	1102 OFFICE	1/22/2024	8:35:00 AM	571	0.2	69.1	11.7	1	Stained Ceiling Tiles
Cherokee Heights Elementary	C100	1/22/2024	10:36:00 AM	532	0.2	71.1	12.1	0	
Cherokee Heights Elementary	C102	1/22/2024	10:48:00 AM	565	0.2	71.1	12	0	
Cherokee Heights Elementary	C108	1/22/2024	10:51:00 AM	544	0.2	70.2	12.6	0	
Cherokee Heights Elementary	C109	1/22/2024	10:55:00 AM	511	0.2	70	12.6	0	Stained Ceiling Tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Cherokee Heights Elementary	C200	1/22/2024	10:56:00 AM	523	0.2	70.2	13	0	Plants: Kept Away From Return And Supply Vents
Cherokee Heights Elementary	C200	1/22/2024	11:06:00 AM	524	0.2	70.9	12.2	0	
Cherokee Heights Elementary	C201	1/22/2024	10:58:00 AM	521	0.2	70.3	12.5	0	
Cherokee Heights Elementary	C202A	1/22/2024	11:00:00 AM	710	0.2	71.1	12.5	0	
Cherokee Heights Elementary	C202B	1/22/2024	11:07:00 AM	530	0.2	70.7	12.9	1	
Cherokee Heights Elementary	OUTDOORS	1/22/2024		508	0.2	29	75		
Como Park Elementary School	1001	1/9/2024	8:59:00 AM	585	1.5	70	25.6	2	
Como Park Elementary School	1002	1/9/2024	9:00:00 AM	589	1.5	69.8	25.9	0	
Como Park Elementary School	1003	1/9/2024	8:58:00 AM	590	1.6	69.8	26.4	0	
Como Park Elementary School	1004	1/9/2024	8:56:00 AM	556	1.7	69.8	26.4	0	
Como Park Elementary School	1005	1/9/2024	8:55:00 AM	479	1.8	69.6	24.2	0	
Como Park Elementary School	1006	1/9/2024	8:54:00 AM	537	1.9	70	25.4	0	
Como Park Elementary School	1007	1/9/2024	9:01:00 AM	548	1.4	70	25.9	0	
Como Park Elementary School	1102	1/9/2024	10:04:00 AM	665		74.1	23.1	50	
Como Park Elementary School	1105	1/9/2024	9:02:00 AM	554	1.3	69.4	26.4	0	
Como Park Elementary School	1107	1/9/2024	9:05:00 AM	609	1.1	73.8	22.3	15	
Como Park Elementary School	1111	1/9/2024	9:08:00 AM	656	1	78.1	19.5	15	
Como Park Elementary School	1112	1/9/2024	9:10:00 AM	669	1.2	78.6	19.5	20	
Como Park Elementary School	1113	1/9/2024	9:11:00 AM	653	1.2	78.3	19.2	3	
Como Park Elementary School	1114	1/9/2024	9:12:00 AM	666	1.2	77.7	19.6	10	
Como Park Elementary School	1115	1/9/2024	9:15:00 AM	749	1.1	77.5	19.8	3	
Como Park Elementary School	1116	1/9/2024	9:19:00 AM	680	0.8	77.5	20.3	10	
Como Park Elementary School	1117	1/9/2024	9:16:00 AM	671	0.9	77.2	20	15	
Como Park Elementary School	1118	1/9/2024	9:20:00 AM	541	0.8	76.5	19.4	0	
Como Park Elementary School	1119	1/9/2024	9:27:00 AM	621	0.4	76.1	19.9	0	
Como Park Elementary School	1120	1/9/2024	9:29:00 AM	707	0.3	76.6	19.8	12	
Como Park Elementary School	1121	1/9/2024	9:31:00 AM	614	0.2	77.7	18.6	1	
Como Park Elementary School	1122	1/9/2024	9:33:00 AM	582	0.2	76.3	18.9	0	
Como Park Elementary School	1123	1/9/2024	9:57:00 AM	583		77	20.2	0	
Como Park Elementary School	1125	1/9/2024	9:55:00 AM	612		76.5	21	0	
Como Park Elementary School	1126	1/9/2024	9:52:00 AM	604		75.9	21.8	0	
Como Park Elementary School	1128	1/9/2024	9:51:00 AM	635		75.2	22.7	10	
Como Park Elementary School	1129	1/9/2024	9:49:00 AM	668		75	21.5	0	
Como Park Elementary School	1130	1/9/2024	9:47:00 AM	663		75.4	21.8	0	
Como Park Elementary School	1131	1/9/2024	9:45:00 AM	580		74.5	22.3	0	
Como Park Elementary School	1132	1/9/2024	10:22:00 AM	768		73.6	23.7	0	
Como Park Elementary School	1133	1/9/2024	10:19:00 AM	597		70.9	25.3	0	
Como Park Elementary School	1134	1/9/2024	10:20:00 AM	568		72	24.3	0	
Como Park Elementary School	1135	1/9/2024	10:21:00 AM	623		72.3	23.9	1	
Como Park Elementary School	1136	1/9/2024	10:22:00 AM	598		73.6	23.1	0	
Como Park Elementary School	1137	1/9/2024	10:02:00 AM	624		74.1	22.1	0	Stuffy, Musty Odor
Como Park Elementary School	1141	1/9/2024	9:59:00 AM	504		76.3	19.8	0	
Como Park Elementary School	1201	1/9/2024	9:36:00 AM	665		74.8	20.1	15	
Como Park Elementary School	1202	1/9/2024	9:38:00 AM	802		74.7	19.6	0	
Como Park Elementary School	1203	1/9/2024	9:41:00 AM	524		74.8	20.2	0	
Como Park Elementary School	1204	1/9/2024	9:43:00 AM	520		75.4	18.7	0	
Como Park Elementary School	1207	1/9/2024	8:11:00 AM	440	2.2	68.7	21.4	20	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Elementary School	1209	1/9/2024	8:30:00 AM	599	2.6	79.2	60.2	0	
Como Park Elementary School	1210	1/9/2024	8:29:00 AM	533	2.5	68.5	27.5	0	
Como Park Elementary School	1302	1/9/2024	8:52:00 AM	532	2.1	70.5	23.7	2	Fragrance Odor
Como Park Elementary School	1305	1/9/2024	8:50:00 AM	565	2.2	70.2	26.6	2	
Como Park Elementary School	1306	1/9/2024	11:02:00 AM	787		75.4	22.3	80	
Como Park Elementary School	1308	1/9/2024	8:46:00 AM	464	2.5	71.1	22.6	0	
Como Park Elementary School	1309	1/9/2024	8:43:00 AM	508	2.8	71.2	22.8	2	
Como Park Elementary School	1310	1/9/2024	8:41:00 AM	458	3.3	73.8	20.3	0	
Como Park Elementary School	1311	1/9/2024	10:08:00 AM	505		75	18.2	0	
Como Park Elementary School	1313	1/9/2024	10:10:00 AM	496		71.1	21.1	0	
Como Park Elementary School	1315	1/9/2024	10:14:00 AM	494		70	21.8	0	
Como Park Elementary School	1319	1/9/2024	10:16:00 AM	464		70.2	21.6	0	
Como Park Elementary School	1320	1/9/2024	10:12:00 AM	502		71.1	21.9	3	
Como Park Elementary School	1321	1/9/2024	10:06:00 AM	586		75.4	18.5	0	
Como Park Elementary School	2001	1/9/2024	10:41:00 AM	602		78.6	17.1	1	
Como Park Elementary School	2002	1/9/2024	10:42:00 AM	663		80.2	16.4	0	
Como Park Elementary School	2101	1/9/2024	10:56:00 AM	874		75.7	21.3	18	Fragrance Odor
Como Park Elementary School	2102	1/9/2024	10:54:00 AM	480		75.4	18.8	0	
Como Park Elementary School	2104	1/9/2024	10:52:00 AM	518		77.7	17.7	5	
Como Park Elementary School	2105	1/9/2024	10:50:00 AM	676		77	18.4	4	
Como Park Elementary School	2106	1/9/2024	10:48:00 AM	498		76.8	19	0	
Como Park Elementary School	2107	1/9/2024	10:34:00 AM	528		75.7	19	0	
Como Park Elementary School	2108	1/9/2024	10:23:00 AM	1024		73.6	23.5	25	
Como Park Elementary School	2201	1/9/2024	10:30:00 AM	742		74.1	23.4	2	
Como Park Elementary School	2202	1/9/2024	10:31:00 AM	540		74.8	19.2	0	
Como Park Elementary School	2203	1/9/2024	10:32:00 AM	474		75.7	18.4	0	
Como Park Elementary School	2203	1/9/2024	10:53:00 AM	515		77.2	18	0	
Como Park Elementary School	2204	1/9/2024	11:09:00 AM	547		76.8	18.5	2	
Como Park Elementary School	2207	1/9/2024	11:11:00 AM	554		76.1	19.5	0	
Como Park Elementary School	2210	1/9/2024	11:25:00 AM	607		72.7	23	16	Fragrance Odor
Como Park Elementary School	2301	1/9/2024	10:57:00 AM	507		77.2	17.8	0	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Como Park Elementary School	2302	1/9/2024	10:59:00 AM	637		78.8	18	18	
Como Park Elementary School	2303	1/9/2024	11:00:00 AM	543		77.7	17.9	0	
Como Park Elementary School	2304	1/9/2024	11:03:00 AM	559		74.5	20.5	1	
Como Park Elementary School	2308	1/9/2024	11:05:00 AM	678		76.1	19.6	25	
Como Park Elementary School	2309	1/9/2024	11:06:00 AM	639		76.8	19.2	25	
Como Park Elementary School	2310	1/9/2024	11:08:00 AM	465		76.5	18.1	0	
Como Park Elementary School	2313	1/9/2024	10:33:00 AM	524		76.1	19.5	0	
Como Park Elementary School	2315	1/9/2024	10:39:00 AM	578		76.3	18.7	0	
Como Park Elementary School	2317	1/9/2024	10:38:00 AM	535		75.4	19.8	0	
Como Park Elementary School	2318	1/9/2024	10:40:00 AM	488		77	17.7	0	
Como Park Elementary School	2321	1/9/2024	10:46:00 AM	471		78.4	16.6	0	
Como Park Elementary School	2323	1/9/2024	10:43:00 AM	1020		80.4	15.8	0	
Como Park Elementary School	2401	1/9/2024	11:58:00 AM	1108		70.2	26.1	16	Bubbling/Peeling Paint
Como Park Elementary School	2402	1/9/2024	12:02:00 PM	581		69.8	25.3	3	
Como Park Elementary School	2403	1/9/2024	12:03:00 PM	724		69.4	25.8	18	
Como Park Elementary School	2404	1/9/2024	12:01:00 PM	640		70	25.1	22	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Elementary School	2501	1/9/2024	11:14:00 AM	571		72.5	22.5	0	
Como Park Elementary School	2504	1/9/2024	11:57:00 AM	468		69.1	22.1	0	
Como Park Elementary School	2505	1/9/2024	11:55:00 AM	580		69.8	23.3	1	
Como Park Elementary School	2506	1/9/2024	11:34:00 AM	540		68.9	23.8	0	
Como Park Elementary School	2509	1/9/2024	11:33:00 AM	508		69.6	21.9	0	
Como Park Elementary School	2510	1/9/2024	11:30:00 AM	562		69.8	22.9	0	
Como Park Elementary School	2511	1/9/2024	11:53:00 AM	553		70	22.4	5	
Como Park Elementary School	2604	1/9/2024	11:49:00 AM	592		69.6	23.9	0	
Como Park Elementary School	2605	1/9/2024	11:20:00 AM	600		70.7	23.2	22	
Como Park Elementary School	2606	1/9/2024	11:22:00 AM	59		71.1	24.1	10	Food Odor
Como Park Elementary School	2607	1/9/2024	11:23:00 AM	517		70.7	21.8	3	
Como Park Elementary School	2608	1/9/2024	11:41:00 AM	632		70	22.9	0	
Como Park Elementary School	2609	1/9/2024	11:42:00 AM	530		69.6	23.6	1	
Como Park Elementary School	2610	1/9/2024	11:46:00 AM	501		69.6	21.3	0	
Como Park Elementary School	2611	1/9/2024	11:47:00 AM	477		69.6	21.7	0	
Como Park Elementary School	2614	1/9/2024	11:30:00 AM	586		70	22.6	22	
Como Park Elementary School	2701	1/9/2024	11:35:00 AM	578		69.8	23.8	2	Food Odor
Como Park Elementary School	2704	1/9/2024	11:37:00 AM	577		69.8	23.7	1	Odor Description: Burning plastic, Food Odor
Como Park Elementary School	2706	1/9/2024	11:38:00 AM	631		70	24.2	0	
Como Park Elementary School	2707	1/9/2024	11:39:00 AM	619		70.5	24.2	1	
Como Park Elementary School	2708	1/9/2024	11:40:00 AM	590		70.7	23.2	1	
Como Park Elementary School	1114A	1/9/2024	9:14:00 AM	802	1.1	77.7	20.1	5	
Como Park Elementary School	1118A	1/9/2024	9:22:00 AM	680	0.7	75.4	20.9	1	
Como Park Elementary School	1120A	1/9/2024	9:30:00 AM	567	0.3	76.8	19.4	0	
Como Park Elementary School	1202A	1/9/2024	9:40:00 AM	521		74.7	20.1	1	
Como Park Elementary School	1204A	1/9/2024	9:42:00 AM	470		74.8	19.5	0	
Como Park Elementary School	1308A	1/9/2024	8:47:00 AM	821	2.3	70	25.3	0	
Como Park Elementary School	2614C	1/9/2024	11:18:00 AM	557		71.4	22.1	0	
Como Park Elementary School	OUTDOORS	1/9/2024		397	2.6	28	90		
Como Park Senior High School	1001	2/2/2024	11:43:00 AM	593		71.1	23.3	1	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1002	2/2/2024	11:45:00 AM	556		71.1	22.4	0	Fragrance Odor
Como Park Senior High School	1003	2/2/2024	11:42:00 AM	544	0.3	70.8	22.6	0	
Como Park Senior High School	1004	2/2/2024	12:01:00 PM	630		69.9	24.6	2	Fragrance Odor, Stained Ceiling Tiles
Como Park Senior High School	1005	2/2/2024	11:41:00 AM	648	0.3	70.6	0.3	1	Fragrance Odor
Como Park Senior High School	1006	2/2/2024	11:46:00 AM	591		72.3	22.1	0	Fragrance Odor
Como Park Senior High School	1007	2/2/2024	11:38:00 AM	580		69.8	23.1	0	Food Odor
Como Park Senior High School	1009	2/2/2024	11:37:00 AM	558		70	0.4	0	
Como Park Senior High School	1011	2/2/2024	11:17:00 AM	544	0.1	70.2	22.9	0	
Como Park Senior High School	1013	2/2/2024	11:16:00 AM	547	0.3	70.8	21.9	0	
Como Park Senior High School	1014	2/2/2024	11:39:00 AM	565	0.1	70	23.1	1	
Como Park Senior High School	1015	2/2/2024	11:07:00 AM	679	0.6	71.3	23.3	1	
Como Park Senior High School	1016	2/2/2024	11:40:00 AM	621	0.1	70.4	23.8	566	
Como Park Senior High School	1017	2/2/2024	11:58:00 AM	597		71.8	23	0	
Como Park Senior High School	1019	2/2/2024	11:59:00 AM	640	0.1	72.2	23.8	2	
Como Park Senior High School	1021	2/2/2024	12:00:00 PM	575	0.3	72.3	21.9	0	
Como Park Senior High School	1022	2/2/2024	11:52:00 AM	527	0.5	71.5	21.3	0	
Como Park Senior High School	1024	2/2/2024	11:51:00 AM	626	0.5	71.8	22.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Senior High School	1026	2/2/2024	11:47:00 AM	536	0.4	71.6	21.3	0	
Como Park Senior High School	1031	2/2/2024	10:14:00 AM	448	0.5	71.4	19.3	0	
Como Park Senior High School	1036	2/2/2024	11:54:00 AM	640	0.4	71.6	24.5	0	
Como Park Senior High School	1038	2/2/2024	11:56:00 AM	544	0.3	71.8	21.7	0	
Como Park Senior High School	1101	2/2/2024	9:44:00 AM	610	1	72.8	20.7	40	
Como Park Senior High School	1106	2/2/2024	9:36:00 AM	475	1.1	75.7	17.5	0	
Como Park Senior High School	1107	2/2/2024	10:03:00 AM	498	0.3	71.2	22.8	0	Food Odor
Como Park Senior High School	1109	2/2/2024	10:00:00 AM	654	0.1	70	24	3	Fragrance Odor
Como Park Senior High School	1113	2/2/2024	9:56:00 AM	462	0.9	69.1	20.1	0	
Como Park Senior High School	1114	2/2/2024	9:27:00 AM	556	0.1	75	44.4	0	
Como Park Senior High School	1119	2/2/2024	10:05:00 AM	468	0.1	71.5	19.9	0	
Como Park Senior High School	1126	2/2/2024	9:38:00 AM	483	1.4	76.9	19.7	1	Taxidermy
Como Park Senior High School	1136	2/2/2024	9:52:00 AM	463	0.6	70.8	19.5	0	
Como Park Senior High School	1142	2/2/2024	9:55:00 AM	457	0.6	70.1	19.8	0	
Como Park Senior High School	1146	2/2/2024	9:50:00 AM	0.9	1	70.2	19.9	3	
Como Park Senior High School	1203	2/2/2024	10:49:00 AM	678	0.6	70.2	23.3	0	
Como Park Senior High School	1204	2/2/2024	10:59:00 AM	1118	0.4	70.1	29.6	24	
Como Park Senior High School	1205	2/2/2024	10:48:00 AM	591	0.5	71.3	21.9	1	
Como Park Senior High School	1206	2/2/2024	10:58:00 AM	746	0.3	70	25.6	2	
Como Park Senior High School	1207	2/2/2024	10:43:00 AM	1071	0.4	71.5	27.6	20	Stuffy Odor
Como Park Senior High School	1208	2/2/2024	10:55:00 AM	655	0.1	70	23.3	0	
Como Park Senior High School	1209	2/2/2024	10:37:00 AM	822	0.4	70.8	25.2	12	
Como Park Senior High School	1211	2/2/2024	10:30:00 AM	812	0.5	70.1	25.6	25	Fragrance Odor
Como Park Senior High School	1212	2/2/2024	10:47:00 AM	670	0.1	71.1	23.6	0	
Como Park Senior High School	1214	2/2/2024	10:44:00 AM	834	0.3	71.3	25.6	18	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1215	2/2/2024	10:23:00 AM	722	0.5	71.5	22.5	0	
Como Park Senior High School	1216	2/2/2024	10:41:00 AM	902	0.3	71.5	26.7	25	Plants
Como Park Senior High School	1217	2/2/2024	10:26:00 AM	793	0.4	71.8	23.3	0	
Como Park Senior High School	1218	2/2/2024	10:39:00 AM	817	0.4	71.1	26.3	20	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1219	2/2/2024	10:27:00 AM	692	0.8	71.6	22.5	0	
Como Park Senior High School	1222	2/2/2024	10:36:00 AM	831	0.1	71.4	25.5	20	Aquariums (fish), Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1224	2/2/2024	9:48:00 AM	583	0.8	72.2	21.1	0	Stained Ceiling Tiles
Como Park Senior High School	1226	2/2/2024	10:12:00 AM	676	1	74.1	21.3	16	Food Odor
Como Park Senior High School	1228	2/2/2024	10:08:00 AM	552		74.2	19.9	1	
Como Park Senior High School	1233	2/2/2024	10:29:00 AM	698	0.8	70.6	23.3	0	Fragrance, Food Odor
Como Park Senior High School	1235	2/2/2024	10:25:00 AM	708	0.8	72	22.9	0	
Como Park Senior High School	1237	2/2/2024	10:19:00 AM	721	0.6	71.6	24.2	20	
Como Park Senior High School	1300	2/2/2024	11:02:00 AM	580	0.1	71.6	22.4	5	
Como Park Senior High School	1302	2/2/2024	10:38:00 AM	566		70.7	21.9	1	
Como Park Senior High School	1303	2/2/2024	10:40:00 AM	508		71.4	21.7	0	
Como Park Senior High School	1304	2/2/2024	10:41:00 AM	626		71.4	21.7	5	
Como Park Senior High School	1305	2/2/2024	11:03:00 AM	558	0.1	71.5	22.6	7	
Como Park Senior High School	1306	2/2/2024	12:04:00 PM	716		70	24.5	1	
Como Park Senior High School	1308	2/2/2024	9:15:00 AM	790	0.2	71.6	22.8	6	
Como Park Senior High School	1309	2/2/2024	11:04:00 AM	589	0.3	71.6	28.4	7	
Como Park Senior High School	1311	2/2/2024	9:26:00 AM	694	0.6	71.3	23	2	
Como Park Senior High School	1312	2/2/2024	11:00:00 AM	571	0.1	70.8	22.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Senior High School	1401	2/2/2024	9:38:00 AM	692	0.1	70.2	24.7	12	
Como Park Senior High School	1403	2/2/2024	9:37:00 AM	664		69.4	24.5	1	
Como Park Senior High School	1405	2/2/2024	9:39:00 AM	597		70.3	26.2	0	
Como Park Senior High School	1406	2/2/2024	9:40:00 AM	564	0.1	69.3	22.4	0	
Como Park Senior High School	1409	2/2/2024	9:35:00 AM	651	0.1	69.1	23.7	25	
Como Park Senior High School	1411	2/2/2024	9:28:00 AM	585	0.3	69.8	21.8	3	Stained Ceiling Tiles
Como Park Senior High School	1412	2/2/2024	10:54:00 AM	661	0.5	69.7	23.7	0	
Como Park Senior High School	1413	2/2/2024	9:30:00 AM	613	0.2	69.3	22.6	1	
Como Park Senior High School	1415	2/2/2024	9:33:00 AM	553	0.1	69.4	21.7	7	
Como Park Senior High School	1416	2/2/2024	10:51:00 AM	598	0.8	69.8	23.1	0	
Como Park Senior High School	1501	2/2/2024	10:42:00 AM	603		70.9	21.9	2	
Como Park Senior High School	1502	2/2/2024	10:45:00 AM	531		70	21.9	0	
Como Park Senior High School	1503	2/2/2024	10:44:00 AM	496		70.2	21.3	0	
Como Park Senior High School	1505	2/2/2024	10:45:00 AM	521		70	22.3	0	
Como Park Senior High School	1506	2/2/2024	10:48:00 AM	501		70.3	21.4	0	
Como Park Senior High School	1507	2/2/2024	10:46:00 AM	546		70.2	23.3	0	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1509	2/2/2024	10:49:00 AM	495		68.9	22.5	0	
Como Park Senior High School	1511	2/2/2024	10:53:00 AM	492		70.9	21.8	0	Stained Ceiling Tiles
Como Park Senior High School	1512	2/2/2024	10:56:00 AM	499		71.6	20.5	0	
Como Park Senior High School	1513	2/2/2024	10:55:00 AM	546		72.1	21.1	1	
Como Park Senior High School	1514	2/2/2024	10:57:00 AM	545		71.1	21.5	0	
Como Park Senior High School	1601	2/2/2024	10:36:00 AM	597		70.7	21.7	0	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1603	2/2/2024	10:36:00 AM	626		71.4	21.6	1	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1605	2/2/2024	10:33:00 AM	911		72	24.9	20	
Como Park Senior High School	1606	2/2/2024	10:35:00 AM	634		72	21.5	1	
Como Park Senior High School	1607	2/2/2024	10:32:00 AM	709		71.6	22.4	4	Plants
Como Park Senior High School	1608	2/2/2024	10:31:00 AM	654		71.6	21.7	0	
Como Park Senior High School	1609	2/2/2024	10:26:00 AM	632		69.8	22.5	0	
Como Park Senior High School	1611	2/2/2024	10:24:00 AM	677		70	23.6	0	
Como Park Senior High School	1612	2/2/2024	10:30:00 AM	611		71.4	21.4	0	
Como Park Senior High School	1613	2/2/2024	10:22:00 AM	662		69.1	23.6	1	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1614	2/2/2024	10:29:00 AM	631		70.9	22.2	1	
Como Park Senior High School	1615	2/2/2024	10:20:00 AM	654		69.3	23.2	3	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1616	2/2/2024	10:28:00 AM	620		70.5	22	1	
Como Park Senior High School	1618	2/2/2024	10:26:00 AM	802		70	24.3	9	
Como Park Senior High School	1701	2/2/2024	10:09:00 AM	930		69.6	26.5	20	
Como Park Senior High School	1703	2/2/2024	10:05:00 AM	904		69.3	25.7	20	
Como Park Senior High School	1706	2/2/2024	10:07:00 AM	665		70	22.9	0	
Como Park Senior High School	1707	2/2/2024	10:04:00 AM	619		69.8	22.5	0	
Como Park Senior High School	1708	2/2/2024	10:01:00 AM	847		71.2	23.2	9	
Como Park Senior High School	1709	2/2/2024	10:02:00 AM	953		70.9	24.4	20	
Como Park Senior High School	1710	2/2/2024	9:47:00 AM	708	0.1	70	23.7	3	
Como Park Senior High School	1711	2/2/2024	9:48:00 AM	750		70.5	23.9	7	
Como Park Senior High School	1712	2/2/2024	10:00:00 AM	814		71.6	22.9	15	
Como Park Senior High School	1713	2/2/2024	9:50:00 AM	605		71.2	21.4	0	
Como Park Senior High School	1716	2/2/2024	9:58:00 AM	862	0.1	71.4	23.6	15	
Como Park Senior High School	1717	2/2/2024	9:53:00 AM	647		71.8	21.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Senior High School	1718	2/2/2024	9:57:00 AM	645		71.6	21.3	12	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1722	2/2/2024	9:56:00 AM	672	0.1	72	21.4	1	
Como Park Senior High School	1724	2/2/2024	9:55:00 AM	834	0.1	72	23.1	0	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1726	2/2/2024	9:53:00 AM	883		72.1	23.8	25	
Como Park Senior High School	1803	2/2/2024	9:44:00 AM	593		70.3	21.8	0	
Como Park Senior High School	1805	2/2/2024	9:45:00 AM	671	0.1	70.2	24	1	
Como Park Senior High School	1811	2/2/2024	9:41:00 AM	597		69.6	22.7	0	
Como Park Senior High School	2302	2/2/2024	11:09:00 AM	619		71.1	22.3	0	
Como Park Senior High School	2303	2/2/2024	10:59:00 AM	591		71.2	22.1	0	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	2307	2/2/2024	11:02:00 AM	594		70.9	22.8	0	Stained Ceiling Tiles
Como Park Senior High School	2308	2/2/2024	11:05:00 AM	590		70.7	22.6	1	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	2309	2/2/2024	11:06:00 AM	570		70.5	22.3	0	Stained Ceiling Tiles
Como Park Senior High School	2311	2/2/2024	11:07:00 AM	669		70.3	23.9	1	
Como Park Senior High School	2313	2/2/2024	11:09:00 AM	637		70.2	23.3	10	
Como Park Senior High School	2601	2/2/2024	11:27:00 AM	1038		71.4	25.9	25	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	2603	2/2/2024	11:29:00 AM	820		71.1	23.9	3	
Como Park Senior High School	2605	2/2/2024	11:30:00 AM	680		71.2	22.9	1	
Como Park Senior High School	2606	2/2/2024	11:13:00 AM	952		71.6	26.3	20	Stained Ceiling Tiles
Como Park Senior High School	2609	2/2/2024	11:35:00 AM	884		71.4	25	7	
Como Park Senior High School	2611	2/2/2024	11:36:00 AM	880		71.6	24.4	18	
Como Park Senior High School	2612	2/2/2024	11:33:00 AM	742		71.2	23.5	2	
Como Park Senior High School	2613	2/2/2024	11:38:00 AM	887		71.2	24.7	20	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	2614	2/2/2024	11:34:00 AM	662		71.4	22.4	0	
Como Park Senior High School	2616	2/2/2024	11:32:00 AM	680		71.2	23	0	
Como Park Senior High School	2617	2/2/2024	11:42:00 AM	666		72	22.7	0	
Como Park Senior High School	2618	2/2/2024	11:37:00 AM	661		71.8	22.2	0	
Como Park Senior High School	2624	2/2/2024	11:40:00 AM	893		71.2	25.4	20	
Como Park Senior High School	2626	2/2/2024	11:41:00 AM	1064		71.6	26.8	10	
Como Park Senior High School	2701	2/2/2024	11:43:00 AM	696		72	23.2	1	
Como Park Senior High School	2703	2/2/2024	11:45:00 AM	662		71.6	23.5	1	
Como Park Senior High School	2707	2/2/2024	11:48:00 AM	673		71.1	23.7	0	
Como Park Senior High School	2708	2/2/2024	11:46:00 AM	707		71.8	22.6	0	
Como Park Senior High School	2709	2/2/2024	11:49:00 AM	678		70.7	24.2	5	
Como Park Senior High School	2712	2/2/2024	11:50:00 AM	603		71.2	23	0	
Como Park Senior High School	2713	2/2/2024	12:03:00 PM	861		70.5	26.1	15	
Como Park Senior High School	2714	2/2/2024	11:51:00 AM	752		71.6	24.1	20	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	2715	2/2/2024	12:02:00 PM	898		70.9	26.3	18	
Como Park Senior High School	2716	2/2/2024	11:52:00 AM	641		71.1	23.3	0	
Como Park Senior High School	2726	2/2/2024	11:53:00 AM	698		70.7	23.8	1	
Como Park Senior High School	2728	2/2/2024	11:55:00 AM	731		70.5	24.1	4	
Como Park Senior High School	2732	2/2/2024	11:56:00 AM	1034		70.3	29.1	25	
Como Park Senior High School	2734	2/2/2024	11:57:00 AM	590		70.7	23.1	0	
Como Park Senior High School	2736	2/2/2024	11:58:00 AM	707		71.1	24	0	
Como Park Senior High School	2738	2/2/2024	11:59:00 AM	1085		71.1	27.6	20	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	2742	2/2/2024	12:00:00 PM	851		70.9	25.6	18	
Como Park Senior High School	2744	2/2/2024	12:01:00 PM	582		70.9	22.7	0	
Como Park Senior High School	1103A	2/2/2024	9:42:00 AM	500	1.1	72.4	16.8	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Como Park Senior High School	1105A	2/2/2024	9:43:00 AM	520	1	72.9	17	0	
Como Park Senior High School	1109A	2/2/2024	10:02:00 AM	538	0.3	70.5	21.4	0	Fragrance Odor
Como Park Senior High School	1113A	2/2/2024	9:59:00 AM	466	0.5	69.8	0.3	0	
Como Park Senior High School	1114B	2/2/2024	9:35:00 AM	495		77.6	35.5	0	
Como Park Senior High School	1214A	2/2/2024	10:45:00 AM	909	0.4	71.4	24.7	1	Fragrance Odor
Como Park Senior High School	1228B	2/2/2024	10:11:00 AM	534	0.1	75.5	18.7	0	
Como Park Senior High School	1307B	2/2/2024	11:06:00 AM	598	0.4	71.7	25.7	1	
Como Park Senior High School	1411B	2/2/2024	9:32:00 AM	516	0.1	69.6	21.6	0	
Como Park Senior High School	1415B	2/2/2024	9:34:00 AM	521	0.1	69.3	21.4	0	
Como Park Senior High School	1609B	2/2/2024	10:25:00 AM	608		70	22.2	0	Stained Ceiling Tiles
Como Park Senior High School	1613B	2/2/2024	10:23:00 AM	647		69.3	22.7	0	Plants: Kept Away From Return And Supply Vents
Como Park Senior High School	1711A	2/2/2024	9:49:00 AM	756		71.1	23.3	1	
Como Park Senior High School	1712A	2/2/2024	9:59:00 AM	801		71.8	23	0	
Como Park Senior High School	1717A	2/2/2024	9:51:00 AM	596		71.8	21.7	0	
Como Park Senior High School	OUTDOORS	2/2/2024		412	1.2	29	85		
Creative Arts Secondary School	102	1/23/2024	9:00:00 AM	558	0.3	71.6	18.9	1	
Creative Arts Secondary School	107	1/23/2024	9:25:00 AM	535	0.4	72.7	18.4	1	
Creative Arts Secondary School	112	1/23/2024	9:24:00 AM	556	0.4	72.7	16.9	0	
Creative Arts Secondary School	113	1/23/2024	9:23:00 AM	718	0.4	72.3	19.4	0	
Creative Arts Secondary School	114	1/23/2024	9:21:00 AM	521	0.4	72	16.7	0	Stained Ceiling Tiles
Creative Arts Secondary School	118	1/23/2024	9:13:00 AM	493	0.5	72	17.2	0	
Creative Arts Secondary School	1102	1/23/2024	12:39:00 PM	612		69.6	20.9	1	
Creative Arts Secondary School	1103	1/23/2024	12:22:00 PM	561		69.1	20.6	2	
Creative Arts Secondary School	1104	1/23/2024	12:28:00 PM	700		71.4	21.5	3	Fragrance Odor
Creative Arts Secondary School	1105	1/23/2024	12:25:00 PM	882		69.8	22.4	0	Food Odor
Creative Arts Secondary School	1106	1/23/2024	12:21:00 PM	614		70.2	21	12	Stained Ceiling Tiles
Creative Arts Secondary School	1201	1/23/2024	12:12:00 PM	517		70	20.9	5	
Creative Arts Secondary School	1207	1/23/2024	12:32:00 PM	553		73	18.3	0	Stained Ceiling Tiles
Creative Arts Secondary School	1208	1/23/2024	12:38:00 PM	578		72	19.5	1	Stained Ceiling Tiles
Creative Arts Secondary School	1209	1/23/2024	12:30:00 PM	470		70	20.8	0	
Creative Arts Secondary School	2100	1/23/2024	11:59:00 AM	747		69.3	23.1	3	
Creative Arts Secondary School	2104	1/23/2024	12:11:00 PM	706		67.6	23.3	0	
Creative Arts Secondary School	2105	1/23/2024	12:09:00 PM	676		67.6	24.9	0	
Creative Arts Secondary School	2106	1/23/2024	12:07:00 PM	680		68.2	24.5	0	
Creative Arts Secondary School	2201	1/23/2024	11:49:00 AM	1153	0.1	71.8	23.4	2	Fragrance Odor
Creative Arts Secondary School	2202	1/23/2024	11:51:00 AM	802		71.6	20.4	7	Fragrance Odor
Creative Arts Secondary School	2204	1/23/2024	11:54:00 AM	790		72.3	20.6	0	
Creative Arts Secondary School	2207	1/23/2024	11:58:00 AM	775		71.6	21.5	0	
Creative Arts Secondary School	2210	1/23/2024	11:27:00 AM	965		69.1	22.7	20	
Creative Arts Secondary School	2305	1/23/2024	11:35:00 AM	902		67.5	24.2	0	
Creative Arts Secondary School	2306	1/23/2024	11:31:00 AM	920		67.6	25.6	20	
Creative Arts Secondary School	2310	1/23/2024	11:38:00 AM	762		67.6	23.8	0	
Creative Arts Secondary School	2311	1/23/2024	11:39:00 AM	772		71.1	21.5	0	
Creative Arts Secondary School	2312	1/23/2024	11:41:00 AM	749		72.1	20.4	0	
Creative Arts Secondary School	2313	1/23/2024	11:33:00 AM	804		67.5	25.3	0	
Creative Arts Secondary School	2314	1/23/2024	11:34:00 AM	957		67.6	24.8	0	
Creative Arts Secondary School	2315	1/23/2024	11:42:00 AM	814		71.6	22.5	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Creative Arts Secondary School	2316	1/23/2024	11:43:00 AM	842		71.4	22.7	0	Musty, Food Odor
Creative Arts Secondary School	2360	1/23/2024	11:48:00 AM	801		71.8	21.9	0	
Creative Arts Secondary School	3102	1/23/2024	11:24:00 AM	842		70.2	22.9	3	
Creative Arts Secondary School	3105	1/23/2024	11:22:00 AM	726		70.2	21.8	100	
Creative Arts Secondary School	4105	1/23/2024	11:13:00 AM	719		70.5	20.7	0	
Creative Arts Secondary School	4106	1/23/2024	11:18:00 AM	991		70.3	23.8	20	Food Odor
Creative Arts Secondary School	4108	1/23/2024	11:21:00 AM	1101		70.7	24.6	20	
Creative Arts Secondary School	4109	1/23/2024	10:59:00 AM	717		70.7	21.1	0	Stained Ceiling Tiles
Creative Arts Secondary School	4111	1/23/2024	10:54:00 AM	951		70.3	23.6	10	
Creative Arts Secondary School	4112	1/23/2024	11:00:00 AM	845		72.1	20.4	0	
Creative Arts Secondary School	5102	1/23/2024	10:47:00 AM	1119		70	24.1	12	
Creative Arts Secondary School	5103	1/23/2024	10:50:00 AM	657		70.7	22.5	1	
Creative Arts Secondary School	5104	1/23/2024	10:48:00 AM	750		70.2	22.2	0	Bubbling/Peeling Paint
Creative Arts Secondary School	5105	1/23/2024	10:46:00 AM	1013	0.1	69.8	23.7	15	
Creative Arts Secondary School	5106	1/23/2024	10:41:00 AM	824	0.1	71.1	22.2	22	
Creative Arts Secondary School	5107	1/23/2024	10:45:00 AM	962		70.2	23.5	12	
Creative Arts Secondary School	5109	1/23/2024	10:43:00 AM	836		71.1	22.2	0	Bubbling/Peeling Paint
Creative Arts Secondary School	6106	1/23/2024	10:22:00 AM	925		70.9	22.5	12	Fragrance Odor
Creative Arts Secondary School	6107	1/23/2024	10:09:00 AM	747	0.1	70.7	21.2	0	Fragrance Odor
Creative Arts Secondary School	6108	1/23/2024	10:23:00 AM	866	0.1	71.2	21	0	
Creative Arts Secondary School	6109	1/23/2024	10:24:00 AM	851	0.1	71.8	21.1	8	
Creative Arts Secondary School	6110	1/23/2024	10:25:00 AM	925	0.1	72.1	22.2	22	
Creative Arts Secondary School	6112	1/23/2024	10:26:00 AM	861	0.1	72	21.1	0	
Creative Arts Secondary School	6113	1/23/2024	10:27:00 AM	775	0.2	72.1	20	0	
Creative Arts Secondary School	6114	1/23/2024	10:29:00 AM	735	0.1	72.3	20.6	0	
Creative Arts Secondary School	7106	1/23/2024	9:58:00 AM	868	0.3	69.6	23.9	20	
Creative Arts Secondary School	7107	1/23/2024	10:00:00 AM	751	0.1	70	21.6	1	
Creative Arts Secondary School	7108	1/23/2024	10:01:00 AM	807	0.1	70.2	21.4	0	
Creative Arts Secondary School	7109	1/23/2024	10:02:00 AM	804	0.1	70	21.8	3	
Creative Arts Secondary School	7110	1/23/2024	10:03:00 AM	759	0.1	70.2	22.7	0	
Creative Arts Secondary School	7112	1/23/2024	10:05:00 AM	982	0.1	70.2	23.1	20	
Creative Arts Secondary School	7113	1/23/2024	10:06:00 AM	728	0.1	70.7	20.9	0	
Creative Arts Secondary School	7114	1/23/2024	10:08:00 AM	722	0.1	70.7	21.2	0	
Creative Arts Secondary School	8106	1/23/2024	9:27:00 AM	886	0.4	69.6	23.8	20	
Creative Arts Secondary School	8107	1/23/2024	9:56:00 AM	1288	0.4	70.7	21.8	15	
Creative Arts Secondary School	8109	1/23/2024	9:39:00 AM	723	0.3	68.2	21.8	4	
Creative Arts Secondary School	8110	1/23/2024	9:42:00 AM	1022	0.2	69.6	25	25	
Creative Arts Secondary School	8112	1/23/2024	9:44:00 AM	791	0.5	73.9	19.2	0	Fragrance Odor, Stained Ceiling Tiles
Creative Arts Secondary School	8113	1/23/2024	9:43:00 AM	954	0.2	70.7	21	0	
Creative Arts Secondary School	8114	1/23/2024	9:41:00 AM	754	0.3	69.1	22.7	1	
Creative Arts Secondary School	0107A	1/23/2024	9:27:00 AM	679	0.4	72.7	18.5	0	
Creative Arts Secondary School	1102A	1/23/2024	12:41:00 PM	647		70.2	21.3	0	
Creative Arts Secondary School	1102B	1/23/2024	12:42:00 PM	594		70	21.1	1	
Creative Arts Secondary School	1102C	1/23/2024	12:43:00 PM	528		70.2	20.4	0	
Creative Arts Secondary School	1105A	1/23/2024	12:27:00 PM	809		71.2	21	1	Fragrance, Food Odor
Creative Arts Secondary School	1105B	1/23/2024	12:26:00 PM	936		71.1	23	1	
Creative Arts Secondary School	1107A	1/23/2024	12:18:00 PM	664		68.9	21.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Creative Arts Secondary School	2203A	1/23/2024	11:57:00 AM	755		71.2	19.6	0	Fragrance Odor
Creative Arts Secondary School	2203B	1/23/2024	11:55:00 AM	765		71.6	20.9	0	
Creative Arts Secondary School	2203C	1/23/2024	11:52:00 AM	892		71.8	17.5	0	
Creative Arts Secondary School	2316A	1/23/2024	11:44:00 AM	804		71.4	21.6	1	Food Odor
Creative Arts Secondary School	2316B	1/23/2024	11:45:00 AM	799		71.8	21.4	1	
Creative Arts Secondary School	2316C	1/23/2024	11:46:00 AM	1026		72	23.9	1	
Creative Arts Secondary School	3102A	1/23/2024	11:26:00 AM	752		70.5	21.3	0	
Creative Arts Secondary School	OUTDOORS	1/23/2024		446	0.4	31	88		
Crossroads Montessori	1004	12/14/2023	10:33:00 AM	642	0.1	69.4	17.4	30	Food Odor
Crossroads Montessori	1006	12/14/2023	9:03:00 AM	648	0.1	69.2	17	20	
Crossroads Montessori	1008	12/14/2023	9:07:00 AM	586	0.1	69.5	16	0	
Crossroads Montessori	1018	12/14/2023	9:52:00 AM	553	0.2	68.2	15.6	0	
Crossroads Montessori	1020	12/14/2023	9:48:00 AM	552	0.1	67.5	15.5	0	
Crossroads Montessori	1100	12/14/2023	10:34:00 AM	602		70.5	16.3	3	Food Odor
Crossroads Montessori	1102	12/14/2023	10:36:00 AM	626	0.2	70.8	16.3	0	Fragrance Odor
Crossroads Montessori	1104	12/14/2023	10:37:00 AM	647	0.3	70.8	17.1	3	Fragrance, Food Odor
Crossroads Montessori	1106	12/14/2023	10:38:00 AM	585	0.2	70.7	15.9	0	
Crossroads Montessori	1108	12/14/2023	10:38:00 AM	572	0.3	70.6	16.6	0	
Crossroads Montessori	1109	12/14/2023	10:41:00 AM	608		71.1	16.1	0	
Crossroads Montessori	1111	12/14/2023	10:42:00 AM	616	0.4	70.7	16.4	0	
Crossroads Montessori	1112	12/14/2023	10:44:00 AM	588	0.3	69.9	16.7	0	Food Odor
Crossroads Montessori	1120	12/14/2023	10:45:00 AM	640	0.2	69.7	16.5	0	
Crossroads Montessori	1122	12/14/2023	10:49:00 AM	668	0.1	69.4	18.1	1	
Crossroads Montessori	1126	12/14/2023	10:48:00 AM	590		69.4	16.5	0	
Crossroads Montessori	1127	12/14/2023	10:47:00 AM	592	0.1	69.6	16.6	0	
Crossroads Montessori	1130	12/14/2023	10:51:00 AM	617	0.1	68.6	16.9	0	
Crossroads Montessori	1202	12/14/2023	11:04:00 AM	620	0.1	69.6	17.5	1	
Crossroads Montessori	1204	12/14/2023	10:27:00 AM	819	0.1	70	19.4	18	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1206	12/14/2023	11:08:00 AM	606	0.3	70.2	16.6	1	
Crossroads Montessori	1208	12/14/2023	10:25:00 AM	758	0.4	69.3	17.9	15	Plants
Crossroads Montessori	1210	12/14/2023	10:23:00 AM	825	0.1	69.6	20.1	20	
Crossroads Montessori	1212	12/14/2023	11:12:00 AM	588	0.1	67.3	18.8	0	
Crossroads Montessori	1214	12/14/2023	11:09:00 AM	617	0.1	70.6	17.7	0	
Crossroads Montessori	1216	12/14/2023	11:11:00 AM	570	0.1	69.4	16.2	0	
Crossroads Montessori	1218	12/14/2023	10:20:00 AM	746	0.3	69	19.1	15	
Crossroads Montessori	1302	12/14/2023	11:03:00 AM	636	0.1	68.5	18.1	0	
Crossroads Montessori	1304	12/14/2023	10:16:00 AM	810	0.3	68.9	20.6	18	
Crossroads Montessori	1306	12/14/2023	11:01:00 AM	552		68.4	17.8	0	
Crossroads Montessori	1308	12/14/2023	10:59:00 AM	621	0.2	68	17.5	0	
Crossroads Montessori	1310	12/14/2023	10:58:00 AM	539		68	17.5	0	
Crossroads Montessori	1312	12/14/2023	10:57:00 AM	585		67.9	17.4	4	
Crossroads Montessori	1314	12/14/2023	10:08:00 AM	592	0.1	69.2	17.1	0	
Crossroads Montessori	1320	12/14/2023	10:54:00 AM	552		68.3	16.7	0	
Crossroads Montessori	1402	12/14/2023	9:53:00 AM	638	0.1	68	17.5	18	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1404	12/14/2023	9:57:00 AM	635		68.2	17.2	15	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1406	12/14/2023	9:58:00 AM	541	0.2	69	16.2	0	
Crossroads Montessori	1408	12/14/2023	9:59:00 AM	534	0.1	69.3	15.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Crossroads Montessori	1410	12/14/2023	10:01:00 AM	738	0.3	68.7	17.6	25	Plants: Kept Away From Return And Supply Vents
Crossroads Montessori	1412	12/14/2023	10:03:00 AM	687	0.2	69	17.5	18	Fragrance Odor
Crossroads Montessori	1414	12/14/2023	10:04:00 AM	631		68.9	17.1	0	
Crossroads Montessori	1416	12/14/2023	10:05:00 AM	725	0.4	68.2	18.2	18	
Crossroads Montessori	1417	12/14/2023	10:07:00 AM	782	0.1	67.8	18.3	0	
Crossroads Montessori	1503	12/14/2023	10:13:00 AM	576		69.3	15.7	0	
Crossroads Montessori	1504	12/14/2023	10:28:00 AM	618		69.2	16.6	20	Food Odor
Crossroads Montessori	1520	12/14/2023	9:09:00 AM	599	0.4	69.4	15.8	1	Food Odor
Crossroads Montessori	1524	12/14/2023	9:11:00 AM	614	0.4	69.4	16.2	1	
Crossroads Montessori	1526	12/14/2023	9:13:00 AM	584	0.4	68.4	16.7	3	Food Odor
Crossroads Montessori	1533	12/14/2023	8:17:00 AM	540		68.2	21.8	1	
Crossroads Montessori	1601	12/14/2023	9:19:00 AM	580	0.2	68.7	16	1	
Crossroads Montessori	1606	12/14/2023	9:36:00 AM	610		68.2	16.8	0	
Crossroads Montessori	1608	12/14/2023	9:14:00 AM	574	0.3	69	15.7	0	
Crossroads Montessori	1612	12/14/2023	9:35:00 AM	598	0.3	68.2	16.4	0	
Crossroads Montessori	1614	12/14/2023	9:33:00 AM	608		68.7	17.2	1	
Crossroads Montessori	1618	12/14/2023	9:30:00 AM	602	0.2	68.6	16.5	0	
Crossroads Montessori	1620	12/14/2023	9:28:00 AM	561	0.2	67.8	17.1	0	
Crossroads Montessori	1624	12/14/2023	9:26:00 AM	599	0.2	67.4	16.9	0	
Crossroads Montessori	1625	12/14/2023	9:24:00 AM	585	0.3	67.8	16.3	0	
Crossroads Montessori	1626	12/14/2023	9:22:00 AM	628		68.8	16.9	1	
Crossroads Montessori	1628	12/14/2023	9:21:00 AM	683	0.2	69.1	17.9	5	
Crossroads Montessori	2001	12/14/2023	8:30:00 AM	584	0.9	67.3	16.8	12	
Crossroads Montessori	2003	12/14/2023	8:35:00 AM	625	0.6	67.7	16.8	0	
Crossroads Montessori	2016	12/14/2023	8:36:00 AM	543	0.9	66.5	16.1	0	
Crossroads Montessori	2018	12/14/2023	8:39:00 AM	528	0.4	68	16.8	0	
Crossroads Montessori	2020	12/14/2023	8:37:00 AM	520	0.2	67.8	17	0	
Crossroads Montessori	2302	12/14/2023	9:00:00 AM	799	0.3	69.4	17.5	18	Fragrance Odor
Crossroads Montessori	2304	12/14/2023	8:57:00 AM	760	0.3	69.3	17.4	15	Fragrance Odor
Crossroads Montessori	2306	12/14/2023	10:09:00 AM	623	0.2	68.5	16.6	0	
Crossroads Montessori	2308	12/14/2023	9:46:00 AM	681	0.4	68.7	16.5	10	
Crossroads Montessori	2310	12/14/2023	9:37:00 AM	693	0.3	69	16.8	4	Fragrance Odor
Crossroads Montessori	2312	12/14/2023	8:55:00 AM	744	0.5	69.6	17.4	16	Plants
Crossroads Montessori	2314	12/14/2023	8:54:00 AM	590	0.1	69.6	17.3	0	Fragrance Odor
Crossroads Montessori	2320	12/14/2023	9:01:00 AM	631	0.4	69.5	15.7	1	
Crossroads Montessori	2322	12/14/2023	9:02:00 AM	632	0.5	69.4	15.8	3	
Crossroads Montessori	2402	12/14/2023	8:43:00 AM	540	0.4	68.1	15.4	0	
Crossroads Montessori	2404	12/14/2023	8:45:00 AM	675	0.2	68.4	17.7	22	
Crossroads Montessori	2406	12/14/2023	8:47:00 AM	637	0.4	68.5	15.9	5	
Crossroads Montessori	2408	12/14/2023	8:48:00 AM	761	0.4	68.8	18.4	20	
Crossroads Montessori	2410	12/14/2023	8:49:00 AM	782	0.4	68.7	17.2	20	
Crossroads Montessori	2412	12/14/2023	8:50:00 AM	615	0.3	68.7	15.1	0	
Crossroads Montessori	2414	12/14/2023	8:51:00 AM	624	0.4	68.7	16.3	1	Fragrance Odor
Crossroads Montessori	2416	12/14/2023	8:52:00 AM	697	0.7	68.7	16.8	20	
Crossroads Montessori	2424	12/14/2023	8:41:00 AM	540	0.5	68.3	15.5	0	
Crossroads Montessori	2426	12/14/2023	8:40:00 AM	537	0.2	68.5	15.9	0	
Crossroads Montessori	1630A	12/14/2023	9:20:00 AM	719	0.1	69.1	19	22	Fragrance Odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Crossroads Montessori	OUTDOORS	12/14/2023		508	2.1	31	59		
Dayton's Bluff Elementary School	126	1/10/2024	10:25:00 AM	542		67.8	20.4	1	
Dayton's Bluff Elementary School	1101	1/10/2024	9:27:00 AM	617		70.3	18.5	1	
Dayton's Bluff Elementary School	1102	1/10/2024	9:26:00 AM	614		70.7	18.3	1	
Dayton's Bluff Elementary School	1103	1/10/2024	8:43:00 AM	571		69.8	18.5	0	
Dayton's Bluff Elementary School	1105	1/10/2024	9:28:00 AM	584		70.3	18.3	0	
Dayton's Bluff Elementary School	1106	1/10/2024	8:42:00 AM	613		69.6	19	0	
Dayton's Bluff Elementary School	1201	1/10/2024	9:30:00 AM	595		69.3	19.4	0	
Dayton's Bluff Elementary School	1202	1/10/2024	8:39:00 AM	760		68.9	21.3	15	
Dayton's Bluff Elementary School	1203	1/10/2024	8:48:00 AM	622		69.6	19.4	1	
Dayton's Bluff Elementary School	1204	1/10/2024	8:44:00 AM	607		69.6	19.2	2	
Dayton's Bluff Elementary School	1301	1/10/2024	8:27:00 AM	575		70.5	18.2	1	
Dayton's Bluff Elementary School	1302	1/10/2024	8:29:00 AM	576		70	18.9	1	
Dayton's Bluff Elementary School	1303	1/10/2024	8:32:00 AM	630		69.4	19.8	6	
Dayton's Bluff Elementary School	1304	1/10/2024	8:34:00 AM	603		69.4	19.2	4	
Dayton's Bluff Elementary School	1305	1/10/2024	8:34:00 AM	594		69.4	19.4	1	
Dayton's Bluff Elementary School	1306	1/10/2024	8:37:00 AM	667		68.4	20.8	20	
Dayton's Bluff Elementary School	1307	1/10/2024	8:31:00 AM	593		68.9	19.6	2	
Dayton's Bluff Elementary School	1402	1/10/2024	8:23:00 AM	565		70.7	17.8	1	
Dayton's Bluff Elementary School	1402	1/10/2024	9:18:00 AM	550		69.3	18.2	3	
Dayton's Bluff Elementary School	1405	1/10/2024	8:25:00 AM	583		74.1	15.7	2	
Dayton's Bluff Elementary School	1406	1/10/2024	8:27:00 AM	522		73.4	16	1	
Dayton's Bluff Elementary School	1407	1/10/2024	8:21:00 AM	607		69.1	19.3	20	
Dayton's Bluff Elementary School	1408	1/10/2024	8:20:00 AM	613		70.3	18.7	25	
Dayton's Bluff Elementary School	1409	1/10/2024	8:19:00 AM	600		70.9	18.5	20	
Dayton's Bluff Elementary School	1507	1/10/2024	9:38:00 AM	509		68.7	17.9	0	
Dayton's Bluff Elementary School	1510	1/10/2024	9:35:00 AM	475		69.6	17.1	0	
Dayton's Bluff Elementary School	1513	1/10/2024	9:22:00 AM	551		70.3	17.1	0	
Dayton's Bluff Elementary School	1514	1/10/2024	9:21:00 AM	608		70.2	19	0	
Dayton's Bluff Elementary School	1516	1/10/2024	9:20:00 AM	722		70	19.4	20	
Dayton's Bluff Elementary School	2001	1/10/2024	9:54:00 AM	634		70.5	18.2	2	
Dayton's Bluff Elementary School	2002	1/10/2024	10:12:00 AM	566		70.3	17.6	1	
Dayton's Bluff Elementary School	2004	1/10/2024	10:09:00 AM	590		69.1	18.6	1	
Dayton's Bluff Elementary School	2005	1/10/2024	10:32:00 AM	520		68.7	17.7	0	
Dayton's Bluff Elementary School	2006	1/10/2024	10:33:00 AM	548		68.5	18.3	0	Stained Ceiling Tiles
Dayton's Bluff Elementary School	2007	1/10/2024	10:35:00 AM	557		70.2	17.8	0	Fragrance Odor
Dayton's Bluff Elementary School	2008	1/10/2024	10:07:00 AM	586		68.9	18.6	1	
Dayton's Bluff Elementary School	2010	1/10/2024	10:06:00 AM	657		68.9	19.3	3	Stained Ceiling Tiles
Dayton's Bluff Elementary School	2011	1/10/2024	10:04:00 AM	539		68.9	17.9	0	
Dayton's Bluff Elementary School	2012	1/10/2024	10:03:00 AM	649		69.1	19.4	2	
Dayton's Bluff Elementary School	2014	1/10/2024	10:37:00 AM	571		69.3	17.7	0	
Dayton's Bluff Elementary School	2015	1/10/2024	10:00:00 AM	595		69.8	17.8	0	Stained Ceiling Tiles
Dayton's Bluff Elementary School	2016	1/10/2024	10:38:00 AM	778		69.4	19.6	1	Fragrance Odor
Dayton's Bluff Elementary School	2017	1/10/2024	10:11:00 AM	592		70.3	17.8	0	
Dayton's Bluff Elementary School	2018	1/10/2024	10:01:00 AM	592		69.3	19	1	
Dayton's Bluff Elementary School	2019	1/10/2024	9:58:00 AM	559		70.2	18	0	
Dayton's Bluff Elementary School	2020	1/10/2024	9:56:00 AM	673		70.3	18.5	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Dayton's Bluff Elementary School	2021	1/10/2024	9:55:00 AM	634		70.5	18.3	1	
Dayton's Bluff Elementary School	2022	1/10/2024	9:52:00 AM	610		70.3	18.2	1	
Dayton's Bluff Elementary School	2101	1/10/2024	9:50:00 AM	653		69.8	18.9	25	
Dayton's Bluff Elementary School	2106	1/10/2024	10:15:00 AM	496		68.9	17.3	0	
Dayton's Bluff Elementary School	2201	1/10/2024	10:41:00 AM	604		69.3	20.6	2	
Dayton's Bluff Elementary School	2202	1/10/2024	10:43:00 AM	624		69.3	20.8	5	
Dayton's Bluff Elementary School	2203	1/10/2024	10:45:00 AM	645		69.6	22.2	1	
Dayton's Bluff Elementary School	2204	1/10/2024	10:45:00 AM	622		70.3	21.1	2	
Dayton's Bluff Elementary School	2301	1/10/2024	8:50:00 AM	654		69.8	19.5	3	
Dayton's Bluff Elementary School	2302	1/10/2024	8:51:00 AM	673		70.3	19.6	15	
Dayton's Bluff Elementary School	2303	1/10/2024	8:54:00 AM	621		70.2	18.8	0	
Dayton's Bluff Elementary School	2304	1/10/2024	8:55:00 AM	662		70	19.3	10	
Dayton's Bluff Elementary School	2305	1/10/2024	8:57:00 AM	623		69.3	19.5	1	
Dayton's Bluff Elementary School	2306	1/10/2024	8:59:00 AM	641		69.8	19.4	20	
Dayton's Bluff Elementary School	2307	1/10/2024	9:02:00 AM	892		69.3	22.2	25	
Dayton's Bluff Elementary School	2313	1/10/2024	9:01:00 AM	589		70	18.5	1	
Dayton's Bluff Elementary School	2401	1/10/2024	9:04:00 AM	576		70	18	1	
Dayton's Bluff Elementary School	2402	1/10/2024	9:06:00 AM	764		70.7	19.6	25	
Dayton's Bluff Elementary School	2403	1/10/2024	9:48:00 AM	601		70.2	18.1	1	
Dayton's Bluff Elementary School	2404	1/10/2024	9:09:00 AM	809		69.8	20.1	20	
Dayton's Bluff Elementary School	2405	1/10/2024	9:08:00 AM	723		69.6	19.3	10	Stained Ceiling Tiles
Dayton's Bluff Elementary School	2406	1/10/2024	9:13:00 AM	747		68.9	20.6	20	
Dayton's Bluff Elementary School	2407	1/10/2024	9:10:00 AM	531		69.1	17.9	0	
Dayton's Bluff Elementary School	2408	1/10/2024	9:12:00 AM	593		68.5	19.1	5	
Dayton's Bluff Elementary School	2409	1/10/2024	9:13:00 AM	553		69.6	18	1	
Dayton's Bluff Elementary School	2410	1/10/2024	9:16:00 AM	560		68.9	18.4	1	
Dayton's Bluff Elementary School	2002A	1/10/2024	10:13:00 AM	533		69.8	17.4	1	Fragrance Odor
Dayton's Bluff Elementary School	CRAFT ROOM	1/10/2024	10:23:00 AM	516		68.5	21.8	0	
Dayton's Bluff Elementary School	DANCE/AEROBICS	1/10/2024	10:58:00 AM	530		68.9	22.5	0	
Dayton's Bluff Elementary School	GYM 1	1/10/2024	10:18:00 AM	442		69.3	17.4	4	
Dayton's Bluff Elementary School	GYM 2	1/10/2024	10:19:00 AM	502		69.4	17.5	4	
Dayton's Bluff Elementary School	JAZZ ROOM	1/10/2024	11:02:00 AM	540		68.2	20.9	0	
Dayton's Bluff Elementary School	KITCHEN	1/10/2024	11:06:00 AM	523		69.6	20.2	0	
Dayton's Bluff Elementary School	MULTI PURPOSE ROOM	1/10/2024	10:27:00 AM	515		68.7	22.7	0	
Dayton's Bluff Elementary School	OUTDOORS	1/10/2024		384		26	81		
Dayton's Bluff Elementary School	R.S.P	1/10/2024	10:55:00 AM	522		69.8	20.4	0	
Dayton's Bluff Elementary School	REC TECH	1/10/2024	11:13:00 AM	533		70	17.9	0	
Dayton's Bluff Elementary School	THEATER	1/10/2024	11:09:00 AM	482		70.3	18.9	0	
Early Childhood Hub West	100	1/17/2024	11:12:00 AM	663	0.1	68.9	7.2	5	
Early Childhood Hub West	101	1/17/2024	11:15:00 AM	751	0.1	70.3	8.7	15	
Early Childhood Hub West	102	1/17/2024	11:14:00 AM	675	0.1	69.6	7.3	15	
Early Childhood Hub West	1001	1/17/2024	11:49:00 AM	560		70.7	8.5	2	
Early Childhood Hub West	1005	1/17/2024	11:51:00 AM	544		69.8	5.9	1	
Early Childhood Hub West	1006	1/17/2024	12:41:00 PM	538		69.4	6.1	0	
Early Childhood Hub West	1009	1/17/2024	11:45:00 AM	520		70	5.3	1	
Early Childhood Hub West	1011	1/17/2024	11:52:00 AM	537		69.6	5.8	0	
Early Childhood Hub West	1013	1/17/2024	11:47:00 AM	516		71.6	5.1	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Early Childhood Hub West	1014	1/17/2024	11:48:00 AM	521		72	4.8	1	
Early Childhood Hub West	1141	1/17/2024	10:58:00 AM	604	0.1	68.9	7.2	20	
Early Childhood Hub West	1142	1/17/2024	12:20:00 PM	581		69.1	7.1	20	
Early Childhood Hub West	1143	1/17/2024	11:02:00 AM	580	0.1	70.3	6.2	1	
Early Childhood Hub West	1144	1/17/2024	12:27:00 PM	525		69.3	6	0	
Early Childhood Hub West	1145	1/17/2024	11:00:00 AM	604	0.1	69.1	7.5	20	Stained Ceiling Tiles
Early Childhood Hub West	1146	1/17/2024	11:03:00 AM	567	0.1	69.8	6.3	1	
Early Childhood Hub West	1153	1/17/2024	11:08:00 AM	618	0.1	69.1	7.5	10	
Early Childhood Hub West	1154	1/17/2024	12:29:00 PM	528		69.4	6.1	0	
Early Childhood Hub West	1155	1/17/2024	11:10:00 AM	581		69.1	7	8	Fragrance Odor
Early Childhood Hub West	1162	1/17/2024	10:45:00 AM	760		61	13	12	
Early Childhood Hub West	1163	1/17/2024	12:38:00 PM	607		69.1	8	1	
Early Childhood Hub West	1201	1/17/2024	12:39:00 PM	569		69.3	7.3	0	
Early Childhood Hub West	1202	1/17/2024	12:33:00 PM	644		68.7	7.5	4	
Early Childhood Hub West	1203	1/17/2024	10:56:00 AM	621	0.2	68.7	6.5	3	
Early Childhood Hub West	1207	1/17/2024	10:53:00 AM	636	0.3	69.3	6.7	0	Stained Ceiling Tiles
Early Childhood Hub West	1208	1/17/2024	10:50:00 AM	731		68.9	10.2	20	
Early Childhood Hub West	2200	1/17/2024	11:55:00 AM	588		69.1	6.6	1	
Early Childhood Hub West	2244	1/17/2024	11:57:00 AM	536		69.3	5.9	0	
Early Childhood Hub West	2245	1/17/2024	12:14:00 PM	549		70	6.1	2	Plants: Kept Away From Return And Supply Vents
Early Childhood Hub West	2246	1/17/2024	11:59:00 AM	568		69.8	6.4	3	
Early Childhood Hub West	2253	1/17/2024	12:02:00 PM	539		70.7	6	2	Plants: Kept Away From Return And Supply Vents
Early Childhood Hub West	1162A	1/17/2024	12:43:00 PM	620	0.1	68.5	7.2	1	
Early Childhood Hub West	1202A	1/17/2024	12:35:00 PM	580		68.4	6.8	0	
Early Childhood Hub West	1202B	1/17/2024	12:34:00 PM	629		68.5	7.4	0	
Early Childhood Hub West	1209C	1/17/2024	12:37:00 PM	555		68.4	7.8	1	
Early Childhood Hub West	2245A	1/17/2024	12:18:00 PM	570		68.9	7	2	Plants: Kept Away From Return And Supply Vents
Early Childhood Hub West	2245B	1/17/2024	12:16:00 PM	539		69.1	6.2	0	
Early Childhood Hub West	2245C	1/17/2024	12:15:00 PM	569		70	6.6	2	Plants: Kept Away From Return And Supply Vents
Early Childhood Hub West	2253A	1/17/2024	12:09:00 PM	545		70.5	6	1	
Early Childhood Hub West	2253B	1/17/2024	12:04:00 PM	588		70.3	6.6	1	Fragrance Odor
Early Childhood Hub West	2253C	1/17/2024	12:11:00 PM	543		70.2	6.4	2	Plants: Kept Away From Return And Supply Vents
Early Childhood Hub West	OUTDOORS	1/17/2024		410	0.2	8	67		
Early Learning Hub East	104	1/9/2024	9:46:00 AM	346	2	68	21.6	1	
Early Learning Hub East	1002	1/9/2024	10:28:00 AM	480	2.6	69.6	21	2	Stained Ceiling Tiles
Early Learning Hub East	1003	1/9/2024	10:27:00 AM	463	2.6	69.4	21	0	
Early Learning Hub East	1006	1/9/2024	10:26:00 AM	447	2.6	69.1	20.4	0	Plants
Early Learning Hub East	1008	1/9/2024	10:25:00 AM	496	2.7	69.1	20.9	1	
Early Learning Hub East	1010	1/9/2024	10:24:00 AM	452	2.7	69.3	20	0	
Early Learning Hub East	1012	1/9/2024	10:23:00 AM	489	2.7	69.4	20.8	0	
Early Learning Hub East	1013	1/9/2024	10:18:00 AM	532	2.7	68.7	21.9	20	
Early Learning Hub East	1014	1/9/2024	10:21:00 AM	436	2.7	69.3	21.1	1	
Early Learning Hub East	1015	1/9/2024	10:22:00 AM	426	2.7	69.6	20.2	0	
Early Learning Hub East	1101	1/9/2024	10:29:00 AM	466	2.5	69.4	19.9	10	Stained Ceiling Tiles
Early Learning Hub East	1102	1/9/2024	10:30:00 AM	603	2.5	68.7	22.3	8	
Early Learning Hub East	1103	1/9/2024	10:33:00 AM	534	2.3	69.8	20.7	2	
Early Learning Hub East	1108	1/9/2024	10:06:00 AM	353	2.6	69.1	18.8	15	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Early Learning Hub East	1114	1/9/2024	10:35:00 AM	406	2.3	70.2	19.1	0	Stained Ceiling Tiles
Early Learning Hub East	1115	1/9/2024	10:32:00 AM	399	2.4	69.1	19.6	0	
Early Learning Hub East	1201	1/9/2024	10:52:00 AM	492	1.7	69.1	20.2	5	
Early Learning Hub East	1202	1/9/2024	10:15:00 AM	393	2.7	69.3	19.6	1	
Early Learning Hub East	1203	1/9/2024	10:51:00 AM	581	1.7	68.9	21.3	7	
Early Learning Hub East	1204	1/9/2024	10:36:00 AM	527	2.3	69.8	20.6	20	
Early Learning Hub East	1205	1/9/2024	10:39:00 AM	518	2.2	68.4	21.5	20	
Early Learning Hub East	1206	1/9/2024	10:37:00 AM	482	2.2	68.7	20.8	22	
Early Learning Hub East	1212	1/9/2024	10:16:00 AM	507	2.7	69.3	22.5	1	Plants
Early Learning Hub East	1301	1/9/2024	10:50:00 AM	483	1.7	69.8	20.2	16	Plants
Early Learning Hub East	1302	1/9/2024	10:40:00 AM	463	2.1	70.5	20.4	20	Plants
Early Learning Hub East	1303	1/9/2024	10:49:00 AM	475	1.8	69.6	20.4	20	Plants
Early Learning Hub East	1304	1/9/2024	10:41:00 AM	424	2	70.9	18.4	2	
Early Learning Hub East	1305	1/9/2024	10:47:00 AM	442	1.9	68.7	20.4	22	
Early Learning Hub East	1306	1/9/2024	10:53:00 AM	424	1.6	68.5	19.9	0	
Early Learning Hub East	1307	1/9/2024	10:46:00 AM	430	1.9	68.5	20	0	
Early Learning Hub East	1308	1/9/2024	10:42:00 AM	405	2.1	68.9	19.8	0	
Early Learning Hub East	1309	1/9/2024	10:45:00 AM	413	1.9	69.1	21.4	0	
Early Learning Hub East	1312	1/9/2024	10:44:00 AM	364	2	68.7	20.2	0	
Early Learning Hub East	1001 RECEPTION	1/9/2024	10:26:00 AM	461	2.6	69.1	20.5	2	
Early Learning Hub East	OUTDOORS	1/9/2024		271	1.3	29	90		
East African Elementary Magnet School	1001	11/30/2023	9:40:00 AM	745	0.4	70.2	23.4	1	
East African Elementary Magnet School	1003	11/30/2023	9:47:00 AM	805	0.5	70.7	23.6	1	Fragrance Odor, Bubbling/Peeling Paint
East African Elementary Magnet School	1004	11/30/2023	9:49:00 AM	875	0.4	70.7	24.2	0	
East African Elementary Magnet School	1102	11/30/2023	9:21:00 AM	747	0.7	72.9	21.3	4	Stained Ceiling Tiles
East African Elementary Magnet School	1103	11/30/2023	9:28:00 AM	705	0.8	72	21.4	0	
East African Elementary Magnet School	1105	11/30/2023	9:32:00 AM	801	0.7	73.6	20.5	1	
East African Elementary Magnet School	1106	11/30/2023	9:30:00 AM	706	0.7	72.7	20.9	0	
East African Elementary Magnet School	1109	11/30/2023	9:51:00 AM	706	0.5	70	22.9	0	
East African Elementary Magnet School	1110	11/30/2023	9:53:00 AM	757	0.5	69.6	23.4	0	
East African Elementary Magnet School	1112	11/30/2023	9:54:00 AM	727	0.4	71.1	22.7	1	
East African Elementary Magnet School	1113	11/30/2023	9:33:00 AM	914	0.7	72	24	20	
East African Elementary Magnet School	1114	11/30/2023	9:35:00 AM	819	0.7	72.5	23.5	8	Bubbling/Peeling Paint
East African Elementary Magnet School	1115	11/30/2023	9:39:00 AM	754	0.6	73	19.5	10	
East African Elementary Magnet School	1116	11/30/2023	10:59:00 AM	603		70.5	21.7	1	Stained Ceiling Tiles
East African Elementary Magnet School	1202	11/30/2023	9:23:00 AM	843	0.8	22.4		0	Stained Ceiling Tiles
East African Elementary Magnet School	1204	11/30/2023	9:17:00 AM	821	0.6	71.8	20.8	15	Stained Ceiling Tiles
East African Elementary Magnet School	1206	11/30/2023	9:15:00 AM	642	0.6	71.4	18.6	6	
East African Elementary Magnet School	1207	11/30/2023	9:18:00 AM	866	0.7	71.8	24.1	15	
East African Elementary Magnet School	1208	11/30/2023	9:13:00 AM	600	0.4	71.4	19.5	15	Stained Ceiling Tiles
East African Elementary Magnet School	1210	11/30/2023	11:11:00 AM	569	0.3	72.7	19.3	12	Fragrance Odor
East African Elementary Magnet School	2101	11/30/2023	10:12:00 AM	774	0.4	72	22.9	0	
East African Elementary Magnet School	2103	11/30/2023	10:18:00 AM	820	0.5	73.4	21.9	12	
East African Elementary Magnet School	2104	11/30/2023	10:21:00 AM	880	0.4	75.4	21.4	12	
East African Elementary Magnet School	2105	11/30/2023	10:23:00 AM	848	0.6	74.5	21.6	20	
East African Elementary Magnet School	2107	11/30/2023	10:08:00 AM	713	0.4	71.6	23	0	
East African Elementary Magnet School	2108	11/30/2023	10:10:00 AM	820	0.6	72	23	4	Fragrance Odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
East African Elementary Magnet School	2109	11/30/2023	10:03:00 AM	728	0.5	71.8	22.4	1	
East African Elementary Magnet School	2113	11/30/2023	9:55:00 AM	1443	0.6	71.8	24.8	15	
East African Elementary Magnet School	2114	11/30/2023	10:01:00 AM	808	0.6	72.3	22.4	3	
East African Elementary Magnet School	2116	11/30/2023	9:58:00 AM	670	0.5	74.3	18.2	0	Stained Ceiling Tiles
East African Elementary Magnet School	2201	11/30/2023	10:15:00 AM	1005	0.5	72.2	22.7	0	
East African Elementary Magnet School	3101	11/30/2023	10:44:00 AM	920	0.3	72.5	24.5	15	Plants
East African Elementary Magnet School	3102	11/30/2023	10:47:00 AM	758	0.5	71.2	23	0	
East African Elementary Magnet School	3103	11/30/2023	11:04:00 AM	726	0.3	72.5	21.9	0	
East African Elementary Magnet School	3105	11/30/2023	10:35:00 AM	726	0.3	72.9	22.1	0	Bubbling/Peeling Paint
East African Elementary Magnet School	3106	11/30/2023	10:41:00 AM	834	0.4	70.3	24.5	15	Bubbling/Peeling Paint
East African Elementary Magnet School	3107	11/30/2023	10:33:00 AM	775	0.4	70.9	23.4	4	
East African Elementary Magnet School	3110	11/30/2023	10:37:00 AM	734	0.4	72.1	22.7	0	Bubbling/Peeling Paint
East African Elementary Magnet School	3111	11/30/2023	10:24:00 AM	802	0.6	70	22.2	0	Stained Ceiling Tiles
East African Elementary Magnet School	3112	11/30/2023	10:30:00 AM	715	0.3	71.2	22.9	0	
East African Elementary Magnet School	3114	11/30/2023	10:28:00 AM	850	0.2	70.9	22.9	1	
East African Elementary Magnet School	3201	11/30/2023	10:48:00 AM	766	0.4	70.5	22.2	0	
East African Elementary Magnet School	4102	11/30/2023	11:08:00 AM	905	0.4	70.5	25.1	1	Food Odor
East African Elementary Magnet School	1212A	11/30/2023	9:04:00 AM	600	0.4	70.3	19.8	1	
East African Elementary Magnet School	2107A	11/30/2023	10:06:00 AM	734	0.5	71.1	22.8	0	
East African Elementary Magnet School	2112A	11/30/2023	10:09:00 AM	895	0.3	73	24.2	1	
East African Elementary Magnet School	CAFETERIA	11/30/2023	11:01:00 AM	722	0.2	71.6	23.9	40	
East African Elementary Magnet School	KITCHEN	11/30/2023	9:09:00 AM	632	0.4	70.7	21.4	2	
East African Elementary Magnet School	KITCHEN OFFICE	11/30/2023	9:12:00 AM	565	0.5	70	19.6	1	
East African Elementary Magnet School	LIBRARY	11/30/2023	10:51:00 AM	439	0.1	67.5	20.4	0	Stained Ceiling Tiles
East African Elementary Magnet School	OUTDOORS	11/30/2023		440	0.4	33	32.4		
Eastern Heights Elementary School	1001	1/22/2024	12:25:00 PM	679	0.1	73.6	12.7	3	
Eastern Heights Elementary School	1003	1/22/2024	2:21:00 PM	792	0.1	70.7	15.7	2	
Eastern Heights Elementary School	1004	1/22/2024	12:31:00 PM	794	0.2	74.1	14.5	6	
Eastern Heights Elementary School	1005	1/22/2024	12:33:00 PM	775	0.1	74.8	13	1	
Eastern Heights Elementary School	1006	1/22/2024	12:34:00 PM	761	0.2	74.8	12.4	1	
Eastern Heights Elementary School	1007	1/22/2024	12:36:00 PM	767	0.1	75	12.4	0	
Eastern Heights Elementary School	1008	1/22/2024	12:37:00 PM	755	0.1	74.7	12.8	1	Plants: Kept Away From Return And Supply Vents
Eastern Heights Elementary School	1010	1/22/2024	12:39:00 PM	738	0.1	74.3	12.7	2	
Eastern Heights Elementary School	1011	1/22/2024	12:41:00 PM	748	0.2	73.9	13.3	1	Plants: Kept Away From Return And Supply Vents
Eastern Heights Elementary School	1101	1/22/2024	12:42:00 PM	842	0.2	75.6	14	70	
Eastern Heights Elementary School	1108	1/22/2024	12:46:00 PM	892	0.2	78.8	13.7	6	
Eastern Heights Elementary School	1109	1/22/2024	12:45:00 PM	942	0.2	77.5	16.7	0	
Eastern Heights Elementary School	1201	1/22/2024	12:47:00 PM	664	0.2	73.9	11.8	16	
Eastern Heights Elementary School	1202	1/22/2024	12:51:00 PM	879	0.1	70.3	16.7	10	
Eastern Heights Elementary School	1207	1/22/2024	12:52:00 PM	661	0.1	69.8	13.3	0	
Eastern Heights Elementary School	1209	1/22/2024	12:54:00 PM	633	0.1	70.3	14.2	1	
Eastern Heights Elementary School	1301	1/22/2024	2:14:00 PM	747	0.1	71.2	15.1	14	Plants: Kept Away From Return And Supply Vents
Eastern Heights Elementary School	1302	1/22/2024	12:55:00 PM	1260	0.2	71.2	19	19	
Eastern Heights Elementary School	1303	1/22/2024	2:12:00 PM	845	0.1	70.7	14.8	14	
Eastern Heights Elementary School	1304	1/22/2024	12:58:00 PM	671	0.1	74.8	13.5	18	
Eastern Heights Elementary School	1305	1/22/2024	1:10:00 PM	599	0.1	69.6	14.6	19	Plants: Kept Away From Return And Supply Vents
Eastern Heights Elementary School	1307	1/22/2024	2:08:00 PM	614	0.1	71.6	13.7	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Eastern Heights Elementary School	1309	1/22/2024	1:17:00 PM	700	0.1	71.1	13.7	17	
Eastern Heights Elementary School	1311	1/22/2024	1:14:00 PM	812	0.1	70.5	15.7	12	
Eastern Heights Elementary School	1313	1/22/2024	2:21:00 PM	910	0.1	76.1	14.9	1	
Eastern Heights Elementary School	1403	1/22/2024	2:18:00 PM	558	0.1	69.8	13.9	2	
Eastern Heights Elementary School	1404	1/22/2024	12:49:00 PM	572	0.1	71.8	12.8	1	
Eastern Heights Elementary School	2101	1/22/2024	1:38:00 PM	797	0.1	73	14.8	3	
Eastern Heights Elementary School	2102	1/22/2024	1:47:00 PM	864	0.1	77.2	13.2	7	
Eastern Heights Elementary School	2201	1/22/2024	1:49:00 PM	654	0.1	73.9	11	1	
Eastern Heights Elementary School	2202	1/22/2024	1:51:00 PM	900	0.2	71.6	16.2	16	Plants: Kept Away From Return And Supply Vents
Eastern Heights Elementary School	2204	1/22/2024	1:53:00 PM	1084	0.1	70.7	16.4	17	
Eastern Heights Elementary School	2206	1/22/2024	1:08:00 PM	922	0.1	70.3	17	14	
Eastern Heights Elementary School	2207	1/22/2024	1:04:00 PM	758	0.1	70.9	14.6	6	
Eastern Heights Elementary School	2301	1/22/2024	1:19:00 PM	879	0.1	70.2	18	25	
Eastern Heights Elementary School	2302	1/22/2024	1:33:00 PM	860	0.2	71.4	16.9	0	
Eastern Heights Elementary School	2303	1/22/2024	1:23:00 PM	881	0.1	70.2	18.2	22	
Eastern Heights Elementary School	2304	1/22/2024	1:36:00 PM	979	0.1	71.8	18.8	2	Plants: Kept Away From Return And Supply Vents
Eastern Heights Elementary School	2305	1/22/2024	1:24:00 PM	676	0.1	70.2	14.7	6	
Eastern Heights Elementary School	2306	1/22/2024	1:39:00 PM	891	0.1	79.2	12.7	9	
Eastern Heights Elementary School	2307	1/22/2024	1:26:00 PM	699	0.1	72.3	14.2	14	
Eastern Heights Elementary School	2309	1/22/2024	1:00:00 PM	1102	0.1	70.7	17	15	
Eastern Heights Elementary School	2311	1/22/2024	1:31:00 PM	1741	0.1	71.8	18.1	12	
Eastern Heights Elementary School	2313	1/22/2024	1:34:00 PM	958	0.1	71.4	16.3	10	
Eastern Heights Elementary School	3101	1/22/2024	2:06:00 PM	784	0.1	71.4	15.4	0	
Eastern Heights Elementary School	3103	1/22/2024	1:55:00 PM	883	0.1	72.7	14.9	0	
Eastern Heights Elementary School	3104	1/22/2024	2:02:00 PM	839	0.1	71.8	15.1	1	
Eastern Heights Elementary School	3105	1/22/2024	2:03:00 PM	1019	0.1	71.4	16.1	2	
Eastern Heights Elementary School	3107	1/22/2024	2:04:00 PM	997	0.1	71.4	16.8	3	
Eastern Heights Elementary School	OUTDOORS	1/22/2024		508	0.2	29	75		
Education & Operations Services	1052	12/12/2023	10:16:00 AM	487	0.4	69.3	11.7	2	
Education & Operations Services	1054	12/12/2023	10:20:00 AM	478	0.3	68.9	11.5	1	Stained Ceiling Tiles
Education & Operations Services	1101	12/12/2023	11:03:00 AM	580	0.3	72	11.9	1	
Education & Operations Services	1102	12/12/2023	11:00:00 AM	532	0.3	72.3	10.8	0	
Education & Operations Services	1103	12/12/2023	10:58:00 AM	902	0.3	72.3	14.7	15	
Education & Operations Services	1104	12/12/2023	10:57:00 AM	883	0.3	72.3	13.7	22	
Education & Operations Services	1105	12/12/2023	10:56:00 AM	831	0.3	72.3	13.5	2	
Education & Operations Services	1108	12/12/2023	10:13:00 AM	482	0.4	69.6	11.2	0	
Education & Operations Services	1116	12/12/2023	10:19:00 AM	498	0.3	68.9	12	1	Stained Ceiling Tiles
Education & Operations Services	1121	12/12/2023	10:59:00 AM	730	0.3	72.1	11.4	3	
Education & Operations Services	1123	12/12/2023	11:04:00 AM	607	0.2	72.1	12.9	0	
Education & Operations Services	1124	12/12/2023	11:06:00 AM	741	0.2	73.8	14.6	1	
Education & Operations Services	1125	12/12/2023	11:07:00 AM	633	0.2	73.8	12.7	0	
Education & Operations Services	1126	12/12/2023	11:10:00 AM	580	0.4	73.8	12.2	0	
Education & Operations Services	1127	12/12/2023	11:05:00 AM	569	0.2	72.3	12.9	0	
Education & Operations Services	1128	12/12/2023	11:06:00 AM	601	0.2	72.7	12.8	0	
Education & Operations Services	1129	12/12/2023	11:08:00 AM	1160	0.3	74.1	14.9	1	
Education & Operations Services	1130	12/12/2023	11:09:00 AM	599	0.3	74.1	11.9	1	
Education & Operations Services	1131	12/12/2023	11:11:00 AM	518	0.3	73.6	13.3	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Education & Operations Services	1132	12/12/2023	11:12:00 AM	587	0.3	73.6	12	0	
Education & Operations Services	1133	12/12/2023	11:13:00 AM	563	0.3	73.4	11.8	0	
Education & Operations Services	1134	12/12/2023	11:14:00 AM	591	0.3	73.2	11.6	0	
Education & Operations Services	1140	12/12/2023	11:14:00 AM	569	0.2	73	11.3	3	
Education & Operations Services	1144	12/12/2023	11:41:00 AM	658	0.3	73.6	11.5	1	
Education & Operations Services	1145	12/12/2023	11:42:00 AM	509	0.2	73.6	9.9	0	
Education & Operations Services	1404	12/12/2023	10:26:00 AM	548	0.3	69.1	14.3	1	
Education & Operations Services	1405	12/12/2023	10:30:00 AM	818	0.4	71.1	15.6	9	
Education & Operations Services	1408	12/12/2023	10:29:00 AM	520	0.4	70.7	17.1	0	Stained Ceiling Tiles
Education & Operations Services	1409	12/12/2023	10:21:00 AM	505	0.3	68.9	14.6	0	
Education & Operations Services	1502	12/12/2023	11:59:00 AM	629	0.2	65.1	15.3	0	
Education & Operations Services	1503	12/12/2023	12:03:00 PM	622	0.2	67.3	14.5	1	
Education & Operations Services	1507	12/12/2023	9:16:00 AM	591	1.4	71.2	11.6	1	
Education & Operations Services	1605	12/12/2023	9:50:00 AM	510	0.8	70.7	14.5	1	
Education & Operations Services	1609	12/12/2023	9:36:00 AM	525	0.9	69.4	15.9	1	
Education & Operations Services	1612	12/12/2023	9:47:00 AM	559	0.8	70.9	14.7	2	
Education & Operations Services	1616	12/12/2023	9:40:00 AM	551	0.8	69.6	14.9	1	
Education & Operations Services	1617	12/12/2023	9:37:00 AM	500	0.8	69.1	14.1	0	
Education & Operations Services	1618	12/12/2023	9:39:00 AM	539	0.9	68.9	16.3	0	
Education & Operations Services	1620	12/12/2023	9:27:00 AM	522	0.8	68.4	15.6	0	
Education & Operations Services	1621	12/12/2023	9:26:00 AM	546	0.8	67.8	16.1	0	
Education & Operations Services	1622	12/12/2023	9:21:00 AM	629	2	66	15.7	2	
Education & Operations Services	1638	12/12/2023	9:41:00 AM	513	0.8	70.2	16	1	
Education & Operations Services	1639	12/12/2023	10:05:00 AM	603	0.5	70.5	13.1	10	
Education & Operations Services	1641	12/12/2023	10:03:00 AM	759	0.5	70.3	14.7	4	
Education & Operations Services	1642	12/12/2023	10:04:00 AM	648	0.6	70.3	14.3	4	
Education & Operations Services	1644	12/12/2023	10:02:00 AM	570	0.5	70.5	13.4	0	
Education & Operations Services	1645	12/12/2023	10:00:00 AM	652	0.6	70.5	13.9	1	
Education & Operations Services	1646	12/12/2023	11:50:00 AM	586	0.1	67.5	74.6	0	
Education & Operations Services	1647	12/12/2023	9:59:00 AM	560	0.6	70.3	13.1	0	
Education & Operations Services	1648	12/12/2023	9:58:00 AM	624	0.6	70.3	13.5	2	
Education & Operations Services	1649	12/12/2023	9:57:00 AM	754	0.5	70.5	14.8	2	
Education & Operations Services	1656	12/12/2023	9:54:00 AM	641	0.4	70.7	13.7	1	
Education & Operations Services	1658	12/12/2023	9:54:00 AM	549	0.6	70.5	13.1	0	
Education & Operations Services	1660	12/12/2023	10:10:00 AM	594	0.5	71.2	12.9	4	
Education & Operations Services	1661	12/12/2023	10:13:00 AM	526	0.8	70	16.9	0	
Education & Operations Services	1663	12/12/2023	10:07:00 AM	728	0.4	71.2	14.6	1	
Education & Operations Services	1664	12/12/2023	9:24:00 AM	507	0.8	67.6	16.4	0	
Education & Operations Services	1664	12/12/2023	10:06:00 AM	593	0.5	70.9	13.5	0	
Education & Operations Services	2100	12/12/2023	11:31:00 AM	659	0.2	70.9	13.7	15	
Education & Operations Services	2101	12/12/2023	11:21:00 AM	991	0.2	72.1	16.4	1	
Education & Operations Services	2102	12/12/2023	11:33:00 AM	1217	0.2	71.8	17.1	1	
Education & Operations Services	2103	12/12/2023	11:23:00 AM	646	0.2	72	13	2	
Education & Operations Services	2103	12/12/2023	11:31:00 AM	1134	0.2	71.2	18.4	1	
Education & Operations Services	2105	12/12/2023	11:24:00 AM	685	0.2	71.8	13.5	0	
Education & Operations Services	2107	12/12/2023	11:17:00 AM	589	0.2	73	11.6	0	
Education & Operations Services	2108	12/12/2023	11:30:00 AM	720	0.2	70.9	12.8	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Education & Operations Services	2109	12/12/2023	11:29:00 AM	1153	0.2	71.2	18.1	2	
Education & Operations Services	2110	12/12/2023	11:28:00 AM	692	0.2	71.4	14	0	
Education & Operations Services	2111	12/12/2023	11:27:00 AM	928	0.2	71.6	16.2	1	
Education & Operations Services	2112	12/12/2023	11:26:00 AM	904	0.2	71.6	15.3	1	
Education & Operations Services	2113	12/12/2023	11:25:00 AM	974	0.2	71.8	16.1	2	
Education & Operations Services	2117	12/12/2023	11:39:00 AM	675	0.3	73.6	12.5	2	
Education & Operations Services	2119	12/12/2023	11:15:00 AM	665	0.2	73	12.8	1	
Education & Operations Services	2120	12/12/2023	11:18:00 AM	767	0.2	73.2	14.1	1	
Education & Operations Services	2121	12/12/2023	11:19:00 AM	604	0.2	73	12.7	0	
Education & Operations Services	2122	12/12/2023	11:19:00 AM	593	0.2	73	12.8	0	
Education & Operations Services	2123	12/12/2023	11:57:00 AM	865	0.1	69.8	16.4	0	
Education & Operations Services	2124	12/12/2023	11:20:00 AM	582	0.2	72.3	11.3	0	
Education & Operations Services	2200	12/12/2023	11:34:00 AM	651	0.2	72.9	12.9	20	
Education & Operations Services	2202	12/12/2023	11:38:00 AM	579	0.2	73.4	11.6	0	
Education & Operations Services	2203	12/12/2023	11:58:00 AM	821	0.1	71.6	14.8	0	
Education & Operations Services	2204	12/12/2023	11:37:00 AM	941	0.3	73.2	15.1	1	
Education & Operations Services	2205	12/12/2023	11:36:00 AM	577	0.2	73.2	11.9	0	
Education & Operations Services	1114A	12/12/2023	10:17:00 AM	557	0.3	69.1	12.6	0	
Education & Operations Services	1116B	12/12/2023	10:18:00 AM	485	0.3	68.9	11.9	0	
Education & Operations Services	1404A	12/12/2023	10:24:00 AM	544	0.3	68.7	14.6	1	
Education & Operations Services	1408A	12/12/2023	10:26:00 AM	531	0.3	70.3	17.1	0	Stained Ceiling Tiles
Education & Operations Services	1506B	12/12/2023	11:48:00 AM	509	0.3	69.8	14.2	1	Stained Ceiling Tiles
Education & Operations Services	1508B	12/12/2023	11:43:00 AM	491	0.4	70.9	15.9	0	
Education & Operations Services	1605 OFFICE	12/12/2023	9:50:00 AM	1154	0.8	70.3	16.4	4	
Education & Operations Services	1605B	12/12/2023	9:49:00 AM	513	0.8	70.9	14	0	
Education & Operations Services	1607A	12/12/2023	9:44:00 AM	528	0.9	70.7	14.4	0	
Education & Operations Services	1609A	12/12/2023	9:29:00 AM	521	0.8	69.1	15.6	0	
Education & Operations Services	1609B	12/12/2023	9:35:00 AM	523	0.8	69.4	16.3	1	
Education & Operations Services	1609C	12/12/2023	9:36:00 AM	509	0.9	69.3	14.9	0	
Education & Operations Services	1611A	12/12/2023	9:18:00 AM	515	0.9	65.5	18.6	0	
Education & Operations Services	1612A	12/12/2023	9:48:00 AM	573	0.8	71.1	14.5	1	
Education & Operations Services	1613A	12/12/2023	9:46:00 AM	514	0.8	70.9	1.5	0	
Education & Operations Services	1613B	12/12/2023	9:43:00 AM	587	0.8	70.7	14.7	0	
Education & Operations Services	1620A	12/12/2023	9:32:00 AM	497	0.8	68.7	14.9	0	
Education & Operations Services	1649A	12/12/2023	9:56:00 AM	655	0.6	70.5	14.7	0	
Education & Operations Services	OUTDOORS	12/12/2023		472	0.6	21	70		
Education & Operations Services	RECEPTION	12/12/2023	11:01:00 AM	569	0.2	72.1	11.6	1	
E-STEM Middle School	1012	12/14/2023	1:06:00 PM	451		70.5	18.3	0	
E-STEM Middle School	1014	12/14/2023	10:31:00 AM	590		72.5	16	0	
E-STEM Middle School	1030	12/14/2023	9:31:00 AM	457		70.9	15.6	0	
E-STEM Middle School	1033	12/14/2023	10:29:00 AM	793	0.3	72.3	19.8	50	
E-STEM Middle School	1042	12/14/2023	9:34:00 AM	606		71.2	16.6	1	
E-STEM Middle School	1042	12/14/2023	10:25:00 AM	584		71.2	16	65	
E-STEM Middle School	1043	12/14/2023	9:39:00 AM	490		71.2	14.8	3	Aquariums (fish)
E-STEM Middle School	1046	12/14/2023	9:48:00 AM	453		70.9	14.7	0	Plants: Kept Away From Return And Supply Vents
E-STEM Middle School	1048	12/14/2023	9:43:00 AM	455		71.1	14.2	0	
E-STEM Middle School	1050	12/14/2023	9:44:00 AM	495		71.2	14.3	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
E-STEM Middle School	1052	12/14/2023	9:45:00 AM	497		70.7	14.9	1	Plants: Kept Away From Return And Supply Vents
E-STEM Middle School	1053	12/14/2023	9:47:00 AM	650		70.3	18	2	Fragrance Odor
E-STEM Middle School	1054	12/14/2023	1:17:00 PM	589		71.8	19.4	3	
E-STEM Middle School	1057	12/14/2023	9:42:00 AM	465		71.2	14.3	1	
E-STEM Middle School	1070	12/14/2023	9:37:00 AM	540		71.2	16.4	2	
E-STEM Middle School	1072	12/14/2023	9:39:00 AM	512		71.2	15.3	1	
E-STEM Middle School	1100	12/14/2023	10:34:00 AM	593		71.4	15.8	0	
E-STEM Middle School	1101	12/14/2023	10:40:00 AM	507		69.8	16	0	
E-STEM Middle School	1102	12/14/2023	10:36:00 AM	606		70.7	16.2	1	
E-STEM Middle School	1102	12/14/2023	10:39:00 AM	686		70.3	17.6	25	
E-STEM Middle School	1103	12/14/2023	10:37:00 AM	651		70.3	17.5	2	
E-STEM Middle School	1105	12/14/2023	10:38:00 AM	609		70.3	16.9	5	
E-STEM Middle School	1105	12/14/2023	10:45:00 AM	608		69.4	17.3	2	
E-STEM Middle School	1106	12/14/2023	10:46:00 AM	470		69.8	15.8	0	
E-STEM Middle School	1108	12/14/2023	10:48:00 AM	680		70	18.5	25	Stained Ceiling Tiles
E-STEM Middle School	1109	12/14/2023	10:53:00 AM	466		70.5	15.8	0	
E-STEM Middle School	1200	12/14/2023	1:07:00 PM	499		70.5	19	0	
E-STEM Middle School	1201	12/14/2023	10:43:00 AM	503		69.4	16	0	
E-STEM Middle School	1202	12/14/2023	1:14:00 PM	627		71.1	20.2	5	
E-STEM Middle School	1203	12/14/2023	1:13:00 PM	589		70.5	20.1	6	
E-STEM Middle School	1204	12/14/2023	1:14:00 PM	587		70.7	20.4	6	
E-STEM Middle School	1205	12/14/2023	1:12:00 PM	638		70.2	20.1	6	
E-STEM Middle School	1206	12/14/2023	1:15:00 PM	458		71.1	18.3	0	
E-STEM Middle School	1208	12/14/2023	1:10:00 PM	487		70	19.3	0	Plants
E-STEM Middle School	1209	12/14/2023	10:55:00 AM	521		70.2	19.3	1	Aquariums (fish)
E-STEM Middle School	1210	12/14/2023	10:58:00 AM	534		69.6	17.4	5	Plants: Kept Away From Return And Supply Vents
E-STEM Middle School	1211	12/14/2023	10:57:00 AM	524		69.8	17.3	2	
E-STEM Middle School	1300	12/14/2023	12:58:00 PM	583		70	20.1	0	
E-STEM Middle School	1303	12/14/2023	1:01:00 PM	651		70.2	21.8	5	
E-STEM Middle School	1304	12/14/2023	1:03:00 PM	676		70.5	20.9	20	Stained Ceiling Tiles
E-STEM Middle School	1305	12/14/2023	1:02:00 PM	620		70.3	20.6	3	Stained Ceiling Tiles
E-STEM Middle School	1306	12/14/2023	11:05:00 AM	560		71.2	16.5	3	
E-STEM Middle School	1306	12/14/2023	1:00:00 PM	644		70.2	20.7	5	
E-STEM Middle School	1308	12/14/2023	11:04:00 AM	790		71.6	18.5	20	
E-STEM Middle School	1309	12/14/2023	11:03:00 AM	671		71.2	17.7	10	
E-STEM Middle School	1310	12/14/2023	10:59:00 AM	630		70.5	17.6	2	
E-STEM Middle School	1311	12/14/2023	11:02:00 AM	695		70.9	18.2	4	
E-STEM Middle School	1400	12/14/2023	12:52:00 PM	602		70.2	19.7	0	
E-STEM Middle School	1402	12/14/2023	12:53:00 PM	652		70	20.4	4	
E-STEM Middle School	1403	12/14/2023	12:56:00 PM	622		69.6	20.5	1	
E-STEM Middle School	1405	12/14/2023	12:55:00 PM	675		70	20.6	2	
E-STEM Middle School	1405	12/14/2023	12:57:00 PM	722		69.6	21.5	8	
E-STEM Middle School	1406	12/14/2023	11:07:00 AM	1037		70.7	21.3	25	
E-STEM Middle School	1408	12/14/2023	12:48:00 PM	820		69.6	22.4	15	
E-STEM Middle School	1409	12/14/2023	12:51:00 PM	768		70	20.3	6	
E-STEM Middle School	1500	12/14/2023	9:49:00 AM	574		70.7	15.4	10	
E-STEM Middle School	1501	12/14/2023	9:52:00 AM	464		70.7	14.4	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
E-STEM Middle School	1502	12/14/2023	9:59:00 AM	522		71.2	14.7	3	
E-STEM Middle School	1503	12/14/2023	10:01:00 AM	522		69.8	16	0	
E-STEM Middle School	1504	12/14/2023	10:00:00 AM	540		70.5	15.1	1	
E-STEM Middle School	1505	12/14/2023	9:58:00 AM	567		71.8	15.1	6	
E-STEM Middle School	1506	12/14/2023	9:55:00 AM	510		71.6	14.6	7	
E-STEM Middle School	1508	12/14/2023	10:03:00 AM	662		70.9	17.4	30	
E-STEM Middle School	1509	12/14/2023	9:57:00 AM	792		72	17.3	2	
E-STEM Middle School	1600	12/14/2023	10:05:00 AM	611		70.9	16.1	1	
E-STEM Middle School	1601	12/14/2023	9:54:00 AM	464		70.7	14.3	0	
E-STEM Middle School	1602	12/14/2023	10:11:00 AM	677		70.3	18	10	
E-STEM Middle School	1603	12/14/2023	10:09:00 AM	740		70.5	19	3	Stained Ceiling Tiles
E-STEM Middle School	1604	12/14/2023	10:10:00 AM	622		70.3	16.7	15	Stained Ceiling Tiles
E-STEM Middle School	1605	12/14/2023	10:07:00 AM	690		70.5	18.8	5	
E-STEM Middle School	1606	12/14/2023	10:12:00 AM	476		70.2	15.1	1	
E-STEM Middle School	1608	12/14/2023	10:18:00 AM	752		72	18.9	15	
E-STEM Middle School	1609	12/14/2023	10:17:00 AM	641		70.7	17	4	
E-STEM Middle School	1610	12/14/2023	10:24:00 AM	627		70.9	16.8	7	
E-STEM Middle School	1611	12/14/2023	10:14:00 AM	645		70.5	17	2	
E-STEM Middle School	1710	12/14/2023	9:26:00 AM	707		65.8	21.5	2	
E-STEM Middle School	1800	12/14/2023	9:27:00 AM	446		68.7	16.1	20	
E-STEM Middle School	1804	12/14/2023	9:29:00 AM	471		69.8	15.4	1	
E-STEM Middle School	2006	12/14/2023	12:04:00 PM	490		68.9	18.6	0	
E-STEM Middle School	2012	12/14/2023	11:41:00 AM	694		71.1	19.9	40	
E-STEM Middle School	2040	12/14/2023	11:20:00 AM	691		71.6	20.2	2	
E-STEM Middle School	2044	12/14/2023	11:18:00 AM	620		71.8	17.5	2	
E-STEM Middle School	2053	12/14/2023	11:10:00 AM	567		71.6	16.6	4	
E-STEM Middle School	2055	12/14/2023	11:16:00 AM	576		71.8	16.4	10	
E-STEM Middle School	2101	12/14/2023	12:17:00 PM	464		69.6	19	0	
E-STEM Middle School	2102	12/14/2023	12:19:00 PM	520		69.4	19	2	
E-STEM Middle School	2103	12/14/2023	12:21:00 PM	497		69.1	19.2	3	
E-STEM Middle School	2104	12/14/2023	12:22:00 PM	539		68.7	20.1	15	
E-STEM Middle School	2105	12/14/2023	12:22:00 PM	559		68.9	19.8	6	
E-STEM Middle School	2106	12/14/2023	12:23:00 PM	448		69.1	18.6	1	
E-STEM Middle School	2108	12/14/2023	12:12:00 PM	566		69.3	19.7	2	Stained Ceiling Tiles
E-STEM Middle School	2109	12/14/2023	12:14:00 PM	557		69.3	20	1	
E-STEM Middle School	2110	12/14/2023	12:16:00 PM	522		69.4	19.3	5	
E-STEM Middle School	2111	12/14/2023	12:15:00 PM	545		69.3	19.6	2	Stained Ceiling Tiles
E-STEM Middle School	2201	12/14/2023	12:26:00 PM	633		70.2	19.9	1	
E-STEM Middle School	2202	12/14/2023	12:27:00 PM	562		70.3	19.4	2	Stained Ceiling Tiles
E-STEM Middle School	2203	12/14/2023	12:30:00 PM	600		70.5	22.4	1	
E-STEM Middle School	2204	12/14/2023	12:31:00 PM	589		70.7	20.5	15	
E-STEM Middle School	2205	12/14/2023	12:29:00 PM	601		70.5	20.1	2	
E-STEM Middle School	2206	12/14/2023	12:31:00 PM	610		70.9	20.5	10	
E-STEM Middle School	2208	12/14/2023	12:25:00 PM	720		69.6	22	20	
E-STEM Middle School	2301	12/14/2023	11:53:00 AM	636		71.4	19.8	1	
E-STEM Middle School	2302	12/14/2023	11:50:00 AM	707		71.6	19.3	4	Stained Ceiling Tiles
E-STEM Middle School	2304	12/14/2023	11:46:00 AM	781		71.4	20.6	30	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
E-STEM Middle School	2304	12/14/2023	11:48:00 AM	766		71.8	22.4	2	
E-STEM Middle School	2305	12/14/2023	11:49:00 AM	789		71.8	23.5	10	Stained Ceiling Tiles
E-STEM Middle School	2306	12/14/2023	11:51:00 AM	640		71.2	19	15	Plants: Kept Away From Return And Supply Vents
E-STEM Middle School	2308	12/14/2023	11:55:00 AM	747		71.2	20.6	40	Plants: Kept Away From Return And Supply Vents
E-STEM Middle School	2401	12/14/2023	12:02:00 PM	485		69.8	17.7	0	
E-STEM Middle School	2402	12/14/2023	12:39:00 PM	640		70.2	20.4	6	
E-STEM Middle School	2403	12/14/2023	12:43:00 PM	614		69.8	20.3	2	
E-STEM Middle School	2404	12/14/2023	12:44:00 PM	631		69.6	20.7	8	
E-STEM Middle School	2405	12/14/2023	12:42:00 PM	625		70	20.4	3	
E-STEM Middle School	2406	12/14/2023	12:00:00 PM	535		70.3	18.1	2	
E-STEM Middle School	2408	12/14/2023	12:47:00 PM	540		68.4	20	0	Stained Ceiling Tiles
E-STEM Middle School	2409	12/14/2023	12:46:00 PM	538		68.5	19.8	0	
E-STEM Middle School	2410	12/14/2023	12:44:00 PM	612		68.9	19.5	0	Stained Ceiling Tiles
E-STEM Middle School	2411	12/14/2023	12:46:00 PM	538		68.4	19.9	0	Stained Ceiling Tiles
E-STEM Middle School	2501	12/14/2023	11:21:00 AM	603		71.2	17	1	Musty Odor
E-STEM Middle School	2502	12/14/2023	12:39:00 PM	563		69.8	20.5	7	Plants: Kept Away From Return And Supply Vents
E-STEM Middle School	2503	12/14/2023	12:38:00 PM	564		70	20.4	3	
E-STEM Middle School	2504	12/14/2023	12:33:00 PM	563		70.3	19.5	2	
E-STEM Middle School	2505	12/14/2023	12:37:00 PM	566		70	20.6	2	
E-STEM Middle School	2506	12/14/2023	11:23:00 AM	450		70.7	16.4	0	
E-STEM Middle School	2508	12/14/2023	11:25:00 AM	600		70.2	19	2	
E-STEM Middle School	2509	12/14/2023	11:26:00 AM	605		70.2	25.7	3	
E-STEM Middle School	2510	12/14/2023	11:28:00 AM	571		70.2	18.9	20	
E-STEM Middle School	2511	12/14/2023	11:27:00 AM	602		70.2	19.5	4	
E-STEM Middle School	2515	12/14/2023	11:29:00 AM	461		69.8	16.8	0	Stained Ceiling Tiles
E-STEM Middle School	2601	12/14/2023	11:39:00 AM	626		69.8	18.1	1	
E-STEM Middle School	2602	12/14/2023	11:35:00 AM	692		70.2	20	25	
E-STEM Middle School	2603	12/14/2023	11:33:00 AM	698		69.8	20.3	4	
E-STEM Middle School	2604	12/14/2023	11:31:00 AM	679		69.8	19.9	1	
E-STEM Middle School	2605	12/14/2023	11:34:00 AM	691		70	20.1	5	Stained Ceiling Tiles
E-STEM Middle School	2606	12/14/2023	11:36:00 AM	462		70	17.8	1	
E-STEM Middle School	2608	12/14/2023	11:37:00 AM	705		69.8	20.3	30	
E-STEM Middle School	2014A	12/14/2023	11:45:00 AM	618		71.2	18.1	0	
E-STEM Middle School	2055 OFFICE	12/14/2023	11:17:00 AM	529		72	16.4	0	
E-STEM Middle School	OUTDOORS	12/14/2023		345		46	56		
EXPO Magnet	7	1/11/2024	8:32:00 AM	578	0.2	69.8	15.3	0	
EXPO Magnet	101	1/11/2024	8:34:00 AM	542	0.1	69.8	15.5	0	
EXPO Magnet	102	1/11/2024	8:36:00 AM	835	0.1	70	17.3	15	
EXPO Magnet	104	1/11/2024	8:37:00 AM	603		70.3	15.6	0	
EXPO Magnet	105	1/11/2024	8:39:00 AM	691		70.7	15.7	18	
EXPO Magnet	106	1/11/2024	9:27:00 AM	644		69.6	14.3	0	
EXPO Magnet	107	1/11/2024	8:40:00 AM	940	0.1	70.9	16.8	20	
EXPO Magnet	108	1/11/2024	8:42:00 AM	735	0.1	70.3	15.8	20	
EXPO Magnet	109	1/11/2024	8:44:00 AM	581	0.1	70	14.3	0	
EXPO Magnet	117	1/11/2024	8:18:00 AM	581		68.5	16.2	0	
EXPO Magnet	201	1/11/2024	9:25:00 AM	661		69.6	16.4	5	
EXPO Magnet	202	1/11/2024	8:47:00 AM	735		71.1	15.2	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
EXPO Magnet	205	1/11/2024	8:45:00 AM	741		70.3	15.6	1	
EXPO Magnet	1001	1/11/2024	9:17:00 AM	563		70.3	14.1	1	Fragrance Odor
EXPO Magnet	1003	1/11/2024	9:16:00 AM	476		70.2	12.7	0	
EXPO Magnet	1004	1/11/2024	9:13:00 AM	602		70.5	14	4	
EXPO Magnet	1005	1/11/2024	9:13:00 AM	492		70.5	14.5	0	
EXPO Magnet	1006	1/11/2024	9:10:00 AM	467		70.3	15.5	0	
EXPO Magnet	1007	1/11/2024	9:11:00 AM	509		70.5	14.6	0	Stained Ceiling Tiles
EXPO Magnet	1008	1/11/2024	9:15:00 AM	536		70.5	14.2	0	
EXPO Magnet	1101	1/11/2024	9:07:00 AM	939		70.2	18.8	2	Stained Ceiling Tiles
EXPO Magnet	1102	1/11/2024	9:04:00 AM	529	0.1	70.2	15.3	0	
EXPO Magnet	1103	1/11/2024	9:18:00 AM	680	0.1	70	16.8	9	
EXPO Magnet	1104	1/11/2024	8:52:00 AM	553		69.8	13.8	0	
EXPO Magnet	1105	1/11/2024	8:51:00 AM	874		69.8	17.7	15	Food Odor
EXPO Magnet	1106	1/11/2024	8:48:00 AM	692	0.1	69.4	15.3	0	
EXPO Magnet	1107	1/11/2024	9:20:00 AM	1114	0.1	69.8	16.9	12	
EXPO Magnet	1108	1/11/2024	9:21:00 AM	783		70	14.1	4	
EXPO Magnet	1109	1/11/2024	9:22:00 AM	955		70.2	16.7	20	
EXPO Magnet	1110	1/11/2024	9:24:00 AM	1016		70.2	18.8	20	Fragrance Odor
EXPO Magnet	1111	1/11/2024	9:29:00 AM	1239		69.6	21.1	16	
EXPO Magnet	1112	1/11/2024	9:31:00 AM	755		70.3	15.2	4	
EXPO Magnet	1113	1/11/2024	9:32:00 AM	862		70.9	15.3	12	
EXPO Magnet	1114	1/11/2024	10:25:00 AM	811		69.8	15.1	20	
EXPO Magnet	1115	1/11/2024	10:02:00 AM	849		69.3	15.8	20	Food Odor, Stained Ceiling Tiles
EXPO Magnet	1116	1/11/2024	9:33:00 AM	790		70.5	15.7	4	
EXPO Magnet	1117	1/11/2024	9:35:00 AM	1126	0.1	70.5	19.4	20	
EXPO Magnet	1201	1/11/2024	8:55:00 AM	582		70.5	13.5	30	
EXPO Magnet	1202	1/11/2024	8:59:00 AM	732	0.1	70.9	15.8	0	
EXPO Magnet	1205	1/11/2024	8:57:00 AM	610		72.1	13.4	1	Stained Ceiling Tiles
EXPO Magnet	1206	1/11/2024	9:03:00 AM	1037	0.1	70.7	18.1	20	
EXPO Magnet	1309	1/11/2024	9:01:00 AM	735	0.1	70.9	13.8	0	
EXPO Magnet	2102	1/11/2024	10:31:00 AM	887		70.5	15.5	28	Food Odor
EXPO Magnet	2103	1/11/2024	10:29:00 AM	1017		70.2	18.9	25	
EXPO Magnet	2104	1/11/2024	10:28:00 AM	924		69.8	14	4	
EXPO Magnet	2105	1/11/2024	10:26:00 AM	1081		69.6	16.3	20	
EXPO Magnet	2106	1/11/2024	9:55:00 AM	740		70.2	16.3	7	
EXPO Magnet	2107	1/11/2024	9:58:00 AM	702		70.2	16.3	6	
EXPO Magnet	2108	1/11/2024	9:59:00 AM	1091		70.3	19.1	18	
EXPO Magnet	2109	1/11/2024	10:00:00 AM	928		70.3	16.9	12	
EXPO Magnet	2111	1/11/2024	9:42:00 AM	765		69.8	16.3	0	
EXPO Magnet	2112	1/11/2024	9:42:00 AM	859		69.8	15.8	0	
EXPO Magnet	2113	1/11/2024	9:41:00 AM	754		69.8	16	0	
EXPO Magnet	2114	1/11/2024	9:36:00 AM	876		70	16.2	30	
EXPO Magnet	2115	1/11/2024	9:43:00 AM	1116		70.3	19.1	22	Fragrance Odor
EXPO Magnet	2116	1/11/2024	9:45:00 AM	796		70.7	17.3	20	
EXPO Magnet	2119	1/11/2024	9:47:00 AM	835		70	16.9	25	
EXPO Magnet	2120	1/11/2024	9:52:00 AM	1115	0.1	70.9	18.7	28	
EXPO Magnet	2121	1/11/2024	9:54:00 AM	1190		70.9	19.1	28	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
EXPO Magnet	2206	1/11/2024	9:50:00 AM	731		70.5	14	0	Stained Ceiling Tiles
EXPO Magnet	2207	1/11/2024	9:51:00 AM	763		70.9	14.7	0	
EXPO Magnet	2208	1/11/2024	9:53:00 AM	959	0.1	70.9	17.7	15	
EXPO Magnet	2210	1/11/2024	10:01:00 AM	885		70.3	18.1	20	
EXPO Magnet	1101A	1/11/2024	9:09:00 AM	733		70.5	16.2	0	
EXPO Magnet	1103A	1/11/2024	8:54:00 AM	585	0.1	69.3	14	0	
EXPO Magnet	2117B	1/11/2024	9:47:00 AM	590		70	13.3	0	
EXPO Magnet	OUTDOORS	1/11/2024		362	0.8	19	72		
Farnsworth Aerospace Lower	1001	11/29/2023	11:31:00 AM	654	0.2	71.1	19.5	3	
Farnsworth Aerospace Lower	1002	11/29/2023	12:25:00 PM	724	0.2	68.9	22	1	
Farnsworth Aerospace Lower	1003	11/29/2023	11:42:00 AM	650	0.2	71.1	19.6	1	
Farnsworth Aerospace Lower	1004	11/29/2023	11:33:00 AM	671	0.2	71.4	19.8	2	
Farnsworth Aerospace Lower	1005	11/29/2023	11:34:00 AM	677	0.2	71.4	19.8	1	
Farnsworth Aerospace Lower	1101	11/29/2023	1:01:00 PM	647	0.2	69.4	21.9	2	
Farnsworth Aerospace Lower	1102	11/29/2023	12:34:00 PM	671	0.2	69.6	22.9	6	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1103	11/29/2023	12:20:00 PM	612	0.2	68.9	21.5	30	
Farnsworth Aerospace Lower	1104	11/29/2023	2:19:00 PM	774	0.2	70.3	23.2	25	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1105	11/29/2023	1:50:00 PM	691	0.2	70.7	21.8	30	
Farnsworth Aerospace Lower	1201	11/29/2023	12:27:00 PM	661	0.2	70.3	20.6	1	Stained Ceiling Tiles
Farnsworth Aerospace Lower	1202	11/29/2023	11:27:00 AM	657	0.2	71.1	20.3	1	
Farnsworth Aerospace Lower	1204	11/29/2023	11:51:00 AM	725	0.2	71.2	20.6	4	
Farnsworth Aerospace Lower	1205	11/29/2023	1:49:00 PM	587	0.2	72.1	19.5	0	
Farnsworth Aerospace Lower	1206	11/29/2023	11:44:00 AM	790	0.2	69.1	22.4	12	Stained Ceiling Tiles
Farnsworth Aerospace Lower	1207	11/29/2023	11:50:00 AM	709	0.2	69.6	21.6	10	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1208	11/29/2023	11:43:00 AM	690	0.2	70	20.8	30	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	1300	11/29/2023	2:12:00 PM	569	0.2	69.4	22.1	0	
Farnsworth Aerospace Lower	1302	11/29/2023	11:18:00 AM	571	0.2	69.8	20.7	1	
Farnsworth Aerospace Lower	1304	11/29/2023	11:23:00 AM	486	0.2	68.9	21.9	15	
Farnsworth Aerospace Lower	1307	11/29/2023	12:31:00 PM	991	0.2	70.7	23.3	0	
Farnsworth Aerospace Lower	2101	11/29/2023	12:45:00 PM	755	0.2	71.1	21.1	25	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	2102	11/29/2023	12:41:00 PM	654	0.2	70.5	20.7	25	
Farnsworth Aerospace Lower	2103	11/29/2023	12:38:00 PM	713	0.2	69.6	22.3	25	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	2104	11/29/2023	12:36:00 PM	665	0.2	69.8	21.1	25	
Farnsworth Aerospace Lower	2105	11/29/2023	12:43:00 PM	680	0.2	71.4	20.4	20	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	2201	11/29/2023	12:13:00 PM	654	0.2	71.4	19.7	2	
Farnsworth Aerospace Lower	2203	11/29/2023	12:48:00 PM	612	0.2	71.8	19.2	2	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	2204	11/29/2023	11:56:00 AM	630	0.2	70	20.4	1	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	2205	11/29/2023	2:08:00 PM	631	0.2	70	20.4	0	Stained Ceiling Tiles
Farnsworth Aerospace Lower	2206	11/29/2023	11:52:00 AM	722	0.2	70.5	20.7	35	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	2208	11/29/2023	12:16:00 PM	625	0.2	71.4	19.5	1	
Farnsworth Aerospace Lower	2209	11/29/2023	12:17:00 PM	605	0.2	71.1	20.5	0	
Farnsworth Aerospace Lower	3101	11/29/2023	1:58:00 PM	900	0.2	71.1	24.1	30	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	3102	11/29/2023	2:04:00 PM	585	0.2	70	21.2	30	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	3103	11/29/2023	1:52:00 PM	848	0.2	70.3	23.9	30	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	3104	11/29/2023	12:07:00 PM	811	0.2	71.2	21.4	30	
Farnsworth Aerospace Lower	3105	11/29/2023	2:06:00 PM	614	0.2	69.6	21.5	25	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	3201	11/29/2023	12:02:00 PM	985	0.2	72.1	23.2	30	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Farnsworth Aerospace Lower	3203	11/29/2023	12:01:00 PM	974	0.2	72	22.2	30	
Farnsworth Aerospace Lower	3204	11/29/2023	12:50:00 PM	687	0.2	70	20.7	25	
Farnsworth Aerospace Lower	3206	11/29/2023	12:59:00 PM	467	0.2	68.7	19.3	1	
Farnsworth Aerospace Lower	3207	11/29/2023	12:58:00 PM	470	0.2	68.7	19.5	2	
Farnsworth Aerospace Lower	3208	11/29/2023	11:58:00 AM	1002	0.2	70.2	23.5	25	
Farnsworth Aerospace Lower	3209	11/29/2023	2:02:00 PM	588	0.2	70.2	20.4	0	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Lower	3210	11/29/2023	1:59:00 PM	936	0.2	70.7	24.5	30	
Farnsworth Aerospace Lower	3211	11/29/2023	12:05:00 PM	687	0.2	71.6	19.8	2	
Farnsworth Aerospace Lower	1203A	11/29/2023	2:14:00 PM	537	0.2	69.3	22	1	
Farnsworth Aerospace Lower	1301A	11/29/2023	11:20:00 AM	516	0.2	70.2	20.6	25	
Farnsworth Aerospace Lower	1301B	11/29/2023	11:22:00 AM	510	0.2	70	20.9	20	
Farnsworth Aerospace Lower	1304A	11/29/2023	11:25:00 AM	432	0.2	69.6	25.6	0	
Farnsworth Aerospace Lower	OUTDOORS	11/29/2023		343	0.2	43	59		
Farnsworth Aerospace Upper	303	1/9/2024	1:43:00 PM	519		72.9	19.9	2	Stained Ceiling Tiles
Farnsworth Aerospace Upper	401	1/9/2024	1:30:00 PM	585		68.2	22.7	0	
Farnsworth Aerospace Upper	402	1/9/2024	1:24:00 PM	630		70.9	21.1	0	
Farnsworth Aerospace Upper	403	1/9/2024	1:27:00 PM	628		68.5	23.4	1	
Farnsworth Aerospace Upper	406	1/9/2024	1:37:00 PM	688		69.4	21.5	0	
Farnsworth Aerospace Upper	408	1/9/2024	1:34:00 PM	402		68.2	19.9	0	
Farnsworth Aerospace Upper	1000	1/9/2024	10:26:00 AM	732		74.3	19.8	5	
Farnsworth Aerospace Upper	1001	1/9/2024	10:26:00 AM	631		73.9	18.6	2	
Farnsworth Aerospace Upper	1003	1/9/2024	10:30:00 AM	631		71.2	20.8	1	
Farnsworth Aerospace Upper	1004	1/9/2024	10:29:00 AM	756		72	21.1	5	
Farnsworth Aerospace Upper	1005	1/9/2024	10:28:00 AM	603		72.9	19	1	
Farnsworth Aerospace Upper	1006	1/9/2024	10:37:00 AM	620		71.8	21.7	2	Stained Ceiling Tiles
Farnsworth Aerospace Upper	1007	1/9/2024	10:39:00 AM	706		72.7	22.3	1	
Farnsworth Aerospace Upper	1008	1/9/2024	1:15:00 PM	668		74.1	20.7	1	
Farnsworth Aerospace Upper	1009	1/9/2024	10:37:00 AM	632		72.1	20.6	7	
Farnsworth Aerospace Upper	1010	1/9/2024	10:38:00 AM	749		72.5	22.7	3	
Farnsworth Aerospace Upper	1102	1/9/2024	11:24:00 AM	840		77.7	23.1	7	
Farnsworth Aerospace Upper	1103	1/9/2024	11:24:00 AM	572		77.5	18.3	1	
Farnsworth Aerospace Upper	1105	1/9/2024	11:27:00 AM	424		77	17.6	0	
Farnsworth Aerospace Upper	1106	1/9/2024	11:21:00 AM	1101	0.5	75.7	31.9	1	
Farnsworth Aerospace Upper	1204	1/9/2024	10:33:00 AM	552		71.4	19.7	3	
Farnsworth Aerospace Upper	1205	1/9/2024	10:30:00 AM	560		71.8	20.4	2	
Farnsworth Aerospace Upper	1303	1/9/2024	10:40:00 AM	631		72.5	20.6	1	
Farnsworth Aerospace Upper	1304	1/9/2024	11:21:00 AM	620		70.9	20.7	1	
Farnsworth Aerospace Upper	1305	1/9/2024	10:43:00 AM	638		71.8	20.9	1	
Farnsworth Aerospace Upper	1306	1/9/2024	11:19:00 AM	591		70.7	20.4	7	
Farnsworth Aerospace Upper	1307	1/9/2024	1:18:00 PM	497		72.7	19.2	1	
Farnsworth Aerospace Upper	1308	1/9/2024	11:17:00 AM	893		71.2	21.7	20	
Farnsworth Aerospace Upper	1309	1/9/2024	1:20:00 PM	452		72	19.2	0	
Farnsworth Aerospace Upper	1310	1/9/2024	11:16:00 AM	803		71.6	22.3	20	
Farnsworth Aerospace Upper	1311	1/9/2024	10:48:00 AM	449		71.6	19	0	
Farnsworth Aerospace Upper	1312	1/9/2024	11:06:00 AM	716		70.7	22.5	1	
Farnsworth Aerospace Upper	1313	1/9/2024	10:48:00 AM	533		71.1	20.4	9	
Farnsworth Aerospace Upper	1314	1/9/2024	11:05:00 AM	465		69.6	20.7	0	Stained Ceiling Tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Farnsworth Aerospace Upper	1315	1/9/2024	10:50:00 AM	547		71.2	20.7	8	
Farnsworth Aerospace Upper	1403	1/9/2024	10:55:00 AM	721		70.9	20.3	1	
Farnsworth Aerospace Upper	1405	1/9/2024	10:55:00 AM	817		70.7	21.3	25	
Farnsworth Aerospace Upper	1407	1/9/2024	10:58:00 AM	808		72	20.8	25	
Farnsworth Aerospace Upper	1409	1/9/2024	10:58:00 AM	757		69.6	21.8	20	
Farnsworth Aerospace Upper	2102	1/9/2024	11:36:00 AM	935		73.6	23.3	15	
Farnsworth Aerospace Upper	2103	1/9/2024	12:27:00 PM	662		71.4	24.6	0	
Farnsworth Aerospace Upper	2104	1/9/2024	11:30:00 AM	551		73.9	18.7	0	
Farnsworth Aerospace Upper	2106	1/9/2024	11:30:00 AM	579		72.5	19.5	0	
Farnsworth Aerospace Upper	2107	1/9/2024	11:33:00 AM	665		71.8	24.4	0	
Farnsworth Aerospace Upper	2202	1/9/2024	11:37:00 AM	691		71.1	22.7	10	
Farnsworth Aerospace Upper	2205	1/9/2024	11:46:00 AM	588		70.7	21	1	
Farnsworth Aerospace Upper	2206	1/9/2024	11:41:00 AM	792		72.5	21.5	1	
Farnsworth Aerospace Upper	2304	1/9/2024	11:46:00 AM	669		70.5	21.7	1	
Farnsworth Aerospace Upper	2305	1/9/2024	12:27:00 PM	548		71.2	20.6	0	
Farnsworth Aerospace Upper	2306	1/9/2024	11:48:00 AM	1413		70.9	28.7	15	
Farnsworth Aerospace Upper	2307	1/9/2024	12:25:00 PM	800		72	22.6	1	
Farnsworth Aerospace Upper	2308	1/9/2024	11:50:00 AM	603		71.2	21.4	1	
Farnsworth Aerospace Upper	2309	1/9/2024	12:24:00 PM	468		72.7	19	0	
Farnsworth Aerospace Upper	2310	1/9/2024	12:30:00 PM	462		70.7	20	0	
Farnsworth Aerospace Upper	2311	1/9/2024	11:56:00 AM	1292		70.3	27.7	6	
Farnsworth Aerospace Upper	2312	1/9/2024	11:53:00 AM	752		70.2	22.4	15	
Farnsworth Aerospace Upper	2313	1/9/2024	11:54:00 AM	640		69.4	23.1	1	
Farnsworth Aerospace Upper	3103	1/9/2024	12:56:00 PM	792		70.7	24.9	0	
Farnsworth Aerospace Upper	3104	1/9/2024	12:53:00 PM	532		69.4	20.6	0	
Farnsworth Aerospace Upper	3202	1/9/2024	12:53:00 PM	547		71.6	19.8	0	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Upper	3303	1/9/2024	12:46:00 PM	952		71.1	22.8	0	
Farnsworth Aerospace Upper	3305	1/9/2024	12:44:00 PM	1400		72.5	27.3	20	Fragrance Odor
Farnsworth Aerospace Upper	3306	1/9/2024	12:45:00 PM	1190		72.5	25.2	20	
Farnsworth Aerospace Upper	3307	1/9/2024	12:41:00 PM	1577		71.8	29.3	20	
Farnsworth Aerospace Upper	3308	1/9/2024	12:41:00 PM	1435		72.3	27	20	
Farnsworth Aerospace Upper	3309	1/9/2024	12:59:00 PM	861		71.4	22.1	1	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Upper	3310	1/9/2024	12:39:00 PM	875		70.9	23.2	1	
Farnsworth Aerospace Upper	3312	1/9/2024	12:38:00 PM	974		70.2	24.2	10	Stained Ceiling Tiles
Farnsworth Aerospace Upper	3399	1/9/2024	12:34:00 PM	824		70.2	22.6	0	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Upper	1006A	1/9/2024	1:13:00 PM	650		74.7	21	0	
Farnsworth Aerospace Upper	1204A	1/9/2024	10:34:00 AM	533		70.3	19.8	1	
Farnsworth Aerospace Upper	1204B	1/9/2024	10:31:00 AM	568		72	19.8	1	
Farnsworth Aerospace Upper	1303B	1/9/2024	10:42:00 AM	600		72	20.5	1	
Farnsworth Aerospace Upper	1402C	1/9/2024	11:01:00 AM	589		68.9	20.6	25	
Farnsworth Aerospace Upper	1420B	1/9/2024	10:51:00 AM	506		70.5	18.8	1	
Farnsworth Aerospace Upper	2202B	1/9/2024	11:41:00 AM	746		72.5	21.6	1	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Upper	2205A	1/9/2024	1:02:00 PM	875		71.4	25.4	2	Plants: Kept Away From Return And Supply Vents
Farnsworth Aerospace Upper	3205B	1/9/2024	12:51:00 PM	1040		72.1	41.1	1	
Farnsworth Aerospace Upper	OUTDOORS	1/9/2024		384		30	84		
Focus Beyond	1003	1/12/2024	10:39:00 AM	556		69.1	9.3	1	
Focus Beyond	1004	1/12/2024	10:38:00 AM	625	0.2	68.7	9.4	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Focus Beyond	1005	1/12/2024	10:36:00 AM	608	0.1	69.3	9	2	Fragrance Odor
Focus Beyond	1006	1/12/2024	10:36:00 AM	581	0.1	70.3	8.6	0	
Focus Beyond	1008	1/12/2024	10:34:00 AM	527	0.1	69.8	7.9	0	
Focus Beyond	1009	1/12/2024	10:35:00 AM	618	0.1	70.2	9.7	1	
Focus Beyond	1101	1/12/2024	10:26:00 AM	778	0.2	68.9	12.9	8	
Focus Beyond	1103	1/12/2024	10:25:00 AM	645	0.2	69.1	11.1	1	
Focus Beyond	1104	1/12/2024	10:23:00 AM	1147	0.2	69.6	10.7	6	
Focus Beyond	1105	1/12/2024	11:19:00 AM	680	0.6	68.5	11	3	Stained Ceiling Tiles
Focus Beyond	1106	1/12/2024	10:20:00 AM	1097	3.1	70	14	1	
Focus Beyond	1111	1/12/2024	9:59:00 AM	726		71.4	13.2	0	Odor Description: WD40 Odor
Focus Beyond	1200	1/12/2024	10:27:00 AM	692	0.2	68.9	10.6	2	
Focus Beyond	1201	1/12/2024	10:29:00 AM	770	0.1	68.9	11.4	8	
Focus Beyond	1202	1/12/2024	10:30:00 AM	711	0.1	69.3	10.6	0	
Focus Beyond	1203	1/12/2024	10:31:00 AM	722	0.1	70.2	10.5	4	
Focus Beyond	1204	1/12/2024	10:32:00 AM	633	0.1	70.3	9.3	1	
Focus Beyond	1300	1/12/2024	11:01:00 AM	787		68.4	11.4	2	
Focus Beyond	1301	1/12/2024	11:04:00 AM	751		68.2	12	6	
Focus Beyond	1302	1/12/2024	11:05:00 AM	1026		68	13.8	14	
Focus Beyond	1303	1/12/2024	11:06:00 AM	565		68	10.5	0	Plants: Kept Away From Return And Supply Vents
Focus Beyond	1304	1/12/2024	11:08:00 AM	703		68.7	10	1	Fragrance Odor
Focus Beyond	1400	1/12/2024	11:09:00 AM	624		68.4	10.4	2	
Focus Beyond	1401	1/12/2024	11:10:00 AM	803		69.1	11.4	8	Fragrance Odor
Focus Beyond	1402	1/12/2024	11:11:00 AM	719		69.4	9.5	1	
Focus Beyond	1403	1/12/2024	11:11:00 AM	779	0.1	69.1	12	8	
Focus Beyond	1404	1/12/2024	11:12:00 AM	784	0.1	68.7	11.6	6	
Focus Beyond	1501	1/12/2024	11:14:00 AM	624		70.9	7.3	1	Stained Ceiling Tiles
Focus Beyond	1502	1/12/2024	10:59:00 AM	572	0.1	68.2	9.1	0	
Focus Beyond	1503	1/12/2024	11:16:00 AM	531	0.1	69.1	8.9	1	
Focus Beyond	1506	1/12/2024	10:56:00 AM	510		68.9	8.2	0	
Focus Beyond	1508	1/12/2024	10:55:00 AM	499	0.1	68.7	8	0	
Focus Beyond	1512	1/12/2024	10:42:00 AM	594	0.1	69.4	10.7	6	
Focus Beyond	1513	1/12/2024	10:40:00 AM	486	0.1	69.3	8.1	0	
Focus Beyond	1600	1/12/2024	10:47:00 AM	558	0.1	71.6	7.5	1	
Focus Beyond	1601	1/12/2024	10:48:00 AM	554		72.3	8.4	0	Stained Ceiling Tiles
Focus Beyond	1602	1/12/2024	10:54:00 AM	519	0.1	70	8.2	1	
Focus Beyond	1603	1/12/2024	10:49:00 AM	574	0.1	70.5	7.9	5	
Focus Beyond	1604	1/12/2024	10:46:00 AM	541	0.1	70.3	7.9	0	
Focus Beyond	1605	1/12/2024	10:44:00 AM	541		70.2	9	0	Stained Ceiling Tiles
Focus Beyond	1606	1/12/2024	10:43:00 AM	647	0.1	69.6	9.5	0	
Focus Beyond	1106A	1/12/2024	10:22:00 AM	1018	1.3	70.2	13.5	2	
Focus Beyond	1506A	1/12/2024	10:57:00 AM	628		70	9.4	2	Fragrance Odor
Focus Beyond	OUTDOORS	1/12/2024		375	0.7	7	73		
Four Seasons A+ Elementary School	1002	1/10/2024	8:49:00 AM	611	0.5	68	19.3	1	
Four Seasons A+ Elementary School	1004	1/10/2024	10:36:00 AM	568	0.2	70.9	16.9	2	
Four Seasons A+ Elementary School	1006	1/10/2024	8:57:00 AM	532	0.6	69.6	17.4	0	
Four Seasons A+ Elementary School	1007	1/10/2024	8:55:00 AM	517	0.5	70.2	17.9	2	
Four Seasons A+ Elementary School	1008	1/10/2024	8:56:00 AM	526	0.6	69.8	17.3	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Four Seasons A+ Elementary School	1008	1/10/2024	9:09:00 AM	506	0.4	68.4	18.2	0	
Four Seasons A+ Elementary School	1009	1/10/2024	8:53:00 AM	547	0.6	69.4	18.3	1	
Four Seasons A+ Elementary School	1010	1/10/2024	8:51:00 AM	464	0.5	68.5	17.5	0	
Four Seasons A+ Elementary School	1101	1/10/2024	10:26:00 AM	489	0.2	68	18.2	30	
Four Seasons A+ Elementary School	1102	1/10/2024	8:46:00 AM	571	0.6	67.3	20.5	18	
Four Seasons A+ Elementary School	1103	1/10/2024	8:44:00 AM	498	0.5	67.5	18.9	16	
Four Seasons A+ Elementary School	1104	1/10/2024	8:43:00 AM	486	0.5	67.8	19	18	
Four Seasons A+ Elementary School	1106	1/10/2024	8:42:00 AM	422	0.5	68.1	18.3	1	
Four Seasons A+ Elementary School	1208	1/10/2024	8:40:00 AM	595	0.5	68	23.9	0	
Four Seasons A+ Elementary School	1211	1/10/2024	8:29:00 AM	625	0.3	68	23.7	0	
Four Seasons A+ Elementary School	1301	1/10/2024	8:58:00 AM	477	0.6	69.3	17.6	0	
Four Seasons A+ Elementary School	1304	1/10/2024	10:22:00 AM	598	0.2	68.9	18.3	20	
Four Seasons A+ Elementary School	1305	1/10/2024	9:07:00 AM	501	0.4	67.6	18	0	
Four Seasons A+ Elementary School	1306	1/10/2024	10:18:00 AM	605	0.2	68.7	18.4	1	
Four Seasons A+ Elementary School	1308	1/10/2024	9:32:00 AM	532	0.3	68.9	17.7	1	
Four Seasons A+ Elementary School	1309	1/10/2024	9:42:00 AM	541	0.2	69.1	17.5	2	
Four Seasons A+ Elementary School	1311	1/10/2024	9:40:00 AM	636	0.3	69.1	17.9	20	
Four Seasons A+ Elementary School	1401	1/10/2024	9:31:00 AM	545	0.4	68.4	17.9	0	
Four Seasons A+ Elementary School	1402	1/10/2024	9:30:00 AM	560	0.4	68.4	17.9	25	
Four Seasons A+ Elementary School	1403	1/10/2024	9:13:00 AM	511	0.4	68.4	17.8	0	
Four Seasons A+ Elementary School	1501	1/10/2024	8:48:00 AM	499	0.5	67.3	19.1	2	
Four Seasons A+ Elementary School	1503	1/10/2024	9:14:00 AM	643	0.4	68.5	18.6	16	
Four Seasons A+ Elementary School	1504	1/10/2024	9:16:00 AM	512	0.4	68.7	18	0	
Four Seasons A+ Elementary School	1506	1/10/2024	9:17:00 AM	526	0.4	68.2	17.9	15	
Four Seasons A+ Elementary School	1507	1/10/2024	9:19:00 AM	584	0.4	68.2	18.4	20	
Four Seasons A+ Elementary School	1508	1/10/2024	9:20:00 AM	586	0.4	68.4	17.9	1	
Four Seasons A+ Elementary School	1509	1/10/2024	9:21:00 AM	540	0.3	68.4	18.1	1	
Four Seasons A+ Elementary School	1510	1/10/2024	9:23:00 AM	561	0.4	68.2	18	1	
Four Seasons A+ Elementary School	1600	1/10/2024	9:29:00 AM	500	0.3	69.1	17.2	0	
Four Seasons A+ Elementary School	1604	1/10/2024	9:25:00 AM	548	0.3	67.8	17.3	12	
Four Seasons A+ Elementary School	1605	1/10/2024	9:27:00 AM	422	0.3	68.4	16.2	3	
Four Seasons A+ Elementary School	1606	1/10/2024	9:28:00 AM	588	0.3	68.9	18.3	7	
Four Seasons A+ Elementary School	2004	1/10/2024	9:43:00 AM	844	0.3	68.7	20.7	25	Plants: Kept Away From Return And Supply Vents
Four Seasons A+ Elementary School	2005	1/10/2024	9:58:00 AM	700	0.2	69.6	18.9	25	
Four Seasons A+ Elementary School	2006	1/10/2024	9:59:00 AM	602	0.2	69.8	18	6	
Four Seasons A+ Elementary School	2007	1/10/2024	9:59:00 AM	527	0.2	69.8	16.8	0	
Four Seasons A+ Elementary School	2008	1/10/2024	10:02:00 AM	615	0.2	69.3	17.8	4	
Four Seasons A+ Elementary School	2009	1/10/2024	10:01:00 AM	503	0.2	69.4	16.7	0	
Four Seasons A+ Elementary School	2010	1/10/2024	10:04:00 AM	751	0.2	69.4	19.4	20	
Four Seasons A+ Elementary School	2011	1/10/2024	10:25:00 AM	607	0.2	68.4	18.8	0	
Four Seasons A+ Elementary School	2301	1/10/2024	10:05:00 AM	535	0.2	69.3	16.9	0	
Four Seasons A+ Elementary School	2302	1/10/2024	10:07:00 AM	1173	0.2	69.3	22.8	20	
Four Seasons A+ Elementary School	2303	1/10/2024	10:17:00 AM	603	0.2	69.4	17.9	0	
Four Seasons A+ Elementary School	2304	1/10/2024	10:08:00 AM	965	0.2	69.4	21.3	25	
Four Seasons A+ Elementary School	2305	1/10/2024	10:09:00 AM	717	0.2	69.3	18.2	5	
Four Seasons A+ Elementary School	2501	1/10/2024	10:16:00 AM	540	0.2	69.3	16.9	4	
Four Seasons A+ Elementary School	2502	1/10/2024	10:15:00 AM	603	0.2	68.9	17.9	6	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Four Seasons A+ Elementary School	2503	1/10/2024	10:10:00 AM	532	0.2	69.8	17.7	0	
Four Seasons A+ Elementary School	2504	1/10/2024	10:13:00 AM	511	0.2	69.3	16.4	0	
Four Seasons A+ Elementary School	2506	1/10/2024	10:14:00 AM	622	0.2	68.9	18.5	20	
Four Seasons A+ Elementary School	1214A	1/10/2024	9:36:00 AM	505	0.3	68.7	17.6	0	
Four Seasons A+ Elementary School	1304A	1/10/2024	8:59:00 AM	455	0.5	67.5	17.3	0	
Four Seasons A+ Elementary School	1308B	1/10/2024	9:33:00 AM	510	0.3	68.9	17.6	0	
Four Seasons A+ Elementary School	1310A	1/10/2024	9:39:00 AM	504	0.3	68.7	17.2	0	
Four Seasons A+ Elementary School	1310B	1/10/2024	9:37:00 AM	515	0.3	68.9	17.9	0	Plants: Kept Away From Return And Supply Vents
Four Seasons A+ Elementary School	1501A	1/10/2024	9:11:00 AM	524	0.4	68.5	17.9	0	
Four Seasons A+ Elementary School	1510A	1/10/2024	9:24:00 AM	523	0.4	68	18.1	0	
Four Seasons A+ Elementary School	OUTDOORS	1/10/2024		292	0.5	23	89		
Frost Lake Elementary School	101	1/19/2024	11:39:00 AM	675		70.5	6.5	20	
Frost Lake Elementary School	105	1/19/2024	11:36:00 AM	707		70.7	11.3	80	
Frost Lake Elementary School	111	1/19/2024	11:24:00 AM	594		69.6	11.5	0	
Frost Lake Elementary School	1001	1/19/2024	1:30:00 PM	667		69.3	9	2	Fragrance Odor
Frost Lake Elementary School	1002	1/19/2024	1:33:00 PM	745		69.6	7.5	0	
Frost Lake Elementary School	1003	1/19/2024	1:32:00 PM	604		69.6	7.8	0	Odor Description: Rotten eggs/Sulfur , Fragrance Odor
Frost Lake Elementary School	1004	1/19/2024	1:31:00 PM	564		69.4	8.5	0	Food Odor
Frost Lake Elementary School	1008	1/19/2024	1:27:00 PM	610		69.8	7.2	2	
Frost Lake Elementary School	1101	1/19/2024	11:50:00 AM	807		71.8	8	30	
Frost Lake Elementary School	1102	1/19/2024	12:26:00 PM	670		70.2	6.7	2	Fragrance Odor
Frost Lake Elementary School	1104	1/19/2024	12:25:00 PM	630		70.2	7.6	3	Food Odor
Frost Lake Elementary School	1113	1/19/2024	12:27:00 PM	528		70	5.5	7	
Frost Lake Elementary School	1114	1/19/2024	12:22:00 PM	997		70.7	12.5	3	Stuffy Odor
Frost Lake Elementary School	1115	1/19/2024	12:29:00 PM	494		70	3.9	1	
Frost Lake Elementary School	1119	1/19/2024	1:26:00 PM	610		70.2	6.1	9	
Frost Lake Elementary School	1121	1/19/2024	1:25:00 PM	631		70.2	7.3	0	Fragrance Odor
Frost Lake Elementary School	1122	1/19/2024	12:19:00 PM	500		70.9	5.1	1	Food Odor
Frost Lake Elementary School	1123	1/19/2024	1:24:00 PM	701		70.3	7.7	0	
Frost Lake Elementary School	1201	1/19/2024	1:23:00 PM	580		70.7	5.8	0	
Frost Lake Elementary School	1203	1/19/2024	1:21:00 PM	811		71.1	7.6	0	
Frost Lake Elementary School	1205	1/19/2024	1:22:00 PM	547		71.1	8	0	
Frost Lake Elementary School	1207	1/19/2024	1:20:00 PM	971		71.1	10.3	20	
Frost Lake Elementary School	1209	1/19/2024	1:19:00 PM	949		70.5	9.3	20	
Frost Lake Elementary School	1210	1/19/2024	11:53:00 AM	1562		72.8	13.6	25	
Frost Lake Elementary School	1211	1/19/2024	1:18:00 PM	594		70.3	6.8	7	
Frost Lake Elementary School	1213	1/19/2024	1:17:00 PM	586		70.2	6.7	0	
Frost Lake Elementary School	1215	1/19/2024	1:15:00 PM	648		70.5	7.9	1	
Frost Lake Elementary School	1217	1/19/2024	1:14:00 PM	832		70.5	8.1	0	
Frost Lake Elementary School	1219	1/19/2024	1:15:00 PM	683		70.7	7.5	0	
Frost Lake Elementary School	1220	1/19/2024	11:56:00 AM	607		71.6	6	1	
Frost Lake Elementary School	1221	1/19/2024	1:12:00 PM	1186		70	11.3	25	
Frost Lake Elementary School	1222	1/19/2024	11:58:00 AM	552		70.9	5.2	4	
Frost Lake Elementary School	1223	1/19/2024	1:11:00 PM	476		70	5.3	0	
Frost Lake Elementary School	1224	1/19/2024	12:00:00 PM	1032		70.2	8.8	2	
Frost Lake Elementary School	1225	1/19/2024	1:09:00 PM	891		71.1	11.6	20	
Frost Lake Elementary School	1227	1/19/2024	1:08:00 PM	955		71.1	10.2	20	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Frost Lake Elementary School	1301	1/19/2024	12:37:00 PM	1237		71.6	10	20	
Frost Lake Elementary School	1303	1/19/2024	12:39:00 PM	1022		71.8	11.9	20	
Frost Lake Elementary School	1305	1/19/2024	12:41:00 PM	714		71.8	7.4	0	
Frost Lake Elementary School	1307	1/19/2024	12:43:00 PM	616		71.8	5.8	0	
Frost Lake Elementary School	1309	1/19/2024	12:44:00 PM	953		70.9	9.8	20	
Frost Lake Elementary School	1310	1/19/2024	12:09:00 PM	1222		71.2	12.1	20	
Frost Lake Elementary School	1311	1/19/2024	12:47:00 PM	884		70.9	10.1	20	
Frost Lake Elementary School	1313	1/19/2024	12:49:00 PM	573		70.9	6.6	0	
Frost Lake Elementary School	1315	1/19/2024	12:50:00 PM	655		70.5	7.6	1	
Frost Lake Elementary School	1320	1/19/2024	12:07:00 PM	581		71.1	5.3	0	
Frost Lake Elementary School	1321	1/19/2024	12:53:00 PM	681		70.3	6.9	1	
Frost Lake Elementary School	1322	1/19/2024	12:06:00 PM	546		70.7	6.5	0	
Frost Lake Elementary School	1323	1/19/2024	12:55:00 PM	718		70.7	10.7	0	
Frost Lake Elementary School	1324	1/19/2024	12:04:00 PM	604		70.3	7	1	
Frost Lake Elementary School	1352	1/19/2024	12:03:00 PM	559		69.8	6.1	0	
Frost Lake Elementary School	1355	1/19/2024	12:17:00 PM	540		70.2	6.4	0	
Frost Lake Elementary School	1357	1/19/2024	12:18:00 PM	579		70.3	6.4	0	
Frost Lake Elementary School	1401	1/19/2024	1:07:00 PM	790		70.7	9.5	20	
Frost Lake Elementary School	1402	1/19/2024	12:15:00 PM	744		70.3	9.1	0	
Frost Lake Elementary School	1403	1/19/2024	1:06:00 PM	723		70.9	8	3	
Frost Lake Elementary School	1405	1/19/2024	1:05:00 PM	898		71.2	10	10	
Frost Lake Elementary School	1409	1/19/2024	1:04:00 PM	687		71.1	7.5	0	
Frost Lake Elementary School	1411	1/19/2024	1:03:00 PM	925		71.1	11.1	20	
Frost Lake Elementary School	1415	1/19/2024	1:03:00 PM	770		70.5	10.3	20	
Frost Lake Elementary School	1416	1/19/2024	12:14:00 PM	841		70.2	10.7	20	Fragrance Odor
Frost Lake Elementary School	1417	1/19/2024	1:01:00 PM	713		70.7	7.4	0	
Frost Lake Elementary School	1419	1/19/2024	1:00:00 PM	651		71.1	7.1	0	
Frost Lake Elementary School	1421	1/19/2024	1:00:00 PM	723		70.7	8.4	1	Food Odor
Frost Lake Elementary School	1423	1/19/2024	12:59:00 PM	730		70.5	8.7	0	
Frost Lake Elementary School	1425	1/19/2024	12:58:00 PM	731		70.7	8.4	2	
Frost Lake Elementary School	1427	1/19/2024	12:57:00 PM	708		70.5	7.8	0	
Frost Lake Elementary School	1428	1/19/2024	12:12:00 PM	784		70.3	8.9	0	
Frost Lake Elementary School	1429	1/19/2024	12:56:00 PM	653		70.3	7.3	0	
Frost Lake Elementary School	1501	1/19/2024	11:42:00 AM	857		70.7	6.2	1	
Frost Lake Elementary School	1503	1/19/2024	11:45:00 AM	886		70.9	9	25	
Frost Lake Elementary School	1504	1/19/2024	11:46:00 AM	571		71.2	5.6	0	
Frost Lake Elementary School	1505	1/19/2024	12:30:00 PM	609		70.3	6.5	25	Plants
Frost Lake Elementary School	1506	1/19/2024	11:48:00 AM	818		71.4	8.1	8	
Frost Lake Elementary School	1507	1/19/2024	12:33:00 PM	889		71.1	8	20	
Frost Lake Elementary School	1508	1/19/2024	11:49:00 AM	536		71.4	5.2	0	
Frost Lake Elementary School	1509	1/19/2024	12:34:00 PM	944		72	10.8	20	
Frost Lake Elementary School	1513	1/19/2024	12:36:00 PM	719		72.1	7.3	20	
Frost Lake Elementary School	0101A	1/19/2024	11:41:00 AM	629		70.7	6.5	0	
Frost Lake Elementary School	0106A	1/19/2024	11:37:00 AM	677		70.7	10.8	3	
Frost Lake Elementary School	0106C	1/19/2024	11:38:00 AM	802		71.1	10.3	0	
Frost Lake Elementary School	1008C	1/19/2024	1:28:00 PM	553		69.3	7.4	0	
Frost Lake Elementary School	1222A	1/19/2024	11:59:00 AM	526		70.9	5.2	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Frost Lake Elementary School	1224A	1/19/2024	12:02:00 PM	803		69.8	7.6	1	
Frost Lake Elementary School	OUTDOORS	1/19/2024		403		3	66		
Global Arts Plus Lower	101	12/13/2023	10:51:00 AM	523		68.5	17	1	
Global Arts Plus Lower	1001	12/13/2023	10:53:00 AM	484		70	13	3	
Global Arts Plus Lower	1002	12/13/2023	11:01:00 AM	413		73	11.2	0	Fragrance Odor
Global Arts Plus Lower	1004	12/13/2023	11:00:00 AM	439		72.3	11.3	3	
Global Arts Plus Lower	1006	12/13/2023	10:56:00 AM	484		70	12.8	1	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	1007	12/13/2023	11:09:00 AM	573		69.6	14.8	3	
Global Arts Plus Lower	1008	12/13/2023	10:57:00 AM	406		71.4	12	0	
Global Arts Plus Lower	1102	12/13/2023	11:20:00 AM	745		71.4	16.5	25	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	1103	12/13/2023	11:24:00 AM	588		71.4	14.3	0	Stained Ceiling Tiles
Global Arts Plus Lower	1104	12/13/2023	11:25:00 AM	687		71.2	16.4	20	
Global Arts Plus Lower	1105	12/13/2023	11:23:00 AM	949		72.5	17.8	12	
Global Arts Plus Lower	1107	12/13/2023	11:27:00 AM	633		71.8	16.2	10	
Global Arts Plus Lower	1201	12/13/2023	11:09:00 AM	482		70	15.5	1	
Global Arts Plus Lower	1301	12/13/2023	11:03:00 AM	514		68.9	15	25	
Global Arts Plus Lower	1403	12/13/2023	11:13:00 AM	911		70.9	17.7	25	
Global Arts Plus Lower	1405	12/13/2023	11:15:00 AM	885		70	18.4	25	
Global Arts Plus Lower	1411	12/13/2023	11:17:00 AM	659		68.9	17	20	
Global Arts Plus Lower	1501	12/13/2023	12:03:00 PM	703		70.3	20.3	80	
Global Arts Plus Lower	1505	12/13/2023	11:19:00 AM	441		72	16.2	1	
Global Arts Plus Lower	2104	12/13/2023	11:50:00 AM	705		71.8	16.9	2	
Global Arts Plus Lower	2106	12/13/2023	11:54:00 AM	725		71.8	15.6	2	
Global Arts Plus Lower	2108	12/13/2023	11:57:00 AM	452		70.7	14.6	0	
Global Arts Plus Lower	2109	12/13/2023	11:55:00 AM	808		70.9	17	20	
Global Arts Plus Lower	2204	12/13/2023	11:32:00 AM	843		70.7	17.5	25	
Global Arts Plus Lower	2206	12/13/2023	11:33:00 AM	602		71.2	15.1	1	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2208	12/13/2023	11:58:00 AM	528		71.2	14.9	0	
Global Arts Plus Lower	2401	12/13/2023	11:37:00 AM	1010		70.7	19.1	25	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2403	12/13/2023	11:34:00 AM	987		71.1	19.2	25	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2404	12/13/2023	11:38:00 AM	612		70.5	16.4	1	
Global Arts Plus Lower	2409	12/13/2023	11:39:00 AM	875		70.3	18.5	20	
Global Arts Plus Lower	2411	12/13/2023	11:41:00 AM	658		70	17.4	9	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2412	12/13/2023	12:01:00 PM	790		71.6	17.9	2	
Global Arts Plus Lower	2413	12/13/2023	11:43:00 AM	945		70.2	19.6	20	
Global Arts Plus Lower	2414	12/13/2023	11:49:00 AM	740		70.5	17.5	8	
Global Arts Plus Lower	2415	12/13/2023	11:47:00 AM	961		70.5	19.6	20	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	2416	12/13/2023	11:46:00 AM	750		70.3	18.6	1	Fragrance Odor
Global Arts Plus Lower	2417	12/13/2023	11:44:00 AM	963		70.2	19.9	15	
Global Arts Plus Lower	3106	12/13/2023	12:31:00 PM	720		71.4	16.9	1	
Global Arts Plus Lower	3107	12/13/2023	12:34:00 PM	1044		70.9	19.5	25	
Global Arts Plus Lower	3108	12/13/2023	12:40:00 PM	625		70.9	16.9	0	
Global Arts Plus Lower	3109	12/13/2023	12:34:00 PM	1013		70.2	19	0	
Global Arts Plus Lower	3202	12/13/2023	12:30:00 PM	472		72.1	14	0	
Global Arts Plus Lower	3204	12/13/2023	12:27:00 PM	850		71.4	20.8	0	
Global Arts Plus Lower	3206	12/13/2023	12:24:00 PM	532		70.7	14.6	8	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	3212	12/13/2023	12:10:00 PM	682		69.8	17.5	1	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Global Arts Plus Lower	3401	12/13/2023	12:21:00 PM	474		70	15.3	0	Live Animals: Kept Away From Return And Supply Vents, Plants: Kept Aw
Global Arts Plus Lower	3403	12/13/2023	12:19:00 PM	459		69.6	15.2	0	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Lower	3404	12/13/2023	12:16:00 PM	799		70	18.7	5	Fragrance Odor, Stained Ceiling Tiles
Global Arts Plus Lower	3409	12/13/2023	12:41:00 PM	586		69.8	17.4	0	
Global Arts Plus Lower	3411	12/13/2023	12:08:00 PM	850		69.8	19.9	6	
Global Arts Plus Lower	3412	12/13/2023	12:12:00 PM	845		71.6	19.7	8	
Global Arts Plus Lower	3413	12/13/2023	12:06:00 PM	857		69.6	19.4	30	
Global Arts Plus Lower	3415	12/13/2023	12:13:00 PM	760		72.3	17.1	30	
Global Arts Plus Lower	3416	12/13/2023	12:43:00 PM	619		70.2	17.7	0	
Global Arts Plus Lower	3417	12/13/2023	12:14:00 PM	863		70.7	19.7	25	Stained Ceiling Tiles
Global Arts Plus Lower	3418	12/13/2023	12:15:00 PM	460		70.2	15.5	0	
Global Arts Plus Lower	1001A	12/13/2023	10:59:00 AM	510		72	13	0	
Global Arts Plus Lower	1007A	12/13/2023	11:11:00 AM	460		71.4	13.1	0	
Global Arts Plus Lower	1301A	12/13/2023	11:07:00 AM	515		69.1	15	0	
Global Arts Plus Lower	2104A	12/13/2023	11:53:00 AM	545		72.1	14.9	0	
Global Arts Plus Lower	3204A	12/13/2023	12:29:00 PM	510		72.9	15.9	0	
Global Arts Plus Lower	OUTDOORS	12/13/2023		335	0.3	37	52		
Global Arts Plus Upper	1002	12/12/2023	10:27:00 AM	414		68.7	13.2	4	
Global Arts Plus Upper	1004	12/12/2023	1:24:00 PM	453		69.1	13.1	0	Stained Ceiling Tiles
Global Arts Plus Upper	1005	12/12/2023	10:36:00 AM	423		68.7	13.1	0	
Global Arts Plus Upper	1006	12/12/2023	10:34:00 AM	482		68.7	13.6	1	
Global Arts Plus Upper	1007	12/12/2023	10:32:00 AM	410		68.4	12.4	0	
Global Arts Plus Upper	1008	12/12/2023	10:28:00 AM	440		68.2	13.4	2	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	1101	12/12/2023	10:38:00 AM	398		69.3	11.8	1	
Global Arts Plus Upper	1104	12/12/2023	10:39:00 AM	500		69.1	13.8	4	
Global Arts Plus Upper	1106	12/12/2023	1:26:00 PM	781		68.5	18	0	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	1120	12/12/2023	11:45:00 AM	766		66.9	18.6	75	
Global Arts Plus Upper	1201	12/12/2023	10:51:00 AM	540		68.7	14	25	
Global Arts Plus Upper	1203	12/12/2023	1:29:00 PM	381		68.9	11.7	0	
Global Arts Plus Upper	1207	12/12/2023	10:53:00 AM	642		68.9	15.9	25	
Global Arts Plus Upper	1209	12/12/2023	10:56:00 AM	768		69.1	16.2	25	
Global Arts Plus Upper	1211	12/12/2023	1:49:00 PM	432		69.1	13.2	0	
Global Arts Plus Upper	1217	12/12/2023	1:51:00 PM	520		68.5	14.2	0	
Global Arts Plus Upper	1219	12/12/2023	1:30:00 PM	739		68.5	15.6	25	
Global Arts Plus Upper	1221	12/12/2023	11:06:00 AM	626		70.7	14.3	20	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	1223	12/12/2023	11:10:00 AM	419		71.6	12.7	0	
Global Arts Plus Upper	1250	12/12/2023	11:04:00 AM	468		71.2	13.3	0	
Global Arts Plus Upper	1255	12/12/2023	10:57:00 AM	505		69.8	14.2	2	
Global Arts Plus Upper	1257	12/12/2023	11:01:00 AM	466		71.4	13.1	1	
Global Arts Plus Upper	1310	12/12/2023	10:42:00 AM	507		68.7	15.6	1	
Global Arts Plus Upper	1320	12/12/2023	12:32:00 PM	538		68.5	14.9	6	
Global Arts Plus Upper	1330	12/12/2023	1:41:00 PM	409		68.2	12.3	0	
Global Arts Plus Upper	1332	12/12/2023	1:40:00 PM	586		67.8	16.4	1	
Global Arts Plus Upper	1334	12/12/2023	1:38:00 PM	463		65.3	17.7	10	
Global Arts Plus Upper	1401	12/12/2023	1:19:00 PM	504		69.3	12.1	2	
Global Arts Plus Upper	1402	12/12/2023	1:17:00 PM	684		69.3	15.3	25	
Global Arts Plus Upper	1405	12/12/2023	10:13:00 AM	519		70.3	15	1	Stained Ceiling Tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Global Arts Plus Upper	1406	12/12/2023	1:16:00 PM	501		68.9	13.7	1	
Global Arts Plus Upper	1408	12/12/2023	12:35:00 PM	405		68.5	11.8	1	
Global Arts Plus Upper	1410	12/12/2023	1:14:00 PM	393		68.9	11.6	0	
Global Arts Plus Upper	1412	12/12/2023	10:14:00 AM	391		70.2	12.2	1	
Global Arts Plus Upper	1414	12/12/2023	12:33:00 PM	450		68.7	12.3	1	
Global Arts Plus Upper	1501	12/12/2023	10:21:00 AM	519		68.9	14.9	3	Stained Ceiling Tiles
Global Arts Plus Upper	1503	12/12/2023	10:16:00 AM	618		70.3	15.5	30	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	1504	12/12/2023	1:22:00 PM	701		69.3	14.4	1	
Global Arts Plus Upper	1507	12/12/2023	12:36:00 PM	588		68.9	14.1	1	
Global Arts Plus Upper	1510	12/12/2023	12:38:00 PM	474		70	14.8	2	
Global Arts Plus Upper	1511	12/12/2023	1:20:00 PM	580		69.4	13.2	10	
Global Arts Plus Upper	2101	12/12/2023	12:51:00 PM	518		70	13.3	25	
Global Arts Plus Upper	2102	12/12/2023	12:21:00 PM	505		69.3	14.5	1	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	2120	12/12/2023	12:16:00 PM	413		70	12.2	0	
Global Arts Plus Upper	2122	12/12/2023	12:20:00 PM	413		69.8	12.2	35	
Global Arts Plus Upper	2201	12/12/2023	12:54:00 PM	499		69.8	13.4	30	
Global Arts Plus Upper	2205	12/12/2023	11:24:00 AM	555		69.6	13.8	2	
Global Arts Plus Upper	2206	12/12/2023	11:12:00 AM	584		69.3	15.2	5	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	2207	12/12/2023	11:22:00 AM	730		70	15.5	3	
Global Arts Plus Upper	2210	12/12/2023	12:59:00 PM	587		69.6	14.4	7	Stained Ceiling Tiles
Global Arts Plus Upper	2215	12/12/2023	11:20:00 AM	955		69.4	18.8	25	
Global Arts Plus Upper	2217	12/12/2023	11:18:00 AM	816		69.3	17.2	30	
Global Arts Plus Upper	2219	12/12/2023	11:15:00 AM	677		69.1	15.3	4	
Global Arts Plus Upper	2301	12/12/2023	11:25:00 AM	650		70.3	14.5	1	
Global Arts Plus Upper	2305	12/12/2023	12:13:00 PM	652		70.7	14.6	15	
Global Arts Plus Upper	2310	12/12/2023	11:43:00 AM	565		68.5	16.8	15	
Global Arts Plus Upper	2330	12/12/2023	12:24:00 PM	425		68.7	14	15	Stained Ceiling Tiles
Global Arts Plus Upper	2402	12/12/2023	11:32:00 AM	475		68.5	12.8	2	
Global Arts Plus Upper	2405	12/12/2023	12:13:00 PM	576		71.4	16.6	0	
Global Arts Plus Upper	2406	12/12/2023	11:35:00 AM	460		68.2	12.5	1	
Global Arts Plus Upper	2408	12/12/2023	12:50:00 PM	650		69.6	15.9	25	Live Animals: Kept Away From Return And Supply Vents, Plants: Kept Aw
Global Arts Plus Upper	2410	12/12/2023	11:41:00 AM	485		68.7	13.2	1	
Global Arts Plus Upper	3101	12/12/2023	11:52:00 AM	615		68.7	14.4	6	
Global Arts Plus Upper	3103	12/12/2023	11:54:00 AM	422		67.6	13.7	3	Bubbling/Peeling Paint, Stained Ceiling Tiles, Aquariums (fish), Plants: Ke
Global Arts Plus Upper	3104	12/12/2023	11:49:00 AM	801		68.4	17.3	30	
Global Arts Plus Upper	3301	12/12/2023	11:59:00 AM	504		68.7	13.6	3	
Global Arts Plus Upper	3302	12/12/2023	11:58:00 AM	533		68.4	14.9	3	
Global Arts Plus Upper	3303	12/12/2023	1:01:00 PM	572		69.3	14.1	7	
Global Arts Plus Upper	3304	12/12/2023	1:08:00 PM	573		69.3	15.4	0	
Global Arts Plus Upper	3402	12/12/2023	1:07:00 PM	552		69.3	12	0	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	3405	12/12/2023	1:12:00 PM	568		70.2	15.4	1	
Global Arts Plus Upper	3406	12/12/2023	1:10:00 PM	378		70.5	11.4	0	
Global Arts Plus Upper	3408	12/12/2023	12:02:00 PM	710		69.6	15.6	30	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	3410	12/12/2023	12:08:00 PM	735		69.4	15.3	35	Plants: Kept Away From Return And Supply Vents
Global Arts Plus Upper	1104A	12/12/2023	10:41:00 AM	516		69.3	14	0	
Global Arts Plus Upper	1104C	12/12/2023	10:42:00 AM	486		69.4	13.5	0	
Global Arts Plus Upper	1120A	12/12/2023	10:48:00 AM	528		68.7	14.4	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Global Arts Plus Upper	1255A	12/12/2023	11:01:00 AM	450		71.1	12.7	0	
Global Arts Plus Upper	1255B	12/12/2023	1:34:00 PM	452		69.3	13.9	1	
Global Arts Plus Upper	1310A	12/12/2023	10:46:00 AM	508		68.5	16.3	0	
Global Arts Plus Upper	2201B	12/12/2023	12:58:00 PM	533		70	13.2	0	
Global Arts Plus Upper	2201D	12/12/2023	12:56:00 PM	549		70	13.5	0	
Global Arts Plus Upper	2330B	12/12/2023	12:26:00 PM	477		69.1	13.4	0	
Global Arts Plus Upper	OUTDOORS	12/12/2023		320		23	61		
Gordon Parks High School	1003	11/30/2023	1:34:00 PM	569	0.1	71.4	19.8	1	
Gordon Parks High School	1007	11/30/2023	1:33:00 PM	643	0.1	72.3	20	2	Plants
Gordon Parks High School	1009	11/30/2023	1:31:00 PM	585	0.1	7.3	20.6	0	
Gordon Parks High School	1019	11/30/2023	1:32:00 PM	532	0.1	69.8	20	2	
Gordon Parks High School	1101	11/30/2023	1:48:00 PM	616	0.3	6.1	24.3	2	Plants
Gordon Parks High School	1102	11/30/2023	1:45:00 PM	634	0.2	71.6	20.3	9	
Gordon Parks High School	1103	11/30/2023	1:46:00 PM	861	0.2	71.4	25.3	12	
Gordon Parks High School	1104	11/30/2023	1:43:00 PM	583	0.3	72.1	19.2	0	
Gordon Parks High School	1107	11/30/2023	1:39:00 PM	686	0.2	70	21.8	0	
Gordon Parks High School	1109	11/30/2023	1:38:00 PM	697	0.2	70.2	21.8	5	
Gordon Parks High School	1115	11/30/2023	1:36:00 PM	817	0.2	70.5	22.6	0	
Gordon Parks High School	1118	11/30/2023	1:04:00 PM	864	0.1	72.9	21.7	2	
Gordon Parks High School	1122	11/30/2023	1:15:00 PM	967	0.4	76.3	20	2	
Gordon Parks High School	1126	11/30/2023	1:21:00 PM	966	0.4	76.3	21	2	
Gordon Parks High School	1130	11/30/2023	1:21:00 PM	930	0.3	76.3	20.1	2	
Gordon Parks High School	1201	11/30/2023	1:23:00 PM	510	0.4	74.1	17.3	1	Plants
Gordon Parks High School	1205	11/30/2023	1:27:00 PM	499	0.1	71.1	18.8	1	Plants
Gordon Parks High School	1207	11/30/2023	1:26:00 PM	541	0.1	72.3	18.9	1	
Gordon Parks High School	1209	11/30/2023	1:24:00 PM	551	0.2	72.9	18.2	1	
Gordon Parks High School	1210	11/30/2023	12:56:00 PM	524		68.4	21.9	0	
Gordon Parks High School	1214	11/30/2023	1:01:00 PM	569	0.1	69.3	23.9	0	
Gordon Parks High School	2001	11/30/2023	2:00:00 PM	652	0.2	70.9	20.6	0	
Gordon Parks High School	2003	11/30/2023	2:01:00 PM	591	0.2	70.5	20.2	2	
Gordon Parks High School	2005	11/30/2023	2:02:00 PM	560	0.2	69.8	20.3	0	
Gordon Parks High School	2011	11/30/2023	2:03:00 PM	565	0.1	69.8	20.1	5	
Gordon Parks High School	2101	11/30/2023	1:50:00 PM	724	0.2	69.3	22.8	6	
Gordon Parks High School	2102	11/30/2023	1:54:00 PM	682	0.1	69.8	22.7	6	Plants
Gordon Parks High School	2103	11/30/2023	1:52:00 PM	1144	0.1	69.6	27.8	15	Odor Description: Essential oils, Fragrance Odor, Essential oils
Gordon Parks High School	2104	11/30/2023	1:56:00 PM	816	0.2	70.5	24	6	
Gordon Parks High School	2105	11/30/2023	1:54:00 PM	978	0.2	40.2	24.3	7	
Gordon Parks High School	2107	11/30/2023	2:05:00 PM	546	0.2	71.1	19.8	7	
Gordon Parks High School	2109	11/30/2023	1:57:00 PM	810	0.2	70.7	22.2	11	
Gordon Parks High School	GYMNASIUM	11/30/2023	1:03:00 PM	480	0.2	68.7	19.2	10	
Gordon Parks High School	KITCHEN	11/30/2023	12:59:00 PM	630	0.1	68.9	27.1	1	
Gordon Parks High School	MAIN COMMONS	11/30/2023	12:58:00 PM	561		68.9	23.7	5	
Gordon Parks High School	MAIN OFFICE	11/30/2023	1:29:00 PM	581	0.1	70.5	20.3	3	Live Animals
Gordon Parks High School	NURSE	11/30/2023	1:07:00 PM	851	0.2	44.1	21.3	2	
Gordon Parks High School	NURSE OFFICE	11/30/2023	1:09:00 PM	763	0.4	74.8	19.4	1	
Gordon Parks High School	OUTDOORS	11/30/2023		422	0.2	40	23.9		
Gordon Parks High School	STAFF LOUNGE	11/30/2023	1:40:00 PM	940	0.1	72	23.3	3	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Groveland Park Elementary School	1101	1/10/2024	11:57:00 AM	588	0.2	70.2	16.7	60	
Groveland Park Elementary School	1105	1/10/2024	11:58:00 AM	397	0.2	69.8	14.7	1	Plants
Groveland Park Elementary School	1113	1/10/2024	11:55:00 AM	497	0.2	72.1	15.9	1	
Groveland Park Elementary School	1118	1/10/2024	11:12:00 AM	424	0.2	72.1	14.3	0	
Groveland Park Elementary School	1123	1/10/2024	11:49:00 AM	600	0.2	71.8	16.4	20	
Groveland Park Elementary School	1135	1/10/2024	12:16:00 PM	567	0.2	72.5	15.9	20	
Groveland Park Elementary School	1200	1/10/2024	11:18:00 AM	407	0.2	67.5	17	1	Plants: Kept Away From Return And Supply Vents
Groveland Park Elementary School	1201	1/10/2024	11:21:00 AM	392	0.2	69.6	15.3	0	
Groveland Park Elementary School	1301	1/10/2024	11:15:00 AM	422	0.2	67.5	20	0	
Groveland Park Elementary School	1302	1/10/2024	11:17:00 AM	462	0.2	67.8	20.2	0	
Groveland Park Elementary School	1320	1/10/2024	11:13:00 AM	407	0.3	67.4	17.1	30	
Groveland Park Elementary School	1321	1/10/2024	11:22:00 AM	429	0.2	69.3	15.6	0	Stained Ceiling Tiles
Groveland Park Elementary School	2001	1/10/2024	11:33:00 AM	464	0.3	71.4	14.9	2	
Groveland Park Elementary School	2011	1/10/2024	11:37:00 AM	578	0.2	70	16.8	1	
Groveland Park Elementary School	2012	1/10/2024	11:34:00 AM	430	0.2	70.9	14.9	0	Stained Ceiling Tiles
Groveland Park Elementary School	2014	1/10/2024	11:36:00 AM	447	0.2	70.2	15.4	1	
Groveland Park Elementary School	2015	1/10/2024	11:36:00 AM	596	0.3	70.2	16.9	2	
Groveland Park Elementary School	2021	1/10/2024	11:32:00 AM	533	0.3	71.8	15	1	
Groveland Park Elementary School	2022	1/10/2024	11:32:00 AM	468	0.2	72.5	14.4	2	
Groveland Park Elementary School	2024	1/10/2024	11:30:00 AM	426	0.2	72.5	13.9	0	
Groveland Park Elementary School	2102	1/10/2024	11:41:00 AM	678	0.2	70.9	16.6	20	
Groveland Park Elementary School	2103	1/10/2024	11:38:00 AM	856	0.2	71.2	17.4	25	
Groveland Park Elementary School	2104	1/10/2024	12:28:00 PM	657	0.2	72.3	16.3	20	Plants: Kept Away From Return And Supply Vents
Groveland Park Elementary School	2109	1/10/2024	12:26:00 PM	567	0.2	72.7	15.4	20	Plants: Kept Away From Return And Supply Vents
Groveland Park Elementary School	2113	1/10/2024	12:25:00 PM	736	0.2	72	18.5	25	
Groveland Park Elementary School	2123	1/10/2024	11:48:00 AM	418	0.2	72.1	14.3	0	
Groveland Park Elementary School	2137	1/10/2024	11:46:00 AM	792	0.2	71.8	18.1	25	Plants: Kept Away From Return And Supply Vents
Groveland Park Elementary School	2138	1/10/2024	11:24:00 AM	962	0.2	71.2	19.7	25	
Groveland Park Elementary School	2139	1/10/2024	11:28:00 AM	703	0.3	72.7	17.7	20	Stained Ceiling Tiles
Groveland Park Elementary School	2142	1/10/2024	11:27:00 AM	1010	0.2	71.6	20.7	25	
Groveland Park Elementary School	3101	1/10/2024	12:35:00 PM	549	0.2	70.9	15.4	0	
Groveland Park Elementary School	3102	1/10/2024	12:34:00 PM	764	0.2	71.6	17.3	25	
Groveland Park Elementary School	3103	1/10/2024	12:36:00 PM	706	0.2	70.3	17.6	25	
Groveland Park Elementary School	3104	1/10/2024	12:33:00 PM	629	0.2	72	15.9	20	Stained Ceiling Tiles, Aquariums (fish)
Groveland Park Elementary School	3108	1/10/2024	12:31:00 PM	736	0.2	72.5	16.7	5	Stained Ceiling Tiles
Groveland Park Elementary School	3109	1/10/2024	12:37:00 PM	536	0.2	70.9	15.1	1	Plants: Kept Away From Return And Supply Vents
Groveland Park Elementary School	3113	1/10/2024	12:12:00 PM	617	0.2	72.3	15.6	25	
Groveland Park Elementary School	3114	1/10/2024	12:11:00 PM	902	0.2	72	19.3	20	
Groveland Park Elementary School	3118	1/10/2024	12:11:00 PM	569	0.3	71.4	16.7	0	
Groveland Park Elementary School	3120	1/10/2024	12:09:00 PM	602	0.2	71.8	16.4	2	
Groveland Park Elementary School	3121	1/10/2024	12:08:00 PM	495	0.2	72.3	14.7	2	Plants: Kept Away From Return And Supply Vents
Groveland Park Elementary School	3123	1/10/2024	12:07:00 PM	809	0.2	72.5	19.7	8	
Groveland Park Elementary School	3124	1/10/2024	12:29:00 PM	562	0.2	72.7	15.5	2	
Groveland Park Elementary School	3136	1/10/2024	12:00:00 PM	567	0.2	70.3	16.4	2	
Groveland Park Elementary School	3137	1/10/2024	12:38:00 PM	778	0.2	72	17.9	8	
Groveland Park Elementary School	3138	1/10/2024	12:04:00 PM	917	0.2	71.2	19.9	25	
Groveland Park Elementary School	3139	1/10/2024	12:06:00 PM	634	0.2	71.8	16.6	3	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Groveland Park Elementary School	3142	1/10/2024	12:05:00 PM	899	0.2	71.4	18.2	25	
Groveland Park Elementary School	1114A	1/10/2024	10:57:00 AM	344	0.2	68.1	17	0	
Groveland Park Elementary School	OUTDOORS	1/10/2024		350	0.5	25	82		
Hamline Elementary School	1000	12/1/2023	10:49:00 AM	637	0.6	70.9	15.2	1	
Hamline Elementary School	1001	12/1/2023	10:52:00 AM	547	0.5	71.4	13.4	0	
Hamline Elementary School	1003	12/1/2023	10:53:00 AM	686	0.6	71.2	15.3	4	
Hamline Elementary School	1004	12/1/2023	11:01:00 AM	681	0.5	72.1	15	2	
Hamline Elementary School	1005	12/1/2023	10:55:00 AM	610	0.5	71.1	14.3	1	Stained Ceiling Tiles
Hamline Elementary School	1006	12/1/2023	11:03:00 AM	712	0.5	72.9	15.2	1	
Hamline Elementary School	1008	12/1/2023	10:59:00 AM	831	0.5	71.1	17	1	Plants: Kept Away From Return And Supply Vents
Hamline Elementary School	1010	12/1/2023	10:57:00 AM	674	0.5	71.1	15.5	2	Plants: Kept Away From Return And Supply Vents
Hamline Elementary School	1012	12/1/2023	11:06:00 AM	563	0.6	71.4	13.8	2	Stained Ceiling Tiles
Hamline Elementary School	1100	12/1/2023	11:05:00 AM	746	0.7	72.3	15.8	20	
Hamline Elementary School	1101	12/1/2023	10:45:00 AM	640	0.5	70.3	15.7	20	
Hamline Elementary School	1103	12/1/2023	11:19:00 AM	651	0.8	72	15.2	0	Plants
Hamline Elementary School	1105	12/1/2023	11:24:00 AM	640	0.7	71.6	15	2	Plants: Kept Away From Return And Supply Vents
Hamline Elementary School	1107	12/1/2023	11:25:00 AM	677	0.7	71.2	16.2	0	
Hamline Elementary School	1109	12/1/2023	11:27:00 AM	875	0.8	72.1	17.9	23	
Hamline Elementary School	1120	12/1/2023	11:13:00 AM	480	0.6	70.5	13.7	1	
Hamline Elementary School	1201	12/1/2023	10:13:00 AM	853	0.6	69.8	19.6	22	
Hamline Elementary School	1202	12/1/2023	10:10:00 AM	833	0.6	70.2	19.3	17	
Hamline Elementary School	1203	12/1/2023	10:17:00 AM	796	0.7	69.4	19.3	2	Plants: Comments: Near return vent
Hamline Elementary School	1204	12/1/2023	10:08:00 AM	859	0.6	70.2	19.4	22	
Hamline Elementary School	1205	12/1/2023	10:19:00 AM	815	0.6	69.4	19.3	1	
Hamline Elementary School	1206	12/1/2023	10:05:00 AM	922	0.8	70.9	19.4	25	
Hamline Elementary School	1208	12/1/2023	9:53:00 AM	732	0.6	74.5	16.2	1	
Hamline Elementary School	1211	12/1/2023	10:32:00 AM	821	0.6	69.8	18.8	0	Plants: Kept Away From Return And Supply Vents
Hamline Elementary School	1212	12/1/2023	10:02:00 AM	712	0.9	73.6	15.9	0	
Hamline Elementary School	1213	12/1/2023	10:31:00 AM	840	0.5	69.3	19.2	3	
Hamline Elementary School	1214	12/1/2023	10:21:00 AM	852	0.6	69.4	19.7	19	
Hamline Elementary School	1215	12/1/2023	10:37:00 AM	853	0.6	70.2	19.2	0	Stained Ceiling Tiles
Hamline Elementary School	1216	12/1/2023	10:24:00 AM	858	0.6	69.3	19.6	19	
Hamline Elementary School	1217	12/1/2023	10:27:00 AM	814	0.6	68.7	19.6	20	
Hamline Elementary School	1223	12/1/2023	10:38:00 AM	865	0.6	70.7	18.6	0	Stained Ceiling Tiles
Hamline Elementary School	1307	12/1/2023	11:54:00 AM	726	0.7	68.2	17.9	1	
Hamline Elementary School	1308	12/1/2023	11:57:00 AM	695	0.8	70.9	15.5	1	
Hamline Elementary School	1401	12/1/2023	11:30:00 AM	493	0.6	66	14.8	0	Stained Ceiling Tiles
Hamline Elementary School	1405	12/1/2023	11:37:00 AM	506	0.5	67.1	14.7	2	
Hamline Elementary School	1407	12/1/2023	11:39:00 AM	484	0.7	66.7	14.7	0	Plants: Kept Away From Return And Supply Vents
Hamline Elementary School	1410	12/1/2023	11:48:00 AM	491	0.7	68.2	13.8	0	
Hamline Elementary School	1411	12/1/2023	11:41:00 AM	517	0.6	68.2	14.2	0	
Hamline Elementary School	1412	12/1/2023	11:49:00 AM	517	0.8	67.6	14	0	
Hamline Elementary School	1414	12/1/2023	11:51:00 AM	482	0.7	67.8	14.2	0	
Hamline Elementary School	1420	12/1/2023	11:53:00 AM	500	0.7	66.9	14.4	0	
Hamline Elementary School	1500	12/1/2023	12:14:00 PM	432	0.7	70.3	11.4	1	
Hamline Elementary School	1501	12/1/2023	12:16:00 PM	438	0.6	73.9	9.2	0	Plants: Kept Away From Return And Supply Vents
Hamline Elementary School	1503	12/1/2023	12:13:00 PM	456	0.7	69.6	11.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hamline Elementary School	1504	12/1/2023	12:17:00 PM	432	0.9	72.1	10	0	
Hamline Elementary School	1506	12/1/2023	12:20:00 PM	455	0.8	71.4	10.2	1	
Hamline Elementary School	1507	12/1/2023	12:08:00 PM	436	0.9	69.6	11.2	0	
Hamline Elementary School	1510	12/1/2023	12:21:00 PM	435	0.8	71.2	11.2	0	
Hamline Elementary School	1515	12/1/2023	12:02:00 PM	447	0.9	70	11.9	0	
Hamline Elementary School	2110	12/1/2023	12:25:00 PM	925	0.9	69.8	19	0	
Hamline Elementary School	2111	12/1/2023	12:30:00 PM	926	0.7	70.3	19	0	
Hamline Elementary School	2201	12/1/2023	12:57:00 PM	919	0.9	70.2	19	0	Plants: Kept Away From Return And Supply Vents
Hamline Elementary School	2202	12/1/2023	12:58:00 PM	910	0.8	69.4	19.1	0	Plants: Kept Away From Return And Supply Vents
Hamline Elementary School	2203	12/1/2023	12:52:00 PM	987	0.8	70.7	19.5	4	
Hamline Elementary School	2204	12/1/2023	12:55:00 PM	935	0.9	70.3	19	2	
Hamline Elementary School	2205	12/1/2023	12:50:00 PM	1162	0.9	71.4	20.4	18	
Hamline Elementary School	2206	12/1/2023	12:51:00 PM	930	0.9	71.1	18.3	1	Stained Ceiling Tiles
Hamline Elementary School	2211	12/1/2023	12:47:00 PM	920	0.9	71.2	18.3	0	
Hamline Elementary School	2213	12/1/2023	12:45:00 PM	957	0.7	70.9	18.9	1	
Hamline Elementary School	2217	12/1/2023	12:31:00 PM	1214	0.8	72.5	20.5	17	Stained Ceiling Tiles
Hamline Elementary School	2218	12/1/2023	12:37:00 PM	937	0.9	69.6	19.4	18	
Hamline Elementary School	2219	12/1/2023	12:40:00 PM	946	0.8	69.8	19.3	1	
Hamline Elementary School	2220	12/1/2023	12:35:00 PM	1014	0.9	71.2	19	4	
Hamline Elementary School	2221	12/1/2023	12:44:00 PM	24	0.9	70.3	18.7	0	
Hamline Elementary School	2222	12/1/2023	12:41:00 PM	994	0.7	70.3	20	5	
Hamline Elementary School	1120A	12/1/2023	11:18:00 AM	489	0.7	71.1	13.7	2	
Hamline Elementary School	1121A	12/1/2023	11:16:00 AM	589	0.6	71.6	15.6	0	
Hamline Elementary School	1123B	12/1/2023	11:11:00 AM	561	0.5	71.1	17.5	0	
Hamline Elementary School	1411A	12/1/2023	11:44:00 AM	478	0.7	67.8	13.9	0	Plants: Kept Away From Return And Supply Vents
Hamline Elementary School	1411B	12/1/2023	11:45:00 AM	522	0.7	68.2	14.8	0	
Hamline Elementary School	KITCHEN	12/1/2023	11:08:00 AM	603	0.6	70	18	3	
Hamline Elementary School	OUTDOORS	12/1/2023		423	1.2	24	68		
Harding Senior High School	213	1/8/2024	9:46:00 AM	541	0.1	68.5	18.9	3	
Harding Senior High School	1001	1/8/2024	11:51:00 AM	691		68.4	21.1	6	
Harding Senior High School	1003	1/8/2024	12:00:00 PM	632		70.9	18.6	0	
Harding Senior High School	1004	1/8/2024	12:01:00 PM	602		70.9	18.8	0	
Harding Senior High School	1005	1/8/2024	11:58:00 AM	653		70.3	19.1	1	
Harding Senior High School	1006	1/8/2024	12:01:00 PM	628	0.1	70.7	19	1	Food Odor
Harding Senior High School	1008	1/8/2024	12:03:00 PM	620	0.1	70.7	18.6	1	
Harding Senior High School	1009	1/8/2024	12:04:00 PM	778	0.1	71.1	18.6	1	
Harding Senior High School	1010	1/8/2024	12:06:00 PM	621	0.1	70.7	19	1	
Harding Senior High School	1011	1/8/2024	12:08:00 PM	668		70.9	18.9	1	Stained Ceiling Tiles
Harding Senior High School	1012	1/8/2024	12:09:00 PM	602		71.4	18.3	1	Stained Ceiling Tiles
Harding Senior High School	1013	1/8/2024	12:07:00 PM	596		70.7	18.4	1	
Harding Senior High School	1014	1/8/2024	12:13:00 PM	576		70	18.8	1	Stained Ceiling Tiles
Harding Senior High School	1015	1/8/2024	12:04:00 PM	627	0.1	70.7	18.5	0	
Harding Senior High School	1016	1/8/2024	12:12:00 PM	643	0.1	70.5	19.1	1	Fragrance, Food Odor, Stained Ceiling Tiles
Harding Senior High School	1017	1/8/2024	12:14:00 PM	620		69.8	19.9	5	
Harding Senior High School	1018	1/8/2024	12:15:00 PM	678		69.8	20	0	
Harding Senior High School	1020	1/8/2024	12:16:00 PM	579	0.1	69.6	18.9	0	Fragrance Odor, Stained Ceiling Tiles
Harding Senior High School	1021	1/8/2024	12:19:00 PM	668		69.9	19.4	1	Fragrance, Food Odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Harding Senior High School	1022	1/8/2024	12:20:00 PM	619		69.3	19.1	0	
Harding Senior High School	1101	1/8/2024	12:24:00 PM	716	0.1	68.7	68.7	120	
Harding Senior High School	1102	1/8/2024	12:28:00 PM	787	0.1	70.2	24.3	4	
Harding Senior High School	1103	1/8/2024	12:29:00 PM	817	0.1	69.8	25.4	0	
Harding Senior High School	1112	1/8/2024	1:02:00 PM	423		69.8	17.2	0	Bubbling/Peeling Paint
Harding Senior High School	1114	1/8/2024	12:56:00 PM	547	0.1	76.1	19.1	1	Food Odor
Harding Senior High School	1115	1/8/2024	12:55:00 PM	497	0.1	74.5	49	0	
Harding Senior High School	1117	1/8/2024	12:49:00 PM	620	0.1	73.4	18.4	1	Food Odor
Harding Senior High School	1119	1/8/2024	12:41:00 PM	453	0.1	70.2	18.6	0	
Harding Senior High School	1120	1/8/2024	12:35:00 PM	475		69.8	17.4	1	
Harding Senior High School	1121	1/8/2024	12:34:00 PM	453	0.1	70	17.5	0	
Harding Senior High School	1123	1/8/2024	12:31:00 PM	474		70.3	17.9	0	
Harding Senior High School	1126	1/8/2024	11:41:00 AM	621	0.1	69.3	20.2	2	
Harding Senior High School	1128	1/8/2024	11:46:00 AM	829		69.1	22.3	15	
Harding Senior High School	1129	1/8/2024	11:45:00 AM	576		68.9	19.5	0	Stained Ceiling Tiles
Harding Senior High School	1130	1/8/2024	11:43:00 AM	585		68.7	19.9	0	
Harding Senior High School	1131	1/8/2024	11:46:00 AM	1222	0.1	68.6	23.6	30	Fragrance Odor
Harding Senior High School	1132	1/8/2024	11:48:00 AM	705		70	20.4	1	Food Odor
Harding Senior High School	1133	1/8/2024	11:50:00 AM	711	0.1	69.8	19.9	18	Food Odor
Harding Senior High School	1134	1/8/2024	11:36:00 AM	654	0.1	69.4	20.5	25	Food Odor, Stained Ceiling Tiles
Harding Senior High School	1135	1/8/2024	11:40:00 AM	605		70.2	20.9	0	
Harding Senior High School	1136	1/8/2024	11:39:00 AM	595		69.8	19.1	0	
Harding Senior High School	1137	1/8/2024	11:38:00 AM	690		69.6	21.2	1	
Harding Senior High School	1138	1/8/2024	11:35:00 AM	735		70.3	20	2	
Harding Senior High School	1139	1/8/2024	11:34:00 AM	625		70.5	19.8	5	
Harding Senior High School	1140	1/8/2024	11:34:00 AM	603	0.1	70.2	19.2	0	
Harding Senior High School	1141	1/8/2024	11:30:00 AM	582	0.1	70.5	18.3	0	
Harding Senior High School	1142	1/8/2024	12:21:00 PM	881	0.1	68.9	19.7	1	Stained Ceiling Tiles
Harding Senior High School	1143	1/8/2024	12:23:00 PM	885	0.1	69.4	21.5	6	Stained Ceiling Tiles
Harding Senior High School	1203	1/8/2024	11:20:00 AM	627	0.1	72	18.1	0	
Harding Senior High School	1205	1/8/2024	11:29:00 AM	669	0.1	72.7	18	25	
Harding Senior High School	1206	1/8/2024	11:28:00 AM	736	0.1	72.5	16.9	25	
Harding Senior High School	1208	1/8/2024	11:26:00 AM	600	0.1	73	17.9	0	Stained Ceiling Tiles
Harding Senior High School	1209	1/8/2024	11:27:00 AM	622	0.1	73.2	18.7	0	Stained Ceiling Tiles
Harding Senior High School	1212	1/8/2024	11:18:00 AM	519	0.1	72.3	16.2	0	
Harding Senior High School	1214	1/8/2024	11:15:00 AM	620		72	19	1	Fragrance Odor
Harding Senior High School	1215	1/8/2024	11:14:00 AM	639		70	18.8	10	
Harding Senior High School	1230	1/8/2024	11:05:00 AM	478	0.2	70.7	17.5	0	
Harding Senior High School	1231	1/8/2024	11:11:00 AM	575	0.2	69.8	18	0	
Harding Senior High School	1233	1/8/2024	11:12:00 AM	444	0.1	68.9	18.4	0	
Harding Senior High School	1240	1/8/2024	11:02:00 AM	586	0.2	73	16.8	0	
Harding Senior High School	1242	1/8/2024	10:50:00 AM	782		71.6	20.7	15	
Harding Senior High School	1244	1/8/2024	10:54:00 AM	750	0.1	72.1	19.3	2	
Harding Senior High School	1245	1/8/2024	10:56:00 AM	987	0.2	72.7	21.5	12	
Harding Senior High School	1246	1/8/2024	10:57:00 AM	912	0.2	73.2	20.5	20	
Harding Senior High School	1247	1/8/2024	10:59:00 AM	959	0.2	73.9	20.2	1	Food Odor
Harding Senior High School	1248	1/8/2024	11:00:00 AM	606	0.3	72.5	17.6	20	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Harding Senior High School	1301	1/8/2024	10:10:00 AM	951		73.2	19.8	20	
Harding Senior High School	1302	1/8/2024	11:46:00 AM	643		71.4	20.2	15	
Harding Senior High School	1304	1/8/2024	11:47:00 AM	672		69.8	20.7	0	
Harding Senior High School	1305	1/8/2024	11:46:00 AM	646		71.6	18.1	15	
Harding Senior High School	1306	1/8/2024	1:19:00 PM	707		70.3	19.5	20	
Harding Senior High School	1307	1/8/2024	10:12:00 AM	770		73.2	17.9	15	
Harding Senior High School	1308	1/8/2024	11:51:00 AM	714		70.2	19.8	20	
Harding Senior High School	1309	1/8/2024	10:16:00 AM	574		72.3	16.3	1	
Harding Senior High School	1310	1/8/2024	11:51:00 AM	735		70	19.9	20	Aquariums (fish)
Harding Senior High School	1311	1/8/2024	10:18:00 AM	660		71.2	18.1	20	
Harding Senior High School	1312	1/8/2024	11:53:00 AM	735		70.2	20.2	15	
Harding Senior High School	1313	1/8/2024	10:19:00 AM	614		71.1	17.4	10	
Harding Senior High School	1314	1/8/2024	11:54:00 AM	705		70.2	19.6	0	
Harding Senior High School	1315	1/8/2024	11:43:00 AM	552		71.6	17.4	10	
Harding Senior High School	1316	1/8/2024	11:56:00 AM	643		70.3	19	20	Aquariums (fish)
Harding Senior High School	1317	1/8/2024	10:20:00 AM	569		70.9	17	1	
Harding Senior High School	1323	1/8/2024	10:48:00 AM	717		71.4	18.4	15	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1324	1/8/2024	11:56:00 AM	667		70.5	19.1	2	
Harding Senior High School	1325	1/8/2024	1:15:00 PM	434		70.9	15.9	0	
Harding Senior High School	1326	1/8/2024	10:48:00 AM	554		70.5	17.3	0	
Harding Senior High School	1327	1/8/2024	1:18:00 PM	429		69.1	17.2	0	
Harding Senior High School	1328	1/8/2024	11:58:00 AM	604		72	17.4	15	
Harding Senior High School	1329	1/8/2024	12:00:00 PM	569		71.2	16.8	20	
Harding Senior High School	1331	1/8/2024	12:02:00 PM	418		71.1	15.4	1	
Harding Senior High School	1333	1/8/2024	12:03:00 PM	504		71.6	16.4	20	
Harding Senior High School	1334	1/8/2024	12:07:00 PM	500		71.2	16.6	3	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1340	1/8/2024	12:12:00 PM	660		72.5	17.1	5	
Harding Senior High School	1341	1/8/2024	12:15:00 PM	694		73.4	17.6	3	
Harding Senior High School	1341	1/8/2024	12:45:00 PM	680		71.6	18.1	3	
Harding Senior High School	1342	1/8/2024	12:15:00 PM	620		72.9	16.8	1	
Harding Senior High School	1343	1/8/2024	12:16:00 PM	682		73.8	17.3	2	
Harding Senior High School	1344	1/8/2024	12:17:00 PM	582		73	16.4	0	
Harding Senior High School	1345	1/8/2024	12:19:00 PM	885		73	19.4	20	
Harding Senior High School	1347	1/8/2024	12:20:00 PM	650		72.3	17.6	1	
Harding Senior High School	1348	1/8/2024	12:22:00 PM	619		72.1	17.2	0	
Harding Senior High School	1349	1/8/2024	12:24:00 PM	877		72.7	19.4	4	
Harding Senior High School	1350	1/8/2024	12:25:00 PM	559		72.9	16.5	0	Fragrance Odor
Harding Senior High School	1351	1/8/2024	12:26:00 PM	601		72.7	16.8	0	
Harding Senior High School	1354	1/8/2024	12:11:00 PM	704		72.9	17.9	3	
Harding Senior High School	1355	1/8/2024	12:11:00 PM	663		72.1	17.7	1	
Harding Senior High School	1356	1/8/2024	12:10:00 PM	653		71.6	17.9	25	
Harding Senior High School	1358	1/8/2024	12:41:00 PM	661		71.2	17.7	1	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1359	1/8/2024	12:44:00 PM	824		71.6	20	30	
Harding Senior High School	1361	1/8/2024	12:47:00 PM	664		71.2	18.4	3	
Harding Senior High School	1363	1/8/2024	12:48:00 PM	678		70.7	18.6	10	Taxidermy
Harding Senior High School	1364	1/8/2024	12:51:00 PM	772		70.2	20.1	1	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1366	1/8/2024	12:51:00 PM	637		70	19	1	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Harding Senior High School	1370	1/8/2024	1:02:00 PM	665		70.2	19.4	1	
Harding Senior High School	1376	1/8/2024	1:00:00 PM	609		70	18.6	0	
Harding Senior High School	1378	1/8/2024	1:00:00 PM	695		69.8	19.8	1	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1379	1/8/2024	12:58:00 PM	684		69.6	20.1	0	
Harding Senior High School	1380	1/8/2024	12:54:00 PM	740		70.2	19.7	1	
Harding Senior High School	1381	1/8/2024	12:55:00 PM	680		70.2	19.4	1	
Harding Senior High School	1382	1/8/2024	12:57:00 PM	634		69.4	18.8	1	
Harding Senior High School	1383	1/8/2024	12:56:00 PM	571		69.4	18.5	0	
Harding Senior High School	1402	1/8/2024	12:27:00 PM	610		72	17.5	5	Stuffy Odor
Harding Senior High School	1403	1/8/2024	1:09:00 PM	684		69.3	20.4	2	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1404	1/8/2024	1:02:00 PM	506		70.2	17.3	0	
Harding Senior High School	1405	1/8/2024	12:29:00 PM	599		71.1	17.8	4	
Harding Senior High School	1406	1/8/2024	1:06:00 PM	496		69.1	18	1	
Harding Senior High School	1407	1/8/2024	12:32:00 PM	559		70.2	18	5	
Harding Senior High School	1409	1/8/2024	12:32:00 PM	629		69.6	19.1	15	
Harding Senior High School	1410	1/8/2024	12:34:00 PM	543		69.3	18.3	3	
Harding Senior High School	1411	1/8/2024	12:35:00 PM	521		69.3	18.1	1	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1412	1/8/2024	1:10:00 PM	686		69.6	22.2	30	
Harding Senior High School	1413	1/8/2024	1:11:00 PM	780		70.2	20.8	2	
Harding Senior High School	1415	1/8/2024	12:36:00 PM	639		70.3	19.1	1	
Harding Senior High School	1416	1/8/2024	12:41:00 PM	656		70.7	18.9	3	
Harding Senior High School	1417	1/8/2024	11:24:00 AM	951		70.2	22.2	4	
Harding Senior High School	1418	1/8/2024	11:22:00 AM	748		70.5	19.3	0	Stained Ceiling Tiles
Harding Senior High School	1419	1/8/2024	11:14:00 AM	770		70.7	19.7	10	
Harding Senior High School	1420	1/8/2024	11:27:00 AM	1031		70.9	22	25	
Harding Senior High School	1421	1/8/2024	11:15:00 AM	844		70.9	20.6	2	
Harding Senior High School	1422	1/8/2024	11:31:00 AM	873		72.5	19.2	1	
Harding Senior High School	1423	1/8/2024	11:30:00 AM	1160		72.1	23.5	20	
Harding Senior High School	1424	1/8/2024	11:34:00 AM	921		71.4	20.2	20	
Harding Senior High School	1425	1/8/2024	11:33:00 AM	878		72.3	20.2	2	
Harding Senior High School	1426	1/8/2024	11:38:00 AM	873		70.7	20.3	20	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1427	1/8/2024	11:36:00 AM	1061		71.6	22.3	25	
Harding Senior High School	1428	1/8/2024	1:12:00 PM	813		71.8	20.3	1	
Harding Senior High School	1430	1/8/2024	11:41:00 AM	882		72.3	20.5	2	
Harding Senior High School	1431	1/8/2024	1:14:00 PM	776		73.2	18.8	0	
Harding Senior High School	1433	1/8/2024	10:51:00 AM	1044		71.6	22.4	25	
Harding Senior High School	1434	1/8/2024	10:52:00 AM	899		71.1	20.2	15	Plants: Kept Away From Return And Supply Vents
Harding Senior High School	1435	1/8/2024	10:53:00 AM	966		71.2	22	20	
Harding Senior High School	1436	1/8/2024	10:55:00 AM	914		71.8	19.8	10	
Harding Senior High School	1437	1/8/2024	10:54:00 AM	1115		72	22.9	20	Stained Ceiling Tiles
Harding Senior High School	1438	1/8/2024	10:56:00 AM	919		71.6	20.3	25	
Harding Senior High School	1439	1/8/2024	11:22:00 AM	888		71.2	20.4	1	
Harding Senior High School	1440	1/8/2024	11:13:00 AM	910		70.5	21.4	20	
Harding Senior High School	1441	1/8/2024	11:11:00 AM	789		69.8	20.4	0	Fragrance Odor
Harding Senior High School	1442	1/8/2024	11:09:00 AM	782		69.3	20.3	0	
Harding Senior High School	1443	1/8/2024	11:00:00 AM	804		70.9	19.8	0	
Harding Senior High School	1444	1/8/2024	11:09:00 AM	748		69.4	20.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Harding Senior High School	1445	1/8/2024	10:59:00 AM	872		71.6	20.6	20	
Harding Senior High School	1446	1/8/2024	10:58:00 AM	976		71.4	20.9	20	
Harding Senior High School	1448	1/8/2024	10:37:00 AM	940		70.5	21.7	25	
Harding Senior High School	1450	1/8/2024	10:37:00 AM	1015		70.5	22.5	20	
Harding Senior High School	1451	1/8/2024	10:36:00 AM	764		70.7	20	20	
Harding Senior High School	1452	1/8/2024	10:38:00 AM	646		70.3	18.8	20	
Harding Senior High School	1452	1/8/2024	10:50:00 AM	895		70	20.8	25	
Harding Senior High School	1453	1/8/2024	10:36:00 AM	738		70.7	19.6	10	
Harding Senior High School	1454	1/8/2024	10:39:00 AM	586		70.2	18.3	2	
Harding Senior High School	1455	1/8/2024	10:23:00 AM	673		70.9	18.6	15	
Harding Senior High School	1456	1/8/2024	10:40:00 AM	644		69.8	19.2	15	
Harding Senior High School	1457	1/8/2024	11:41:00 AM	818		71.6	21.4	25	
Harding Senior High School	1458	1/8/2024	10:42:00 AM	642		69.8	19.1	1	
Harding Senior High School	1460	1/8/2024	10:43:00 AM	586		69.4	18.8	1	
Harding Senior High School	1461	1/8/2024	10:43:00 AM	657		69.1	19.6	1	
Harding Senior High School	1462	1/8/2024	10:44:00 AM	649		71.1	18.4	0	
Harding Senior High School	1600	1/8/2024	10:44:00 AM	532	0.3	68.4	18.5	5	
Harding Senior High School	1601	1/8/2024	10:46:00 AM	604	0.2	69.3	19.7	3	
Harding Senior High School	1602	1/8/2024	10:47:00 AM	532	0.3	69.3	18.3	0	
Harding Senior High School	1603	1/8/2024	10:46:00 AM	522	0.2	69.1	18.5	2	
Harding Senior High School	1604	1/8/2024	10:48:00 AM	561	0.3	68.7	17.8	0	
Harding Senior High School	1605	1/8/2024	10:42:00 AM	571	0.3	68.7	17.9	0	
Harding Senior High School	1606	1/8/2024	10:41:00 AM	522	0.2	70.2	16.9	0	
Harding Senior High School	1609	1/8/2024	10:40:00 AM	624	0.2	70.3	16.6	0	
Harding Senior High School	1610	1/8/2024	10:38:00 AM	615	0.2	70	17.5	0	
Harding Senior High School	1615	1/8/2024	10:36:00 AM	684	0.3	70.2	18.9	12	Fragrance Odor
Harding Senior High School	1618	1/8/2024	10:32:00 AM	566	0.3	71.2	17.4	7	
Harding Senior High School	1622	1/8/2024	10:34:00 AM	562	0.3	70.7	16.7	0	
Harding Senior High School	1626	1/8/2024	10:30:00 AM	614	0.3	70.9	16.1	0	
Harding Senior High School	1627	1/8/2024	10:18:00 AM	460	0.2	69.9	17.8	0	
Harding Senior High School	1628	1/8/2024	10:29:00 AM	476		70.7	16.6	0	
Harding Senior High School	1631	1/8/2024	10:26:00 AM	613	0.2	70	16.3	0	
Harding Senior High School	1632	1/8/2024	10:27:00 AM	547	0.2	70.2	16.8	0	
Harding Senior High School	1633	1/8/2024	10:28:00 AM	542	0.2	70.3	17	0	
Harding Senior High School	0213 OFFICE	1/8/2024	10:17:00 AM	522	0.1	68.5	19	1	
Harding Senior High School	1101C	1/8/2024	12:26:00 PM	722		72.1	42	2	
Harding Senior High School	1110C	1/8/2024	12:58:00 PM	834	0.1	70.7	24.8	0	
Harding Senior High School	1112C	1/8/2024	12:45:00 PM	400		71.1	16.2	0	
Harding Senior High School	1244A	1/8/2024	10:55:00 AM	788	0.2	72.1	19.2	0	
Harding Senior High School	1604A	1/8/2024	10:49:00 AM	519	0.3	68.5	19.8	0	
Harding Senior High School	OUTDOORS	1/8/2024		385	0.4	26	85		
Harding Senior High School	OUTDOORS	1/8/2024		385	0.4	26	85		
Hazel Park Academy	1002	11/29/2023	2:17:00 PM	617	0.4	70.2	20.9	2	
Hazel Park Academy	1003	11/29/2023	2:17:00 PM	614	0.4	70	20.8	0	
Hazel Park Academy	1004	11/29/2023	2:13:00 PM	643	0.3	70.5	20.7	0	
Hazel Park Academy	1005	11/29/2023	2:11:00 PM	715	0.3	70.2	22.4	1	
Hazel Park Academy	1007	11/29/2023	2:14:00 PM	645	0.3	70.5	20.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hazel Park Academy	1008	11/29/2023	2:15:00 PM	613	0.3	70.3	20.5	1	
Hazel Park Academy	1010	11/29/2023	2:22:00 PM	569	0.5	70.2	19.8	0	Fragrance Odor
Hazel Park Academy	1011	11/29/2023	2:18:00 PM	342	0.4	70.7	20.6	4	
Hazel Park Academy	1012	11/29/2023	2:25:00 PM	605	0.5	69.1	21	0	
Hazel Park Academy	1013	11/29/2023	2:24:00 PM	608	0.5	69.3	21	0	
Hazel Park Academy	1014	11/29/2023	2:23:00 PM	722	0.5	69.8	21.1	1	
Hazel Park Academy	1015	11/29/2023	2:22:00 PM	568	0.5	70.5	19.8	0	Fragrance Odor
Hazel Park Academy	1016	11/29/2023	2:20:00 PM	585	0.4	71.1	19.5	0	
Hazel Park Academy	1104	11/29/2023	10:32:00 AM	557	0.2	70.3	21.7	7	
Hazel Park Academy	1106	11/29/2023	10:35:00 AM	521	0.3	70.9	19.4	1	
Hazel Park Academy	1107	11/29/2023	2:29:00 PM	658	0.5	70	23	24	
Hazel Park Academy	1107	11/29/2023	11:52:00 AM	495	0.2	70.7	19.6	20	
Hazel Park Academy	1108	11/29/2023	10:37:00 AM	511	0.3	71.1	18.5	1	
Hazel Park Academy	1110	11/29/2023	10:30:00 AM	518	0.4	70.5	18.9	0	Stuffy, Dirty Or Dusty Carpet Odor
Hazel Park Academy	1201	11/29/2023	2:50:00 PM	655	0.5	70.5	20.9	1	Fragrance Odor
Hazel Park Academy	1202	11/29/2023	2:52:00 PM	637	6	70.5	21.8	0	
Hazel Park Academy	1205	11/29/2023	2:30:00 PM	722	0.6	70.5	30.7	1	
Hazel Park Academy	1210	11/29/2023	11:55:00 AM	712	0.4	70.2	20.8	1	
Hazel Park Academy	1301	11/29/2023	2:36:00 PM	752	0.7	70.3	22.4	20	
Hazel Park Academy	1302	11/29/2023	11:35:00 AM	633	0.3	70.5	20.1	2	
Hazel Park Academy	1305	11/29/2023	2:37:00 PM	849	0.6	70.3	23.5	22	Stained Ceiling Tiles
Hazel Park Academy	1307	11/29/2023	2:38:00 PM	834	0.6	70.3	22.8	17	
Hazel Park Academy	1308	11/29/2023	11:32:00 AM	764	0.3	72	21.5	15	
Hazel Park Academy	1309	11/29/2023	10:45:00 AM	852	0.4	70	21.8	12	
Hazel Park Academy	1310	11/29/2023	11:31:00 AM	845	0.4	70.3	28.7	12	Aquariums (fish), Plants
Hazel Park Academy	1311	11/29/2023	10:55:00 AM	661	0.4	69.6	20.1	1	
Hazel Park Academy	1312	11/29/2023	11:29:00 AM	705	0.4	70.7	20.7	3	
Hazel Park Academy	1313	11/29/2023	11:21:00 AM	702	0.4	70.2	20.4	23	
Hazel Park Academy	1314	11/29/2023	11:10:00 AM	735	0.3	70.5	20.5	3	Moisture Impacted Materials Location: North end of the windows, Com
Hazel Park Academy	1314	11/29/2023	11:17:00 AM	642	0.4	69.1	20.1	0	
Hazel Park Academy	1315	11/29/2023	11:19:00 AM	682	0.3	70	20.3	21	Stained Ceiling Tiles, Plants
Hazel Park Academy	1316	11/29/2023	11:06:00 AM	957	0.4	71.6	22.5	14	Fragrance Odor, Stained Ceiling Tiles
Hazel Park Academy	1317	11/29/2023	11:08:00 AM	653	0.5	69.8	19.9	19	
Hazel Park Academy	1318	11/29/2023	11:03:00 AM	973	0.4	70.7	25.5	18	
Hazel Park Academy	1319	11/29/2023	2:40:00 PM	930	0.6	70.2	24	25	Stained Ceiling Tiles
Hazel Park Academy	1320	11/29/2023	11:01:00 AM	721	0.4	69.8	20.9	3	
Hazel Park Academy	1321	11/29/2023	2:42:00 PM	1077	0.6	71.4	25.1	22	Stained Ceiling Tiles
Hazel Park Academy	1402	11/29/2023	11:44:00 AM	508	0.3	71.8	18.5	0	Fragrance Odor
Hazel Park Academy	1403	11/29/2023	11:46:00 AM	470	0.3	72	17.5	0	
Hazel Park Academy	1404	11/29/2023	11:50:00 AM	497	0.3	71.6	17.5	0	
Hazel Park Academy	2300	11/29/2023	1:12:00 PM	840	0.3	70	22.4	12	
Hazel Park Academy	2301	11/29/2023	12:07:00 PM	641	0.3	70.3	20	0	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2303	11/29/2023	12:11:00 PM	1086	0.2	70.3	22.4	24	
Hazel Park Academy	2304	11/29/2023	1:06:00 PM	600	0.3	69.3	21	1	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2305	11/29/2023	12:14:00 PM	642	0.3	70.3	20	0	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2307	11/29/2023	1:13:00 PM	843	0.3	70.2	23.7	19	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2308	11/29/2023	12:53:00 PM	762	0.3	70.7	21.9	6	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hazel Park Academy	2309	11/29/2023	1:16:00 PM	631	0.3	70.3	20.3	1	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2310	11/29/2023	12:52:00 PM	588	0.3	69.3	20.4	0	
Hazel Park Academy	2311	11/29/2023	1:18:00 PM	858	0.3	70.3	23.2	16	
Hazel Park Academy	2312	11/29/2023	12:47:00 PM	779	0.4	70.2	22.1	0	
Hazel Park Academy	2313	11/29/2023	12:20:00 PM	942	0.3	69.6	24	18	Fragrance Odor, Stained Ceiling Tiles, Plants: Kept Away From Return And
Hazel Park Academy	2314	11/29/2023	12:46:00 PM	624	0.3	71.1	19.7	2	Food Odor, Plants
Hazel Park Academy	2317	11/29/2023	12:26:00 PM	612	0.3	69.6	20.4	0	
Hazel Park Academy	2319	11/29/2023	12:30:00 PM	767	0.3	70.3	22.2	6	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2320	11/29/2023	12:40:00 PM	941	0.3	69.6	24.3	23	Stuffy, Dirty Or Dusty Carpet Odor, Efflorescence
Hazel Park Academy	2321	11/29/2023	12:35:00 PM	1063	0.4	70	25.5	22	
Hazel Park Academy	2322	11/29/2023	12:38:00 PM	1001	0.4	68.9	25.1	21	Food Odor
Hazel Park Academy	2400	11/29/2023	11:58:00 AM	490	0.2	75.7	15	2	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2402	11/29/2023	12:04:00 PM	532	0.4	74.5	15.7	1	
Hazel Park Academy	1312A	11/29/2023	11:23:00 AM	660	0.4	70.2	21	4	Efflorescence
Hazel Park Academy	2302B	11/29/2023	1:08:00 PM	577	0.3	69.4	20.4	0	
Hazel Park Academy	2304E	11/29/2023	1:04:00 PM	613	0.3	69.8	20.3	0	
Hazel Park Academy	2306A	11/29/2023	12:57:00 PM	658	0.4	69.6	20.6	1	Fragrance Odor
Hazel Park Academy	2306B	11/29/2023	12:59:00 PM	584	0.3	68	21.4	0	Plants: Kept Away From Return And Supply Vents
Hazel Park Academy	2306C	11/29/2023	1:02:00 PM	901	0.2	69.4	24	1	
Hazel Park Academy	AUDITORIUM	11/29/2023	2:48:00 PM	461	0.6	69.4	19.9	6	
Hazel Park Academy	CAFETERIA	11/29/2023	9:51:00 AM	620	0.7	76.5	17.6	1	Stained Ceiling Tiles
Hazel Park Academy	KITCHEN OFFICE	11/29/2023	9:39:00 AM	850	0.6	69.1	26.6	0	Plants
Hazel Park Academy	MAIN KITCHEN	11/29/2023	9:46:00 AM	630	0.7	71.8	22.7	2	
Hazel Park Academy	MEDIA CENTER	11/29/2023	11:40:00 AM	466	0.3	72	17.5	15	
Hazel Park Academy	OUTDOORS	11/29/2023		437	0.6	31	32.6		
Hazel Park Academy	SMALL KITCHEN	11/29/2023	9:55:00 AM	608	0.8	76.5	19.4	1	
Hidden River Middle School	101	12/1/2023	9:40:00 AM	672	0.1	72.5	15.4	0	
Hidden River Middle School	105	12/1/2023	9:44:00 AM	1570	0.4	75.2	23.7	25	
Hidden River Middle School	107	12/1/2023	9:57:00 AM	962	0.1	73	19	11	Stuffy Odor, Stained Ceiling Tiles
Hidden River Middle School	108	12/1/2023	10:00:00 AM	873	0.4	72.3	16.4	9	
Hidden River Middle School	109	12/1/2023	10:02:00 AM	713	0.2	72.9	14.8	8	
Hidden River Middle School	204	12/1/2023	1:06:00 PM	653	0.1	73	13.7	23	
Hidden River Middle School	205	12/1/2023	9:51:00 AM	559	0.4	71.1	13.7	0	
Hidden River Middle School	207	12/1/2023	9:55:00 AM	721	0.2	69.4	16.5	19	
Hidden River Middle School	208	12/1/2023	9:53:00 AM	558	0.3	70.2	14.2	0	
Hidden River Middle School	1001	12/1/2023	10:59:00 AM	589		74.5	13.5	2	Plants: Kept Away From Return And Supply Vents
Hidden River Middle School	1002	12/1/2023	11:02:00 AM	561	0.1	74.7	12.6	0	
Hidden River Middle School	1004	12/1/2023	11:05:00 AM	608	0.1	74.1	13.2	2	
Hidden River Middle School	1005	12/1/2023	11:08:00 AM	523		74.8	11.5	0	
Hidden River Middle School	1006	12/1/2023	11:11:00 AM	640	0.1	73.2	13.4	2	
Hidden River Middle School	1007	12/1/2023	11:13:00 AM	584		77	11.2	1	Food Odor
Hidden River Middle School	1008	12/1/2023	12:41:00 PM	635		76	12.5	1	
Hidden River Middle School	1009	12/1/2023	10:56:00 AM	515	0.1	73.6	12.3	0	
Hidden River Middle School	1011	12/1/2023	10:53:00 AM	574	0.1	73.8	12.7	1	
Hidden River Middle School	1012	12/1/2023	10:55:00 AM	555	0.1	74.1	12.5	1	
Hidden River Middle School	1013	12/1/2023	12:45:00 PM	536	0.1	76.5	11.2	1	Fragrance Odor
Hidden River Middle School	1014	12/1/2023	10:47:00 AM	558	0.1	72.5	13.3	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hidden River Middle School	1015	12/1/2023	10:49:00 AM	597	0.1	72.1	13.8	2	
Hidden River Middle School	1016	12/1/2023	10:51:00 AM	592	0.1	72.9	13.7	0	
Hidden River Middle School	1101	12/1/2023	12:54:00 PM	486		71.6	12.2	0	
Hidden River Middle School	1102	12/1/2023	12:51:00 PM	496	0.1	71.6	12.5	0	Live Animals: Kept Away From Return And Supply Vents, Plants: Kept Aw
Hidden River Middle School	1106	12/1/2023	10:43:00 AM	855	0.2	72.5	16.3	28	
Hidden River Middle School	1107	12/1/2023	12:47:00 PM	520	0.3	74.7	11.4	1	Food Odor
Hidden River Middle School	1108	12/1/2023	12:48:00 PM	498	0.1	72.9	11.8	0	
Hidden River Middle School	1204	12/1/2023	1:07:00 PM	588	0.2	72.1	14.4	0	Plants
Hidden River Middle School	1205	12/1/2023	10:04:00 AM	668	0.3	72.9	14.2	27	
Hidden River Middle School	1206	12/1/2023	10:09:00 AM	505	0.2	71.8	12.9	0	
Hidden River Middle School	1207	12/1/2023	10:12:00 AM	528	0.2	71.1	13.5	0	
Hidden River Middle School	1208	12/1/2023	10:17:00 AM	459	0.1	70.7	13.7	493	
Hidden River Middle School	1209	12/1/2023	10:14:00 AM	504	0.1	70.7	13.7	0	
Hidden River Middle School	1212	12/1/2023	10:20:00 AM	555	0.1	70.2	14.1	21	
Hidden River Middle School	1213	12/1/2023	10:22:00 AM	709	0.1	69.8	16.4	20	Plants: Kept Away From Return And Supply Vents
Hidden River Middle School	1215	12/1/2023	10:24:00 AM	555	0.1	68.7	15.2	0	
Hidden River Middle School	1301	12/1/2023	10:26:00 AM	496	0.1	70	14.2	0	
Hidden River Middle School	1302	12/1/2023	12:38:00 PM	640	0.1	70.5	15.8	80	
Hidden River Middle School	1304	12/1/2023	10:34:00 AM	594	0.2	71.8	14.9	1	
Hidden River Middle School	1305	12/1/2023	10:29:00 AM	605	0.1	69.8	15.2	14	
Hidden River Middle School	1306	12/1/2023	10:33:00 AM	724	0.1	71.6	17	30	
Hidden River Middle School	1308	12/1/2023	10:37:00 AM	650	0.2	72.9	17.2	0	
Hidden River Middle School	1310	12/1/2023	10:40:00 AM	630	0.2	73.8	14.9	0	Plants: Kept Away From Return And Supply Vents
Hidden River Middle School	2101	12/1/2023	11:24:00 AM	773		71.8	17.3	15	Fragrance Odor
Hidden River Middle School	2102	12/1/2023	11:22:00 AM	530		71.8	13.2	0	
Hidden River Middle School	2103	12/1/2023	11:17:00 AM	581		72.5	13.5	2	Plants: Kept Away From Return And Supply Vents
Hidden River Middle School	2105	12/1/2023	11:26:00 AM	805		71.6	16.7	28	Fragrance Odor
Hidden River Middle School	2107	12/1/2023	11:28:00 AM	623		71.8	15.5	0	
Hidden River Middle School	2108	12/1/2023	12:09:00 PM	659		72	15.6	20	
Hidden River Middle School	2109	12/1/2023	12:07:00 PM	827	0.1	71.4	17.3	17	Stained Ceiling Tiles
Hidden River Middle School	2110	12/1/2023	11:31:00 AM	618		73.2	14.5	1	
Hidden River Middle School	2111	12/1/2023	12:04:00 PM	931		71.4	19.5	27	
Hidden River Middle School	2112	12/1/2023	12:03:00 PM	665		70.2	15.5	22	Stuffy Odor
Hidden River Middle School	2113	12/1/2023	12:01:00 PM	567		70.3	14.6	0	
Hidden River Middle School	2114	12/1/2023	12:00:00 PM	672	0.1	70.5	15.4	4	Stained Ceiling Tiles
Hidden River Middle School	2116	12/1/2023	11:50:00 AM	581	0.1	71.2	13.8	0	Food Odor
Hidden River Middle School	2119	12/1/2023	11:34:00 AM	630		76.5	12.6	0	Stained Ceiling Tiles
Hidden River Middle School	2201	12/1/2023	1:01:00 PM	691		70.3	16.1	1	Stained Ceiling Tiles
Hidden River Middle School	2202	12/1/2023	11:49:00 AM	828		69.8	17.4	20	Stained Ceiling Tiles
Hidden River Middle School	2203	12/1/2023	11:46:00 AM	797		70	16.9	19	
Hidden River Middle School	2204	12/1/2023	12:57:00 PM	637	0.1	70	14.4	2	
Hidden River Middle School	2302	12/1/2023	11:35:00 AM	741	0.3	73.6	14.6	16	
Hidden River Middle School	2304	12/1/2023	11:40:00 AM	534		69.6	14.4	0	
Hidden River Middle School	2305	12/1/2023	11:42:00 AM	695		69.3	16.4	20	
Hidden River Middle School	3101	12/1/2023	12:14:00 PM	536		71.2	13.5	1	
Hidden River Middle School	3103	12/1/2023	12:16:00 PM	515	0.1	69.8	13.8	1	
Hidden River Middle School	3105	12/1/2023	12:11:00 PM	835	0.1	70.9	17.4	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hidden River Middle School	3107	12/1/2023	12:18:00 PM	608		69.1	15.7	1	
Hidden River Middle School	3110	12/1/2023	12:21:00 PM	698		69.8	15.3	1	Taxidermy
Hidden River Middle School	3111	12/1/2023	12:33:00 PM	673		71.4	15.9	0	
Hidden River Middle School	3112	12/1/2023	12:25:00 PM	494		69.6	13.4	0	
Hidden River Middle School	3114	12/1/2023	12:29:00 PM	599		71.1	14.1	17	
Hidden River Middle School	3116	12/1/2023	12:31:00 PM	636	0.1	70.2	15.1	21	
Hidden River Middle School	2303A	12/1/2023	11:37:00 AM	626	0.1	71.2	14.8	5	Stuffy, Fragrance Odor
Hidden River Middle School	2303B	12/1/2023	11:39:00 AM	944		71.1	19.7	12	
Hidden River Middle School	2304A	12/1/2023	11:44:00 AM	547		68.7	15	0	
Hidden River Middle School	OUTDOORS	12/1/2023		425	0.6	24	69		
Highland Park Elementary School	250	12/13/2023	9:39:00 AM	635	0.5	70.7	13.2	0	
Highland Park Elementary School	251	12/13/2023	9:48:00 AM	650	0.4	70.9	14	1	
Highland Park Elementary School	1101	12/13/2023	11:52:00 AM	672	0.1	72.5	13.6	2	
Highland Park Elementary School	1102	12/13/2023	11:50:00 AM	667	0.4	72.2	13	1	
Highland Park Elementary School	1104	12/13/2023	11:56:00 AM	588	0.2	73.5	12.8	20	
Highland Park Elementary School	1105	12/13/2023	11:30:00 AM	719	0.3	71.1	14.7	12	Taxidermy
Highland Park Elementary School	1106	12/13/2023	11:17:00 AM	689	0.3	73.4	13.4	3	Food Odor
Highland Park Elementary School	1107	12/13/2023	11:45:00 AM	783		71.9		2	
Highland Park Elementary School	1108	12/13/2023	9:27:00 AM	712	0.1	73	17.4	1	
Highland Park Elementary School	1109	12/13/2023	10:40:00 AM	699	0.5	70.7	14.4	10	
Highland Park Elementary School	1110	12/13/2023	11:27:00 AM	705	0.1	71.7	14.2	18	
Highland Park Elementary School	1111	12/13/2023	10:41:00 AM	561	0.1	70.1	13.1	20	
Highland Park Elementary School	1112	12/13/2023	10:42:00 AM	627	0.3	70.4	14.1	20	
Highland Park Elementary School	1113	12/13/2023	10:36:00 AM	693	0.2	70.8	13.5	1	Food Odor
Highland Park Elementary School	1118	12/13/2023	10:27:00 AM	977	1.7	70	16.3	3	Food Odor
Highland Park Elementary School	1119	12/13/2023	10:22:00 AM	707	0.6	70.6	14	80	Food Odor
Highland Park Elementary School	1120	12/13/2023	10:31:00 AM	581		69.3	11.3	20	
Highland Park Elementary School	1213	12/13/2023	10:43:00 AM	912	0.2	70.8	17	15	
Highland Park Elementary School	1214	12/13/2023	11:42:00 AM	686		69.8	15.2	0	
Highland Park Elementary School	1215	12/13/2023	11:39:00 AM	578		70.1	14.7	0	
Highland Park Elementary School	1216	12/13/2023	11:38:00 AM	619	0.3	70.2	15.5	0	
Highland Park Elementary School	1217	12/13/2023	11:35:00 AM	692	0.3	70.5	16.2	0	Fragrance Odor
Highland Park Elementary School	1218	12/13/2023	11:41:00 AM	912	0.1	70.1	17.7	20	
Highland Park Elementary School	1219	12/13/2023	11:43:00 AM	727	0.4	71.1	15.3	2	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	1220	12/13/2023	10:46:00 AM	628	0.4	70.2	13.1	0	
Highland Park Elementary School	1303	12/13/2023	10:47:00 AM	853		70.8	13.8	0	
Highland Park Elementary School	1304	12/13/2023	10:52:00 AM	569		70.9	12.7	0	
Highland Park Elementary School	1305	12/13/2023	10:54:00 AM	604	0.1	71.6	12.8	5	
Highland Park Elementary School	1306	12/13/2023	10:55:00 AM	578	0.1	72.2	13.1	0	Moisture Impacted Materials Location: Corner carpet , Further Assessment
Highland Park Elementary School	1307	12/13/2023	10:57:00 AM	618	0.2	71.8	13.7	0	
Highland Park Elementary School	2001	12/13/2023	11:07:00 AM	544		72	11.9	0	Plants
Highland Park Elementary School	2002	12/13/2023	11:13:00 AM	614	0.4	74.1	11.5	0	
Highland Park Elementary School	2003	12/13/2023	12:12:00 PM	575	0.6	72.4	12.2	7	Fragrance Odor
Highland Park Elementary School	2005	12/13/2023	11:14:00 AM	591	0.3	73	11.9	0	
Highland Park Elementary School	2009	12/13/2023	11:05:00 AM	590		71.2	13.8	6	Food Odor
Highland Park Elementary School	2010	12/13/2023	11:32:00 AM	582	0.1	71	13	7	
Highland Park Elementary School	2011	12/13/2023	11:00:00 AM	596	0.1	69.9	13.5	15	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Elementary School	2012	12/13/2023	11:04:00 AM	565		70.5	14.4	15	
Highland Park Elementary School	2014	12/13/2023	11:10:00 AM	655	0.1	73.7	13.1	4	Food Odor
Highland Park Elementary School	2101	12/13/2023	10:15:00 AM	598	0.5	72.5	11.3	1	
Highland Park Elementary School	2102	12/13/2023	10:16:00 AM	736	0.3	73.3	13.3	3	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	2103	12/13/2023	10:13:00 AM	609	0.5	72.5	11.6	0	
Highland Park Elementary School	2104	12/13/2023	10:06:00 AM	615	0.4	72.9	11.3	0	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	2105	12/13/2023	10:05:00 AM	651	0.3	73.1	12.2	3	
Highland Park Elementary School	2106	12/13/2023	10:04:00 AM	608	0.5	72.7	12	1	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	2109	12/13/2023	10:09:00 AM	632	0.3	72.6	12.5	0	
Highland Park Elementary School	2110	12/13/2023	10:12:00 AM	709	0.2	72.9	13.9	28	
Highland Park Elementary School	2111	12/13/2023	10:09:00 AM	723		72.8	14.5	20	
Highland Park Elementary School	2112	12/13/2023	10:08:00 AM	670	0.3	72.6	13.6	18	
Highland Park Elementary School	2115	12/13/2023	10:00:00 AM	587	0.1	72.5	12.5	4	
Highland Park Elementary School	2116	12/13/2023	10:17:00 AM	665	0.3	72.5	14	20	
Highland Park Elementary School	2117	12/13/2023	10:19:00 AM	684	0.3	72.3	14.1	18	Fragrance Odor
Highland Park Elementary School	2118	12/13/2023	11:20:00 AM	801		72.5	17.3	18	
Highland Park Elementary School	2122	12/13/2023	9:54:00 AM	620	0.4	71.8	12.5	0	
Highland Park Elementary School	2123	12/13/2023	11:24:00 AM	721	0.2	72.1	15.9	15	
Highland Park Elementary School	2124	12/13/2023	10:21:00 AM	771	0.2	72.2	14.5	20	
Highland Park Elementary School	2125	12/13/2023	10:20:00 AM	676	0.2	72	13.9	18	Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	1101A	12/13/2023	11:55:00 AM	776	0.4	72.9	13.9	1	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Highland Park Elementary School	1101B	12/13/2023	11:53:00 AM	670	0.1	72.7	13.2	3	
Highland Park Elementary School	1107B	12/13/2023	11:49:00 AM	781	0.3	72.4	13	0	
Highland Park Elementary School	1118A	12/13/2023	10:29:00 AM	876	1.6	70.6	14.1	0	Fragrance Odor
Highland Park Elementary School	1120C	12/13/2023	10:34:00 AM	532		69.8	11	0	
Highland Park Elementary School	2109A	12/13/2023	10:10:00 AM	629	0.2	72.9	13.7	0	Fragrance Odor
Highland Park Elementary School	2109B	12/13/2023	10:02:00 AM	696	0.3	72.6	13.6	1	
Highland Park Elementary School	2115A	12/13/2023	10:01:00 AM	570	0.3	72.4	12.1	0	
Highland Park Elementary School	2115B	12/13/2023	9:57:00 AM	568	0.3	72.4	12.4	0	
Highland Park Elementary School	2122A	12/13/2023	9:55:00 AM	517	0.1	71.7	11.6	8	
Highland Park Elementary School	2122B	12/13/2023	9:49:00 AM	811	0.5	71.8	15.3	5	
Highland Park Elementary School	OUTDOORS	12/13/2023		495	1.7	26	55		
Highland Park Middle School	105	12/6/2023	9:27:00 AM	635		71.4	20.6	0	
Highland Park Middle School	108	12/6/2023	9:31:00 AM	650		71.1	21.1	0	
Highland Park Middle School	119	12/6/2023	9:33:00 AM	531		72.5	19.4	0	
Highland Park Middle School	1002	12/6/2023	9:45:00 AM	519		68.7	19.8	1	
Highland Park Middle School	1003	12/6/2023	9:57:00 AM	585		70.9	18.2	0	
Highland Park Middle School	1004	12/6/2023	9:46:00 AM	481		68.9	18.9	1	
Highland Park Middle School	1006	12/6/2023	9:48:00 AM	463		68.9	18.6	0	
Highland Park Middle School	1007	12/6/2023	9:54:00 AM	540		71.6	18	1	
Highland Park Middle School	1008	12/6/2023	9:49:00 AM	471		69.1	19	1	
Highland Park Middle School	1008	12/6/2023	9:55:00 AM	780		70.9	18.1	0	
Highland Park Middle School	1009	12/6/2023	9:53:00 AM	452		71.4	17.5	0	
Highland Park Middle School	1010	12/6/2023	9:50:00 AM	555		70.7	19.7	2	
Highland Park Middle School	1012	12/6/2023	9:52:00 AM	470		70.5	18.4	1	
Highland Park Middle School	1013	12/6/2023	9:51:00 AM	487		70.5	18.3	1	
Highland Park Middle School	1014	12/6/2023	9:47:00 AM	535		68.4	19.3	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Middle School	1015	12/6/2023	9:58:00 AM	506		69.8	19	1	
Highland Park Middle School	1101	12/6/2023	11:55:00 AM	1070	1	70.3	27.3	100	Fragrance Odor, Plants
Highland Park Middle School	1112	12/6/2023	11:57:00 AM	1268		70.7	27.6	65	
Highland Park Middle School	1202	12/6/2023	9:59:00 AM	526		69.3	18.5	0	
Highland Park Middle School	1208	12/6/2023	10:00:00 AM	590		69.1	20.1	17	
Highland Park Middle School	1210	12/6/2023	10:06:00 AM	430		70.2	18.7	0	Stuffy Odor
Highland Park Middle School	1211	12/6/2023	10:05:00 AM	454		71.2	17.9	0	
Highland Park Middle School	1212	12/6/2023	10:03:00 AM	446		72.1	17.6	0	
Highland Park Middle School	1214	12/6/2023	10:07:00 AM	595		69.1	20.8	29	
Highland Park Middle School	1215	12/6/2023	10:09:00 AM	772		69.3	23.3	16	
Highland Park Middle School	1216	12/6/2023	10:10:00 AM	603	0.1	68.4	21.5	0	
Highland Park Middle School	1301	12/6/2023	10:40:00 AM	675	0.1	70.3	21.2	24	
Highland Park Middle School	1302	12/6/2023	10:37:00 AM	1141		71.4	21.2	27	
Highland Park Middle School	1304	12/6/2023	11:01:00 AM	507		71.2	19.9	15	
Highland Park Middle School	1305	12/6/2023	10:33:00 AM	774		69.1	24.2	27	
Highland Park Middle School	1306	12/6/2023	11:12:00 AM	571		70.9	21	16	
Highland Park Middle School	1307	12/6/2023	11:15:00 AM	889		70.3	23.5	17	
Highland Park Middle School	1308	12/6/2023	11:14:00 AM	534		70.9	20.6	19	
Highland Park Middle School	1309	12/6/2023	10:29:00 AM	701		67.8	24	17	
Highland Park Middle School	1310	12/6/2023	10:13:00 AM	457		69.1	19.3	1	Plants
Highland Park Middle School	1311	12/6/2023	11:19:00 AM	1155		70.2	23.7	23	
Highland Park Middle School	1312	12/6/2023	10:15:00 AM	433		70.2	18.5	0	Plants
Highland Park Middle School	1313	12/6/2023	10:21:00 AM	953		70.3	23.9	7	Fragrance Odor
Highland Park Middle School	1314	12/6/2023	11:16:00 AM	537		70.5	20.9	18	Stained Ceiling Tiles, Plants
Highland Park Middle School	1315	12/6/2023	10:22:00 AM	777	0.1	69.6	23.1	5	
Highland Park Middle School	1316	12/6/2023	11:18:00 AM	747		70.5	22.6	20	
Highland Park Middle School	1317	12/6/2023	10:28:00 AM	670		66.9	23.7	6	Fragrance Odor
Highland Park Middle School	1319	12/6/2023	10:24:00 AM	660		68.7	22.6	0	
Highland Park Middle School	1320	12/6/2023	10:17:00 AM	598		70.3	20.7	15	
Highland Park Middle School	1321	12/6/2023	10:27:00 AM	593		68.2	21.5	8	
Highland Park Middle School	1323	12/6/2023	10:43:00 AM	635		69.4	25.6	26	Food Odor
Highland Park Middle School	1325	12/6/2023	10:41:00 AM	528		0.2	19.9	4	
Highland Park Middle School	1401	12/6/2023	10:48:00 AM	1545	0.1	71.6	28.8	23	Plants
Highland Park Middle School	1403	12/6/2023	11:23:00 AM	758		72.1	22.7	17	Fragrance Odor, Plants
Highland Park Middle School	1405	12/6/2023	10:47:00 AM	677		70.7	22	3	
Highland Park Middle School	1406	12/6/2023	10:45:00 AM	477		69.8	20.1	0	
Highland Park Middle School	1407	12/6/2023	11:22:00 AM	522		71.6	20.2	20	
Highland Park Middle School	1408	12/6/2023	10:51:00 AM	461		72	19.1	0	
Highland Park Middle School	1409	12/6/2023	10:55:00 AM	510		72	19.3	1	Stained Ceiling Tiles
Highland Park Middle School	1415	12/6/2023	10:58:00 AM	1487		72.5	27.6	14	Plants
Highland Park Middle School	1416	12/6/2023	11:00:00 AM	1688	0.1	73	27.6	26	Plants
Highland Park Middle School	2401	12/6/2023	11:25:00 AM	1915	0.1	71.1	31.1	14	
Highland Park Middle School	2403	12/6/2023	11:27:00 AM	985		71.2	26.4	22	
Highland Park Middle School	2405	12/6/2023	11:30:00 AM	2236	0.1	71.6	34.2	25	Stuffy Odor
Highland Park Middle School	2406	12/6/2023	11:29:00 AM	993		71.1	24.5	1	Plants
Highland Park Middle School	2407	12/6/2023	11:31:00 AM	951		72.9	24	26	
Highland Park Middle School	2410	12/6/2023	11:35:00 AM	699	0.1	73	20.4	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Middle School	2411	12/6/2023	11:32:00 AM	1112		72.7	25.2	19	
Highland Park Middle School	2413	12/6/2023	11:33:00 AM	994	0.1	73	23	21	Stuffy Odor
Highland Park Middle School	2415	12/6/2023	11:36:00 AM	977	0.1	74.1	23.9	21	Food Odor
Highland Park Middle School	2417	12/6/2023	11:37:00 AM	1646	0.1	73.9	26.4	23	Plants
Highland Park Middle School	3401	12/6/2023	11:51:00 AM	1204		72.7	25.6	24	Plants
Highland Park Middle School	3403	12/6/2023	11:49:00 AM	930		72.1	23.6	28	
Highland Park Middle School	3405	12/6/2023	11:46:00 AM	1111		72.1	24.7	35	
Highland Park Middle School	3406	12/6/2023	11:48:00 AM	695		71.1	22.3	0	
Highland Park Middle School	3407	12/6/2023	11:45:00 AM	1091	0.1	71.2	25.8	12	
Highland Park Middle School	3411	12/6/2023	11:44:00 AM	963		71.4	24.4	20	
Highland Park Middle School	3413	12/6/2023	11:40:00 AM	1360		72	27.6	15	Musty Odor
Highland Park Middle School	3415	12/6/2023	11:43:00 AM	968		72.1	23.2	8	
Highland Park Middle School	3417	12/6/2023	11:38:00 AM	1173	0.2	71.8	25.7	14	
Highland Park Middle School	1319B	12/6/2023	10:26:00 AM	690		68.5	23	0	
Highland Park Middle School	1410A	12/6/2023	10:56:00 AM	497		71.1	19.3	0	
Highland Park Middle School	1410B	12/6/2023	10:57:00 AM	468	0.1	70.9	19.6	0	
Highland Park Middle School	EAST	12/6/2023	9:22:00 AM	1174		70.9	25.1	35	
Highland Park Middle School	KITCHEN	12/6/2023	9:37:00 AM	651		70.7	23.9	2	
Highland Park Middle School	KITCHEN OFFICE	12/6/2023	9:40:00 AM	1322	0.1	71.1	23.8	2	
Highland Park Middle School	LOWER GYM	12/6/2023	9:30:00 AM	999		71.8	23.6	18	
Highland Park Middle School	MAIN OFFICE	12/6/2023	9:41:00 AM	518		68	19.7	1	
Highland Park Middle School	OUTDOORS	12/6/2023		407		32	22.1		
Highland Park Senior High School	150	12/6/2023	11:40:00 AM	1001	0.2	72	25	25	
Highland Park Senior High School	154	12/6/2023	11:43:00 AM	500	0.2	71.1	19.9	1	Stained Ceiling Tiles
Highland Park Senior High School	158	12/6/2023	11:45:00 AM	535	0.2	70.3	20.3	1	Stained Ceiling Tiles
Highland Park Senior High School	159	12/6/2023	2:40:00 PM	610	0.2	72.5	21.9	20	Stained Ceiling Tiles
Highland Park Senior High School	160	12/6/2023	2:44:00 PM	616	0.2	72.5	24	0	
Highland Park Senior High School	303	12/6/2023	11:19:00 AM	459	0.2	72	18.4	0	
Highland Park Senior High School	304	12/6/2023	11:22:00 AM	456	0.2	72	18.4	0	
Highland Park Senior High School	401	12/6/2023	11:03:00 AM	408	0.2	71.4	17.7	10	Stained Ceiling Tiles
Highland Park Senior High School	403	12/6/2023	11:17:00 AM	469	0.2	72	18.4	1	
Highland Park Senior High School	412	12/6/2023	11:12:00 AM	397	0.2	73	18.8	1	
Highland Park Senior High School	425	12/6/2023	11:07:00 AM	379	0.2	72.7	17.4	1	Moisture Impacted Materials Location: Ceiling tiles cracking, Further Ass
Highland Park Senior High School	1001	12/6/2023	10:36:00 AM	648	0.2	69.6	20.1	4	Stained Ceiling Tiles
Highland Park Senior High School	1002	12/6/2023	10:43:00 AM	614	0.2	70.2	19.4	1	Stained Ceiling Tiles
Highland Park Senior High School	1003	12/6/2023	10:40:00 AM	728	0.2	70	20.7	2	
Highland Park Senior High School	1004	12/6/2023	10:38:00 AM	714	0.2	69.8	20.7	5	
Highland Park Senior High School	1005	12/6/2023	10:43:00 AM	653	0.2	70.2	19.9	1	
Highland Park Senior High School	1006	12/6/2023	10:45:00 AM	700	0.2	70	20.9	1	Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	1008	12/6/2023	10:35:00 AM	666	0.2	69.6	20.3	3	Stained Ceiling Tiles
Highland Park Senior High School	1009	12/6/2023	10:30:00 AM	613	0.2	69.6	19.8	1	
Highland Park Senior High School	1010	12/6/2023	10:33:00 AM	805	0.2	69.8	21.8	5	
Highland Park Senior High School	1101	12/6/2023	10:46:00 AM	468	0.2	70.3	18	25	
Highland Park Senior High School	1102	12/6/2023	10:48:00 AM	448	0.2	70.7	17.5	0	
Highland Park Senior High School	1103	12/6/2023	10:50:00 AM	451	0.2	70.7	17.5	0	
Highland Park Senior High School	1115	12/6/2023	10:55:00 AM	499	0.2	68.4	19.7	25	Bubbling/Peeling Paint
Highland Park Senior High School	1117	12/6/2023	10:52:00 AM	607	0.2	69.3	20.2	3	Stained Ceiling Tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Senior High School	1118	12/6/2023	10:54:00 AM	527	0.2	68.9	19.5	5	
Highland Park Senior High School	1201	12/6/2023	9:15:00 AM	508	0.2	72.5	17.2	1	
Highland Park Senior High School	1202	12/6/2023	9:17:00 AM	528	0.2	73	17.5	1	
Highland Park Senior High School	1203	12/6/2023	11:02:00 AM	534	0.2	73.4	18.5	1	
Highland Park Senior High School	1204	12/6/2023	10:57:00 AM	624	0.2	73.9	18.8	6	
Highland Park Senior High School	1205	12/6/2023	9:18:00 AM	558	0.2	69.6	19.2	25	Stained Ceiling Tiles
Highland Park Senior High School	1209	12/6/2023	9:22:00 AM	603	0.2	68.9	20.3	2	
Highland Park Senior High School	1210	12/6/2023	9:26:00 AM	795	0.2	68.4	20.8	15	
Highland Park Senior High School	1211	12/6/2023	9:28:00 AM	568	0.2	68.9	19.8	30	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	1212	12/6/2023	9:30:00 AM	505	0.2	68.7	19.1	1	
Highland Park Senior High School	1213	12/6/2023	9:31:00 AM	496	0.2	68.7	19	1	
Highland Park Senior High School	1215	12/6/2023	11:31:00 AM	490	0.2	70.2	19.7	0	Stained Ceiling Tiles
Highland Park Senior High School	1216	12/6/2023	11:29:00 AM	543	0.2	71.1	19.7	1	
Highland Park Senior High School	1217	12/6/2023	9:32:00 AM	517	0.2	69.1	19.3	4	
Highland Park Senior High School	1218	12/6/2023	11:22:00 AM	511	0.2	72	18.8	0	
Highland Park Senior High School	1303	12/6/2023	9:46:00 AM	572	0.2	70.7	18.3	1	
Highland Park Senior High School	1304	12/6/2023	9:50:00 AM	476	0.2	70.5	17	1	
Highland Park Senior High School	1305	12/6/2023	11:34:00 AM	503	0.2	71.6	19.3	1	
Highland Park Senior High School	1306	12/6/2023	9:47:00 AM	554	0.2	70.5	17.9	1	Fragrance Odor
Highland Park Senior High School	1307	12/6/2023	9:48:00 AM	465	0.2	70.7	16.8	0	
Highland Park Senior High School	1308	12/6/2023	9:51:00 AM	473	0.2	70.3	17.4	0	
Highland Park Senior High School	1309	12/6/2023	9:46:00 AM	594	0.2	70.3	18.3	1	
Highland Park Senior High School	1310	12/6/2023	9:52:00 AM	627	0.2	70.7	18.8	6	
Highland Park Senior High School	1311	12/6/2023	9:57:00 AM	612	0.2	71.8	17.9	1	
Highland Park Senior High School	1312	12/6/2023	9:58:00 AM	492	0.2	70.9	17.5	0	Stained Ceiling Tiles
Highland Park Senior High School	1314	12/6/2023	9:59:00 AM	688	0.2	70.7	19.4	9	Stained Ceiling Tiles
Highland Park Senior High School	1315	12/6/2023	10:02:00 AM	573	0.2	71.6	17.8	1	
Highland Park Senior High School	1316	12/6/2023	10:07:00 AM	535	0.2	72.1	17.3	0	
Highland Park Senior High School	1317	12/6/2023	10:19:00 AM	536	0.2	71.8	17.3	0	
Highland Park Senior High School	1319	12/6/2023	10:20:00 AM	521	0.2	71.1	17.7	0	Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	1320	12/6/2023	10:21:00 AM	518	0.2	70.9	17.9	0	
Highland Park Senior High School	1321	12/6/2023	10:21:00 AM	505	0.2	70.3	18.1	0	
Highland Park Senior High School	1322	12/6/2023	10:23:00 AM	553	0.2	70	18.9	0	Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	1323	12/6/2023	10:06:00 AM	574	0.2	73.4	16.7	0	
Highland Park Senior High School	1324	12/6/2023	10:05:00 AM	603	0.2	72.7	18.4	1	Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	1325	12/6/2023	10:04:00 AM	620	0.2	72.3	18.2	1	
Highland Park Senior High School	1328	12/6/2023	10:24:00 AM	637	0.2	70.3	19.5	25	
Highland Park Senior High School	1329	12/6/2023	10:25:00 AM	567	0.2	69.4	19.6	1	
Highland Park Senior High School	1330	12/6/2023	10:28:00 AM	593	0.2	67.6	21.2	1	Stained Ceiling Tiles
Highland Park Senior High School	1401	12/6/2023	9:23:00 AM	549	0.2	68.2	19.9	10	Stained Ceiling Tiles
Highland Park Senior High School	1405	12/6/2023	9:54:00 AM	559	0.2	69.8	19.5	25	
Highland Park Senior High School	2201	12/6/2023	2:25:00 PM	968	0.2	72.5	24.8	25	Stained Ceiling Tiles
Highland Park Senior High School	2202	12/6/2023	2:24:00 PM	793	0.2	72.1	23.4	30	Stained Ceiling Tiles
Highland Park Senior High School	2203	12/6/2023	12:50:00 PM	551	0.2	72	20.5	1	Stained Ceiling Tiles
Highland Park Senior High School	2204	12/6/2023	2:22:00 PM	1160	0.2	72	27.3	30	Stained Ceiling Tiles
Highland Park Senior High School	2205	12/6/2023	12:48:00 PM	628	0.2	72.1	20.7	2	Stained Ceiling Tiles
Highland Park Senior High School	2206	12/6/2023	2:20:00 PM	697	0.2	71.2	22.7	0	Fragrance Odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Senior High School	2207	12/6/2023	12:45:00 PM	809	0.2	72.5	22.5	1	
Highland Park Senior High School	2208	12/6/2023	2:18:00 PM	854	0.2	71.4	24.6	25	Stained Ceiling Tiles
Highland Park Senior High School	2209	12/6/2023	2:16:00 PM	689	0.2	71.2	23.3	25	
Highland Park Senior High School	2210	12/6/2023	12:43:00 PM	710	0.2	71.4	22.6	4	Stained Ceiling Tiles
Highland Park Senior High School	2211	12/6/2023	2:13:00 PM	582	0.2	70.3	22.4	3	
Highland Park Senior High School	2213	12/6/2023	2:12:00 PM	578	0.2	71.2	21.8	1	Stained Ceiling Tiles
Highland Park Senior High School	2214	12/6/2023	2:09:00 PM	801	0.2	71.2	24.5	40	
Highland Park Senior High School	2216	12/6/2023	12:42:00 PM	785	0.2	72.1	22.7	1	Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	2217	12/6/2023	12:38:00 PM	762	0.2	71.6	23.1	2	Stained Ceiling Tiles
Highland Park Senior High School	2218	12/6/2023	12:41:00 PM	707	0.2	72.5	22.5	2	Musty Odor
Highland Park Senior High School	2220	12/6/2023	2:08:00 PM	762	0.2	70.7	24.3	25	Stained Ceiling Tiles
Highland Park Senior High School	2222	12/6/2023	2:05:00 PM	891	0.2	71.4	25	35	
Highland Park Senior High School	2303	12/6/2023	2:38:00 PM	1085	0.2	72.7	25.4	25	
Highland Park Senior High School	2304	12/6/2023	12:36:00 PM	575	0.2	73.4	19.6	1	Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	2305	12/6/2023	12:35:00 PM	554	0.2	73.6	19.2	1	Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	2306	12/6/2023	12:33:00 PM	760	0.2	74.1	22	25	
Highland Park Senior High School	2307	12/6/2023	2:36:00 PM	858	0.2	72.3	23.9	25	
Highland Park Senior High School	2308	12/6/2023	12:32:00 PM	561	0.2	73.6	19.4	3	
Highland Park Senior High School	2309	12/6/2023	11:58:00 AM	945	0.2	73.4	23.5	30	
Highland Park Senior High School	2310	12/6/2023	12:30:00 PM	854	0.2	74.1	22.2	30	
Highland Park Senior High School	2311	12/6/2023	2:34:00 PM	894	0.2	73	24.1	20	
Highland Park Senior High School	2312	12/6/2023	12:52:00 PM	645	0.2	72.7	20.7	10	
Highland Park Senior High School	2313	12/6/2023	2:27:00 PM	846	0.2	72.9	23.3	25	
Highland Park Senior High School	2314	12/6/2023	2:32:00 PM	843	0.2	71.9	22.6	25	
Highland Park Senior High School	2401	12/6/2023	12:47:00 PM	540	0.2	72	21.3	11	
Highland Park Senior High School	3201	12/6/2023	12:57:00 PM	750	0.2	70.5	22.8	30	Bubbling/Peeling Paint
Highland Park Senior High School	3202	12/6/2023	12:58:00 PM	826	0.2	71.2	23.8	25	
Highland Park Senior High School	3203	12/6/2023	1:00:00 PM	871	0.2	71.4	24.1	30	Aquariums (fish), Plants: Kept Away From Return And Supply Vents, Taxidermy
Highland Park Senior High School	3204	12/6/2023	1:05:00 PM	806	0.2	71.4	23.7	15	Stained Ceiling Tiles, Aquariums (fish), Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	3205	12/6/2023	1:07:00 PM	740	0.2	71.1	23	25	Taxidermy
Highland Park Senior High School	3206	12/6/2023	1:11:00 PM	847	0.2	69.8	26.5	20	
Highland Park Senior High School	3207	12/6/2023	1:19:00 PM	725	0.2	70.3	24.4	25	Fragrance Odor
Highland Park Senior High School	3208	12/6/2023	1:22:00 PM	562	0.2	70.5	21.9	1	Stained Ceiling Tiles
Highland Park Senior High School	3209	12/6/2023	2:02:00 PM	523	0.2	70.7	22.8	0	
Highland Park Senior High School	3210	12/6/2023	1:25:00 PM	674	0.2	69.3	25.1	25	Stained Ceiling Tiles: Some stains look like splattered paint by others looking at it
Highland Park Senior High School	3211	12/6/2023	1:30:00 PM	684	0.2	66.6	26.5	20	
Highland Park Senior High School	3302	12/6/2023	1:34:00 PM	746	0.2	69.6	24.6	1	
Highland Park Senior High School	3303	12/6/2023	1:39:00 PM	818	0.2	71.6	23.4	15	
Highland Park Senior High School	3304	12/6/2023	1:40:00 PM	758	0.2	72.7	22.2	25	
Highland Park Senior High School	3305	12/6/2023	1:44:00 PM	718	0.2	74.8	20.1	1	
Highland Park Senior High School	3306	12/6/2023	1:46:00 PM	707	0.2	75	19.1	1	
Highland Park Senior High School	3307	12/6/2023	1:54:00 PM	674	0.2	73.8	20.9	8	Stained Ceiling Tiles
Highland Park Senior High School	3308	12/6/2023	1:50:00 PM	1143	0.2	72.5	25.5	25	Fragrance Odor, Stained Ceiling Tiles
Highland Park Senior High School	3309	12/6/2023	1:52:00 PM	962	0.2	72.5	24.6	25	
Highland Park Senior High School	3310	12/6/2023	1:56:00 PM	918	0.2	72.5	23.6	25	
Highland Park Senior High School	3311	12/6/2023	1:57:00 PM	960	0.2	71.2	24.6	25	Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	3312	12/6/2023	1:59:00 PM	840	0.2	70	24.6	25	Fragrance Odor, Stained Ceiling Tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highland Park Senior High School	1001A	12/6/2023	10:37:00 AM	654	0.2	69.6	20.3	2	
Highland Park Senior High School	1215A	12/6/2023	11:33:00 AM	463	0.2	69.8	19.9	0	
Highland Park Senior High School	1217A	12/6/2023	9:34:00 AM	630	0.2	70.5	21.8	1	Plants: Kept Away From Return And Supply Vents
Highland Park Senior High School	1328A	12/6/2023	10:30:00 AM	577	0.2	67.3	21.4	0	
Highland Park Senior High School	1329A	12/6/2023	10:28:00 AM	509	0.2	68.4	19.8	0	
Highland Park Senior High School	1329B	12/6/2023	10:26:00 AM	569	0.2	69.3	20	1	
Highland Park Senior High School	2213B	12/6/2023	2:15:00 PM	564	0.2	70.5	22.1	0	
Highland Park Senior High School	3202A	12/6/2023	1:37:00 PM	762	0.2	70.5	24.3	1	
Highland Park Senior High School	3204A	12/6/2023	1:02:00 PM	895	0.2	71.8	24.2	1	Fragrance Odor
Highland Park Senior High School	3205C	12/6/2023	1:10:00 PM	792	0.2	71.2	23.3	2	
Highland Park Senior High School	3206A	12/6/2023	1:16:00 PM	868	0.2	69.6	26.3	0	Bubbling/Peeling Paint along edges of the window, Stained Ceiling Tiles
Highland Park Senior High School	3210B	12/6/2023	1:28:00 PM	725	0.2	67.3	26.4	0	Stained Ceiling Tiles
Highland Park Senior High School	3304A	12/6/2023	1:42:00 PM	1120	0.2	74.5	23	1	
Highland Park Senior High School	3306A	12/6/2023	1:49:00 PM	590	0.2	73.2	19.7	1	
Highland Park Senior High School	CAFETERIA	12/6/2023	11:46:00 AM	666	0.2	70.7	23.5	65	Stained Ceiling Tiles
Highland Park Senior High School	OUTDOORS	12/6/2023		413	0.2	30	78		
Highwood Hills Elementary School	1103	1/19/2024	8:41:00 AM	623		72.7	6.5	0	
Highwood Hills Elementary School	1104	1/19/2024	8:44:00 AM	490		73.8	5.9	0	
Highwood Hills Elementary School	1107	1/19/2024	8:45:00 AM	493		73	6.6	0	
Highwood Hills Elementary School	1108	1/19/2024	8:48:00 AM	502		72.1	6.5	0	
Highwood Hills Elementary School	1112	1/19/2024	8:43:00 AM	588		73.4	6.5	0	
Highwood Hills Elementary School	1501	1/19/2024	8:34:00 AM	632		67.3	8.3	0	
Highwood Hills Elementary School	1502	1/19/2024	8:35:00 AM	838		68.7	11	30	
Highwood Hills Elementary School	1505	1/19/2024	8:33:00 AM	693		67.1	8.4	3	
Highwood Hills Elementary School	1506	1/19/2024	8:32:00 AM	603		68	7.7	0	
Highwood Hills Elementary School	1507	1/19/2024	8:29:00 AM	624		69	7.5	0	
Highwood Hills Elementary School	1601	1/19/2024	8:38:00 AM	718		69.8	8	0	
Highwood Hills Elementary School	1602	1/19/2024	8:40:00 AM	580		70.6	6.8	0	
Highwood Hills Elementary School	1603	1/19/2024	9:38:00 AM	608		70	6.7	0	
Highwood Hills Elementary School	1604	1/19/2024	8:39:00 AM	611		70.2	6.9	2	
Highwood Hills Elementary School	1605	1/19/2024	8:36:00 AM	660		69.6	7.6	3	
Highwood Hills Elementary School	1606	1/19/2024	9:46:00 AM	607		70.5	6.6	0	
Highwood Hills Elementary School	1607	1/19/2024	8:39:00 AM	637		70.3	8.4	3	
Highwood Hills Elementary School	2001	1/19/2024	10:03:00 AM	753		70.9	8.6	3	
Highwood Hills Elementary School	2003	1/19/2024	10:03:00 AM	748		70.9	7.6	1	
Highwood Hills Elementary School	2004	1/19/2024	10:04:00 AM	737		70.9	8.7	0	Fragrance Odor
Highwood Hills Elementary School	2005	1/19/2024	10:01:00 AM	653		71.1	7.4	1	
Highwood Hills Elementary School	2006	1/19/2024	10:06:00 AM	633		70.5	7.4	0	
Highwood Hills Elementary School	2007	1/19/2024	10:08:00 AM	617		70.5	7.3	0	
Highwood Hills Elementary School	2009	1/19/2024	10:07:00 AM	631		70.5	8.5	0	
Highwood Hills Elementary School	2011	1/19/2024	10:06:00 AM	632		70.5	7.6	0	
Highwood Hills Elementary School	2020	1/19/2024	8:25:00 AM	701		70.3	8.3	1	
Highwood Hills Elementary School	2101	1/19/2024	8:49:00 AM	769		69.6	8.8	0	
Highwood Hills Elementary School	2104	1/19/2024	9:37:00 AM	561		70.7	8.3	0	
Highwood Hills Elementary School	2201	1/19/2024	9:36:00 AM	1100		73.4	10.6	15	
Highwood Hills Elementary School	2203	1/19/2024	9:34:00 AM	777		73	8.1	20	
Highwood Hills Elementary School	2220	1/19/2024	9:30:00 AM	833		71.4	9.2	2	Fragrance Odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highwood Hills Elementary School	2221	1/19/2024	9:33:00 AM	756		71.1	8.4	1	Fragrance Odor
Highwood Hills Elementary School	2222	1/19/2024	9:33:00 AM	696		71.1	9.1	0	
Highwood Hills Elementary School	2225	1/19/2024	9:32:00 AM	749		71.2	10.1	0	
Highwood Hills Elementary School	2230	1/19/2024	9:29:00 AM	938		72.1	9.2	1	Fragrance Odor
Highwood Hills Elementary School	2302	1/19/2024	9:12:00 AM	761		70	9.5	0	
Highwood Hills Elementary School	2303	1/19/2024	9:10:00 AM	626		70	9	0	
Highwood Hills Elementary School	2304	1/19/2024	9:09:00 AM	709		70.3	10.2	2	
Highwood Hills Elementary School	2306	1/19/2024	9:07:00 AM	785		70.2	9	0	
Highwood Hills Elementary School	2309	1/19/2024	9:06:00 AM	667		70	8.3	0	
Highwood Hills Elementary School	2310	1/19/2024	9:03:00 AM	843		69.6	8	0	Taxidermy
Highwood Hills Elementary School	2311	1/19/2024	9:13:00 AM	1142		70.5	17.3	12	
Highwood Hills Elementary School	2312	1/19/2024	9:14:00 AM	625		70.3	7.4	0	
Highwood Hills Elementary School	2313	1/19/2024	9:17:00 AM	671		69.6	8.7	1	
Highwood Hills Elementary School	2314	1/19/2024	9:15:00 AM	681		70	7.4	2	
Highwood Hills Elementary School	2315	1/19/2024	9:19:00 AM	680		70	8.6	10	
Highwood Hills Elementary School	2316	1/19/2024	9:17:00 AM	728		69.4	7.5	0	
Highwood Hills Elementary School	2317	1/19/2024	9:20:00 AM	945		70.7	12.9	10	Odor Description: Rust/metallic Odor
Highwood Hills Elementary School	2318	1/19/2024	9:22:00 AM	610		70.7	8	0	
Highwood Hills Elementary School	2402	1/19/2024	9:24:00 AM	667		70.7	7.2	0	
Highwood Hills Elementary School	2403	1/19/2024	8:23:00 AM	673		68.4	8.7	1	
Highwood Hills Elementary School	2406	1/19/2024	9:26:00 AM	623		70.2	7.5	0	
Highwood Hills Elementary School	2407	1/19/2024	9:28:00 AM	681		73.8	6.6	4	
Highwood Hills Elementary School	2410	1/19/2024	10:20:00 AM	637		72.3	7	0	
Highwood Hills Elementary School	2416	1/19/2024	10:09:00 AM	630		70.5	7	0	
Highwood Hills Elementary School	2421	1/19/2024	10:11:00 AM	665		70.7	6.9	0	Food Odor
Highwood Hills Elementary School	2423	1/19/2024	10:12:00 AM	615		70.7	7.1	0	Food Odor
Highwood Hills Elementary School	2424	1/19/2024	10:13:00 AM	791		70.7	9	20	
Highwood Hills Elementary School	2426	1/19/2024	10:14:00 AM	623		70.9	7.9	0	
Highwood Hills Elementary School	2427	1/19/2024	10:10:00 AM	869		70.7	8.6	18	
Highwood Hills Elementary School	2501	1/19/2024	9:58:00 AM	659		71.8	7.1	0	
Highwood Hills Elementary School	2502	1/19/2024	9:55:00 AM	661		71.1	6.7	1	
Highwood Hills Elementary School	2503	1/19/2024	9:56:00 AM	755		72.5	7.8	12	Fragrance Odor
Highwood Hills Elementary School	2504	1/19/2024	9:57:00 AM	702		72.1	7.5	15	Plants: Kept Away From Return And Supply Vents
Highwood Hills Elementary School	2505	1/19/2024	9:58:00 AM	615		71.2	7.3	2	
Highwood Hills Elementary School	2506	1/19/2024	9:59:00 AM	770		70.7	7.8	22	
Highwood Hills Elementary School	2507	1/19/2024	10:00:00 AM	792		71.2	9.4	20	
Highwood Hills Elementary School	2601	1/19/2024	9:51:00 AM	949		70.7	8.8	0	
Highwood Hills Elementary School	2602	1/19/2024	9:47:00 AM	628		70.9	6.8	0	
Highwood Hills Elementary School	2603	1/19/2024	9:49:00 AM	789		70.9	8.5	20	
Highwood Hills Elementary School	2604	1/19/2024	9:50:00 AM	778		70.7	9.6	24	
Highwood Hills Elementary School	2605	1/19/2024	9:52:00 AM	607		70.7	8.8	0	
Highwood Hills Elementary School	2606	1/19/2024	9:53:00 AM	575		70.5	6.6	0	
Highwood Hills Elementary School	2607	1/19/2024	9:54:00 AM	626		70.5	7.2	2	
Highwood Hills Elementary School	2020A	1/19/2024	8:28:00 AM	583		70.3	7.7	0	
Highwood Hills Elementary School	2101A	1/19/2024	8:59:00 AM	680		70.9	7.5	0	
Highwood Hills Elementary School	2101B	1/19/2024	9:00:00 AM	671		72.3	6.5	0	
Highwood Hills Elementary School	2104A	1/19/2024	9:01:00 AM	594		70.7	7.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Highwood Hills Elementary School	2318A	1/19/2024	9:23:00 AM	733		70.5	9.2	0	
Highwood Hills Elementary School	OUTDOORS	1/19/2024		390	1.1		75		
Horace Mann School	204	12/12/2023	9:42:00 AM	681		71.7	13.7	5	
Horace Mann School	206	12/12/2023	8:31:00 AM	585		69.6	13.5	0	
Horace Mann School	210	12/12/2023	8:34:00 AM	530		68.4	13.6	0	
Horace Mann School	1001	12/12/2023	9:23:00 AM	697	0.1	68.2	15.8	1	
Horace Mann School	1002	12/12/2023	9:21:00 AM	610		67.5	15.4	0	
Horace Mann School	1003	12/12/2023	9:18:00 AM	624		67	16.1	2	
Horace Mann School	1005	12/12/2023	9:24:00 AM	714		68.4	16.8	3	
Horace Mann School	1101	12/12/2023	9:13:00 AM	695	0.1	68.2	15	20	
Horace Mann School	1102	12/12/2023	9:14:00 AM	877		68.5	17.7	22	Food Odor
Horace Mann School	1103	12/12/2023	9:15:00 AM	953	0.3	68.1	17.2	20	Fragrance Odor, Stained Ceiling Tiles, Plants: Kept Away From Return And
Horace Mann School	1108	12/12/2023	9:16:00 AM	610		67.8	13.1	2	Fragrance Odor
Horace Mann School	1202	12/12/2023	9:06:00 AM	743		69.8	15.1	20	
Horace Mann School	1203	12/12/2023	9:05:00 AM	695	0.1	69.7	13.9	3	Food Odor
Horace Mann School	1204	12/12/2023	9:00:00 AM	728		69.4	14.4	20	
Horace Mann School	1205	12/12/2023	9:01:00 AM	688		69.7	13.7	20	
Horace Mann School	1207	12/12/2023	9:02:00 AM	693		69.7	13.5	3	Fragrance Odor
Horace Mann School	1303	12/12/2023	9:12:00 AM	643		68	15.1	3	
Horace Mann School	1306	12/12/2023	9:07:00 AM	732	0.1	68	16.4	25	
Horace Mann School	1307	12/12/2023	10:01:00 AM	837		69.1	15.9	1	
Horace Mann School	1404	12/12/2023	8:45:00 AM	552	0.3	69.3	11.7	20	
Horace Mann School	1406	12/12/2023	8:49:00 AM	528		68.9	11.9	0	Food Odor
Horace Mann School	1501	12/12/2023	8:54:00 AM	761	0.2	68.8	14.7	20	Fragrance Odor
Horace Mann School	1504	12/12/2023	9:48:00 AM	731	0.7	71.5	11.5	20	Food Odor
Horace Mann School	1505	12/12/2023	8:51:00 AM	993	1.5	70.3	14.8	1	Food Odor
Horace Mann School	1600	12/12/2023	8:58:00 AM	718	0.2	68.3	13.4	4	
Horace Mann School	1601	12/12/2023	8:58:00 AM	762		69.2	15.2	25	
Horace Mann School	1603	12/12/2023	9:25:00 AM	653		67.4	13.9	15	
Horace Mann School	1605	12/12/2023	8:56:00 AM	929		68.9	17.3	18	
Horace Mann School	2102	12/12/2023	8:30:00 AM	661	0.1	69.6	16.3	3	
Horace Mann School	2103	12/12/2023	8:28:00 AM	876	0.2	69.4	18.1	20	
Horace Mann School	2104	12/12/2023	8:27:00 AM	813		69.1	17.6	15	
Horace Mann School	2105	12/12/2023	8:19:00 AM	1020		69	19.6	20	
Horace Mann School	2202	12/12/2023	9:28:00 AM	735	0.1	69.7	13.7	18	
Horace Mann School	2204	12/12/2023	9:32:00 AM	631		69.5	12.7	0	
Horace Mann School	2205	12/12/2023	9:33:00 AM	649		70.4	12.3	12	
Horace Mann School	2206	12/12/2023	9:35:00 AM	845	0.1	70.8	14.6	18	Fragrance Odor
Horace Mann School	2207	12/12/2023	8:44:00 AM	553		69.7	12.4	0	
Horace Mann School	2301	12/12/2023	9:41:00 AM	657		71	12.6	3	
Horace Mann School	2302	12/12/2023	8:42:00 AM	661		69.3	13.6	6	
Horace Mann School	2303	12/12/2023	9:40:00 AM	730		70.5	14	25	
Horace Mann School	2305	12/12/2023	9:38:00 AM	790	0.1	69.6	13.2	20	
Horace Mann School	2307	12/12/2023	8:41:00 AM	622	0.1	68.9	13.8	1	Plants
Horace Mann School	2308	12/12/2023	9:36:00 AM	584		69.9	10.9	0	
Horace Mann School	2309	12/12/2023	8:36:00 AM	631	0.2	68.7	13.5	1	Fragrance Odor
Horace Mann School	0208A	12/12/2023	8:07:00 AM	650	0.5	70.1	18.5	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Horace Mann School	0210A	12/12/2023	8:36:00 AM	516	0.1	68.3	13.2	0	
Horace Mann School	1505D	12/12/2023	8:53:00 AM	1157	1.2	70.5	15.8	2	Fragrance Odor
Horace Mann School	2100A	12/12/2023	8:29:00 AM	693		68.7	15.3	3	
Horace Mann School	2304A	12/12/2023	8:43:00 AM	658	0.1	69.3	13.2	1	
Horace Mann School	OUTDOORS	12/12/2023		456	2.4	22	66		
Hubbs Lifelong Learning	1001	11/29/2023	10:45:00 AM	710	1.6	72.1	18.9	1	
Hubbs Lifelong Learning	1002	11/29/2023	12:44:00 PM	608	0.4	71.4	18.8	0	
Hubbs Lifelong Learning	1003	11/29/2023	10:44:00 AM	697	1.6	72.1	18.3	1	
Hubbs Lifelong Learning	1004	11/29/2023	10:43:00 AM	659	1.6	72.3	18.5	0	
Hubbs Lifelong Learning	1005	11/29/2023	10:41:00 AM	710	1.7	72.5	18.2	1	
Hubbs Lifelong Learning	1101	11/29/2023	10:34:00 AM	696	1.8	73.4	17.5	7	
Hubbs Lifelong Learning	1102	11/29/2023	10:35:00 AM	857	1.8	73.4	18.4	3	Stained Ceiling Tiles
Hubbs Lifelong Learning	1103	11/29/2023	10:36:00 AM	727	1.8	73.4	19.1	3	
Hubbs Lifelong Learning	1104	11/29/2023	10:37:00 AM	584	1.8	72.7	17	0	
Hubbs Lifelong Learning	1105	11/29/2023	10:38:00 AM	608	1.8	72.1	17.4	0	
Hubbs Lifelong Learning	1106	11/29/2023	10:39:00 AM	734	1.7	72.1	18.8	1	
Hubbs Lifelong Learning	1107	11/29/2023	10:40:00 AM	613	1.7	72.5	17.1	0	
Hubbs Lifelong Learning	1108	11/29/2023	10:32:00 AM	985	1.7	73.9	20.3	15	
Hubbs Lifelong Learning	1109	11/29/2023	10:10:00 AM	721	1.1	68.5	22.3	1	
Hubbs Lifelong Learning	1110	11/29/2023	12:45:00 PM	730	0.4	72.3	20.1	1	
Hubbs Lifelong Learning	1201	11/29/2023	10:47:00 AM	696	1.5	72.1	19	10	
Hubbs Lifelong Learning	1203	11/29/2023	10:52:00 AM	606	1.5	73	16.5	0	
Hubbs Lifelong Learning	1204	11/29/2023	12:21:00 PM	760	0.5	70.9	20.9	6	
Hubbs Lifelong Learning	1205	11/29/2023	10:49:00 AM	739	1.5	72.7	18.1	1	
Hubbs Lifelong Learning	1206	11/29/2023	10:52:00 AM	1146	1.5	72.9	22.8	20	
Hubbs Lifelong Learning	1209	11/29/2023	10:31:00 AM	740	1.7	72.3	19.1	10	
Hubbs Lifelong Learning	1210	11/29/2023	12:25:00 PM	514	0.4	72.5	18	0	
Hubbs Lifelong Learning	1211	11/29/2023	10:17:00 AM	501	1.5	71.4	18	1	
Hubbs Lifelong Learning	1212	11/29/2023	10:13:00 AM	534	1.3	70.7	19.1	0	
Hubbs Lifelong Learning	1213	11/29/2023	10:17:00 AM	712	1.5	71.8	20.8	13	
Hubbs Lifelong Learning	1214	11/29/2023	10:19:00 AM	601	1.6	71.2	20.1	1	
Hubbs Lifelong Learning	1215	11/29/2023	10:23:00 AM	636	1.7	71.8	20	2	
Hubbs Lifelong Learning	1216	11/29/2023	10:20:00 AM	554	1.6	71.6	25	0	
Hubbs Lifelong Learning	1217	11/29/2023	10:28:00 AM	593	1.7	72.5	17.8	0	
Hubbs Lifelong Learning	1218	11/29/2023	10:30:00 AM	534	1.7	72.5	17.2	0	
Hubbs Lifelong Learning	1219	11/29/2023	10:27:00 AM	509	1.7	71.2	17.5	0	
Hubbs Lifelong Learning	1220	11/29/2023	12:42:00 PM	490	0.4	71.1	18.4	0	
Hubbs Lifelong Learning	1221	11/29/2023	10:25:00 AM	601	1.7	71.4	17.6	0	Stained Ceiling Tiles
Hubbs Lifelong Learning	1301	11/29/2023	12:22:00 PM	613	0.6	70.7	19	0	
Hubbs Lifelong Learning	1302	11/29/2023	12:14:00 PM	647	0.5	70.5	20.4	1	
Hubbs Lifelong Learning	1303	11/29/2023	12:19:00 PM	681	0.5	70.2	20.4	1	
Hubbs Lifelong Learning	1304	11/29/2023	12:18:00 PM	635	0.5	70.2	20.3	0	Plants
Hubbs Lifelong Learning	1305	11/29/2023	12:17:00 PM	590	0.5	70.3	19.7	0	
Hubbs Lifelong Learning	1306	11/29/2023	12:16:00 PM	660	0.5	70.3	19.8	1	
Hubbs Lifelong Learning	1307	11/29/2023	12:12:00 PM	849	0.5	70.3	22.3	12	
Hubbs Lifelong Learning	1308	11/29/2023	12:11:00 PM	830	0.6	70.5	21.7	12	
Hubbs Lifelong Learning	1309	11/29/2023	12:36:00 PM	715	0.4	72.1	19.9	12	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hubbs Lifelong Learning	1310	11/29/2023	12:40:00 PM	664	0.5	71.4	19.8	0	
Hubbs Lifelong Learning	1311	11/29/2023	12:39:00 PM	625	0.5	71.8	19.2	0	
Hubbs Lifelong Learning	1312	11/29/2023	12:38:00 PM	979	0.5	72.1	19.4	0	
Hubbs Lifelong Learning	1313	11/29/2023	12:37:00 PM	908	0.5	72.3	20.8	1	
Hubbs Lifelong Learning	1314	11/29/2023	12:33:00 PM	571	0.5	70.7	19.5	0	
Hubbs Lifelong Learning	1315	11/29/2023	12:09:00 PM	642	0.6	70.5	20.1	0	
Hubbs Lifelong Learning	1316	11/29/2023	12:04:00 PM	865	0.4	69.4	23.5	15	
Hubbs Lifelong Learning	1318	11/29/2023	12:07:00 PM	745	0.5	70	22.2	1	
Hubbs Lifelong Learning	1319	11/29/2023	12:06:00 PM	665	0.5	69.6	20.5	0	
Hubbs Lifelong Learning	1320	11/29/2023	12:05:00 PM	662	0.5	70	20.1	0	
Hubbs Lifelong Learning	1401	11/29/2023	12:24:00 PM	629	0.5	70.3	19.5	0	
Hubbs Lifelong Learning	1402	11/29/2023	12:28:00 PM	783	0.6	72	20.4	15	
Hubbs Lifelong Learning	1403	11/29/2023	12:30:00 PM	848	0.5	71.6	20.1	1	
Hubbs Lifelong Learning	1404	11/29/2023	12:31:00 PM	627	0.5	70.7	19.4	0	
Hubbs Lifelong Learning	1405	11/29/2023	12:32:00 PM	626	0.4	70.7	19.1	0	
Hubbs Lifelong Learning	1406	11/29/2023	11:24:00 AM	1223	0.9	72.3	24.5	15	
Hubbs Lifelong Learning	1407	11/29/2023	11:21:00 AM	1068	0.9	71.8	23.3	12	
Hubbs Lifelong Learning	1408	11/29/2023	11:26:00 AM	751	0.9	71.8	20.8	25	Plants
Hubbs Lifelong Learning	1409	11/29/2023	11:25:00 AM	752	0.9	72.1	19.1	3	
Hubbs Lifelong Learning	1410	11/29/2023	11:38:00 AM	875	0.7	70	21.1	0	
Hubbs Lifelong Learning	1411	11/29/2023	11:43:00 AM	802	0.7	69.8	21.6	1	
Hubbs Lifelong Learning	1412	11/29/2023	11:41:00 AM	643	0.7	70	19.4	0	
Hubbs Lifelong Learning	1413	11/29/2023	11:46:00 AM	918	0.6	68.5	24.6	15	
Hubbs Lifelong Learning	1414	11/29/2023	11:44:00 AM	668	0.6	69.3	20.8	0	
Hubbs Lifelong Learning	1415	11/29/2023	11:45:00 AM	712	0.6	68.7	21.1	0	
Hubbs Lifelong Learning	1416	11/29/2023	11:48:00 AM	1070	0.5	69.3	24.5	15	
Hubbs Lifelong Learning	1417	11/29/2023	11:40:00 AM	709	0.7	70.5	19.1	0	
Hubbs Lifelong Learning	1418	11/29/2023	11:29:00 AM	705	0.9	71.1	19.6	0	
Hubbs Lifelong Learning	1419	11/29/2023	11:30:00 AM	621	0.8	70.2	19.4	0	Stained Ceiling Tiles
Hubbs Lifelong Learning	1420	11/29/2023	11:32:00 AM	611	0.7	69.4	19.4	0	
Hubbs Lifelong Learning	1421	11/29/2023	11:33:00 AM	691	0.7	69.4	20.7	1	
Hubbs Lifelong Learning	1422	11/29/2023	11:34:00 AM	605	0.7	69.1	19.8	0	
Hubbs Lifelong Learning	1424	11/29/2023	11:36:00 AM	677	0.6	69.3	20.7	0	
Hubbs Lifelong Learning	1425	11/29/2023	11:37:00 AM	700	0.6	69.8	20.4	0	Stained Ceiling Tiles
Hubbs Lifelong Learning	1426	11/29/2023	11:50:00 AM	652	0.6	69.4	20.9	0	Stained Ceiling Tiles
Hubbs Lifelong Learning	1427	11/29/2023	11:53:00 AM	626	0.5	69.6	20.1	0	
Hubbs Lifelong Learning	1428	11/29/2023	11:55:00 AM	596	0.6	68.7	20.3	0	
Hubbs Lifelong Learning	1429	11/29/2023	11:57:00 AM	637	0.5	68.4	21.1	0	
Hubbs Lifelong Learning	1501	11/29/2023	11:19:00 AM	782	1	72	19.6	1	
Hubbs Lifelong Learning	1502	11/29/2023	11:17:00 AM	743	1	71	19	0	
Hubbs Lifelong Learning	1503	11/29/2023	11:16:00 AM	760	1.1	72	20	4	Stained Ceiling Tiles
Hubbs Lifelong Learning	1504	11/29/2023	11:14:00 AM	682	0.9	72	19	4	
Hubbs Lifelong Learning	1505	11/29/2023	11:12:00 AM	930	1	70	21.5	4	Stained Ceiling Tiles
Hubbs Lifelong Learning	1506	11/29/2023	11:11:00 AM	661	1	70	18	0	
Hubbs Lifelong Learning	1507	11/29/2023	11:10:00 AM	593	1	70	19	0	
Hubbs Lifelong Learning	1508	11/29/2023	11:07:00 AM	591	1.1	70.2	17.8	0	Stained Ceiling Tiles
Hubbs Lifelong Learning	1509	11/29/2023	10:59:00 AM	740	1.3	71.8	19.3	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Hubbs Lifelong Learning	1510	11/29/2023	11:00:00 AM	750	1.3	71.2	19.7	1	
Hubbs Lifelong Learning	1511	11/29/2023	11:02:00 AM	595	1.3	69.8	19.3	0	
Hubbs Lifelong Learning	1512	11/29/2023	11:03:00 AM	841	1	70	21.2	6	
Hubbs Lifelong Learning	1513	11/29/2023	11:06:00 AM	827	1	70.2	19.3	1	
Hubbs Lifelong Learning	LOBBY	11/29/2023	11:20:00 AM	748	1	71.4	20.2	10	
Hubbs Lifelong Learning	OUTDOORS	11/29/2023		434	1.4	34	76		
Humboldt Senior High School	1001	1/31/2024	11:15:00 AM	756	0.1	71.4	24.9	2	
Humboldt Senior High School	1003	1/31/2024	11:23:00 AM	723	0.1	69.4	25.9	0	
Humboldt Senior High School	1004	1/31/2024	11:23:00 AM	769	0.1	69.8	26.4	1	
Humboldt Senior High School	1005	1/31/2024	11:25:00 AM	762	0.1	70	26.1	1	
Humboldt Senior High School	1006	1/31/2024	10:52:00 AM	822	0.1	72	24.4	1	
Humboldt Senior High School	1007	1/31/2024	10:51:00 AM	843	0.1	72	25.1	1	
Humboldt Senior High School	1008	1/31/2024	10:50:00 AM	917	0.1	71.6	25.7	2	
Humboldt Senior High School	1009	1/31/2024	10:48:00 AM	777	0.1	71.2	25.1	1	
Humboldt Senior High School	1010	1/31/2024	10:44:00 AM	619	0.1	71.8	23.8	0	
Humboldt Senior High School	1011	1/31/2024	10:42:00 AM	699	0.1	71.8	23.2	1	
Humboldt Senior High School	1012	1/31/2024	10:40:00 AM	791	0.1	72.1	24.6	2	Live Animals: Mice trying to get in
Humboldt Senior High School	1013	1/31/2024	10:37:00 AM	682	0.1	71.2	24	0	
Humboldt Senior High School	1015	1/31/2024	11:02:00 AM	886	0.1	71.6	26.1	2	
Humboldt Senior High School	1016	1/31/2024	11:01:00 AM	709	0.1	71.8	23.5	1	
Humboldt Senior High School	1017	1/31/2024	10:59:00 AM	707	0.1	71.8	23.7	0	
Humboldt Senior High School	1018	1/31/2024	10:58:00 AM	716	0.1	72.1	23.7	0	
Humboldt Senior High School	1019	1/31/2024	10:56:00 AM	1025	0.1	71.4	25.8	3	Stained Ceiling Tiles
Humboldt Senior High School	1020	1/31/2024	10:54:00 AM	812	0.1	71.2	25.1	1	
Humboldt Senior High School	1021	1/31/2024	10:46:00 AM	834	0.1	71.2	25.4	1	
Humboldt Senior High School	1022	1/31/2024	10:49:00 AM	835	0.1	71.4	25.7	1	
Humboldt Senior High School	1023	1/31/2024	10:53:00 AM	807	0.1	71.4	24.8	2	
Humboldt Senior High School	1103	1/31/2024	12:42:00 PM	514	0.1	70	26.6	0	
Humboldt Senior High School	1104	1/31/2024	12:44:00 PM	523	0.1	70.3	26.7	3	
Humboldt Senior High School	1105	1/31/2024	12:40:00 PM	770	0.1	71.6	28.2	20	
Humboldt Senior High School	1106	1/31/2024	12:39:00 PM	494	0.1	71.4	25.4	0	
Humboldt Senior High School	1107	1/31/2024	12:36:00 PM	720	0.1	71.4	27.9	19	
Humboldt Senior High School	1108	1/31/2024	12:34:00 PM	698	0.1	72	27.4	18	
Humboldt Senior High School	1109	1/31/2024	11:12:00 AM	736	0.1	72.9	24.5	0	Musty Odor
Humboldt Senior High School	1112	1/31/2024	12:30:00 PM	723	0.1	71.6	27.2	20	
Humboldt Senior High School	1113	1/31/2024	11:09:00 AM	708	0.1	72.1	24.4	2	
Humboldt Senior High School	1115	1/31/2024	11:07:00 AM	662	0.1	71.8	24.7	6	Plants
Humboldt Senior High School	1201	1/31/2024	2:55:00 PM	484	0.1	70.5	28.9	2	
Humboldt Senior High School	1202	1/31/2024	2:45:00 PM	619	0.1	71.4	32.1	18	Aquariums (fish), Plants
Humboldt Senior High School	1203	1/31/2024	2:53:00 PM	489	0.1	70.9	29.7	0	
Humboldt Senior High School	1204	1/31/2024	2:54:00 PM	517	0.1	70.5	30.3	9	
Humboldt Senior High School	1205	1/31/2024	2:57:00 PM	469	0.1	70.9	27.9	8	Odor Description: Rubber Odor
Humboldt Senior High School	1206	1/31/2024	2:58:00 PM	493	0.1	71.1	28.1	0	
Humboldt Senior High School	1207	1/31/2024	9:57:00 AM	635	0.1	72	23.2	12	
Humboldt Senior High School	1208	1/31/2024	2:59:00 PM	763	2.1	72	29	0	Odor Description: Gas Odor, Gas
Humboldt Senior High School	1301	1/31/2024	11:30:00 AM	844	0.1	72	28	20	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	1302	1/31/2024	11:29:00 AM	890	0.1	71.8	28.3	33	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Humboldt Senior High School	1303	1/31/2024	11:26:00 AM	788	0.1	71.6	28.1	26	
Humboldt Senior High School	1304	1/31/2024	10:06:00 AM	580	0.1	72.5	22.1	1	
Humboldt Senior High School	1402	1/31/2024	3:01:00 PM	767	0.1	71.4	27.9	0	Stuffy Odor
Humboldt Senior High School	1403	1/31/2024	3:04:00 PM	808	0.1	70.2	30.6	1	
Humboldt Senior High School	1404	1/31/2024	3:08:00 PM	736	0.1	69.1	30	0	
Humboldt Senior High School	1502	1/31/2024	11:33:00 AM	711	0.1	70	28.6	18	
Humboldt Senior High School	1608	1/31/2024	10:11:00 AM	547	0.1	70.7	24.1	0	
Humboldt Senior High School	1701	1/31/2024	10:23:00 AM	778	0.1	71.6	24.4	7	
Humboldt Senior High School	1702	1/31/2024	10:26:00 AM	861	0.1	71.4	25.1	2	
Humboldt Senior High School	1703	1/31/2024	10:28:00 AM	873	0.1	71.1	25.9	2	
Humboldt Senior High School	1704	1/31/2024	10:29:00 AM	907	0.1	70.3	26.1	1	
Humboldt Senior High School	1705	1/31/2024	10:31:00 AM	849	0.1	70.3	25.7	1	
Humboldt Senior High School	1706	1/31/2024	10:31:00 AM	770	0.1	70	24.6	0	
Humboldt Senior High School	1707	1/31/2024	11:05:00 AM	816	0.1	72	25.6	2	
Humboldt Senior High School	1708	1/31/2024	10:33:00 AM	782	0.1	70.4	25.2	0	
Humboldt Senior High School	1709	1/31/2024	10:35:00 AM	663	0.1	70.9	24.2	0	
Humboldt Senior High School	1710	1/31/2024	9:55:00 AM	585	0.1	70.9	23.5	1	
Humboldt Senior High School	1711	1/31/2024	9:48:00 AM	490	0.1	70.5	22.9	5	
Humboldt Senior High School	1802	1/31/2024	9:44:00 AM	544	0.1	70	23.8	8	
Humboldt Senior High School	1803	1/31/2024	9:47:00 AM	549	0.1	70.3	23	1	
Humboldt Senior High School	1804	1/31/2024	9:51:00 AM	753	0.1	71.1	25.4	1	
Humboldt Senior High School	1805	1/31/2024	9:50:00 AM	686	0.1	70.5	24	6	
Humboldt Senior High School	1807	1/31/2024	9:54:00 AM	517	0.1	71.1	22.5	0	
Humboldt Senior High School	2102	1/31/2024	1:17:00 PM	597	0.1	70.3	27.5	1	Fragrance, Food Odor
Humboldt Senior High School	2104	1/31/2024	1:08:00 PM	901	0.1	71.4	29.5	29	
Humboldt Senior High School	2105	1/31/2024	1:10:00 PM	613	0.1	70.9	26.9	2	
Humboldt Senior High School	2106	1/31/2024	1:11:00 PM	637	0.1	70.9	28	22	
Humboldt Senior High School	2107	1/31/2024	1:13:00 PM	585	0.1	71.6	26	0	
Humboldt Senior High School	2108	1/31/2024	1:14:00 PM	576	0.1	71.1	26.5	0	
Humboldt Senior High School	2109	1/31/2024	1:18:00 PM	589	0.1	71.2	26.3	0	
Humboldt Senior High School	2201	1/31/2024	1:20:00 PM	990	0.1	72.3	28.9	14	
Humboldt Senior High School	2202	1/31/2024	1:23:00 PM	1047	0.1	73	29	21	
Humboldt Senior High School	2302	1/31/2024	12:50:00 PM	851	0.1	73	27.6	4	
Humboldt Senior High School	2303	1/31/2024	12:46:00 PM	944	0.1	72.5	29.7	30	
Humboldt Senior High School	2304	1/31/2024	12:53:00 PM	894	0.1	74.1	27.1	25	
Humboldt Senior High School	2305	1/31/2024	12:54:00 PM	803	0.1	73.9	25.3	7	
Humboldt Senior High School	2306	1/31/2024	12:55:00 PM	1129	0.1	74.3	28.5	21	
Humboldt Senior High School	2307	1/31/2024	12:57:00 PM	1030	0.1	74.5	27.7	24	
Humboldt Senior High School	2308	1/31/2024	12:58:00 PM	1034	0.1	74.5	26.7	1	
Humboldt Senior High School	2309	1/31/2024	11:56:00 AM	761	0.1	71.4	27.6	1	
Humboldt Senior High School	2310	1/31/2024	12:03:00 PM	680	0.1	71.6	26.6	2	
Humboldt Senior High School	2311	1/31/2024	12:08:00 PM	724	0.1	72	26.8	0	
Humboldt Senior High School	2312	1/31/2024	12:05:00 PM	799	0.1	71.8	27.5	6	
Humboldt Senior High School	2314	1/31/2024	1:00:00 PM	768	0.1	72.7	26.1	1	
Humboldt Senior High School	2402	1/31/2024	12:13:00 PM	808	0.1	73	25.9	1	
Humboldt Senior High School	2403	1/31/2024	12:21:00 PM	1007	0.1	73.4	27.6	24	
Humboldt Senior High School	2404	1/31/2024	12:15:00 PM	1084	0.1	73	29.3	40	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Humboldt Senior High School	2405	1/31/2024	12:17:00 PM	788	0.1	73	26.2	1	
Humboldt Senior High School	2406	1/31/2024	12:19:00 PM	830	0.1	73.2	26.5	6	
Humboldt Senior High School	2409	1/31/2024	12:22:00 PM	793	0.1	73.2	25.8	0	
Humboldt Senior High School	2501	1/31/2024	1:03:00 PM	827	0.1	72.7	26.8	1	
Humboldt Senior High School	2502	1/31/2024	1:05:00 PM	1237	0.1	72.9	30.8	22	
Humboldt Senior High School	2503	1/31/2024	1:06:00 PM	828	0.1	72	27.1	1	
Humboldt Senior High School	2504	1/31/2024	12:24:00 PM	825	0.1	73.2	26.2	19	
Humboldt Senior High School	2505	1/31/2024	12:26:00 PM	923	0.1	73.4	28.1	30	
Humboldt Senior High School	2506	1/31/2024	12:28:00 PM	905	0.1	73	27.7	28	
Humboldt Senior High School	2600	1/31/2024	12:12:00 PM	790	0.1	72.9	25.8	6	
Humboldt Senior High School	2606	1/31/2024	12:09:00 PM	765	0.1	72.3	24.3	1	
Humboldt Senior High School	3103	1/31/2024	2:26:00 PM	615	0.1	71.8	27	0	
Humboldt Senior High School	3104	1/31/2024	2:37:00 PM	984	0.1	72.7	30.9	14	
Humboldt Senior High School	3105	1/31/2024	2:28:00 PM	635	0.1	71.4	27.4	0	
Humboldt Senior High School	3106	1/31/2024	2:29:00 PM	1063	0.1	71.8	32.6	26	
Humboldt Senior High School	3107	1/31/2024	2:31:00 PM	954	0.1	72.1	29.4	32	
Humboldt Senior High School	3108	1/31/2024	2:32:00 PM	843	0.1	72.7	29.2	17	
Humboldt Senior High School	3109	1/31/2024	2:34:00 PM	598	0.1	72.7	26.1	0	
Humboldt Senior High School	3110	1/31/2024	2:35:00 PM	822	0.1	72.7	28.7	24	
Humboldt Senior High School	3111	1/31/2024	2:39:00 PM	587	0.1	72	26.7	0	
Humboldt Senior High School	3112	1/31/2024	3:22:00 PM	573	0.1	72.5	27.7	3	
Humboldt Senior High School	3114	1/31/2024	3:13:00 PM	513	0.1	72.1	27.7	6	Stained Ceiling Tiles
Humboldt Senior High School	3117	1/31/2024	3:19:00 PM	581	0.1	72.9	28	4	
Humboldt Senior High School	3126	1/31/2024	3:20:00 PM	493	0.1	72.3	27.3	0	
Humboldt Senior High School	3136	1/31/2024	11:48:00 AM	830	0.1	71.2	28.2	3	
Humboldt Senior High School	3150	1/31/2024	11:54:00 AM	647	0.1	67.1	35.2	25	
Humboldt Senior High School	3201	1/31/2024	2:40:00 PM	642	0.1	72.1	27.2	0	
Humboldt Senior High School	3202	1/31/2024	1:50:00 PM	688	0.1	72	27.3	2	
Humboldt Senior High School	3203	1/31/2024	1:52:00 PM	771	0.1	72.3	27.9	10	
Humboldt Senior High School	3301	1/31/2024	1:55:00 PM	705	0.1	72.5	26.9	0	
Humboldt Senior High School	3302	1/31/2024	1:57:00 PM	667	0.1	73.2	26.4	0	
Humboldt Senior High School	3303	1/31/2024	1:58:00 PM	762	0.1	73.2	26.6	10	
Humboldt Senior High School	3305	1/31/2024	2:00:00 PM	1002	0.1	73.2	29.4	22	
Humboldt Senior High School	3306	1/31/2024	2:01:00 PM	954	0.1	73.4	29	26	
Humboldt Senior High School	3307	1/31/2024	2:03:00 PM	693	0.1	73.2	26.2	0	
Humboldt Senior High School	3308	1/31/2024	2:05:00 PM	697	0.1	72.9	26	0	
Humboldt Senior High School	3309	1/31/2024	2:06:00 PM	1030	0.1	73	30.1	20	Stained Ceiling Tiles
Humboldt Senior High School	3310	1/31/2024	2:08:00 PM	906	0.1	73.2	27.4	8	
Humboldt Senior High School	3312	1/31/2024	2:09:00 PM	770	0.1	72.7	26.2	1	
Humboldt Senior High School	3401	1/31/2024	2:11:00 PM	938	0.1	72.5	28.2	25	
Humboldt Senior High School	3402	1/31/2024	2:13:00 PM	786	0.1	72.3	26.9	0	Plants: Kept Away From Return And Supply Vents
Humboldt Senior High School	3403	1/31/2024	2:17:00 PM	816	0.1	71.8	27.3	2	
Humboldt Senior High School	3404	1/31/2024	2:14:00 PM	780	0.1	72	27.1	0	Fragrance Odor
Humboldt Senior High School	3501	1/31/2024	2:18:00 PM	959	0.1	71.4	28.9	22	
Humboldt Senior High School	3502	1/31/2024	2:19:00 PM	920	0.1	72.1	28.4	18	
Humboldt Senior High School	3503	1/31/2024	2:21:00 PM	758	0.1	72.3	26.7	0	
Humboldt Senior High School	3504	1/31/2024	2:23:00 PM	735	0.1	72	26.4	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Humboldt Senior High School	3505	1/31/2024	2:25:00 PM	764	0.1	72	27.6	4	
Humboldt Senior High School	3601	1/31/2024	2:42:00 PM	975	0.1	72.9	28.8	9	
Humboldt Senior High School	3605	1/31/2024	2:43:00 PM	772	0.1	73	26.5	2	
Humboldt Senior High School	3608	1/31/2024	1:24:00 PM	665	0.1	71.2	27.4	2	
Humboldt Senior High School	1114A	1/31/2024	11:52:00 AM	424	0.1	64.2	31.2	1	
Humboldt Senior High School	1301B	1/31/2024	11:32:00 AM	546	0.1	72.1	23.3	0	
Humboldt Senior High School	1304A	1/31/2024	10:09:00 AM	1080	0.1	72.5	27.7	6	
Humboldt Senior High School	1304B	1/31/2024	10:08:00 AM	551	0.1	72.3	21.7	0	
Humboldt Senior High School	1304C	1/31/2024	10:07:00 AM	556	0.1	72.3	22	0	
Humboldt Senior High School	1403B	1/31/2024	3:07:00 PM	852	0.1	70	31.1	0	
Humboldt Senior High School	1502A	1/31/2024	11:36:00 AM	697	0.1	70.2	26.2	0	
Humboldt Senior High School	1502B	1/31/2024	11:38:00 AM	750	0.1	70.2	27.1	0	
Humboldt Senior High School	1608A	1/31/2024	10:15:00 AM	854	0.1	73.8	23.5	2	
Humboldt Senior High School	1608B	1/31/2024	10:19:00 AM	802	0.1	74.5	23.5	2	
Humboldt Senior High School	1608E	1/31/2024	10:21:00 AM	622	0.1	74.8	21.5	0	
Humboldt Senior High School	1608F	1/31/2024	10:20:00 AM	600	0.1	74.8	21.1	0	
Humboldt Senior High School	1608G	1/31/2024	10:13:00 AM	623	0.1	72.3	23.4	1	
Humboldt Senior High School	1608H	1/31/2024	10:18:00 AM	755	0.1	74.1	23.2	1	
Humboldt Senior High School	2300D	1/31/2024	3:16:00 PM	495	0.1	72.1	27.5	22	
Humboldt Senior High School	2300G	1/31/2024	9:40:00 AM	570	0.1	71.4	23.9	45	
Humboldt Senior High School	2300L	1/31/2024	9:43:00 AM	558	0.1	71.8	22.3	0	
Humboldt Senior High School	AUDITORIUM	1/31/2024	3:10:00 PM	433	0.1	70.2	27.9	0	
Humboldt Senior High School	CAFETERIA	1/31/2024	11:40:00 AM	684	0.1	70.9	27.5	60	
Humboldt Senior High School	DISHROOM	1/31/2024	11:46:00 AM	638	0.1	71.8	28.8	0	
Humboldt Senior High School	KITCHEN	1/31/2024	11:53:00 AM	465	0.1	62.8	34.4	6	
Humboldt Senior High School	OUTDOORS	1/31/2024		450	0.1	37	78		
Humboldt Senior High School	STAGE	1/31/2024	3:12:00 PM	419	0.1	70.5	27.6	0	
J.J. Hill Montessori	1001	1/17/2024	8:27:00 AM	554		70	7.7	2	
J.J. Hill Montessori	1002	1/17/2024	8:31:00 AM	616		70.7	8.3	3	
J.J. Hill Montessori	1003	1/17/2024	8:30:00 AM	647		70.5	8.9	1	
J.J. Hill Montessori	1004	1/17/2024	8:29:00 AM	533		69.8	6.7	1	
J.J. Hill Montessori	1005	1/17/2024	8:29:00 AM	544		69.6	6.9	1	
J.J. Hill Montessori	1008	1/17/2024	8:27:00 AM	558		69.6	7.9	1	
J.J. Hill Montessori	1009	1/17/2024	8:25:00 AM	614		69.3	9.2	2	
J.J. Hill Montessori	1010	1/17/2024	8:24:00 AM	526		68.2	7.2	0	
J.J. Hill Montessori	1011	1/17/2024	8:26:00 AM	522		69.3	6.8	0	
J.J. Hill Montessori	1012	1/17/2024	8:32:00 AM	549		70.9	6.6	1	
J.J. Hill Montessori	1013	1/17/2024	8:33:00 AM	574		70.5	6.6	1	
J.J. Hill Montessori	1014	1/17/2024	10:05:00 AM	635		69.6	7.7	1	
J.J. Hill Montessori	1101	1/17/2024	9:59:00 AM	655		69.3	8.4	0	
J.J. Hill Montessori	1102	1/17/2024	10:01:00 AM	661		69.3	8.3	0	
J.J. Hill Montessori	1103	1/17/2024	8:21:00 AM	573		66.2	10.1	3	
J.J. Hill Montessori	1105	1/17/2024	8:19:00 AM	625		63.9	11.7	1	
J.J. Hill Montessori	1108	1/17/2024	9:19:00 AM	579		69.3	8.4	1	
J.J. Hill Montessori	1109	1/17/2024	9:16:00 AM	606		68.9	8.8	10	
J.J. Hill Montessori	1110	1/17/2024	9:17:00 AM	589		69.3	8.5	10	
J.J. Hill Montessori	1201	1/17/2024	9:23:00 AM	808		69.8	10.8	25	Live Animals: Kept Away From Return And Supply Vents, Plants: Kept Aw

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
J.J. Hill Montessori	1203	1/17/2024	9:25:00 AM	779	0.1	69.4	10	8	Aquariums (fish), Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	1204	1/17/2024	9:27:00 AM	659		69.3	8.9	2	Stained Ceiling Tiles
J.J. Hill Montessori	1207	1/17/2024	9:29:00 AM	839		69.1	11.1	20	
J.J. Hill Montessori	1208	1/17/2024	9:31:00 AM	690	0.1	68.7	9.3	4	
J.J. Hill Montessori	1209	1/17/2024	9:32:00 AM	714		70	9.4	4	
J.J. Hill Montessori	1210	1/17/2024	9:34:00 AM	858		70.9	10.3	20	
J.J. Hill Montessori	1213	1/17/2024	9:39:00 AM	654	0.2	71.2	8.1	0	
J.J. Hill Montessori	1214	1/17/2024	9:36:00 AM	746	0.1	72.5	8.7	20	
J.J. Hill Montessori	1216	1/17/2024	9:40:00 AM	950	0.1	70.7	11.2	20	Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	1302	1/17/2024	8:38:00 AM	678		68.7	9.8	20	Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	1304	1/17/2024	8:39:00 AM	628		68.7	9	1	
J.J. Hill Montessori	1305	1/17/2024	8:48:00 AM	655		69.1	9.4	4	
J.J. Hill Montessori	1306	1/17/2024	9:43:00 AM	654	0.1	70.3	8.2	0	
J.J. Hill Montessori	1307	1/17/2024	9:54:00 AM	725		69.1	9.6	1	
J.J. Hill Montessori	1308	1/17/2024	8:58:00 AM	750		68.5	10.7	20	
J.J. Hill Montessori	1309	1/17/2024	9:00:00 AM	782		69.3	10.6	20	
J.J. Hill Montessori	1401	1/17/2024	8:35:00 AM	598		69.6	8.6	1	Aquariums (fish), Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	1402	1/17/2024	8:36:00 AM	679		68.9	9.4	20	
J.J. Hill Montessori	1403	1/17/2024	8:43:00 AM	685		69.1	9.3	20	Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	1404	1/17/2024	8:46:00 AM	614		68.7	9.4	2	Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	1405	1/17/2024	8:50:00 AM	713		69.3	9.8	20	Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	1407	1/17/2024	8:53:00 AM	756		69.1	10.5	15	Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	1409	1/17/2024	8:55:00 AM	777		68.4	11.3	20	Live Animals: Kept Away From Return And Supply Vents, Plants: Kept Aw
J.J. Hill Montessori	2200	1/17/2024	9:02:00 AM	725		69.3	10.3	5	
J.J. Hill Montessori	2201	1/17/2024	9:04:00 AM	684		70	9.5	1	Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	2203	1/17/2024	9:49:00 AM	715		68.7	9.1	0	
J.J. Hill Montessori	2204	1/17/2024	9:47:00 AM	681	0.1	69.4	8.8	3	
J.J. Hill Montessori	2207	1/17/2024	9:13:00 AM	667		69.4	9.3	1	Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	2208	1/17/2024	9:46:00 AM	684	0.1	70	8.6	3	
J.J. Hill Montessori	2209	1/17/2024	9:06:00 AM	812	0.1	70	10.4	15	Plants: Kept Away From Return And Supply Vents
J.J. Hill Montessori	2212	1/17/2024	9:08:00 AM	763	0.1	69.6	10.1	15	
J.J. Hill Montessori	2213	1/17/2024	9:10:00 AM	740	0.1	69.3	9.8	5	
J.J. Hill Montessori	2214	1/17/2024	9:11:00 AM	659		68.5	9.1	1	
J.J. Hill Montessori	2215	1/17/2024	9:03:00 AM	749		69.6	10.2	20	
J.J. Hill Montessori	1103E	1/17/2024	8:22:00 AM	566		67.3	9.5	1	
J.J. Hill Montessori	OUTDOORS	1/17/2024		405	0.2	2	79		
Jie Ming Mandarin Immersion Academy	1001	12/4/2023	12:40:00 PM	512	0.2	70.9	20.5	2	
Jie Ming Mandarin Immersion Academy	1003	12/4/2023	2:46:00 PM	538	0.2	69.6	21.6	0	Stained Ceiling Tiles
Jie Ming Mandarin Immersion Academy	1004	12/4/2023	12:44:00 PM	520	0.2	70.3	21.6	1	Plants: Kept Away From Return And Supply Vents
Jie Ming Mandarin Immersion Academy	1010	12/4/2023	12:42:00 PM	541	0.2	70.9	20.6	1	Stained Ceiling Tiles
Jie Ming Mandarin Immersion Academy	1012	12/4/2023	12:43:00 PM	558	0.2	70.9	20.8	1	
Jie Ming Mandarin Immersion Academy	1101	12/4/2023	12:35:00 PM	515	0.2	71.2	20.6	1	Stained Ceiling Tiles
Jie Ming Mandarin Immersion Academy	1103	12/4/2023	1:37:00 PM	557	0.2	71.4	20.5	25	Stained Ceiling Tiles
Jie Ming Mandarin Immersion Academy	1105	12/4/2023	1:46:00 PM	546	0.2	71.6	20.1	1	
Jie Ming Mandarin Immersion Academy	1107	12/4/2023	1:45:00 PM	592	0.2	71.4	20.7	1	
Jie Ming Mandarin Immersion Academy	1108	12/4/2023	1:28:00 PM	831	0.2	71.2	23.5	25	Plants: Kept Away From Return And Supply Vents
Jie Ming Mandarin Immersion Academy	1109	12/4/2023	12:31:00 PM	607	0.2	70.2	21.9	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Jie Ming Mandarin Immersion Academy	1110	12/4/2023	12:34:00 PM	711	0.2	70	22.9	1	
Jie Ming Mandarin Immersion Academy	1111	12/4/2023	2:19:00 PM	713	0.2	71.2	22.5	25	
Jie Ming Mandarin Immersion Academy	1112	12/4/2023	2:22:00 PM	612	0.2	70.5	22.4	20	
Jie Ming Mandarin Immersion Academy	1113	12/4/2023	2:25:00 PM	665	0.2	70.3	22.9	20	
Jie Ming Mandarin Immersion Academy	1114	12/4/2023	2:26:00 PM	670	0.2	70.5	23.2	20	
Jie Ming Mandarin Immersion Academy	1201	12/4/2023	1:26:00 PM	825	0.2	72.1	22.8	25	
Jie Ming Mandarin Immersion Academy	1203	12/4/2023	1:21:00 PM	715	0.2	71.6	22	25	
Jie Ming Mandarin Immersion Academy	1205	12/4/2023	2:32:00 PM	617	0.2	70.5	22	1	
Jie Ming Mandarin Immersion Academy	1206	12/4/2023	12:45:00 PM	671	0.2	70.2	23.3	6	
Jie Ming Mandarin Immersion Academy	1304	12/4/2023	1:00:00 PM	532	0.2	71.8	19.8	20	Plants: Kept Away From Return And Supply Vents
Jie Ming Mandarin Immersion Academy	1305	12/4/2023	12:15:00 PM	450	0.2	69.6	20.9	1	
Jie Ming Mandarin Immersion Academy	1315	12/4/2023	12:56:00 PM	519	0.2	72	20.2	5	Plants: Kept Away From Return And Supply Vents
Jie Ming Mandarin Immersion Academy	1316	12/4/2023	12:49:00 PM	640	0.2	70.7	21.7	30	
Jie Ming Mandarin Immersion Academy	1401	12/4/2023	1:47:00 PM	433	0.2	74.5	17.8	0	
Jie Ming Mandarin Immersion Academy	1402	12/4/2023	1:33:00 PM	474	0.2	69.1	20.5	20	
Jie Ming Mandarin Immersion Academy	1404	12/4/2023	12:52:00 PM	470	0.2	69.4	21.4	1	
Jie Ming Mandarin Immersion Academy	1502	12/4/2023	12:16:00 PM	624	0.2	70.3	23.2	60	
Jie Ming Mandarin Immersion Academy	1504	12/4/2023	12:21:00 PM	646	0.2	69.3	25.9	20	
Jie Ming Mandarin Immersion Academy	1508	12/4/2023	1:30:00 PM	674	0.2	69.6	23.6	25	
Jie Ming Mandarin Immersion Academy	1601	12/4/2023	12:24:00 PM	619	0.2	69.4	23	8	
Jie Ming Mandarin Immersion Academy	1602	12/4/2023	12:26:00 PM	723	0.2	69.4	23.9	30	
Jie Ming Mandarin Immersion Academy	1605	12/4/2023	12:30:00 PM	857	0.2	70.9	24.1	25	
Jie Ming Mandarin Immersion Academy	1606	12/4/2023	12:28:00 PM	788	0.2	70.5	24.4	20	
Jie Ming Mandarin Immersion Academy	2304	12/4/2023	1:02:00 PM	664	0.2	69.8	22.1	30	
Jie Ming Mandarin Immersion Academy	2307	12/4/2023	1:05:00 PM	600	0.2	71.2	21.4	25	
Jie Ming Mandarin Immersion Academy	2315	12/4/2023	2:27:00 PM	570	0.2	70.5	22.1	1	
Jie Ming Mandarin Immersion Academy	2316	12/4/2023	2:31:00 PM	620	0.2	71.1	22.1	25	
Jie Ming Mandarin Immersion Academy	3304	12/4/2023	1:15:00 PM	608	0.2	71.1	21.6	20	
Jie Ming Mandarin Immersion Academy	3305	12/4/2023	1:12:00 PM	500	0.2	70.7	20.4	4	
Jie Ming Mandarin Immersion Academy	3315	12/4/2023	1:11:00 PM	598	0.2	69.6	22.7	25	Plants: Kept Away From Return And Supply Vents
Jie Ming Mandarin Immersion Academy	3316	12/4/2023	1:17:00 PM	635	0.2	71.2	22.2	25	Bubbling/Peeling Paint
Jie Ming Mandarin Immersion Academy	1504A	12/4/2023	12:23:00 PM	653	0.2	69.4	28	1	
Jie Ming Mandarin Immersion Academy	1504C	12/4/2023	12:19:00 PM	696	0.2	69.4	25.4	1	
Jie Ming Mandarin Immersion Academy	OUTDOORS	12/4/2023		345	0.2	34	81		
Johnson Senior High School	201	2/9/2024	11:55:00 AM	823	0.2	70.2	22.3	13	
Johnson Senior High School	204	2/9/2024	12:09:00 PM	789	0.1	71.3	19.9	3	
Johnson Senior High School	208	1/22/2024	11:20:00 AM	735	0.1	69.8	13.8	1	
Johnson Senior High School	211	1/22/2024	11:23:00 AM	655	0.1	69.3	13.5	0	
Johnson Senior High School	212	1/22/2024	11:25:00 AM	630	0.1	69.1	15	0	
Johnson Senior High School	214	2/9/2024	11:51:00 AM	863	0.2	70.9	22.3	10	
Johnson Senior High School	215	2/9/2024	11:46:00 AM	709	0.2	70.7	21	7	
Johnson Senior High School	216	1/22/2024	11:31:00 AM	962	0.3	70.7	16.4	2	
Johnson Senior High School	217	1/22/2024	11:30:00 AM	1083	0.3	70.5	17.7	30	
Johnson Senior High School	218	1/22/2024	11:34:00 AM	928	0.3	70.9	18.7	25	
Johnson Senior High School	219	1/22/2024	11:33:00 AM	925	0.3	70.9	15.8	1	
Johnson Senior High School	307	1/22/2024	12:07:00 PM	727	0.9	70.3	21.3	0	
Johnson Senior High School	401	1/22/2024	11:34:00 AM	600	0.4	71.2	19	0	Musty Odor

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Johnson Senior High School	404	1/22/2024	12:06:00 PM	808	0.7	70.9	21.3	0	
Johnson Senior High School	1002	1/22/2024	11:34:00 AM	729	0.4	72.4	12.4	2	
Johnson Senior High School	1010	1/22/2024	11:45:00 AM	927	0.4	72.7	13.5	3	
Johnson Senior High School	1011	1/22/2024	11:46:00 AM	823	0.6	72.9	13.2	1	
Johnson Senior High School	1012	1/22/2024	11:47:00 AM	1003	0.4	73.2	13.6	2	
Johnson Senior High School	1013	1/22/2024	11:48:00 AM	846	0.5	73.4	12.8	1	
Johnson Senior High School	1014	1/22/2024	11:51:00 AM	824	0.5	72.5	12.7	1	Fragrance Odor
Johnson Senior High School	1015	1/22/2024	11:52:00 AM	1024	0.9	71.8	14.1	2	
Johnson Senior High School	1016	1/22/2024	11:49:00 AM	850	0.6	73.1	12.4	1	
Johnson Senior High School	1017	1/22/2024	9:59:00 AM	900	0.7	70.6	13.7	1	
Johnson Senior High School	1018	1/22/2024	10:02:00 AM	839	0.9	71.1	12.4	0	
Johnson Senior High School	1019	1/22/2024	10:11:00 AM	893	0.6	73	12.8	1	
Johnson Senior High School	1020	1/22/2024	10:14:00 AM	899	0.8	72.4	14.4	1	
Johnson Senior High School	1021	1/22/2024	10:13:00 AM	874	0.8	72.7	12.5	0	
Johnson Senior High School	1023	2/9/2024	11:03:00 AM	953	0.2	73.2	20.7	1	
Johnson Senior High School	1024	2/9/2024	11:02:00 AM	794	0.1	73	20.9	1	
Johnson Senior High School	1025	1/22/2024	10:06:00 AM	1049	0.7	73.1	13.6	0	
Johnson Senior High School	1026	2/9/2024	11:00:00 AM	760	0.1	72.7	20.8	4	
Johnson Senior High School	1027	2/9/2024	11:03:00 AM	842	0.1	73.1	21	3	
Johnson Senior High School	1101	2/9/2024	10:54:00 AM	1001	0.1	70.5	21.4	16	
Johnson Senior High School	1102	2/9/2024	10:56:00 AM	844	0.1	71.4	21.2	14	
Johnson Senior High School	1103	2/9/2024	10:49:00 AM	572	0.1	70.5	19.3	2	
Johnson Senior High School	1104	2/9/2024	10:52:00 AM	557	0.1	70.5	18.8	2	
Johnson Senior High School	1107	2/9/2024	10:45:00 AM	552	0.1	71.2	18.5	2	
Johnson Senior High School	1109	2/9/2024	10:42:00 AM	1040	0.1	71.1	21.4	22	
Johnson Senior High School	1111	2/9/2024	10:40:00 AM	684	0.1	70.9	20.2	2	
Johnson Senior High School	1112	2/9/2024	10:27:00 AM	548	0.1	70.7	19.1	2	
Johnson Senior High School	1113	2/9/2024	10:37:00 AM	779	0.1	70.9	20.5	17	
Johnson Senior High School	1115	2/9/2024	10:35:00 AM	563	0.1	70.9	19.3	1	
Johnson Senior High School	1117	2/9/2024	10:33:00 AM	550	0.1	70.9	18.3	1	
Johnson Senior High School	1119	2/9/2024	10:19:00 AM	789	0.1	72.3	19.3	16	
Johnson Senior High School	1201	2/9/2024	10:17:00 AM	711	0.1	71.8	19	13	
Johnson Senior High School	1203	2/9/2024	10:14:00 AM	655	0.1	71.1	18.6	2	
Johnson Senior High School	1205	2/9/2024	10:13:00 AM	628	0.1	70.5	19.1	4	
Johnson Senior High School	1206	2/9/2024	10:04:00 AM	556	0.1	70.2	19.3	6	
Johnson Senior High School	1207	2/9/2024	10:11:00 AM	671	0.1	70.7	19.3	15	
Johnson Senior High School	1208	2/9/2024	10:00:00 AM	778	0.1	70.3	20.5	12	
Johnson Senior High School	1209	2/9/2024	10:06:00 AM	865	0.1	70.2	20.8	11	
Johnson Senior High School	1210	2/9/2024	11:07:00 AM	573	0.1	72.3	18.8	3	
Johnson Senior High School	1212	2/9/2024	9:56:00 AM	622	0.1	70	20.1	7	
Johnson Senior High School	1213	2/9/2024	10:02:00 AM	732	0.1	70	20.5	11	
Johnson Senior High School	1215	2/9/2024	9:57:00 AM	734	0.1	70.2	20.7	14	
Johnson Senior High School	1217	2/9/2024	9:55:00 AM	613	0.1	69.4	19.8	14	
Johnson Senior High School	1218	2/9/2024	9:48:00 AM	539	0.1	69.4	19.4	2	
Johnson Senior High School	1219	2/9/2024	9:51:00 AM	511	0.1	69.3	18.6	15	
Johnson Senior High School	1221	2/9/2024	9:44:00 AM	469	0.1	68.4	20.1	4	
Johnson Senior High School	1224	1/22/2024	10:26:00 AM	958	0.9	72.2	13.9	3	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Johnson Senior High School	1302	1/22/2024	9:46:00 AM	601	0.5	68	15.2	5	
Johnson Senior High School	1310	1/22/2024	9:44:00 AM	769	0.9	68.5	12.8	0	
Johnson Senior High School	1311	1/22/2024	9:30:00 AM	539	1.3	70.1	11.2	2	
Johnson Senior High School	1401	1/22/2024	11:57:00 AM	891	0.5	71.5	16.1	200	
Johnson Senior High School	1407	1/22/2024	9:53:00 AM	681	0.9	70.2	15	1	
Johnson Senior High School	1410	1/22/2024	9:51:00 AM	528	0.9	69.7	13.6	5	
Johnson Senior High School	1502	1/22/2024	9:58:00 AM	494	0.3	70.5	10.4	0	
Johnson Senior High School	1504	1/22/2024	9:56:00 AM	705	0.3	69.7	11	0	
Johnson Senior High School	1601	1/22/2024	9:53:00 AM	826	0.9	67.9	12.5	24	
Johnson Senior High School	2102	1/22/2024	9:52:00 AM	542	0.3	72.7	11.2	4	
Johnson Senior High School	2103	1/22/2024	9:58:00 AM	715	0.2	71.4	12.8	4	
Johnson Senior High School	2107	1/22/2024	10:08:00 AM	940	0.2	72	13	1	
Johnson Senior High School	2108	1/22/2024	9:50:00 AM	646	0.2	76.6	10.2	5	
Johnson Senior High School	2110	1/22/2024	9:49:00 AM	600	0.2	72.3	11.4	2	
Johnson Senior High School	2111	1/22/2024	10:10:00 AM	974	0.2	71.4	14	15	
Johnson Senior High School	2112	1/22/2024	10:05:00 AM	1073	0.3	72.3	14.3	3	
Johnson Senior High School	2113	1/22/2024	10:12:00 AM	990	0.2	72	14	20	Plants: Kept Away From Return And Supply Vents
Johnson Senior High School	2114	2/9/2024	11:35:00 AM	566	0.1	71.1	19.8	2	
Johnson Senior High School	2115	1/22/2024	10:15:00 AM	1055	0.3	72.7	13.6	5	
Johnson Senior High School	2117	2/9/2024	11:30:00 AM	618	0.1	71.2	20.6	4	
Johnson Senior High School	2118	2/9/2024	11:32:00 AM	645	0.2	71.6	20.5	8	
Johnson Senior High School	2119	2/9/2024	11:24:00 AM	619	0.1	71.1	20.9	6	
Johnson Senior High School	2120	1/22/2024	10:19:00 AM	934	0.3	70.7	14	10	
Johnson Senior High School	2121	2/9/2024	11:22:00 AM	693	0.1	71.1	21.2	14	
Johnson Senior High School	2122	2/9/2024	11:27:00 AM	640	0.2	71.1	20.6	5	
Johnson Senior High School	2123	2/9/2024	11:20:00 AM	667	0.2	71.2	21	4	
Johnson Senior High School	2203	2/9/2024	11:19:00 AM	676	0.2	72.3	19.9	1	
Johnson Senior High School	2205	1/22/2024	10:33:00 AM	1041	0.3	70.5	13.5	0	
Johnson Senior High School	2206	2/9/2024	11:16:00 AM	1284	0.2	72.9	21.6	5	
Johnson Senior High School	2207	2/9/2024	11:13:00 AM	1048	0.1	71.8	22.8	15	
Johnson Senior High School	2208	2/9/2024	11:15:00 AM	674	0.1	72	20.7	6	
Johnson Senior High School	2209	2/9/2024	11:10:00 AM	844	0.1	72	21.2	16	
Johnson Senior High School	2210	2/9/2024	11:11:00 AM	963	0.1	71.6	22.1	16	
Johnson Senior High School	2211	1/22/2024	9:40:00 AM	805	0.4	72.9	12.3	20	
Johnson Senior High School	2212	1/22/2024	9:44:00 AM	812	0.2	72.7	11.8	10	
Johnson Senior High School	2213	1/22/2024	10:37:00 AM	755	0.7	71.8	13.3	0	
Johnson Senior High School	2218	1/22/2024	9:41:00 AM	893	0.4	73.4	13.4	3	
Johnson Senior High School	2220	1/22/2024	9:38:00 AM	821	0.3	72	11.5	0	Plants: Kept Away From Return And Supply Vents
Johnson Senior High School	2222	1/22/2024	9:31:00 AM	649	0.2	69.1	12.8	5	
Johnson Senior High School	2401	1/22/2024	10:55:00 AM	559	0.3	68.7	14	6	
Johnson Senior High School	2402	1/22/2024	10:42:00 AM	762	0.2	70.9	13.5	30	
Johnson Senior High School	2407	1/22/2024	10:43:00 AM	695	0.2	70.5	12.6	0	
Johnson Senior High School	2409	1/22/2024	10:41:00 AM	676	0.4	71.4	12.5	35	
Johnson Senior High School	2418	1/22/2024	10:53:00 AM	595	0.3	70.2	12.2	0	
Johnson Senior High School	2420	2/9/2024	11:42:00 AM	733	0.2	71.2	21.7	1	
Johnson Senior High School	2421	2/9/2024	11:40:00 AM	539	0.2	70.9	19.6	1	
Johnson Senior High School	2422	1/22/2024	10:49:00 AM	925	0.4	70.6	14	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Johnson Senior High School	2423	1/22/2024	10:47:00 AM	876	0.4	70.3	12.6	0	
Johnson Senior High School	2424	1/22/2024	10:45:00 AM	912	0.3	70.5	14.6	2	
Johnson Senior High School	2426	1/22/2024	10:57:00 AM	1025	0.1	68	17.8	30	
Johnson Senior High School	2427	1/22/2024	10:56:00 AM	906	0.2	67.3	17.2	0	
Johnson Senior High School	2503	1/22/2024	11:02:00 AM	446	0.1	70.9	10.1	0	
Johnson Senior High School	12088	1/22/2024	10:29:00 AM	1137	0.7	70.9	15.2	12	
Johnson Senior High School	100300	1/22/2024	11:29:00 AM	724	0.7	72.2	12	0	
Johnson Senior High School	0202A	2/9/2024	12:00:00 PM	625	1	70.2	21.3	2	
Johnson Senior High School	0202B	2/9/2024	12:01:00 PM	603	0.1	70	20.3	1	
Johnson Senior High School	0204A	2/9/2024	12:06:00 PM	834	0.1	70	21.1	1	
Johnson Senior High School	0208C	1/22/2024	11:21:00 AM	683	0.2	69.6	13.5	0	
Johnson Senior High School	1003A	1/22/2024	11:31:00 AM	810	0.6	72.4	14.3	1	
Johnson Senior High School	1003B	1/22/2024	11:32:00 AM	759	0.6	72.4	12.5	0	
Johnson Senior High School	1003C	1/22/2024	11:33:00 AM	725	0.7	72.3	11.5	0	
Johnson Senior High School	1003D	1/22/2024	11:27:00 AM	732	0.9	72.2	12.3	0	
Johnson Senior High School	1005A	1/22/2024	11:36:00 AM	795	0.6	72.3	14	3	
Johnson Senior High School	1005B	1/22/2024	11:37:00 AM	684	0.7	72.2	12.6	0	
Johnson Senior High School	1005C	1/22/2024	11:40:00 AM	958	0.2	73.3	15	2	
Johnson Senior High School	1005D	1/22/2024	11:41:00 AM	686	0.6	72.8	12.5	0	
Johnson Senior High School	1005E	1/22/2024	11:42:00 AM	713	0.7	72.4	13.5	1	Plants
Johnson Senior High School	1005F	1/22/2024	11:43:00 AM	852	0.7	72.5	14.8	5	
Johnson Senior High School	1006A	1/22/2024	11:26:00 AM	764	0.5	71.9	12.4	0	
Johnson Senior High School	1006B	1/22/2024	11:25:00 AM	979	0.6	71.7	14.9	4	
Johnson Senior High School	1006C	1/22/2024	11:22:00 AM	745	0.7	71.7	12	0	
Johnson Senior High School	1006D	1/22/2024	11:21:00 AM	811	0.5	72.2	12.8	1	
Johnson Senior High School	1006E	1/22/2024	11:19:00 AM	792	0.6	71.8	13	1	
Johnson Senior High School	1007B	1/22/2024	11:13:00 AM	775	0.9	71.6	12.5	0	
Johnson Senior High School	1103A	2/9/2024	10:47:00 AM	591	0.1	71.1	18.8	1	
Johnson Senior High School	1110A	2/9/2024	10:29:00 AM	742	0.1	70.7	20.9	1	
Johnson Senior High School	1110B	2/9/2024	10:27:00 AM	546	0.1	70.6	18.5	1	
Johnson Senior High School	1212A	2/9/2024	10:08:00 AM	520	0.1	70.7	19.3	1	
Johnson Senior High School	1219A	2/9/2024	9:53:00 AM	522	0.1	69.1	19.9	2	
Johnson Senior High School	2101A	1/22/2024	9:57:00 AM	674	0.2	71.1	12.8	6	Aquariums (fish)
Johnson Senior High School	2101B	1/22/2024	9:56:00 AM	715	0.2	71.8	13.1	20	
Johnson Senior High School	2105A	1/22/2024	10:03:00 AM	625	0.2	72.3	11.6	1	
Johnson Senior High School	2105B	1/22/2024	10:01:00 AM	729	0.2	72	12.9	15	Plants: Kept Away From Return And Supply Vents
Johnson Senior High School	2105C	1/22/2024	10:00:00 AM	767	0.2	71.8	13.1	20	
Johnson Senior High School	2113B	1/22/2024	10:14:00 AM	944	0.3	73	13	1	
Johnson Senior High School	2212B	1/22/2024	9:43:00 AM	883	0.2	73.2	12	25	
Johnson Senior High School	2222B	1/22/2024	9:35:00 AM	603	0.3	70.2	11.7	1	Plants: Kept Away From Return And Supply Vents
Johnson Senior High School	CR	1/22/2024	11:23:00 AM	784	0.7	71.5	12.4	0	
Johnson Senior High School	MEDIA CENTER	2/9/2024	10:22:00 AM	532	0.1	72.1	17.6	6	
Johnson Senior High School	OUTDOORS	2/9/2024	12:08:00 PM	454	0.4	32	30.6	0	
Johnson Senior High School	OUTDOORS	1/22/2024		412	3.6	22	27.3		
Journeys Secondary School	301	12/4/2023	12:52:00 PM	615	0.3	76.5	23.5	3	
Journeys Secondary School	1001	12/4/2023	1:12:00 PM	504	0.2	77.9	18.1	1	
Journeys Secondary School	1003	12/4/2023	1:29:00 PM	462	0.1	76.3	18.7	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Journeys Secondary School	1004	12/4/2023	1:19:00 PM	488		74.7	20.2	1	Food Odor, Plants: Kept Away From Return And Supply Vents
Journeys Secondary School	1005	12/4/2023	1:26:00 PM	461		75.7	19.2	0	
Journeys Secondary School	1006	12/4/2023	1:30:00 PM	452	0.1	76.3	18.8	0	
Journeys Secondary School	1101	12/4/2023	1:25:00 PM	474	0.1	75	19.5	1	
Journeys Secondary School	1104	12/4/2023	3:38:00 PM	444		77.7	17.3	1	
Journeys Secondary School	1106	12/4/2023	3:35:00 PM	566		77.2	20.5	7	
Journeys Secondary School	1109	12/4/2023	3:32:00 PM	419		74.3	19.4	0	
Journeys Secondary School	1110	12/4/2023	3:10:00 PM	437		77.2	17.7	0	
Journeys Secondary School	1111	12/4/2023	1:08:00 PM	531	0.3	77.5	19.3	4	Plants: Kept Away From Return And Supply Vents
Journeys Secondary School	1112	12/4/2023	1:06:00 PM	442		77.2	17.8	0	Fragrance Odor
Journeys Secondary School	1114	12/4/2023	1:03:00 PM	532	0.3	76.3	20	1	
Journeys Secondary School	1115	12/4/2023	12:56:00 PM	432	0.2	73.2	20.5	9	
Journeys Secondary School	1116	12/4/2023	3:25:00 PM	445		76.8	18.1	2	
Journeys Secondary School	1117	12/4/2023	1:00:00 PM	494	0.1	76.6	20	1	Stuffy Odor
Journeys Secondary School	1118	12/4/2023	3:23:00 PM	471		77.2	18.1	3	
Journeys Secondary School	2101	12/4/2023	1:31:00 PM	444		77.7	17.7	0	
Journeys Secondary School	2102	12/4/2023	1:45:00 PM	519		77.9	18.8	2	
Journeys Secondary School	2104	12/4/2023	1:49:00 PM	463		77	18.5	1	
Journeys Secondary School	2105	12/4/2023	1:48:00 PM	516		77.5	19.2	4	Plants: Kept Away From Return And Supply Vents
Journeys Secondary School	2106	12/4/2023	1:51:00 PM	472		77.5	18.1	0	
Journeys Secondary School	2107	12/4/2023	1:53:00 PM	500	0.1	76.5	19.6	1	Plants: Kept Away From Return And Supply Vents
Journeys Secondary School	2108	12/4/2023	1:55:00 PM	464		75.9	19.1	0	
Journeys Secondary School	2112	12/4/2023	1:59:00 PM	433		76.3	18.5	0	
Journeys Secondary School	2114	12/4/2023	2:17:00 PM	512		75	19.9	1	
Journeys Secondary School	2115	12/4/2023	2:14:00 PM	482		75.6	20.2	1	
Journeys Secondary School	3101	12/4/2023	3:05:00 PM	487		77.9	17.6	1	Fragrance Odor
Journeys Secondary School	3102	12/4/2023	3:02:00 PM	423		78.3	17	0	
Journeys Secondary School	3104	12/4/2023	2:58:00 PM	451		76.3	18.7	1	Live Animals: Kept Away From Return And Supply Vents, Plants: Kept Aw
Journeys Secondary School	3105	12/4/2023	3:02:00 PM	437		77	17.9	0	
Journeys Secondary School	3106	12/4/2023	2:46:00 PM	475		78.8	17.3	0	
Journeys Secondary School	3107	12/4/2023	2:48:00 PM	448		77.2	18	1	
Journeys Secondary School	3108	12/4/2023	2:43:00 PM	466		78.6	17.7	1	
Journeys Secondary School	3112	12/4/2023	2:39:00 PM	511		78.6	17.5	0	
Journeys Secondary School	3113	12/4/2023	2:28:00 PM	464	0.2	71.8	21.7	4	
Journeys Secondary School	3114	12/4/2023	2:24:00 PM	451		78.4	17.4	0	
Journeys Secondary School	3115	12/4/2023	2:22:00 PM	490		77.5	18	0	
Journeys Secondary School	3116	12/4/2023	2:19:00 PM	454		75.2	19.3	1	
Journeys Secondary School	1104A	12/4/2023	3:40:00 PM	437		77.5	17.7	0	
Journeys Secondary School	1115G	12/4/2023	3:28:00 PM	408		73.2	20.3	0	
Journeys Secondary School	1116A	12/4/2023	3:27:00 PM	440		76.5	18.4	0	
Journeys Secondary School	2112A	12/4/2023	2:10:00 PM	448		76.3	18.9	0	
Journeys Secondary School	2112B	12/4/2023	2:13:00 PM	477		75.9	19.2	1	
Journeys Secondary School	3101A	12/4/2023	3:07:00 PM	426		77	17.8	0	
Journeys Secondary School	3112B	12/4/2023	2:38:00 PM	615		76.5	19.9	6	
Journeys Secondary School	3113A	12/4/2023	2:32:00 PM	561		73.6	23.4	1	
Journeys Secondary School	3114A	12/4/2023	2:27:00 PM	451		77.9	17.8	0	Live Animals, Plants: Kept Away From Return And Supply Vents
Journeys Secondary School	OUTDOORS	12/4/2023		398	0.5	33	85		

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
LEAP at John A Johnson	1105	1/16/2024	11:59:00 AM	616		75.7	4.7	2	
LEAP at John A Johnson	1107	1/16/2024	11:58:00 AM	621		75	4.1	0	
LEAP at John A Johnson	1202	1/16/2024	9:19:00 AM	492		60.1	6.7	1	
LEAP at John A Johnson	2001	1/16/2024	9:33:00 AM	459		66.4	4.2	0	
LEAP at John A Johnson	2002	1/16/2024	9:34:00 AM	509		68.2	6.1	4	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	2003	1/16/2024	9:29:00 AM	482		67.6	4.4	1	
LEAP at John A Johnson	2004	1/16/2024	10:34:00 AM	525		78.1	4.8	0	
LEAP at John A Johnson	2005	1/16/2024	10:31:00 AM	540		77	4.5	1	
LEAP at John A Johnson	2102	1/16/2024	10:35:00 AM	495		74.5	3.2	0	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	2103	1/16/2024	9:43:00 AM	578		73	6.6	0	
LEAP at John A Johnson	2107	1/16/2024	9:50:00 AM	538		74.5	6.2	1	
LEAP at John A Johnson	2108	1/16/2024	10:05:00 AM	533		76.1	5.8	0	
LEAP at John A Johnson	2109	1/16/2024	10:00:00 AM	526		73	6.6	0	Stained Ceiling Tiles
LEAP at John A Johnson	2113	1/16/2024	10:02:00 AM	613		73.2	7.2	0	
LEAP at John A Johnson	2115	1/16/2024	10:03:00 AM	547		75.7	6.1	2	Stained Ceiling Tiles
LEAP at John A Johnson	2118	1/16/2024	9:42:00 AM	550		72.9	6.2	2	
LEAP at John A Johnson	2314	1/16/2024	10:29:00 AM	493		75.9	4.4	0	
LEAP at John A Johnson	2315	1/16/2024	10:16:00 AM	448		67.5	4.4	0	Suspect Microbial Growth: Ceiling tiles above sink, Further Assessment N
LEAP at John A Johnson	2316	1/16/2024	10:20:00 AM	604		72.9	5.7	0	
LEAP at John A Johnson	2317	1/16/2024	10:15:00 AM	469		75.4	3.2	0	
LEAP at John A Johnson	2319	1/16/2024	10:12:00 AM	514		76.3	4.8	0	Stained Ceiling Tiles
LEAP at John A Johnson	2320	1/16/2024	10:13:00 AM	479		76.6	4.8	0	Stained Ceiling Tiles
LEAP at John A Johnson	2322	1/16/2024	10:24:00 AM	478		74.1	4.9	0	
LEAP at John A Johnson	2323	1/16/2024	10:26:00 AM	495		73.4	4.5	2	
LEAP at John A Johnson	3003	1/16/2024	11:00:00 AM	660		82.4	4.7	2	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3005	1/16/2024	11:01:00 AM	642		83.3	4.4	1	
LEAP at John A Johnson	3007	1/16/2024	11:03:00 AM	643		81.3	5.1	1	
LEAP at John A Johnson	3113	1/16/2024	11:05:00 AM	748		75.7	6.6	12	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3115	1/16/2024	11:09:00 AM	891		70.2	10	15	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3117	1/16/2024	11:10:00 AM	946		70.2	10.7	15	
LEAP at John A Johnson	3201	1/16/2024	11:13:00 AM	939		68.7	11.2	15	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3202	1/16/2024	11:22:00 AM	766		72.5	8.3	3	
LEAP at John A Johnson	3203	1/16/2024	11:15:00 AM	914		70.3	11.5	15	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3301	1/16/2024	10:41:00 AM	802		76.1	7.3	5	Fragrance Odor
LEAP at John A Johnson	3303	1/16/2024	10:43:00 AM	758		74.3	7.3	12	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3305	1/16/2024	10:44:00 AM	840		74.8	9.1	20	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3400	1/16/2024	10:45:00 AM	647		77.5	6.3	1	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3401	1/16/2024	10:57:00 AM	660		85.1	4.3	0	
LEAP at John A Johnson	3402	1/16/2024	10:56:00 AM	639		86.7	3.6	0	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3402	1/16/2024	11:20:00 AM	767		72.3	8.4	0	
LEAP at John A Johnson	3403	1/16/2024	10:54:00 AM	656		87.4	3.8	1	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3404	1/16/2024	10:53:00 AM	645		87.4	3.4	0	
LEAP at John A Johnson	3405	1/16/2024	10:52:00 AM	639		87.6	3.6	0	
LEAP at John A Johnson	3406	1/16/2024	10:50:00 AM	681		83.7	4.8	1	
LEAP at John A Johnson	3408	1/16/2024	10:49:00 AM	647		82.8	5	1	
LEAP at John A Johnson	3409	1/16/2024	10:48:00 AM	683		80.4	6	1	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3410	1/16/2024	10:47:00 AM	669		79.5	6.5	1	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
LEAP at John A Johnson	4113	1/16/2024	11:50:00 AM	696		71.2	7.5	12	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	4115	1/16/2024	11:45:00 AM	690		71.6	7.9	0	
LEAP at John A Johnson	4117	1/16/2024	11:42:00 AM	749		74.3	7.6	2	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	4205	1/16/2024	11:41:00 AM	884		72.5	9.9	20	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	4206	1/16/2024	11:53:00 AM	656		72.9	7	0	
LEAP at John A Johnson	4207	1/16/2024	11:39:00 AM	741		74.7	7.7	0	
LEAP at John A Johnson	4301	1/16/2024	11:26:00 AM	980		73.8	11.1	20	
LEAP at John A Johnson	4303	1/16/2024	11:27:00 AM	778		73.8	8.5	1	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	4305	1/16/2024	11:37:00 AM	723		73.8	7.3	1	
LEAP at John A Johnson	4307	1/16/2024	11:31:00 AM	755		75.9	8.4	1	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	4311	1/16/2024	11:33:00 AM	558		75	4	1	Musty Odor
LEAP at John A Johnson	4313	1/16/2024	11:35:00 AM	490		71.4	5.8	0	
LEAP at John A Johnson	1105A	1/16/2024	9:24:00 AM	481		73	2.4	1	
LEAP at John A Johnson	1105J	1/16/2024	9:22:00 AM	480		71.2	2.8	1	
LEAP at John A Johnson	2002A	1/16/2024	9:36:00 AM	543		70.2	7.7	1	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	2002B	1/16/2024	9:40:00 AM	530		71.4	7.5	0	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	2002C	1/16/2024	9:39:00 AM	515		72.1	6.8	0	
LEAP at John A Johnson	2002E	1/16/2024	9:37:00 AM	566		71.4	6.8	1	
LEAP at John A Johnson	2003A	1/16/2024	9:27:00 AM	685		70.2	7	2	
LEAP at John A Johnson	2003B	1/16/2024	9:28:00 AM	498		69.1	4.5	1	
LEAP at John A Johnson	2003D	1/16/2024	9:30:00 AM	467		66.6	4.9	0	
LEAP at John A Johnson	2003E	1/16/2024	9:31:00 AM	467		66.2	5.3	0	
LEAP at John A Johnson	2003F	1/16/2024	9:31:00 AM	461		65.5	5	0	
LEAP at John A Johnson	2103A	1/16/2024	9:45:00 AM	527		72.9	6.5	0	
LEAP at John A Johnson	2103B	1/16/2024	9:46:00 AM	512		72.5	6.7	0	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	2103D	1/16/2024	9:48:00 AM	558		73	7	0	
LEAP at John A Johnson	2107A	1/16/2024	9:57:00 AM	588		74.3	7	0	
LEAP at John A Johnson	2107B	1/16/2024	9:58:00 AM	525		74.1	6.4	0	
LEAP at John A Johnson	2107C	1/16/2024	9:51:00 AM	609		73.9	6.7	1	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	2107D	1/16/2024	9:53:00 AM	772		75	8.3	0	Stained Ceiling Tiles
LEAP at John A Johnson	2107E	1/16/2024	9:55:00 AM	528		74.1	6.2	0	
LEAP at John A Johnson	2107F	1/16/2024	9:56:00 AM	567		74.3	6.6	0	
LEAP at John A Johnson	2118A	1/16/2024	9:41:00 AM	614		72.1	7.4	1	
LEAP at John A Johnson	3113A	1/16/2024	11:06:00 AM	705		70.9	7.3	0	Plants: Kept Away From Return And Supply Vents
LEAP at John A Johnson	3117A	1/16/2024	11:11:00 AM	981		68.5	10.6	1	
LEAP at John A Johnson	3117B	1/16/2024	11:12:00 AM	997		67.8	11.8	0	
LEAP at John A Johnson	3203B	1/16/2024	11:19:00 AM	851		71.2	10.6	1	
LEAP at John A Johnson	4115A	1/16/2024	11:48:00 AM	636		71.2	7.3	0	
LEAP at John A Johnson	4115B	1/16/2024	11:49:00 AM	714		70.7	8.6	0	
LEAP at John A Johnson	4117A	1/16/2024	11:45:00 AM	772		72.5	9.2	1	
LEAP at John A Johnson	4303A	1/16/2024	11:28:00 AM	760		73.9	8.5	0	
LEAP at John A Johnson	OUTDOORS	1/16/2024		422		3	57		
LEAP at John A Johnson	TA31	1/16/2024	10:32:00 AM	520		78.3	4.3	1	
LEAP at John A Johnson	TA6	1/16/2024	12:01:00 PM	764		74.8	5.6	1	
LEAP at John A Johnson	TA9	1/16/2024	9:23:00 AM	482		72.3	2.7	1	
L'Etoile du Nord - French Immersion	1101	1/12/2024	11:18:00 AM	736	0.2	69.6	12.1	0	
L'Etoile du Nord - French Immersion	1103	1/12/2024	10:28:00 AM	670	0.2	68.2	11.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
L'Etoile du Nord - French Immersion	1105	1/12/2024	10:26:00 AM	701	0.2	68.2	11.4	0	
L'Etoile du Nord - French Immersion	1106	1/12/2024	11:22:00 AM	903	0.2	70	13.3	20	
L'Etoile du Nord - French Immersion	1109	1/12/2024	11:23:00 AM	699	0.2	69.6	10.9	0	
L'Etoile du Nord - French Immersion	1111	1/12/2024	11:24:00 AM	720	0.2	69.8	11.9	1	
L'Etoile du Nord - French Immersion	1119	1/12/2024	11:25:00 AM	650	0.2	70.5	13.2	1	
L'Etoile du Nord - French Immersion	1122	1/12/2024	11:26:00 AM	601	0.2	70.5	11.3	0	Stained Ceiling Tiles
L'Etoile du Nord - French Immersion	1123	1/12/2024	11:27:00 AM	716	0.2	70.5	12.4	2	Plants: Kept Away From Return And Supply Vents
L'Etoile du Nord - French Immersion	1124	1/12/2024	11:28:00 AM	634	0.2	67.6	12.7	1	Stained Ceiling Tiles, Suspect Microbial Growth: Ceiling tile near window
L'Etoile du Nord - French Immersion	1125	1/12/2024	11:30:00 AM	655	0.2	68	13.2	0	Stained Ceiling Tiles
L'Etoile du Nord - French Immersion	1201	1/12/2024	11:15:00 AM	1125	0.2	67.5	20.2	60	
L'Etoile du Nord - French Immersion	1221	1/12/2024	10:29:00 AM	983	0.2	67.6	25.1	25	Stained Ceiling Tiles
L'Etoile du Nord - French Immersion	1226	1/12/2024	10:31:00 AM	702	0.2	67.6	23.8	0	
L'Etoile du Nord - French Immersion	2101	1/12/2024	10:40:00 AM	820	0.2	71.2	11.6	20	
L'Etoile du Nord - French Immersion	2102	1/12/2024	10:32:00 AM	758	0.2	69.6	11.8	24	
L'Etoile du Nord - French Immersion	2103	1/12/2024	10:39:00 AM	826	0.2	71.4	12.8	0	
L'Etoile du Nord - French Immersion	2105	1/12/2024	10:38:00 AM	830	0.2	71.2	12.2	0	
L'Etoile du Nord - French Immersion	2106	1/12/2024	10:35:00 AM	993	0.2	70.7	13.2	24	
L'Etoile du Nord - French Immersion	2107	1/12/2024	10:37:00 AM	838	0.2	71.2	11.8	15	
L'Etoile du Nord - French Immersion	2202	1/12/2024	10:41:00 AM	684	0.2	72	10.7	3	
L'Etoile du Nord - French Immersion	2212	1/12/2024	10:43:00 AM	735	0.2	71.4	10.5	0	
L'Etoile du Nord - French Immersion	2214	1/12/2024	10:44:00 AM	798	0.2	71.2	11.3	20	
L'Etoile du Nord - French Immersion	2215	1/12/2024	10:45:00 AM	991	0.2	71.1	12.6	20	
L'Etoile du Nord - French Immersion	2216	1/12/2024	10:46:00 AM	993	0.2	70.7	14.8	24	
L'Etoile du Nord - French Immersion	2217	1/12/2024	10:47:00 AM	983	0.2	70	14.4	24	Stained Ceiling Tiles: Pink stain, glycol
L'Etoile du Nord - French Immersion	2218	1/12/2024	10:49:00 AM	891	0.2	69.1	11.9	12	
L'Etoile du Nord - French Immersion	3101	1/12/2024	11:02:00 AM	1198	0.2	67.8	17.4	20	
L'Etoile du Nord - French Immersion	3102	1/12/2024	11:37:00 AM	1020	0.2	69.4	14.9	24	
L'Etoile du Nord - French Immersion	3105	1/12/2024	11:03:00 AM	705	0.2	68.4	11.5	0	
L'Etoile du Nord - French Immersion	3106	1/12/2024	11:04:00 AM	982	0.2	69.4	13.8	25	
L'Etoile du Nord - French Immersion	3107	1/12/2024	11:38:00 AM	774	0.2	70.2	11.9	0	
L'Etoile du Nord - French Immersion	3201	1/12/2024	10:56:00 AM	814	0.2	67.3	14.6	0	
L'Etoile du Nord - French Immersion	3202	1/12/2024	10:54:00 AM	1035	0.2	68.5	15.6	25	Stained Ceiling Tiles
L'Etoile du Nord - French Immersion	3212	1/12/2024	11:36:00 AM	744	0.2	68.7	12.1	0	
L'Etoile du Nord - French Immersion	3214	1/12/2024	10:50:00 AM	846	0.2	68.2	13.1	2	
L'Etoile du Nord - French Immersion	3215	1/12/2024	11:34:00 AM	859	0.2	68.2	12.9	20	Plants: Kept Away From Return And Supply Vents
L'Etoile du Nord - French Immersion	3216	1/12/2024	11:14:00 AM	725	0.2	67.8	11	20	
L'Etoile du Nord - French Immersion	3217	1/12/2024	11:31:00 AM	956	0.2	68.2	12.3	20	Plants
L'Etoile du Nord - French Immersion	3218	1/12/2024	11:11:00 AM	745	0.2	68	10.8	25	Plants: Kept Away From Return And Supply Vents
L'Etoile du Nord - French Immersion	1107A	1/12/2024	10:14:00 AM	677	0.2	70.3	10.6	1	
L'Etoile du Nord - French Immersion	1201A	1/12/2024	11:20:00 AM	972	0.2	70.9	16.7	2	
L'Etoile du Nord - French Immersion	3202A	1/12/2024	10:55:00 AM	1104	0.2	69.4	15.3	0	
L'Etoile du Nord - French Immersion	3214A	1/12/2024	10:52:00 AM	879	0.2	68.5	13.1	1	
L'Etoile du Nord - French Immersion	3214B	1/12/2024	10:53:00 AM	787	0.2	68.9	12	1	
L'Etoile du Nord - French Immersion	OUTDOORS	1/12/2024		510	1.1	8	79		
Maxfield Elementary School	1001	1/18/2024	9:37:00 AM	671		70.7	7.6	3	Plants: Kept Away From Return And Supply Vents
Maxfield Elementary School	1002	1/18/2024	9:39:00 AM	594		70.7	7.4	1	
Maxfield Elementary School	1003	1/18/2024	9:41:00 AM	576		70.5	7.6	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Maxfield Elementary School	1006	1/18/2024	9:42:00 AM	616		71.1	7.7	0	
Maxfield Elementary School	1007	1/18/2024	9:38:00 AM	644		71.1	6.7	1	Stained Ceiling Tiles
Maxfield Elementary School	1102	1/18/2024	9:04:00 AM	803		70	7.9	20	
Maxfield Elementary School	1103	1/18/2024	9:06:00 AM	775		70.5	7.5	15	Plants: Kept Away From Return And Supply Vents
Maxfield Elementary School	1104	1/18/2024	10:12:00 AM	575		69.3	5.5	15	Plants: Kept Away From Return And Supply Vents
Maxfield Elementary School	1105	1/18/2024	10:10:00 AM	610		69.1	6.5	20	Plants: Kept Away From Return And Supply Vents
Maxfield Elementary School	1106	1/18/2024	9:09:00 AM	550		69.1	5.9	4	Plants: Kept Away From Return And Supply Vents
Maxfield Elementary School	1110	1/18/2024	9:55:00 AM	451		70.3	4.4	0	Bubbling/Peeling Paint, Plants: Kept Away From Return And Supply Vents
Maxfield Elementary School	1111	1/18/2024	10:13:00 AM	570		69.1	6.4	0	
Maxfield Elementary School	1112	1/18/2024	9:36:00 AM	568		69.6	6.7	2	Fragrance Odor
Maxfield Elementary School	1201	1/18/2024	9:44:00 AM	641		71.6	7.6	20	
Maxfield Elementary School	1203	1/18/2024	9:45:00 AM	684		71.2	8.4	3	
Maxfield Elementary School	1204	1/18/2024	9:49:00 AM	695		73.8	11	5	
Maxfield Elementary School	1205	1/18/2024	9:48:00 AM	695		72.5	9.5	1	
Maxfield Elementary School	1208	1/18/2024	9:51:00 AM	705		73.4	11.2	1	
Maxfield Elementary School	1209	1/18/2024	9:52:00 AM	625	0.1	72.5	6.5	1	
Maxfield Elementary School	1210	1/18/2024	8:20:00 AM	712		67.3	10.5	1	
Maxfield Elementary School	1301	1/18/2024	8:28:00 AM	603		68.7	8.3	2	
Maxfield Elementary School	1302	1/18/2024	9:33:00 AM	712		69.3	9.1	15	
Maxfield Elementary School	1303	1/18/2024	9:30:00 AM	800	0.1	70.7	9.3	20	
Maxfield Elementary School	1304	1/18/2024	9:32:00 AM	628		69.8	7.1	0	
Maxfield Elementary School	1305	1/18/2024	8:27:00 AM	568		68.7	9.9	15	
Maxfield Elementary School	1306	1/18/2024	8:23:00 AM	681		68	9.5	20	
Maxfield Elementary School	1307	1/18/2024	8:30:00 AM	490		68	5.6	20	
Maxfield Elementary School	1308	1/18/2024	8:33:00 AM	615		67.5	8.3	1	Fragrance Odor
Maxfield Elementary School	1402	1/18/2024	8:34:00 AM	639		67.1	9.1	1	
Maxfield Elementary School	1403	1/18/2024	8:37:00 AM	590		68.4	7.8	0	
Maxfield Elementary School	1404	1/18/2024	8:39:00 AM	641		69.3	8.4	4	
Maxfield Elementary School	1405	1/18/2024	8:40:00 AM	645		69.4	8.3	0	
Maxfield Elementary School	1406	1/18/2024	8:41:00 AM	669		69.3	8.6	2	
Maxfield Elementary School	1407	1/18/2024	8:44:00 AM	671		68	8.9	1	
Maxfield Elementary School	1408	1/18/2024	8:43:00 AM	657		68.4	8.9	1	
Maxfield Elementary School	1409	1/18/2024	9:28:00 AM	867	0.4	74.5	8.3	15	
Maxfield Elementary School	1410	1/18/2024	9:27:00 AM	675	0.6	77.2	6.2	2	
Maxfield Elementary School	1411	1/18/2024	8:46:00 AM	681		67.6	9.038	0	
Maxfield Elementary School	1412	1/18/2024	8:46:00 AM	670		67.8	9.3	0	
Maxfield Elementary School	1413	1/18/2024	8:48:00 AM	791		68.4	9.6	20	
Maxfield Elementary School	1445	1/18/2024	8:35:00 AM	741		68.4	9.4	20	Stained Ceiling Tiles
Maxfield Elementary School	1501	1/18/2024	8:57:00 AM	660		68.7	8.8	15	
Maxfield Elementary School	1502	1/18/2024	8:58:00 AM	637		6.1	8	1	Stained Ceiling Tiles
Maxfield Elementary School	1504	1/18/2024	9:17:00 AM	640		68.5	8.1	15	Aquariums (fish), Live Animals: Kept Away From Return And Supply Vents
Maxfield Elementary School	1505	1/18/2024	8:55:00 AM	676		69.3	8.5	7	
Maxfield Elementary School	1506	1/18/2024	9:16:00 AM	636		69.3	8.4	15	
Maxfield Elementary School	1507	1/18/2024	8:53:00 AM	688		69.8	9.3	7	
Maxfield Elementary School	1508	1/18/2024	9:21:00 AM	650		68	9.6	0	
Maxfield Elementary School	1509	1/18/2024	9:20:00 AM	607		68.2	7.8	0	
Maxfield Elementary School	1510	1/18/2024	9:15:00 AM	650		69.4	8.4	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Maxfield Elementary School	1512	1/18/2024	9:23:00 AM	644		81.1	4.8	0	
Maxfield Elementary School	1602	1/18/2024	9:11:00 AM	987		68	14.2	20	Musty Odor
Maxfield Elementary School	1603	1/18/2024	9:13:00 AM	1108		68.5	12.6	20	
Maxfield Elementary School	2101	1/18/2024	10:06:00 AM	812		70.3	6.9	20	
Maxfield Elementary School	2102	1/18/2024	10:05:00 AM	907		70.3	8.4	15	
Maxfield Elementary School	2103	1/18/2024	10:04:00 AM	917		69.6	7.5	20	
Maxfield Elementary School	2104	1/18/2024	10:01:00 AM	1042		70	9.5	20	
Maxfield Elementary School	2105	1/18/2024	10:00:00 AM	768		69.8	7.1	20	
Maxfield Elementary School	2106	1/18/2024	9:58:00 AM	770		69.1	7.6	20	
Maxfield Elementary School	2110	1/18/2024	10:02:00 AM	553		70	5.9	1	Fragrance Odor, Bubbling/Peeling Paint
Maxfield Elementary School	2111	1/18/2024	10:08:00 AM	505		70	4	0	
Maxfield Elementary School	1412A	1/18/2024	8:59:00 AM	640		70	8.1	3	
Maxfield Elementary School	OUTDOORS	1/18/2024		402	0.3	5	72		
Mississippi Elementary School	1001	1/10/2024	1:03:00 PM	610		69.1	19.7	1	Stained Ceiling Tiles
Mississippi Elementary School	1002	1/10/2024	1:05:00 PM	643		70	19.8	1	Stained Ceiling Tiles
Mississippi Elementary School	1003	1/10/2024	1:03:00 PM	595		70.9	18.4	1	Stained Ceiling Tiles
Mississippi Elementary School	1004	1/10/2024	1:06:00 PM	632		72	18.5	1	Stained Ceiling Tiles
Mississippi Elementary School	1005	1/10/2024	1:08:00 PM	708		73.6	18.2	2	Stained Ceiling Tiles
Mississippi Elementary School	1103	1/10/2024	12:31:00 PM	600		69.6	19.9	2	
Mississippi Elementary School	1104	1/10/2024	12:59:00 PM	424		69.1	16.9	1	
Mississippi Elementary School	1106	1/10/2024	12:56:00 PM	404		70.2	14.5	8	
Mississippi Elementary School	1108	1/10/2024	1:10:00 PM	593		72.1	17.9	0	
Mississippi Elementary School	1110	1/10/2024	1:11:00 PM	778		71.6	22.1	60	Stained Ceiling Tiles
Mississippi Elementary School	1111	1/10/2024	1:13:00 PM	650		71.4	20.4	10	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1112	1/10/2024	2:30:00 PM	890		73.9	27.5	2	
Mississippi Elementary School	1113	1/10/2024	1:16:00 PM	687		71.1	21.4	5	Stained Ceiling Tiles
Mississippi Elementary School	1211	1/10/2024	12:32:00 PM	790		70.9	20	15	
Mississippi Elementary School	1212	1/10/2024	12:54:00 PM	969		73	20.5	5	
Mississippi Elementary School	1213	1/10/2024	12:35:00 PM	1153		72.3	24.4	6	
Mississippi Elementary School	1214	1/10/2024	2:24:00 PM	1284		77.9	23	20	
Mississippi Elementary School	1215	1/10/2024	12:40:00 PM	1760		73.9	32	30	
Mississippi Elementary School	1216	1/10/2024	2:20:00 PM	725		73.6	15.5	20	
Mississippi Elementary School	1218	1/10/2024	2:14:00 PM	1295		72.5	22.8	12	
Mississippi Elementary School	1219	1/10/2024	12:49:00 PM	708		72	22.1	20	
Mississippi Elementary School	1220	1/10/2024	12:52:00 PM	762		73	20	3	
Mississippi Elementary School	1221	1/10/2024	12:48:00 PM	824		72.1	33.5	20	
Mississippi Elementary School	1222	1/10/2024	12:47:00 PM	766		72.1	21.8	1	
Mississippi Elementary School	1223	1/10/2024	12:43:00 PM	615		73	19.3	3	
Mississippi Elementary School	1225	1/10/2024	12:44:00 PM	485		73.4	16.3	20	
Mississippi Elementary School	1230	1/10/2024	12:45:00 PM	489		72.5	17.6	20	
Mississippi Elementary School	1304	1/10/2024	1:19:00 PM	1334		71.4	24.6	20	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1309	1/10/2024	1:23:00 PM	979		72	20.4	2	
Mississippi Elementary School	1310	1/10/2024	1:21:00 PM	1035		71.2	22.8	20	
Mississippi Elementary School	1311	1/10/2024	2:35:00 PM	1353		71.1	23.7	0	
Mississippi Elementary School	1313	1/10/2024	2:38:00 PM	1014		70.2	22.3	1	
Mississippi Elementary School	1314	1/10/2024	1:25:00 PM	737		73.2	18.1	11	
Mississippi Elementary School	1315	1/10/2024	1:27:00 PM	905		73.2	19	3	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Mississippi Elementary School	1316	1/10/2024	1:37:00 PM	688		68.9	19.1	1	Fragrance Odor
Mississippi Elementary School	1318	1/10/2024	1:36:00 PM	899		69.3	20.7	1	
Mississippi Elementary School	1320	1/10/2024	1:34:00 PM	926		69.4	36.5	20	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1321	1/10/2024	2:43:00 PM	772		69.6	20.2	1	Stained Ceiling Tiles
Mississippi Elementary School	1322	1/10/2024	1:31:00 PM	814		69.1	22.1	20	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	1323	1/10/2024	1:29:00 PM	738		70.7	18.2	20	Stained Ceiling Tiles
Mississippi Elementary School	1325	1/10/2024	2:44:00 PM	1189		69.3	23.5	20	Stained Ceiling Tiles
Mississippi Elementary School	2211	1/10/2024	1:45:00 PM	1308		72.3	25.2	3	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2212	1/10/2024	1:47:00 PM	1115		72.7	24.4	20	
Mississippi Elementary School	2213	1/10/2024	1:48:00 PM	1385		73.8	26.1	20	Dirty Or Dusty Carpet Odor
Mississippi Elementary School	2214	1/10/2024	1:51:00 PM	1288		73	23.1	25	Taxidermy
Mississippi Elementary School	2215	1/10/2024	1:50:00 PM	890		74.1	20.8	25	
Mississippi Elementary School	2216	1/10/2024	1:54:00 PM	1284		73.6	22.6	20	
Mississippi Elementary School	2217	1/10/2024	1:53:00 PM	935		73.4	21	20	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2218	1/10/2024	1:56:00 PM	1269		73	21.8	25	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2219	1/10/2024	1:58:00 PM	793		72.5	18.3	12	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2220	1/10/2024	1:59:00 PM	997		72.5	19.5	2	
Mississippi Elementary School	2221	1/10/2024	2:01:00 PM	579		72	17.4	3	
Mississippi Elementary School	2222	1/10/2024	2:00:00 PM	863		72.3	19.2	3	
Mississippi Elementary School	2223	1/10/2024	2:49:00 PM	833		72.3	23.3	1	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2225	1/10/2024	2:04:00 PM	927		72.7	21.5	1	
Mississippi Elementary School	2228	1/10/2024	2:46:00 PM	631		72.1	17.5	25	Plants: Kept Away From Return And Supply Vents
Mississippi Elementary School	2229	1/10/2024	2:05:00 PM	985		73.6	21.4	5	
Mississippi Elementary School	1004A	1/10/2024	1:07:00 PM	671		72.5	18.5	1	Stained Ceiling Tiles
Mississippi Elementary School	1110A	1/10/2024	2:32:00 PM	876		72.9	25	1	
Mississippi Elementary School	1111A	1/10/2024	1:14:00 PM	606		71.1	19.7	0	
Mississippi Elementary School	OUTDOORS	1/10/2024		423		21	81		
Murray Junior High School	203	1/16/2024	9:39:00 AM	736	0.1	68.9	8	20	
Murray Junior High School	206	1/16/2024	10:32:00 AM	1054	0.3	71.8	6.9	0	
Murray Junior High School	209	1/16/2024	10:33:00 AM	1156	0.5	71.8	9.9	18	
Murray Junior High School	211	1/16/2024	9:35:00 AM	845	0.3	69.3	8.5	12	
Murray Junior High School	212	1/16/2024	9:37:00 AM	646	0.2	68.4	6.8	2	
Murray Junior High School	215	1/16/2024	9:34:00 AM	836	0.4	69.6	9.2	20	
Murray Junior High School	216	1/16/2024	9:36:00 AM	695	0.2	69.1	7.2	0	Fragrance Odor
Murray Junior High School	217	1/16/2024	9:32:00 AM	820	0.3	70.2	8.4	20	
Murray Junior High School	405	1/16/2024	9:24:00 AM	619	0.2	72.9	4	0	
Murray Junior High School	407	1/16/2024	9:29:00 AM	593	0.3	72.5	4.4	12	
Murray Junior High School	408	1/16/2024	9:23:00 AM	576	0.1	71.1	5.6	16	
Murray Junior High School	409	1/16/2024	9:31:00 AM	830	0.2	73	6.7	20	
Murray Junior High School	410	1/16/2024	9:26:00 AM	634	0.4	74.3	4.1	30	
Murray Junior High School	412	1/16/2024	9:30:00 AM	724	0.3	73	6.9	15	
Murray Junior High School	1001	1/16/2024	11:32:00 AM	698		7.9	8.2	1	Stained Ceiling Tiles
Murray Junior High School	1002	1/16/2024	11:29:00 AM	806	0.2	69.1	9.2	0	Food Odor
Murray Junior High School	1003	1/16/2024	11:32:00 AM	863	0.1	70.5	9.2	1	
Murray Junior High School	1004	1/16/2024	11:34:00 AM	738	0.1	71.6	8.3	0	
Murray Junior High School	1005	1/16/2024	11:34:00 AM	720	0.2	71.6	7.2	1	
Murray Junior High School	1006	1/16/2024	11:35:00 AM	758	0.2	71.4	8.4	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Murray Junior High School	1007	1/16/2024	11:36:00 AM	897	0.2	71.8	8.1	2	
Murray Junior High School	1008	1/16/2024	11:37:00 AM	770	0.2	71.6	7.2	0	
Murray Junior High School	1009	1/16/2024	11:38:00 AM	766	0.3	71.6	7.9	2	Fragrance Odor
Murray Junior High School	1010	1/16/2024	11:39:00 AM	674	0.1	71.2	6.5	0	
Murray Junior High School	1011	1/16/2024	11:43:00 AM	883	0.2	70	8.7	0	Fragrance Odor
Murray Junior High School	1012	1/16/2024	11:42:00 AM	751	0.2	70.2	9	1	Stained Ceiling Tiles
Murray Junior High School	1013	1/16/2024	11:41:00 AM	742	0.2	71.1	10.5	1	Fragrance Odor, Stained Ceiling Tiles
Murray Junior High School	1101	1/16/2024	10:36:00 AM	531	0.3	68.2	7.8	15	
Murray Junior High School	1104	1/16/2024	11:44:00 AM	636	0.3	67.6	9.5	60	
Murray Junior High School	1105	1/16/2024	10:57:00 AM	702	0.4	73	8.5	20	
Murray Junior High School	1108	1/16/2024	10:45:00 AM	691	0.1	68	9.3	0	
Murray Junior High School	1202	1/16/2024	11:26:00 AM	1076	0.3	72.5	10.8	20	Fragrance Odor
Murray Junior High School	1203	1/16/2024	11:25:00 AM	982	0.3	71.1	9.9	1	
Murray Junior High School	1204	1/16/2024	11:27:00 AM	1237	0.2	72.9	9.9	0	Fragrance Odor
Murray Junior High School	1205	1/16/2024	11:22:00 AM	1008	0.3	70.5	10.2	1	
Murray Junior High School	1207	1/16/2024	11:21:00 AM	1075	0.2	70.5	10.3	0	Plants: Kept Away From Return And Supply Vents
Murray Junior High School	1209	1/16/2024	11:19:00 AM	867	0.2	70.2	10.8	3	Food Odor
Murray Junior High School	1211	1/16/2024	11:17:00 AM	1024	0.3	70.3	11.4	22	
Murray Junior High School	1212	1/16/2024	11:24:00 AM	1027	0.2	71.2	12.6	10	
Murray Junior High School	1214	1/16/2024	11:20:00 AM	1155	0.3	70	12.6	25	
Murray Junior High School	1216	1/16/2024	11:18:00 AM	814	0.3	70.2	9.3	1	
Murray Junior High School	1218	1/16/2024	11:13:00 AM	1110	0.3	70.5	11.6	25	
Murray Junior High School	1301	1/16/2024	11:03:00 AM	553	0.2	67.5	7.5	0	
Murray Junior High School	1401	1/16/2024	11:11:00 AM	1072	0.3	72.1	9.3	1	
Murray Junior High School	1403	1/16/2024	11:09:00 AM	1037	0.3	71.6	9.8	1	
Murray Junior High School	2102	1/16/2024	10:03:00 AM	824	0.2	69.1	9.9	20	Food Odor
Murray Junior High School	2103	1/16/2024	10:15:00 AM	928	0.2	69.4	10.7	25	
Murray Junior High School	2104	1/16/2024	10:19:00 AM	853	0.3	69.8	12.2	18	
Murray Junior High School	2105	1/16/2024	10:20:00 AM	821	0.3	72.3	9.7	0	
Murray Junior High School	2108	1/16/2024	10:22:00 AM	896	0.4	72.9	10	0	Stained Ceiling Tiles
Murray Junior High School	2109	1/16/2024	10:18:00 AM	704	0.2	69.6	9.4	20	
Murray Junior High School	2110	1/16/2024	10:16:00 AM	802	0.3	69.6	10.3	3	
Murray Junior High School	2202	1/16/2024	9:40:00 AM	769	0.2	69.6	7.8	0	
Murray Junior High School	2203	1/16/2024	9:47:00 AM	1015	0.1	69.8	9.7	4	
Murray Junior High School	2205	1/16/2024	9:45:00 AM	832	0.2	69.4	8.4	1	
Murray Junior High School	2207	1/16/2024	9:48:00 AM	907	0.2	69.3	10.1	12	
Murray Junior High School	2208	1/16/2024	10:24:00 AM	859	0.5	71.1	8.2	0	
Murray Junior High School	2209	1/16/2024	9:49:00 AM	928	0.2	69.4	10.7	22	Food Odor
Murray Junior High School	2210	1/16/2024	10:27:00 AM	990	0.5	71.1	9.4	9	
Murray Junior High School	2212	1/16/2024	9:52:00 AM	924	0.1	69.4	11.2	22	Fragrance Odor
Murray Junior High School	2213	1/16/2024	9:50:00 AM	1010	0.2	69.1	12.2	20	
Murray Junior High School	2214	1/16/2024	9:53:00 AM	965	0.1	70	12.6	22	
Murray Junior High School	2215	1/16/2024	10:28:00 AM	916	0.4	70.9	9.7	22	
Murray Junior High School	2216	1/16/2024	9:55:00 AM	919	0.2	70.7	10.4	0	
Murray Junior High School	2217	1/16/2024	9:56:00 AM	1119	0.2	70.9	15.6	0	
Murray Junior High School	2402	1/16/2024	9:58:00 AM	875	0.3	69.3	10.4	1	
Murray Junior High School	2403	1/16/2024	9:59:00 AM	853	0.3	69.1	12.5	4	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Murray Junior High School	2404	1/16/2024	10:00:00 AM	755	0.2	70.9	7.7	0	
Murray Junior High School	0404A	1/16/2024	9:04:00 AM	620		68.7	9.7	1	
Murray Junior High School	1103B	1/16/2024	10:43:00 AM	693	0.3	70.9	11	0	
Murray Junior High School	1104A	1/16/2024	10:58:00 AM	655	0.3	67.5	12.4	2	
Murray Junior High School	1104C	1/16/2024	11:01:00 AM	538	0.2	68	13.7	0	
Murray Junior High School	1104F	1/16/2024	11:02:00 AM	502	0.2	68	13.4	0	
Murray Junior High School	1105B	1/16/2024	10:50:00 AM	881	0.2	71.1	7.1	0	
Murray Junior High School	1105C	1/16/2024	10:54:00 AM	756	0.3	72	8.4	0	
Murray Junior High School	1105D	1/16/2024	10:56:00 AM	804	0.3	73.6	9.6	0	
Murray Junior High School	1108C	1/16/2024	10:55:00 AM	784	0.3	73	8	0	
Murray Junior High School	1109B	1/16/2024	10:41:00 AM	658	0.2	70.5	8.4	0	Food Odor
Murray Junior High School	1301A	1/16/2024	11:05:00 AM	439	0.1	68.7	5.9	0	
Murray Junior High School	1301B	1/16/2024	11:06:00 AM	399	0.2	69.6	5	0	Stained Ceiling Tiles
Murray Junior High School	1301D	1/16/2024	11:08:00 AM	642	0.2	70.9	6.4	1	
Murray Junior High School	2103B	1/16/2024	10:12:00 AM	768	0.2	69.1	9.7	0	
Murray Junior High School	2105A	1/16/2024	10:21:00 AM	904	0.3	72.3	10.3	0	Fragrance Odor
Murray Junior High School	OUTDOORS	1/16/2024		376	1.2		61		
Nokomis Montessori North	1001	1/9/2024	11:53:00 AM	491	1.3	70.5	20.9	1	
Nokomis Montessori North	1002	1/9/2024	11:52:00 AM	447	1.4	70.2	20.7	0	
Nokomis Montessori North	1003	1/9/2024	11:53:00 AM	471	1.3	70.3	20.7	1	
Nokomis Montessori North	1004	1/9/2024	11:54:00 AM	472	1.3	70	20.6	1	Stained Ceiling Tiles
Nokomis Montessori North	1005	1/9/2024	11:50:00 AM	416	1.3	70	19.6	0	
Nokomis Montessori North	1006	1/9/2024	11:47:00 AM	431	1.2	69.6	20.9	0	
Nokomis Montessori North	1007	1/9/2024	11:46:00 AM	502	1.1	69.3	21.4	4	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	1008	1/9/2024	11:45:00 AM	524	1.2	68.5	22.4	5	
Nokomis Montessori North	1009	1/9/2024	11:48:00 AM	482	1.3	70	20.5	1	
Nokomis Montessori North	1010	1/9/2024	11:49:00 AM	654	1.3	70.7	22.1	2	
Nokomis Montessori North	1101	1/9/2024	11:55:00 AM	489	1.4	69.4	22.4	1	
Nokomis Montessori North	1107	1/9/2024	11:38:00 AM	475	1.2	68	25	1	
Nokomis Montessori North	1111	1/9/2024	12:37:00 PM	567	0.8	69.1	22.1	20	
Nokomis Montessori North	1112	1/9/2024	11:58:00 AM	478	1.3	69.3	20.8	2	Stained Ceiling Tiles
Nokomis Montessori North	1113	1/9/2024	11:56:00 AM	887	1.3	69.6	25.3	50	
Nokomis Montessori North	1114	1/9/2024	12:36:00 PM	846	0.8	69.1	24.6	1	
Nokomis Montessori North	1203	1/9/2024	11:58:00 AM	1011	1.3	70	24.5	15	Stained Ceiling Tiles
Nokomis Montessori North	1204	1/9/2024	12:01:00 PM	953	1.3	70.2	24	6	
Nokomis Montessori North	1205	1/9/2024	12:02:00 PM	886	1.2	70.3	24.5	20	
Nokomis Montessori North	1206	1/9/2024	12:30:00 PM	604	0.8	69.6	22.1	25	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	1207	1/9/2024	12:28:00 PM	1115	0.8	69.6	25.8	25	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	1301	1/9/2024	12:03:00 PM	841	1.2	70.5	23	8	
Nokomis Montessori North	1302	1/9/2024	12:04:00 PM	595	1.2	70	21	0	
Nokomis Montessori North	1303	1/9/2024	12:05:00 PM	664	1.2	69.4	22.4	5	
Nokomis Montessori North	1305	1/9/2024	12:31:00 PM	578	0.9	69.8	22.9	1	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	1307	1/9/2024	12:33:00 PM	517	0.8	69.8	22.2	0	
Nokomis Montessori North	1401	1/9/2024	12:06:00 PM	760	1.2	69.4	23.4	5	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	1402	1/9/2024	12:08:00 PM	656	1.2	69.6	22.1	20	
Nokomis Montessori North	1403	1/9/2024	12:09:00 PM	875	1.1	70	23.5	20	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	1404	1/9/2024	12:10:00 PM	853	1.1	70	22.8	20	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Nokomis Montessori North	1405	1/9/2024	12:12:00 PM	577	1.1	69.8	21.6	20	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	1406	1/9/2024	12:33:00 PM	670	0.8	69.8	22.9	4	
Nokomis Montessori North	1407	1/9/2024	12:35:00 PM	582	0.8	69.6	22.3	8	
Nokomis Montessori North	2203	1/9/2024	12:13:00 PM	1576	1.1	70.9	29.9	25	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	2204	1/9/2024	12:27:00 PM	760	0.8	69.1	24.2	0	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	2205	1/9/2024	12:16:00 PM	1352	1.1	70.9	26.1	23	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	2206	1/9/2024	12:26:00 PM	1152	0.8	68.9	27.4	30	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	2207	1/9/2024	12:17:00 PM	1049	1.1	70.5	25.3	24	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	2208	1/9/2024	12:18:00 PM	1309	0.8	68.3	30.4	25	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori North	OUTDOORS	1/9/2024		375	1.2	30	86		
Nokomis Montessori South	1002	1/31/2024	11:34:00 AM	603	0.5	70.5	27.5	0	Stained Ceiling Tiles
Nokomis Montessori South	1003	1/31/2024	11:30:00 AM	687	0.5	70.6	27.1	2	
Nokomis Montessori South	1004	1/31/2024	11:28:00 AM	610		70.6	28.4	3	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori South	1005	1/31/2024	11:29:00 AM	604	0.3	71.1	27.9	0	
Nokomis Montessori South	1006	1/31/2024	11:25:00 AM	588	0.6	69.4	28.1	0	
Nokomis Montessori South	1007	1/31/2024	11:31:00 AM	586	0.4	70.5	27.1	0	Stained Ceiling Tiles
Nokomis Montessori South	1102	1/31/2024	11:00:00 AM	624	0.4	71.1	26.2	7	
Nokomis Montessori South	1103	1/31/2024	11:06:00 AM	568		71	24.6	0	Stained Ceiling Tiles
Nokomis Montessori South	1105	1/31/2024	11:02:00 AM	587	0.6	70.3	26.1	0	Stained Ceiling Tiles
Nokomis Montessori South	1201	1/31/2024	10:50:00 AM	1034	1	71	27.4	0	
Nokomis Montessori South	1202	1/31/2024	10:48:00 AM	780	0.5	73	26	18	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori South	1203	1/31/2024	10:44:00 AM	819	0.9	72.7	26.8	18	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori South	1204	1/31/2024	10:39:00 AM	1131	0.9	72.4	30	23	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori South	1303	1/31/2024	10:34:00 AM	642	1	71	26.3	0	Stained Ceiling Tiles
Nokomis Montessori South	1304	1/31/2024	10:32:00 AM	716	1.2	70.1	27.2	2	
Nokomis Montessori South	1305	1/31/2024	10:26:00 AM	801	1.5	70.5	27.9	19	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Nokomis Montessori South	1403	1/31/2024	11:21:00 AM	557	0.8	70.4	27.6	1	
Nokomis Montessori South	1404	1/31/2024	10:14:00 AM	785	1.7	71.7	27.4	2	
Nokomis Montessori South	1407	1/31/2024	10:22:00 AM	810	2.1	71.5	27.7	0	
Nokomis Montessori South	1502	1/31/2024	11:15:00 AM	1122	0.6	71.2	29.3	19	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori South	1504	1/31/2024	11:16:00 AM	1007	0.5	69.6	29.1	21	
Nokomis Montessori South	2100	1/31/2024	11:37:00 AM	1133	0.4	71.5	30.8	0	
Nokomis Montessori South	2201	1/31/2024	11:48:00 AM	1633	0.1	68.9	37.1	0	Plants: Kept Away Comments: Flowering plants near return vents
Nokomis Montessori South	2202	1/31/2024	11:53:00 AM	1477	0.5	70.9	37.6	16	Live Animals: Kept Away From Return And Supply Vents, Plants: Kept Aw
Nokomis Montessori South	2203	1/31/2024	12:01:00 PM	1383	0.8	72.8	31.7	19	Live Animals: Kept Away From Return And Supply Vents
Nokomis Montessori South	2204	1/31/2024	12:08:00 PM	1034	0.6	73.7	30.6	21	
Nokomis Montessori South	2205	1/31/2024	11:57:00 AM	1060	0.5	71.9	30.6	6	Bubbling/Peeling Paint, Stained Ceiling Tiles, Plants: Kept Away From Ret
Nokomis Montessori South	2206	1/31/2024	11:51:00 AM	1085	0.1	69.8	32.5	0	Plants: Kept Away From Return And Supply Vents
Nokomis Montessori South	2207	1/31/2024	11:45:00 AM	1298	0.1	69	30.1	15	Stained Ceiling Tiles
Nokomis Montessori South	2304	1/31/2024	12:09:00 PM	775	0.5	71.6	28.6	0	Stained Ceiling Tiles
Nokomis Montessori South	2305	1/31/2024	12:18:00 PM	734	0.5	70.1	29.8	1	
Nokomis Montessori South	2306	1/31/2024	12:13:00 PM	698	0.9	69.9	29.5	1	Stained Ceiling Tiles, Aquariums (fish), Plants: Kept Away From Return Ar
Nokomis Montessori South	1000 COMMONS	1/31/2024	11:11:00 AM	678	0.4	71.3	26.4	0	Stained Ceiling Tiles
Nokomis Montessori South	1200 HALLWAY	1/31/2024	10:42:00 AM	750	1	72.2	25.9	6	
Nokomis Montessori South	1500 HALLWAY	1/31/2024	11:13:00 AM	602	0.1	71.2	27.1	3	
Nokomis Montessori South	CAFETERIA	1/31/2024	11:22:00 AM	531	1.6	67.8	29.7	2	
Nokomis Montessori South	CUSTODIAL OFFICE	1/31/2024	10:03:00 AM	710	1.9	71.5	26.1	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Nokomis Montessori South	GYM 1	1/31/2024	11:19:00 AM	505	0.4	70.4	27.4	2	
Nokomis Montessori South	LIBRARY	1/31/2024	10:54:00 AM	706	0.4	70.7	27.1	21	
Nokomis Montessori South	MAIN OFFICE	1/31/2024	11:33:00 AM	631	0.3	70.5	27.2	1	
Nokomis Montessori South	OUTDOORS	1/31/2024		461	4.7	37	80		
Open World Learning	1002	12/14/2023	9:43:00 AM	595		68.9	17.1	2	
Open World Learning	1003	12/14/2023	9:44:00 AM	568		68.7	16.8	1	
Open World Learning	1004	12/14/2023	9:45:00 AM	660		68.7	17.5	2	
Open World Learning	1006	12/14/2023	9:44:00 AM	533		68.9	16.5	0	
Open World Learning	1007	12/14/2023	9:46:00 AM	519		69.1	16	1	
Open World Learning	1008	12/14/2023	9:46:00 AM	652		69.3	16.4	1	
Open World Learning	1103	12/14/2023	10:24:00 AM	713		72.9	17.2	1	
Open World Learning	1104	12/14/2023	12:57:00 PM	852		72.5	21.3	25	
Open World Learning	1106	12/14/2023	11:34:00 AM	918		73.4	22.6	30	
Open World Learning	1108	12/14/2023	10:26:00 AM	881		72.1	19.4	30	
Open World Learning	1110	12/14/2023	10:23:00 AM	669		73	17	11	
Open World Learning	1112	12/14/2023	10:21:00 AM	895		73	20	28	
Open World Learning	1114	12/14/2023	10:19:00 AM	763		72.5	17.9	20	
Open World Learning	1116	12/14/2023	10:18:00 AM	780		73.2	19.1	1	
Open World Learning	1207	12/14/2023	9:52:00 AM	509		68.9	16	2	
Open World Learning	1208	12/14/2023	9:48:00 AM	545		68.5	16.8	0	
Open World Learning	1212	12/14/2023	10:27:00 AM	589		70.2	17.2	8	
Open World Learning	1221	12/14/2023	10:01:00 AM	902		70.3	19.5	30	
Open World Learning	1304	12/14/2023	9:53:00 AM	486		69.4	15.8	2	
Open World Learning	2103	12/14/2023	10:32:00 AM	669		71.8	17	3	
Open World Learning	2105	12/14/2023	10:34:00 AM	596		71.6	16.3	5	Stained Ceiling Tiles
Open World Learning	2106	12/14/2023	11:38:00 AM	653		71.6	17.7	0	
Open World Learning	2107	12/14/2023	10:34:00 AM	652		71.6	16.8	1	
Open World Learning	2108	12/14/2023	10:28:00 AM	1092		72	23.9	25	Plants
Open World Learning	2109	12/14/2023	10:39:00 AM	599		70.2	17	0	
Open World Learning	2110	12/14/2023	10:32:00 AM	990		72.3	19.6	25	
Open World Learning	2111	12/14/2023	10:40:00 AM	585		70.3	17.2	0	
Open World Learning	2112	12/14/2023	10:36:00 AM	1379		70.3	22.8	30	
Open World Learning	2114	12/14/2023	11:28:00 AM	841		71.4	19.7	25	
Open World Learning	2115	12/14/2023	10:45:00 AM	607		72.3	16.6	0	
Open World Learning	2116	12/14/2023	10:44:00 AM	701		71.6	18	4	
Open World Learning	2118	12/14/2023	11:31:00 AM	923		72	20.7	30	
Open World Learning	2202	12/14/2023	11:27:00 AM	587		70.9	17.7	2	
Open World Learning	2202	12/14/2023	12:04:00 PM	823		72.1	20.2	25	
Open World Learning	2204	12/14/2023	11:26:00 AM	541		71.1	17.3	0	
Open World Learning	2206	12/14/2023	11:25:00 AM	540		70.9	17.3	0	Plants: Kept Away From Return And Supply Vents
Open World Learning	2207	12/14/2023	10:50:00 AM	528		72.1	15.6	0	
Open World Learning	2208	12/14/2023	11:24:00 AM	514		70.7	16.9	0	
Open World Learning	2209	12/14/2023	10:47:00 AM	836		72.9	20.3	25	Stained Ceiling Tiles
Open World Learning	2210	12/14/2023	11:21:00 AM	525		73.2	15.5	0	
Open World Learning	2215	12/14/2023	10:49:00 AM	913		72.1	19	25	
Open World Learning	2300	12/14/2023	10:51:00 AM	498		74.8	13.8	2	
Open World Learning	2301	12/14/2023	11:08:00 AM	460		73.6	14.7	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Open World Learning	2601	12/14/2023	11:19:00 AM	521		71.1	17	0	Fragrance Odor, Stained Ceiling Tiles
Open World Learning	2602	12/14/2023	1:10:00 PM	778		73	19.4	25	
Open World Learning	2606	12/14/2023	11:17:00 AM	651		71.2	18.1	20	
Open World Learning	2608	12/14/2023	11:16:00 AM	509		71.1	16.7	1	
Open World Learning	2609	12/14/2023	11:13:00 AM	512		71.4	16.5	0	
Open World Learning	2610	12/14/2023	11:09:00 AM	533		72.1	16.5	2	
Open World Learning	3201	12/14/2023	11:58:00 AM	515		74.5	14.7	2	
Open World Learning	3202	12/14/2023	11:59:00 AM	672		73.6	17.9	30	
Open World Learning	3203	12/14/2023	11:52:00 AM	444		73	15.5	0	
Open World Learning	3204	12/14/2023	12:00:00 PM	732		72.3	20.2	15	Stained Ceiling Tiles
Open World Learning	3205	12/14/2023	1:11:00 PM	582		72.1	17.9	3	
Open World Learning	3206	12/14/2023	12:01:00 PM	690		71.4	19.2	18	
Open World Learning	3208	12/14/2023	12:03:00 PM	559		72.5	17.1	0	
Open World Learning	3209	12/14/2023	11:50:00 AM	847		72.3	21	20	
Open World Learning	3210	12/14/2023	11:56:00 AM	919		74.9	20.7	35	Stained Ceiling Tiles
Open World Learning	3212	12/14/2023	11:51:00 AM	532		75	15.3	0	
Open World Learning	3214	12/14/2023	11:45:00 AM	550		73.9	16.4	0	
Open World Learning	3215	12/14/2023	11:42:00 AM	736		73.4	19	30	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Open World Learning	1008A	12/14/2023	9:47:00 AM	526		69.1	16	0	
Open World Learning	1106A	12/14/2023	11:38:00 AM	697		70.7	19.5	1	
Open World Learning	1106C	12/14/2023	11:37:00 AM	696		72.5	19.6	0	
Open World Learning	1111A	12/14/2023	10:02:00 AM	765		73.6	18.1	1	
Open World Learning	1207A	12/14/2023	9:51:00 AM	531		68.7	16.5	1	
Open World Learning	1301 GYM	12/14/2023	9:57:00 AM	860		68.7	28.8	20	
Open World Learning	1305A	12/14/2023	9:55:00 AM	450		67.5	16.9	0	
Open World Learning	2116A	12/14/2023	10:44:00 AM	675		71.2	17.4	0	
Open World Learning	2116B	12/14/2023	10:43:00 AM	825		70.9	18.4	3	
Open World Learning	2116C	12/14/2023	10:41:00 AM	684		70.7	17.7	0	
Open World Learning	2600A	12/14/2023	11:15:00 AM	531		70.7	17.2	0	Stained Ceiling Tiles
Open World Learning	2609A	12/14/2023	11:11:00 AM	569		72.3	16.8	0	
Open World Learning	3214A	12/14/2023	11:48:00 AM	556		77.5	18.3	0	Plants: Kept Away From Return And Supply Vents
Open World Learning	CAFETERIA	12/14/2023	11:32:00 AM	845		72.9	20.6	75	
Open World Learning	MAIN OFFICE	12/14/2023	9:26:00 AM	622		69.4	17.4	3	
Open World Learning	OUTDOORS	12/14/2023		435	0.1	33	77		
Randolph Heights Elementary School	1203	12/4/2023	10:25:00 AM	943		71.4	25.4	27	
Randolph Heights Elementary School	1204	12/4/2023	11:26:00 PM	769		71.8	24.6	20	
Randolph Heights Elementary School	1403	12/4/2023	10:48:00 AM	888	0.1	72.5	23.1	22	
Randolph Heights Elementary School	1407	12/4/2023	10:45:00 AM	872		73	22.6	27	Dirty Or Dusty Carpet Odor
Randolph Heights Elementary School	1409	12/4/2023	10:43:00 AM	796	0.1	70.7	23.2	28	
Randolph Heights Elementary School	1410	12/4/2023	11:24:00 PM	851		71.2	24.2	1	
Randolph Heights Elementary School	1411	12/4/2023	10:42:00 AM	766		71.2	23.2	26	
Randolph Heights Elementary School	1415	12/4/2023	10:40:00 AM	868	0.1	71.1	24.2	26	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2001	12/4/2023	9:49:00 AM	600	0.1	69.4	22.7	30	Odor Description: Coffee Odor, Coffee
Randolph Heights Elementary School	2002	12/4/2023	10:47:00 AM	607		68	24.1	3	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2003	12/4/2023	9:45:00 AM	603	0.1	68.4	23.3	0	
Randolph Heights Elementary School	2004	12/4/2023	8:25:00 AM	681	0.4	66.4	25.8	3	
Randolph Heights Elementary School	2005	12/4/2023	8:35:00 AM	780	0.6	70	23.5	21	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Randolph Heights Elementary School	2100	12/4/2023	11:54:00 AM	683	0.1	69.6	26.1	100	Food Odor
Randolph Heights Elementary School	2202	12/4/2023	8:40:00 AM	659	0.5	69.6	22.7	2	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2204	12/4/2023	8:50:00 AM	804	0.5	70.5	23.6	22	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2205	12/4/2023	11:17:00 AM	626	0.1	71.6	21.8	0	
Randolph Heights Elementary School	2206	12/4/2023	9:00:00 AM	819	0.6	69.8	25.4	26	Stained Ceiling Tiles
Randolph Heights Elementary School	2207	12/4/2023	10:58:00 AM	640		72.1	22	2	
Randolph Heights Elementary School	2208	12/4/2023	9:06:00 AM	1232	0.5	69.8	28.3	6	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2210	12/4/2023	9:11:00 AM	901	0.5	69.8	24.7	28	
Randolph Heights Elementary School	2211	12/4/2023	9:20:00 AM	979	0.4	70	25.7	30	
Randolph Heights Elementary School	2212	12/4/2023	9:15:00 AM	680	0.5	70.2	23.1	0	Stained Ceiling Tiles
Randolph Heights Elementary School	2221	12/4/2023	9:31:00 AM	679	0.3	77.5	22.2	2	
Randolph Heights Elementary School	2230	12/4/2023	10:50:00 AM	655		75.9	19.4	3	Fragrance Odor
Randolph Heights Elementary School	2312	12/4/2023	9:52:00 AM	1126	0.2	71.1	25.1	26	
Randolph Heights Elementary School	2313	12/4/2023	11:14:00 AM	885		72.9	23.6	25	
Randolph Heights Elementary School	2315	12/4/2023	9:55:00 AM	888	0.1	73.6	24	25	Stuffy Odor
Randolph Heights Elementary School	2401	12/4/2023	10:00:00 AM	923	0.3	75	21.3	1	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2402	12/4/2023	10:06:00 AM	1193	0.4	72.9	27.3	22	
Randolph Heights Elementary School	2405	12/4/2023	10:07:00 AM	977	0.2	71.2	24.2	28	Taxidermy
Randolph Heights Elementary School	2407	12/4/2023	10:09:00 AM	962	0.1	71.2	23.6	18	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2409	12/4/2023	11:10:00 AM	663		70.2	22.4	23	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2410	12/4/2023	10:22:00 AM	645	0.1	71.4	20.8	0	
Randolph Heights Elementary School	2411	12/4/2023	10:15:00 AM	858	0.1	74.1	20.9	24	Plants: Kept Away From Return And Supply Vents
Randolph Heights Elementary School	2415	12/4/2023	11:20:00 AM	799	0.1	73.9	20.3	24	Plants
Randolph Heights Elementary School	1203A	12/4/2023	10:30:00 AM	1299	0.1	72.3	24.1	1	
Randolph Heights Elementary School	2003A	12/4/2023	9:41:00 AM	566	0.2	69.3	22.5	0	Bubbling/Peeling Paint, Taxidermy: Antlers and fur
Randolph Heights Elementary School	2004A	12/4/2023	8:25:00 AM	617	0.5	68.5	23.3	0	Bubbling/Peeling Paint on ceiling, paint peeling down slightly. Not bubbli
Randolph Heights Elementary School	2004B	12/4/2023	8:30:00 AM	545	0.6	70.3	21.3	0	
Randolph Heights Elementary School	OUTDOORS	12/4/2023		395	0.6	28	94		
RiverEast School	1101	12/13/2023	10:06:00 AM	462		71.6	11.9	1	
RiverEast School	1105	12/13/2023	10:05:00 AM	433		72.1	11.4	0	
RiverEast School	1106	12/13/2023	10:05:00 AM	435		72	11.9	0	
RiverEast School	1107	12/13/2023	10:04:00 AM	424		72	11.7	0	
RiverEast School	1112	12/13/2023	10:00:00 AM	444		71.1	11.7	0	
RiverEast School	1120	12/13/2023	10:01:00 AM	430		71.2	11.8	0	
RiverEast School	1125	12/13/2023	9:59:00 AM	582		70.9	13.1	2	
RiverEast School	1133	12/13/2023	9:58:00 AM	423	0.3	71.2	13.3	0	
RiverEast School	1142	12/13/2023	9:57:00 AM	559	3.3	70.3	13.3	0	
RiverEast School	1145	12/13/2023	9:56:00 AM	436		69.4	12.3	0	
RiverEast School	1146	12/13/2023	9:53:00 AM	418		69.1	13.8	0	
RiverEast School	1147	12/13/2023	9:52:00 AM	416		69.1	14	0	
RiverEast School	1148	12/13/2023	9:51:00 AM	598		68.9	15.2	0	Fragrance Odor
RiverEast School	1201	12/13/2023	9:50:00 AM	388		67.8	15.4	0	
RiverEast School	1303	12/13/2023	9:27:00 AM	364		68.5	12.6	0	Fragrance Odor
RiverEast School	1304	12/13/2023	9:28:00 AM	366		68.5	14.2	0	
RiverEast School	1305	12/13/2023	9:29:00 AM	383		68.7	13.7	0	
RiverEast School	1306	12/13/2023	9:49:00 AM	385		69.6	12.9	0	
RiverEast School	1307	12/13/2023	9:48:00 AM	393		69.4	12.2	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
RiverEast School	1308	12/13/2023	9:47:00 AM	410		69.4	12.6	0	
RiverEast School	1309	12/13/2023	9:46:00 AM	385		69.3	13	0	
RiverEast School	1401	12/13/2023	9:40:00 AM	520		69.8	13.9	8	
RiverEast School	1402	12/13/2023	9:42:00 AM	432		69.6	13	1	
RiverEast School	1403	12/13/2023	9:43:00 AM	469		69.6	13.4	5	Fragrance Odor
RiverEast School	1404	12/13/2023	9:45:00 AM	383		69.4	13.6	0	
RiverEast School	1405	12/13/2023	9:45:00 AM	433		69.6	13.5	0	
RiverEast School	1413	12/13/2023	9:40:00 AM	380		70	13.1	0	
RiverEast School	1415	12/13/2023	9:39:00 AM	395		70.2	13.1	0	Live Animals: Kept Away From Return And Supply Vents
RiverEast School	1501	12/13/2023	10:16:00 AM	432		69.8	13.5	3	
RiverEast School	1502	12/13/2023	10:16:00 AM	446		70	13.5	7	
RiverEast School	1504	12/13/2023	9:29:00 AM	420		69.1	13.5	0	
RiverEast School	1504	12/13/2023	9:32:00 AM	593		69.3	14.9	7	
RiverEast School	1505	12/13/2023	9:30:00 AM	485		69.1	13.4	1	Fragrance Odor
RiverEast School	1513	12/13/2023	10:17:00 AM	389		70.3	12.5	0	
RiverEast School	1515	12/13/2023	10:18:00 AM	408		70.3	12.9	1	Fragrance Odor
RiverEast School	1601	12/13/2023	9:23:00 AM	495		69.1	14.3	5	
RiverEast School	1602	12/13/2023	9:24:00 AM	429		69.3	13.7	4	
RiverEast School	1603	12/13/2023	9:25:00 AM	480		68.9	12.6	0	
RiverEast School	1605	12/13/2023	9:26:00 AM	391		68.7	13.9	0	
RiverEast School	1611	12/13/2023	9:22:00 AM	363		69.1	13.6	0	
RiverEast School	1612	12/13/2023	9:20:00 AM	383		69.4	13.1	0	
RiverEast School	1701	12/13/2023	9:18:00 AM	395		68.9	12.9	2	
RiverEast School	1702	12/13/2023	9:16:00 AM	362		68.9	13	2	
RiverEast School	1703	12/13/2023	9:15:00 AM	346		68.7	12.7	0	
RiverEast School	1706	12/13/2023	9:13:00 AM	331		68	14.4	0	
RiverEast School	1710	12/13/2023	9:54:00 AM	498		69.3	13.9	1	
RiverEast School	1711	12/13/2023	9:55:00 AM	431		69.3	12.9	0	
RiverEast School	1104A	12/13/2023	10:03:00 AM	418		72	11.3	1	
RiverEast School	1104B	12/13/2023	10:02:00 AM	454		71.8	11.8	0	
RiverEast School	1120A	12/13/2023	10:01:00 AM	469		71.4	12.9	1	
RiverEast School	1401B	12/13/2023	9:41:00 AM	460		69.8	13.5	0	
RiverEast School	1402B	12/13/2023	9:43:00 AM	545		69.6	12.8	0	
RiverEast School	1501B	12/13/2023	10:16:00 AM	419		70.5	14.6	0	
RiverEast School	1502B	12/13/2023	9:32:00 AM	479		69.6	15.4	0	Fragrance Odor
RiverEast School	1601B	12/13/2023	9:23:00 AM	381		69.1	13.8	0	
RiverEast School	1701A	12/13/2023	9:19:00 AM	419		69.1	13.8	1	
RiverEast School	1701B	12/13/2023	9:17:00 AM	350		68.9	13	0	
RiverEast School	OUTDOORS	12/13/2023		370		30	56		
Riverview West Side School of Excellence	1000	1/11/2024	12:23:00 PM	777	1.7	69.8	18.8	3	
Riverview West Side School of Excellence	1001	1/11/2024	12:25:00 PM	760	1.8	70.3	21.1	2	
Riverview West Side School of Excellence	1002	1/11/2024	12:25:00 PM	719	1.8	71.1	17.9	0	
Riverview West Side School of Excellence	1003	1/11/2024	12:26:00 PM	743	1.8	71.1	18.2	1	Stained Ceiling Tiles
Riverview West Side School of Excellence	1004	1/11/2024	1:51:00 PM	701	0.2	71.1	18	0	
Riverview West Side School of Excellence	1005	1/11/2024	12:27:00 PM	709	1.9	71.1	18	0	
Riverview West Side School of Excellence	1110	1/11/2024	12:19:00 PM	510	1.3	69.8	10.4	60	
Riverview West Side School of Excellence	1112	1/11/2024	12:21:00 PM	457	1.5	69.6	9.7	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Riverview West Side School of Excellence	1114	1/11/2024	12:21:00 PM	438	1.7	69.4	10.9	0	
Riverview West Side School of Excellence	1201	1/11/2024	1:53:00 PM	823	0.2	70.2	19.1	24	
Riverview West Side School of Excellence	1202	1/11/2024	1:54:00 PM	693	0.2	69.6	18.6	0	
Riverview West Side School of Excellence	1204	1/11/2024	1:52:00 PM	763	0.2	70	18.6	24	
Riverview West Side School of Excellence	1205	1/11/2024	12:28:00 PM	721	1.8	69.6	18.5	0	
Riverview West Side School of Excellence	1206	1/11/2024	1:55:00 PM	807	0.2	68.5	19.9	20	
Riverview West Side School of Excellence	1207	1/11/2024	1:56:00 PM	806	0.2	68.4	20	20	
Riverview West Side School of Excellence	1301	1/11/2024	1:44:00 PM	711	0.2	68.9	18.6	0	
Riverview West Side School of Excellence	1302	1/11/2024	1:42:00 PM	706	0.2	69.4	18.9	0	
Riverview West Side School of Excellence	1303	1/11/2024	1:45:00 PM	714	0.2	68.4	20.3	0	
Riverview West Side School of Excellence	1304	1/11/2024	2:26:00 PM	809	0.2	68.5	18.8	20	
Riverview West Side School of Excellence	1305	1/11/2024	12:10:00 PM	769	1	68.9	19.8	1	
Riverview West Side School of Excellence	1306	1/11/2024	1:57:00 PM	804	0.2	68.4	19.6	22	
Riverview West Side School of Excellence	1307	1/11/2024	1:48:00 PM	719	0.2	68	19.4	0	
Riverview West Side School of Excellence	1308	1/11/2024	1:47:00 PM	691	0.2	68.4	19.2	0	
Riverview West Side School of Excellence	1320	1/11/2024	1:49:00 PM	718	0.2	68	19.9	1	
Riverview West Side School of Excellence	2105	1/11/2024	12:34:00 PM	707	1.8	67.6	19.7	0	
Riverview West Side School of Excellence	2106	1/11/2024	12:30:00 PM	704	1.9	67.8	19.8	0	
Riverview West Side School of Excellence	2111	1/11/2024	12:35:00 PM	764	1.6	68.5	19.9	5	
Riverview West Side School of Excellence	2119	1/11/2024	12:36:00 PM	705	1.6	68.7	19	0	
Riverview West Side School of Excellence	2120	1/11/2024	1:16:00 PM	745	0.2	68	20.2	0	
Riverview West Side School of Excellence	2201	1/11/2024	1:27:00 PM	700	0.2	68.9	18.9	0	
Riverview West Side School of Excellence	2202	1/11/2024	1:25:00 PM	815	0.2	69.4	19.8	20	
Riverview West Side School of Excellence	2204	1/11/2024	1:24:00 PM	897	0.2	69.6	21	20	
Riverview West Side School of Excellence	2205	1/11/2024	1:18:00 PM	703	0.2	68.2	19.4	1	
Riverview West Side School of Excellence	2206	1/11/2024	1:23:00 PM	716	0.2	69.1	19.2	2	
Riverview West Side School of Excellence	2207	1/11/2024	1:20:00 PM	717	0.2	68.4	19.6	0	
Riverview West Side School of Excellence	2208	1/11/2024	1:21:00 PM	688	0.2	68.5	19	1	
Riverview West Side School of Excellence	2301	1/11/2024	1:38:00 PM	694	0.2	68.4	19.4	0	
Riverview West Side School of Excellence	2302	1/11/2024	1:38:00 PM	694	0.2	68	19.4	0	
Riverview West Side School of Excellence	2304	1/11/2024	1:40:00 PM	831	0.2	68.4	20.8	2	
Riverview West Side School of Excellence	2305	1/11/2024	1:15:00 PM	701	0.2	67.8	19.7	0	
Riverview West Side School of Excellence	2306	1/11/2024	1:41:00 PM	714	0.2	68.5	19.2	0	
Riverview West Side School of Excellence	2307	1/11/2024	1:14:00 PM	717	0.2	68.4	19.4	2	Plants: Kept Away From Return And Supply Vents
Riverview West Side School of Excellence	2308	1/11/2024	1:12:00 PM	751	0.2	68.7	20	10	
Riverview West Side School of Excellence	3105	1/11/2024	12:44:00 PM	792	1	69.1	20.2	0	
Riverview West Side School of Excellence	3109	1/11/2024	1:34:00 PM	807	0.3	68.2	21.2	22	
Riverview West Side School of Excellence	3111	1/11/2024	12:42:00 PM	982	1.3	70.7	20.2	25	
Riverview West Side School of Excellence	3114	1/11/2024	12:43:00 PM	827	1.4	69.6	19.9	20	
Riverview West Side School of Excellence	3119	1/11/2024	12:41:00 PM	834	1.4	69.8	20.2	0	
Riverview West Side School of Excellence	3120	1/11/2024	1:33:00 PM	728	0.2	68	19.6	1	
Riverview West Side School of Excellence	3201	1/11/2024	1:00:00 PM	716	0.6	67.5	19.7	0	
Riverview West Side School of Excellence	3202	1/11/2024	12:59:00 PM	685	0.6	67.8	19.4	0	
Riverview West Side School of Excellence	3204	1/11/2024	12:58:00 PM	731	0.7	68.2	20.3	0	
Riverview West Side School of Excellence	3205	1/11/2024	12:53:00 PM	705	1	68.7	19	0	
Riverview West Side School of Excellence	3206	1/11/2024	12:56:00 PM	739	0.8	68.2	22	2	Plants: Kept Away From Return And Supply Vents
Riverview West Side School of Excellence	3207	1/11/2024	12:54:00 PM	694	0.9	68.5	19.2	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Riverview West Side School of Excellence	3208	1/11/2024	12:55:00 PM	690	0.9	68	19.5	0	
Riverview West Side School of Excellence	3301	1/11/2024	1:09:00 PM	712	0.3	69.3	19.4	0	
Riverview West Side School of Excellence	3302	1/11/2024	1:11:00 PM	682	0.2	69.3	18.6	0	
Riverview West Side School of Excellence	3304	1/11/2024	12:37:00 PM	925	1.5	69.1	21	25	
Riverview West Side School of Excellence	3305	1/11/2024	1:03:00 PM	700	0.4	68.2	19.4	0	
Riverview West Side School of Excellence	3306	1/11/2024	12:40:00 PM	897	1.5	69.1	20.3	20	
Riverview West Side School of Excellence	3307	1/11/2024	1:07:00 PM	833	0.3	68.4	20.9	25	
Riverview West Side School of Excellence	3308	1/11/2024	1:06:00 PM	685	0.4	68.2	19.1	0	
Riverview West Side School of Excellence	OUTDOORS	1/11/2024		366	0.4	16	67		
Rondo Education Center	1101	12/5/2023	11:05:00 AM	573	0.2	71.1	20.9	25	
Rondo Education Center	1102	12/5/2023	1:13:00 PM	714	0.3	71.4	21.1	25	Stained Ceiling Tiles
Rondo Education Center	1103	12/5/2023	12:16:00 PM	626	0.2	70.3	22	15	Stained Ceiling Tiles
Rondo Education Center	1104	12/5/2023	1:08:00 PM	551	0.2	71.4	19.5	1	
Rondo Education Center	1105	12/5/2023	11:44:00 AM	617	0.2	68.4	24	25	
Rondo Education Center	1106	12/5/2023	12:11:00 PM	496	0.2	70.9	20.4	15	
Rondo Education Center	1107	12/5/2023	12:06:00 PM	558	0.2	70.5	21.4	25	
Rondo Education Center	1108	12/5/2023	11:48:00 AM	598	0.2	70.5	21.3	20	Stained Ceiling Tiles
Rondo Education Center	1112	12/5/2023	10:55:00 AM	500	0.2	70.5	24.2	1	
Rondo Education Center	1113	12/5/2023	10:53:00 AM	555	0.2	70.9	21.1	6	
Rondo Education Center	1114	12/5/2023	10:51:00 AM	614	0.3	71.1	22.6	45	
Rondo Education Center	1115	12/5/2023	1:22:00 PM	657	0.2	70.7	21.8	2	
Rondo Education Center	1116	12/5/2023	10:46:00 AM	526	0.2	71.6	20.5	2	
Rondo Education Center	1118	12/5/2023	11:35:00 AM	452	0.2	65.1	24.4	20	
Rondo Education Center	1119	12/5/2023	11:58:00 AM	433	0.2	70.2	19.9	1	
Rondo Education Center	1201	12/5/2023	1:33:00 PM	477	0.2	71.8	18.6	1	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1202	12/5/2023	1:44:00 PM	456	0.2	69.1	20.4	0	Stained Ceiling Tiles
Rondo Education Center	1203	12/5/2023	1:42:00 PM	463	0.2	69.1	20.2	1	
Rondo Education Center	1204	12/5/2023	1:39:00 PM	454	0.2	69.6	19.9	1	
Rondo Education Center	1205	12/5/2023	3:00:00 PM	455	0.2	69.8	19.2	0	
Rondo Education Center	1206	12/5/2023	1:38:00 PM	477	0.2	69.6	19.9	1	
Rondo Education Center	1208	12/5/2023	1:46:00 PM	458	0.2	69.4	20.1	0	
Rondo Education Center	1209	12/5/2023	1:35:00 PM	455	0.2	70.3	19.7	0	
Rondo Education Center	1210	12/5/2023	1:54:00 PM	471	0.2	68.2	20.8	0	Stained Ceiling Tiles
Rondo Education Center	1211	12/5/2023	1:49:00 PM	451	0.2	67.8	20.7	0	
Rondo Education Center	1212	12/5/2023	2:58:00 PM	461	0.2	68.9	19.6	0	
Rondo Education Center	1213	12/5/2023	2:57:00 PM	469	0.2	68.2	20.7	0	
Rondo Education Center	1214	12/5/2023	2:55:00 PM	452	0.2	67.6	20.6	0	
Rondo Education Center	1217	12/5/2023	2:53:00 PM	455	0.2	67.5	21	0	Stained Ceiling Tiles
Rondo Education Center	1224	12/5/2023	1:25:00 PM	485	0.2	71.8	18.9	1	
Rondo Education Center	1225	12/5/2023	1:29:00 PM	553	0.2	72.7	18.5	0	
Rondo Education Center	1226	12/5/2023	1:32:00 PM	493	0.2	72.5	18.3	0	
Rondo Education Center	1228	12/5/2023	11:55:00 AM	498	0.2	71.2	20.1	2	
Rondo Education Center	1229	12/5/2023	3:02:00 PM	586	0.2	71.2	20.7	2	Food Odor, Stained Ceiling Tiles
Rondo Education Center	1230	12/5/2023	3:10:00 PM	578	0.2	74.7	18.2	2	Stained Ceiling Tiles
Rondo Education Center	1230	12/5/2023	3:12:00 PM	524	0.2	74.3	17.1	1	
Rondo Education Center	1231	12/5/2023	3:07:00 PM	565	0.2	72.1	19.6	1	
Rondo Education Center	1232	12/5/2023	3:08:00 PM	597	0.2	72.9	19.2	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Rondo Education Center	1234	12/5/2023	11:50:00 AM	531	0.2	72	21.3	1	
Rondo Education Center	1235	12/5/2023	11:54:00 AM	615	0.2	72.1	21.6	2	
Rondo Education Center	1243	12/5/2023	3:13:00 PM	569	0.2	71.8	19.4	0	
Rondo Education Center	1246	12/5/2023	12:22:00 PM	520	0.2	70.5	21.3	1	
Rondo Education Center	1301	12/5/2023	12:39:00 PM	524	0.2	71.6	19.7	2	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1302	12/5/2023	12:43:00 PM	508	0.2	71.1	19.6	0	
Rondo Education Center	1303	12/5/2023	12:44:00 PM	562	0.2	70.7	20.3	1	
Rondo Education Center	1304	12/5/2023	12:45:00 PM	520	0.2	70.7	20.2	0	
Rondo Education Center	1305	12/5/2023	12:48:00 PM	495	0.2	71.6	19.2	0	
Rondo Education Center	1306	12/5/2023	12:49:00 PM	521	0.2	72.3	19	1	
Rondo Education Center	1307	12/5/2023	12:51:00 PM	493	0.2	71.8	18.9	0	
Rondo Education Center	1308	12/5/2023	12:52:00 PM	510	0.2	70.9	19.8	1	
Rondo Education Center	1316	12/5/2023	12:25:00 PM	550	0.2	71.2	20.6	3	
Rondo Education Center	1317	12/5/2023	12:27:00 PM	530	0.2	72	19.5	1	
Rondo Education Center	1318	12/5/2023	12:28:00 PM	507	0.2	71.8	19.5	0	
Rondo Education Center	1319	12/5/2023	1:02:00 PM	512	0.2	71.2	19.9	2	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1320	12/5/2023	1:01:00 PM	505	0.2	70.9	20.2	1	Stained Ceiling Tiles
Rondo Education Center	1322	12/5/2023	12:59:00 PM	507	0.2	70.9	19.8	3	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1323	12/5/2023	12:57:00 PM	580	0.2	70.9	20.6	4	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1326	12/5/2023	12:54:00 PM	551	0.2	71.6	20	1	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1327	12/5/2023	1:04:00 PM	481	0.2	73.8	17.7	0	
Rondo Education Center	1328	12/5/2023	1:06:00 PM	473	0.2	72.5	18.1	0	
Rondo Education Center	1329	12/5/2023	3:42:00 PM	460	0.2	69.1	19.2	0	
Rondo Education Center	1331	12/5/2023	3:45:00 PM	454	0.2	69.8	19	0	Stained Ceiling Tiles
Rondo Education Center	1332	12/5/2023	3:48:00 PM	511	0.2	70	19.8	0	
Rondo Education Center	1334	12/5/2023	3:50:00 PM	465	0.2	70.2	18.6	0	
Rondo Education Center	1335	12/5/2023	4:04:00 PM	480	0.2	70.9	18.2	15	Stained Ceiling Tiles
Rondo Education Center	1336	12/5/2023	3:52:00 PM	511	0.2	71.1	18.8	0	
Rondo Education Center	1337	12/5/2023	4:02:00 PM	468	0.2	70.7	18.8	0	
Rondo Education Center	1339	12/5/2023	4:02:00 PM	461	0.2	70.3	18.4	0	
Rondo Education Center	1340	12/5/2023	4:05:00 PM	517	0.2	71.1	18.1	4	
Rondo Education Center	1341	12/5/2023	4:07:00 PM	492	0.2	70.7	18.3	0	
Rondo Education Center	1343	12/5/2023	4:08:00 PM	462	0.2	70.3	18.2	0	
Rondo Education Center	1344	12/5/2023	4:09:00 PM	479	0.2	70	18.6	0	Stained Ceiling Tiles
Rondo Education Center	1401	12/5/2023	11:20:00 AM	413	0.2	65.7	22.7	15	
Rondo Education Center	1406	12/5/2023	4:14:00 PM	515	0.2	67.3	22.2	0	Fragrance Odor
Rondo Education Center	1410	12/5/2023	11:24:00 AM	463	0.2	68.7	21.2	20	
Rondo Education Center	1412	12/5/2023	3:35:00 PM	590	0.2	69.1	21	2	
Rondo Education Center	1413	12/5/2023	11:22:00 AM	563	0.2	68.4	23.1	3	Stained Ceiling Tiles
Rondo Education Center	1414	12/5/2023	3:29:00 PM	639	0.2	68.9	21.1	0	Stained Ceiling Tiles
Rondo Education Center	1501	12/5/2023	12:29:00 PM	589	0.2	71.4	20.4	3	
Rondo Education Center	1502	12/5/2023	12:32:00 PM	585	0.2	71.6	20.4	1	
Rondo Education Center	1503	12/5/2023	3:34:00 PM	653	0.2	70.5	20.9	1	Fragrance Odor
Rondo Education Center	1504	12/5/2023	12:33:00 PM	604	0.2	72.1	20.4	1	
Rondo Education Center	1505	12/5/2023	3:32:00 PM	649	0.2	70	21.3	1	Fragrance Odor
Rondo Education Center	1506	12/5/2023	3:17:00 PM	574	0.2	70.9	19.7	0	Food Odor
Rondo Education Center	1507	12/5/2023	3:20:00 PM	535	0.2	71.1	18.3	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Rondo Education Center	1508	12/5/2023	12:35:00 PM	515	0.2	71.8	19.1	1	Stained Ceiling Tiles
Rondo Education Center	1511	12/5/2023	11:07:00 AM	730	0.2	70.5	22.5	25	
Rondo Education Center	1512	12/5/2023	3:22:00 PM	557	0.2	70.9	19.2	2	
Rondo Education Center	1513	12/5/2023	3:26:00 PM	596	0.2	70.3	20	4	
Rondo Education Center	1514	12/5/2023	3:28:00 PM	553	0.2	70.2	19.5	0	
Rondo Education Center	1515	12/5/2023	11:16:00 AM	661	0.2	69.4	23.7	30	Fragrance Odor, Stained Ceiling Tiles
Rondo Education Center	1516	12/5/2023	11:18:00 AM	713	0.2	69.6	22.8	25	Stained Ceiling Tiles
Rondo Education Center	1517	12/5/2023	11:14:00 AM	876	0.2	70.7	23.3	20	
Rondo Education Center	1518	12/5/2023	11:11:00 AM	791	0.2	71.6	22.4	20	
Rondo Education Center	1523	12/5/2023	11:33:00 AM	858	0.2	70.5	24	30	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1524	12/5/2023	11:31:00 AM	834	0.2	70.7	23.9	20	
Rondo Education Center	1525	12/5/2023	11:29:00 AM	1034	0.2	70.9	27.3	25	Musty Odor, Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1526	12/5/2023	11:26:00 AM	750	0.2	69.6	24.1	25	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	1704	12/5/2023	4:22:00 PM	553	0.2	69.3	21.2	0	
Rondo Education Center	1705	12/5/2023	4:18:00 PM	579	0.2	68.5	22	0	
Rondo Education Center	1707	12/5/2023	1:21:00 PM	674	0.2	70.5	21.5	0	
Rondo Education Center	1709	12/5/2023	10:36:00 AM	656	0.2	72.1	23.1	45	
Rondo Education Center	1710	12/5/2023	2:43:00 PM	686	0.2	70	23.2	0	
Rondo Education Center	1711	12/5/2023	2:46:00 PM	752	0.2	70.9	22.8	0	Fragrance Odor
Rondo Education Center	1712	12/5/2023	1:15:00 PM	768	0.2	70.9	23.4	1	
Rondo Education Center	1713	12/5/2023	10:40:00 AM	759	0.2	72.1	21.9	25	
Rondo Education Center	1714	12/5/2023	10:42:00 AM	858	0.2	72.3	23.6	30	
Rondo Education Center	1715	12/5/2023	10:44:00 AM	790	0.2	71.8	22.4	25	
Rondo Education Center	1716	12/5/2023	12:13:00 PM	677	0.2	71.2	22	15	
Rondo Education Center	1717	12/5/2023	10:34:00 AM	581	0.2	72.5	20.7	5	
Rondo Education Center	1718	12/5/2023	2:00:00 PM	456	0.2	69.8	19.4	0	
Rondo Education Center	1719	12/5/2023	2:48:00 PM	571	0.2	70.5	21.1	0	Fragrance Odor, Stained Ceiling Tiles
Rondo Education Center	1720	12/5/2023	10:59:00 AM	534	0.2	69.1	21.9	2	
Rondo Education Center	1722	12/5/2023	2:51:00 PM	424	0.2	68.9	18.7	0	Stained Ceiling Tiles
Rondo Education Center	1724	12/5/2023	11:04:00 AM	440	0.2	70	20.4	4	
Rondo Education Center	1801	12/5/2023	10:20:00 AM	700	0.2	71.2	22.6	15	
Rondo Education Center	2001	12/5/2023	10:30:00 AM	566	0.1	70.9	21.5	20	
Rondo Education Center	2002	12/5/2023	10:37:00 AM	522	0.1	70	21.7	0	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2003	12/5/2023	10:39:00 AM	604	0.1	70.5	22	3	
Rondo Education Center	2004	12/5/2023	10:42:00 AM	526	0.1	69.3	22.2	0	
Rondo Education Center	2005	12/5/2023	10:43:00 AM	515		70.2	21.6	1	
Rondo Education Center	2007	12/5/2023	10:45:00 AM	543	0.1	70.2	21.7	1	
Rondo Education Center	2009	12/5/2023	10:48:00 AM	516	0.1	70.3	21.2	0	
Rondo Education Center	2012	12/5/2023	10:51:00 AM	514	0.1	71.1	20.8	0	
Rondo Education Center	2015	12/5/2023	10:50:00 AM	534	0.1	70.9	21.3	0	
Rondo Education Center	2016	12/5/2023	10:35:00 AM	558	0.1	70.3	21.8	1	
Rondo Education Center	2101	12/5/2023	11:28:00 AM	671	0.2	70.7	23.1	17	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2102	12/5/2023	11:34:00 AM	782		71.8	23.7	0	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2103	12/5/2023	11:37:00 AM	501	0.1	71.2	20.5	0	Stained Ceiling Tiles
Rondo Education Center	2104	12/5/2023	11:40:00 AM	491		71.2	20.5	0	Stuffy, Musty Odor
Rondo Education Center	2105	12/5/2023	1:05:00 PM	849	0.1	70.5	24.4	14	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2106	12/5/2023	1:02:00 PM	638	0.1	70.5	22.3	15	Fragrance Odor, Stained Ceiling Tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Rondo Education Center	2107	12/5/2023	12:54:00 PM	620		71.4	20.6	11	
Rondo Education Center	2108	12/5/2023	12:51:00 PM	587	0.1	70.7	21.1	12	
Rondo Education Center	2201	12/5/2023	11:24:00 AM	544		71.8	20.7	2	
Rondo Education Center	2202	12/5/2023	11:32:00 AM	545		71.2	20.9	1	
Rondo Education Center	2203	12/5/2023	11:27:00 AM	717	0.1	72.9	20.1	1	Stained Ceiling Tiles
Rondo Education Center	2204	12/5/2023	11:25:00 AM	524		72.1	20.5	0	
Rondo Education Center	2206	12/5/2023	11:19:00 AM	499		71.6	20.2	0	
Rondo Education Center	2215	12/5/2023	11:05:00 AM	503	0.1	70.7	20.7	0	
Rondo Education Center	2216	12/5/2023	11:09:00 AM	543		73.6	19.3	2	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2217	12/5/2023	11:12:00 AM	609	0.1	73.9	19.7	2	
Rondo Education Center	2218	12/5/2023	11:13:00 AM	533	0.2	72.7	19.6	0	
Rondo Education Center	2223	12/5/2023	11:50:00 AM	731		70.2	26.9	42	
Rondo Education Center	2224	12/5/2023	11:53:00 AM	531	0.1	70.5	21.5	1	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2225	12/5/2023	11:57:00 AM	770		71.8	23	26	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2226	12/5/2023	12:09:00 PM	1137		71.1	26.8	14	
Rondo Education Center	2227	12/5/2023	12:10:00 PM	798	0.1	70.5	24.3	32	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2232	12/5/2023	12:18:00 PM	530		70	21.5	0	Stuffy, Food Odor
Rondo Education Center	2233	12/5/2023	12:29:00 PM	565	0.1	70.7	21.2	0	
Rondo Education Center	2236	12/5/2023	12:27:00 PM	561		71.2	21.5	1	
Rondo Education Center	2237	12/5/2023	11:59:00 AM	746	0.1	71.6	23	44	
Rondo Education Center	2239	12/5/2023	12:03:00 PM	512	0.1	70.3	21.1	0	
Rondo Education Center	2240	12/5/2023	12:04:00 PM	648		70.2	22.5	0	
Rondo Education Center	2241	12/5/2023	12:06:00 PM	615	0.1	69.6	22.8	0	
Rondo Education Center	2243	12/5/2023	11:42:00 AM	543	0.1	70.2	21.5	2	
Rondo Education Center	2246	12/5/2023	11:45:00 AM	595		69.4	23	1	
Rondo Education Center	2247	12/5/2023	12:31:00 PM	674	0.1	70.7	22.8	2	
Rondo Education Center	2248	12/5/2023	12:33:00 PM	564		70.2	22.1	4	
Rondo Education Center	2301	12/5/2023	12:14:00 PM	688		69.4	23.7	32	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2302	12/5/2023	2:49:00 PM	545	0.1	68.2	21.7	0	
Rondo Education Center	2303	12/5/2023	4:33:00 PM	490	0.2	69.3	19.5	0	
Rondo Education Center	2304	12/5/2023	2:52:00 PM	883		69.3	25	6	
Rondo Education Center	2305	12/5/2023	2:55:00 PM	750	0.1	70.5	22.3	24	Odor Description: Glue Odor, Glue
Rondo Education Center	2306	12/5/2023	2:59:00 PM	553	0.1	71.1	20.3	1	Fragrance Odor
Rondo Education Center	2307	12/5/2023	3:02:00 PM	952	0.2	70.9	24.4	30	Food Odor, Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2308	12/5/2023	3:03:00 PM	899	0.1	71.2	24.2	20	
Rondo Education Center	2309	12/5/2023	3:05:00 PM	968	0.1	71.2	24.7	24	
Rondo Education Center	2310	12/5/2023	3:06:00 PM	813	0.2	70.2	22.5	25	Plants: Kept Away From Return And Supply Vents
Rondo Education Center	2312	12/5/2023	4:35:00 PM	467	0.1	69.8	18.9	0	
Rondo Education Center	2313	12/5/2023	3:08:00 PM	771	0.1	71.2	22.4	27	
Rondo Education Center	2314	12/5/2023	3:12:00 PM	654	0.2	70.5	21.2	10	
Rondo Education Center	2315	12/5/2023	3:13:00 PM	893	0.1	69.6	24.9	30	
Rondo Education Center	2317	12/5/2023	3:15:00 PM	551		70.7	20	1	
Rondo Education Center	2320	12/5/2023	3:16:00 PM	670	0.2	70.9	20.9	28	
Rondo Education Center	2501	12/5/2023	4:40:00 PM	667	0.1	69.3	21.8	0	
Rondo Education Center	2502	12/5/2023	4:44:00 PM	665	0.1	69.4	22.3	0	
Rondo Education Center	2504	12/5/2023	3:41:00 PM	629	0.3	71.6	20.2	2	Stained Ceiling Tiles
Rondo Education Center	2505	12/5/2023	3:38:00 PM	1532	0.2	72.3	32.8	15	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Rondo Education Center	2506	12/5/2023	3:37:00 PM	1240	0.2	71.8	29.1	20	
Rondo Education Center	2507	12/5/2023	3:34:00 PM	931	0.2	71.8	23.1	22	
Rondo Education Center	2508	12/5/2023	3:20:00 PM	622	0.1	72	19.6	8	Plants
Rondo Education Center	2511	12/5/2023	4:01:00 PM	825	0.2	70.9	23	0	
Rondo Education Center	2511	12/5/2023	4:38:00 PM	480	0.1	70.3	18.9	0	
Rondo Education Center	2512	12/5/2023	4:18:00 PM	587	0.2	70.5	19.9	1	
Rondo Education Center	2513	12/5/2023	3:45:00 PM	1117	0.3	72.3	25.4	21	
Rondo Education Center	2514	12/5/2023	3:41:00 PM	863	0.2	71.2	23.5	20	Stuffy, Musty Odor, Stained Ceiling Tiles, Plants: Kept Away From Return
Rondo Education Center	2515	12/5/2023	3:52:00 PM	1022	0.3	71.1	24.2	26	Stuffy Odor
Rondo Education Center	2516	12/5/2023	3:53:00 PM	905	0.2	72	22.6	21	
Rondo Education Center	2517	12/5/2023	3:55:00 PM	1099	0.3	71.6	24.3	22	
Rondo Education Center	2518	12/5/2023	3:59:00 PM	834	0.2	71.6	21.8	0	
Rondo Education Center	2523	12/5/2023	4:11:00 PM	760	0.1	70.9	22.6	0	
Rondo Education Center	2524	12/5/2023	4:14:00 PM	643	0.2	70.7	20.7	1	
Rondo Education Center	2525	12/5/2023	4:52:00 PM	539	0.1	70.7	19.9	0	
Rondo Education Center	2526	12/5/2023	4:50:00 PM	532	0.1	70	20.5	0	
Rondo Education Center	2527	12/5/2023	4:46:00 PM	775		69.4	23.2	0	
Rondo Education Center	2601	12/5/2023	2:48:00 PM	699	0.1	68.9	23.9	4	
Rondo Education Center	2602	12/5/2023	2:46:00 PM	982		71.6	25.6	12	
Rondo Education Center	2604	12/5/2023	2:41:00 PM	758		70.9	22.9	20	Stuffy, Dirty Or Dusty Carpet Odor
Rondo Education Center	2605	12/5/2023	2:43:00 PM	646		71.2	21.7	0	Stuffy, Food Odor
Rondo Education Center	2607	12/5/2023	12:42:00 PM	718	0.1	71.2	22.9	4	Food Odor
Rondo Education Center	2608	12/5/2023	12:49:00 PM	635		71.6	21.8	0	
Rondo Education Center	2610	12/5/2023	4:24:00 PM	791	0.1	71.4	22.9	75	
Rondo Education Center	2611	12/5/2023	4:07:00 PM	680	0.2	69.6	23.5	3	
Rondo Education Center	2613	12/5/2023	1:19:00 PM	762	0.1	71.8	22.7	7	
Rondo Education Center	2614	12/5/2023	4:54:00 PM	638	0.1	70.2	21.2	0	
Rondo Education Center	2615	12/5/2023	1:27:00 PM	811	0.1	71.1	23.7	0	
Rondo Education Center	2704	12/5/2023	1:32:00 PM	585		69.6	21.9	0	Odor Description: Paint Odor
Rondo Education Center	2705	12/5/2023	1:34:00 PM	619		70.2	22.5	3	
Rondo Education Center	2706	12/5/2023	1:36:00 PM	690	0.1	69.6	22.9	9	
Rondo Education Center	2707	12/5/2023	1:38:00 PM	802		69.4	24.4	8	
Rondo Education Center	2708	12/5/2023	1:14:00 PM	570	0.2	71.4	20.7	1	
Rondo Education Center	2709	12/5/2023	1:16:00 PM	881	0.1	71.6	24.2	15	Dirty Or Dusty Carpet Odor
Rondo Education Center	2710	12/5/2023	1:13:00 PM	1016	0.1	71.8	25.2	24	
Rondo Education Center	2711	12/5/2023	1:08:00 PM	673	0.1	71.1	22.5	8	Stuffy Odor
Rondo Education Center	2714	12/5/2023	1:40:00 PM	782	0.1	69.4	24.6	10	Stuffy, Food Odor
Rondo Education Center	1344B	12/5/2023	4:13:00 PM	471	0.2	70.9	17.8	0	
Rondo Education Center	134A	12/5/2023	4:11:00 PM	525	0.2	70.5	18.6	1	
Rondo Education Center	2220A	12/5/2023	11:15:00 AM	493	0.1	72.1	19.7	0	
Rondo Education Center	2220B	12/5/2023	11:48:00 AM	497		70.2	21.5	0	
Rondo Education Center	2304A	12/5/2023	2:54:00 PM	584		69.4	21.2	0	Stained Ceiling Tiles
Rondo Education Center	2613B	12/5/2023	1:25:00 PM	787		72	22.4	0	
Rondo Education Center	2613C	12/5/2023	1:30:00 PM	779	0.1	70.3	23.6	0	
Rondo Education Center	OUTDOORS	12/5/2023		447	0.1	31	88		
Saint Anthony Park Elementary School	1001	1/11/2024	9:32:00 AM	840		69.6	16.4	2	
Saint Anthony Park Elementary School	1002	1/11/2024	9:38:00 AM	739		71.4	15.6	1	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Saint Anthony Park Elementary School	1003	1/11/2024	9:33:00 AM	755		70.2	17.3	3	
Saint Anthony Park Elementary School	1005	1/11/2024	9:37:00 AM	707		71.1	15.9	1	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1006	1/11/2024	9:34:00 AM	672		70.7	16.1	1	
Saint Anthony Park Elementary School	1101	1/11/2024	10:34:00 AM	774		70	12.7	75	
Saint Anthony Park Elementary School	1107	1/11/2024	9:17:00 AM	794	0.9	68.9	15.5	0	
Saint Anthony Park Elementary School	1109	1/11/2024	8:41:00 AM	693		69.4	16.4	30	
Saint Anthony Park Elementary School	1110	1/11/2024	9:14:00 AM	640		70.5	14.6	1	
Saint Anthony Park Elementary School	1112	1/11/2024	10:37:00 AM	621		70.3	11.4	0	
Saint Anthony Park Elementary School	1201	1/11/2024	9:12:00 AM	737		69.6	15.1	20	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1203	1/11/2024	9:09:00 AM	776		69.6	15.6	20	
Saint Anthony Park Elementary School	1204	1/11/2024	10:32:00 AM	566		69.3	11.5	0	
Saint Anthony Park Elementary School	1205	1/11/2024	9:07:00 AM	777		69.8	15.2	20	
Saint Anthony Park Elementary School	1207	1/11/2024	9:05:00 AM	843		69.6	16.6	20	
Saint Anthony Park Elementary School	1216	1/11/2024	9:04:00 AM	610		69.4	15	3	
Saint Anthony Park Elementary School	1218	1/11/2024	9:02:00 AM	724		69.4	15.1	20	
Saint Anthony Park Elementary School	1220	1/11/2024	9:00:00 AM	637		69.3	14	20	Stained Ceiling Tiles
Saint Anthony Park Elementary School	1302	1/11/2024	8:46:00 AM	812		69.3	14.9	25	
Saint Anthony Park Elementary School	1303	1/11/2024	10:30:00 AM	534		69.4	10.6	1	
Saint Anthony Park Elementary School	1304	1/11/2024	10:27:00 AM	507		70	9.7	0	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1305	1/11/2024	10:29:00 AM	650		69.6	11.3	15	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1306	1/11/2024	8:52:00 AM	649		69.4	14.3	15	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1307	1/11/2024	8:51:00 AM	581		69.3	12.9	4	
Saint Anthony Park Elementary School	1308	1/11/2024	8:55:00 AM	540		69.6	14.1	3	
Saint Anthony Park Elementary School	1309	1/11/2024	10:26:00 AM	463		70	9.9	0	
Saint Anthony Park Elementary School	1310	1/11/2024	8:58:00 AM	763		69.8	15.2	20	
Saint Anthony Park Elementary School	1311	1/11/2024	8:56:00 AM	804		69.8	15.8	25	Aquariums (fish), Live Animals: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	1401	1/11/2024	10:23:00 AM	477		69.6	9	0	
Saint Anthony Park Elementary School	1402	1/11/2024	10:25:00 AM	489		69.3	9.8	0	
Saint Anthony Park Elementary School	1403	1/11/2024	9:44:00 AM	583		70.5	12.4	1	
Saint Anthony Park Elementary School	1405	1/11/2024	9:43:00 AM	499		71.1	9.7	1	
Saint Anthony Park Elementary School	1407	1/11/2024	9:41:00 AM	500		69.6	10.3	0	
Saint Anthony Park Elementary School	1409	1/11/2024	9:27:00 AM	539		69.8	11.4	1	
Saint Anthony Park Elementary School	1411	1/11/2024	9:25:00 AM	582		69.8	12.1	1	Fragrance Odor
Saint Anthony Park Elementary School	1413	1/11/2024	9:24:00 AM	560		69.6	12.1	25	
Saint Anthony Park Elementary School	2201	1/11/2024	10:06:00 AM	1098		68.9	18.5	25	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	2202	1/11/2024	10:12:00 AM	705		70.3	14.2	0	
Saint Anthony Park Elementary School	2203	1/11/2024	10:10:00 AM	875		70.7	14.4	15	
Saint Anthony Park Elementary School	2205	1/11/2024	10:03:00 AM	900		70.3	14.8	20	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	2207	1/11/2024	10:02:00 AM	846		70.7	14.3	20	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	2209	1/11/2024	9:57:00 AM	861		70.3	15.1	20	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	2211	1/11/2024	9:59:00 AM	703		70.5	12.7	2	
Saint Anthony Park Elementary School	2212	1/11/2024	10:00:00 AM	658		70.7	12.3	1	Fragrance Odor
Saint Anthony Park Elementary School	2401	1/11/2024	10:21:00 AM	756		71.1	12.9	0	
Saint Anthony Park Elementary School	2403	1/11/2024	10:17:00 AM	737		70	14.2	25	
Saint Anthony Park Elementary School	2404	1/11/2024	9:55:00 AM	673		70.9	14.4	2	
Saint Anthony Park Elementary School	2405	1/11/2024	10:19:00 AM	1119		70.5	17.6	20	Plants: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	2406	1/11/2024	10:20:00 AM	853		71.1	14.8	25	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Saint Anthony Park Elementary School	2408	1/11/2024	9:54:00 AM	969		70.5	17.5	30	
Saint Anthony Park Elementary School	2409	1/11/2024	9:48:00 AM	488		69.4	10	1	Fragrance Odor, Live Animals: Kept Away From Return And Supply Vents
Saint Anthony Park Elementary School	2410	1/11/2024	9:52:00 AM	749		69.8	15.2	2	
Saint Anthony Park Elementary School	2412	1/11/2024	9:50:00 AM	653		69.4	13.9	1	
Saint Anthony Park Elementary School	1101A	1/11/2024	10:35:00 AM	773		70.7	12.7	8	
Saint Anthony Park Elementary School	1103C	1/11/2024	9:20:00 AM	709	0.1	68.9	15.8	1	
Saint Anthony Park Elementary School	1109A	1/11/2024	8:42:00 AM	551		69.3	15.3	1	
Saint Anthony Park Elementary School	CUSTODIAL OFFICE	1/11/2024	9:15:00 AM	632		71.1	13.7	1	
Saint Anthony Park Elementary School	KITCHEN	1/11/2024	9:21:00 AM	1320	2.5	68.9	21	5	
Saint Anthony Park Elementary School	MEDIA CENTER	1/11/2024	8:48:00 AM	634		69.3	14.2	8	
Saint Anthony Park Elementary School	OUTDOORS	1/11/2024		420		14	71		
Saint Paul Music Academy	1102	1/11/2024	10:48:00 AM	1198	0.2	72.3	20.5	50	
Saint Paul Music Academy	1103	1/11/2024	8:47:00 AM	970	1.5	69.3	21.2	20	
Saint Paul Music Academy	1104	1/11/2024	8:46:00 AM	1060	1.6	69.1	19.9	18	
Saint Paul Music Academy	1105	1/11/2024	8:42:00 AM	1021	1.6	68.9	22.5	15	
Saint Paul Music Academy	1106	1/11/2024	8:41:00 AM	457	1.2	68.2	11.7	20	
Saint Paul Music Academy	1107	1/11/2024	8:39:00 AM	561	1.2	68.7	12	25	
Saint Paul Music Academy	1109	1/11/2024	10:31:00 AM	1027	0.2	71.2	19.7	40	
Saint Paul Music Academy	1111	1/11/2024	8:36:00 AM	557	1.2	70.7	16.3	0	
Saint Paul Music Academy	1112	1/11/2024	8:37:00 AM	564	1.3	70.2	16.9	1	
Saint Paul Music Academy	1116	1/11/2024	8:38:00 AM	445	1.3	68.9	15.6	0	
Saint Paul Music Academy	1201	1/11/2024	8:49:00 AM	893	1.4	71.2	18	20	
Saint Paul Music Academy	1202	1/11/2024	8:50:00 AM	771	1.4	71.6	17	16	
Saint Paul Music Academy	1203	1/11/2024	8:51:00 AM	383	1.4	72	12.6	0	
Saint Paul Music Academy	1204	1/11/2024	8:55:00 AM	741	1.3	71.2	15.8	8	
Saint Paul Music Academy	1205	1/11/2024	8:54:00 AM	602	1.4	71.4	14.2	5	
Saint Paul Music Academy	1206	1/11/2024	9:00:00 AM	555	1	70.9	13.3	0	
Saint Paul Music Academy	1207	1/11/2024	8:56:00 AM	719	1.3	70.5	16.4	0	
Saint Paul Music Academy	1208	1/11/2024	8:58:00 AM	391	1.1	70.9	11.9	0	
Saint Paul Music Academy	1209	1/11/2024	9:00:00 AM	362	1.1	71.1	11.4	0	
Saint Paul Music Academy	1210	1/11/2024	8:30:00 AM	635	0.9	72.1	15.7	20	
Saint Paul Music Academy	1211	1/11/2024	8:33:00 AM	523	1.1	71.1	14.4	6	
Saint Paul Music Academy	1216	1/11/2024	8:48:00 AM	582	1.4	70.2	16.5	0	
Saint Paul Music Academy	1218	1/11/2024	8:20:00 AM	581	0.7	70.9	17.6	2	
Saint Paul Music Academy	1219	1/11/2024	8:34:00 AM	515	1	71.1	15.7	0	
Saint Paul Music Academy	1301	1/11/2024	10:49:00 AM	952	0.2	70.9	16.6	15	
Saint Paul Music Academy	1302	1/11/2024	9:27:00 AM	957	0.3	69.1	18.2	10	
Saint Paul Music Academy	1303	1/11/2024	9:26:00 AM	905	0.3	70	17.5	8	Stained Ceiling Tiles
Saint Paul Music Academy	1304	1/11/2024	9:25:00 AM	1404	0.3	70.2	20	24	Stained Ceiling Tiles
Saint Paul Music Academy	1305	1/11/2024	9:10:00 AM	1197	0.3	69.4	19.8	18	
Saint Paul Music Academy	1306	1/11/2024	9:09:00 AM	1026	0.7	69.8	18.2	18	
Saint Paul Music Academy	1307	1/11/2024	9:08:00 AM	836	0.7	69.4	15.5	20	
Saint Paul Music Academy	1308	1/11/2024	9:08:00 AM	965	0.7	69.3	19.8	9	
Saint Paul Music Academy	1309	1/11/2024	9:07:00 AM	1061	0.8	69.1	21	8	
Saint Paul Music Academy	1310	1/11/2024	9:05:00 AM	716	0.8	69.1	18.2	0	
Saint Paul Music Academy	1312	1/11/2024	9:01:00 AM	601	1	69.4	16.1	0	
Saint Paul Music Academy	1313	1/11/2024	9:03:00 AM	669	0.9	69.1	18.4	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Saint Paul Music Academy	1317	1/11/2024	9:28:00 AM	1038	0.2	69.1	22.2	1	
Saint Paul Music Academy	1320	1/11/2024	9:30:00 AM	816	0.2	69.8	18.1	0	
Saint Paul Music Academy	1321	1/11/2024	9:31:00 AM	789	0.2	69.6	18.5	0	
Saint Paul Music Academy	2001	1/11/2024	10:14:00 AM	752	0.2	71.4	14.8	3	
Saint Paul Music Academy	2002	1/11/2024	10:25:00 AM	751	0.2	70.5	15.4	2	
Saint Paul Music Academy	2005	1/11/2024	10:23:00 AM	689	0.2	69.4	14.6	0	
Saint Paul Music Academy	2006	1/11/2024	10:22:00 AM	695	0.2	69.4	15.2	1	
Saint Paul Music Academy	2007	1/11/2024	10:19:00 AM	710	0.2	70	15.6	0	
Saint Paul Music Academy	2008	1/11/2024	10:21:00 AM	704	0.2	69.4	14.9	1	
Saint Paul Music Academy	2009	1/11/2024	10:18:00 AM	726	0.2	70	15.1	2	
Saint Paul Music Academy	2010	1/11/2024	10:15:00 AM	792	0.2	70.3	15.6	4	
Saint Paul Music Academy	2016	1/11/2024	10:31:00 AM	686	0.2	70.3	14.8	1	
Saint Paul Music Academy	2101	1/11/2024	10:29:00 AM	976	0.2	69.8	18.5	1	
Saint Paul Music Academy	2102	1/11/2024	10:28:00 AM	953	0.2	69.8	16.8	20	
Saint Paul Music Academy	2103	1/11/2024	10:26:00 AM	667	0.2	70.3	14.4	0	
Saint Paul Music Academy	2104	1/11/2024	10:07:00 AM	884	0.2	72	15.9	0	
Saint Paul Music Academy	2105	1/11/2024	11:01:00 AM	1081	0.2	70.7	20.3	20	
Saint Paul Music Academy	2106	1/11/2024	10:11:00 AM	761	0.2	72	16.5	30	
Saint Paul Music Academy	2107	1/11/2024	10:54:00 AM	1027	0.2	71.2	18	25	Plants: Kept Away From Return And Supply Vents
Saint Paul Music Academy	2201	1/11/2024	9:57:00 AM	564	0.2	71.4	13.3	1	
Saint Paul Music Academy	2202	1/11/2024	9:56:00 AM	603	0.2	71.4	14	6	
Saint Paul Music Academy	2203	1/11/2024	9:54:00 AM	836	0.2	70.7	14.8	15	
Saint Paul Music Academy	2204	1/11/2024	9:52:00 AM	834	0.2	70.9	14.9	15	
Saint Paul Music Academy	2205	1/11/2024	10:06:00 AM	855	0.2	72.5	14.7	30	
Saint Paul Music Academy	2206	1/11/2024	9:59:00 AM	873	0.2	72	14.4	12	
Saint Paul Music Academy	2207	1/11/2024	10:00:00 AM	858	0.2	72.3	14	15	
Saint Paul Music Academy	2208	1/11/2024	10:04:00 AM	1097	0.2	72.1	17.3	25	
Saint Paul Music Academy	2209	1/11/2024	10:05:00 AM	567	0.2	72.5	13.6	0	
Saint Paul Music Academy	2210	1/11/2024	10:02:00 AM	917	0.2	72.9	16.3	1	
Saint Paul Music Academy	2211	1/11/2024	10:01:00 AM	861	0.2	72.5	15.5	1	
Saint Paul Music Academy	2212	1/11/2024	9:58:00 AM	838	0.2	72.1	14.8	0	
Saint Paul Music Academy	2301	1/11/2024	9:47:00 AM	1139	0.2	71.4	18.9	9	
Saint Paul Music Academy	2302	1/11/2024	9:46:00 AM	1131	0.2	71.1	19.1	7	
Saint Paul Music Academy	2303	1/11/2024	9:45:00 AM	1084	0.2	70.9	19.3	1	
Saint Paul Music Academy	2304	1/11/2024	9:44:00 AM	1296	0.2	70.5	20.8	20	
Saint Paul Music Academy	2305	1/11/2024	9:42:00 AM	981	0.2	70	18.1	1	
Saint Paul Music Academy	2306	1/11/2024	9:41:00 AM	1598	0.2	69.6	22.7	18	
Saint Paul Music Academy	2307	1/11/2024	9:40:00 AM	1384	0.2	69.4	21.7	24	
Saint Paul Music Academy	2308	1/11/2024	9:39:00 AM	1072	0.2	70	18.4	3	
Saint Paul Music Academy	2309	1/11/2024	9:38:00 AM	1290	0.2	70.2	21.2	18	
Saint Paul Music Academy	2310	1/11/2024	9:37:00 AM	1117	0.2	69.4	20.3	1	
Saint Paul Music Academy	2311	1/11/2024	9:37:00 AM	1112	0.2	69.3	20.7	1	
Saint Paul Music Academy	2312	1/11/2024	9:36:00 AM	853	0.2	69.4	17.1	1	
Saint Paul Music Academy	2313	1/11/2024	9:33:00 AM	1013	0.2	70.2	19.8	0	
Saint Paul Music Academy	2317	1/11/2024	9:48:00 AM	704	0.2	71.2	19.4	0	
Saint Paul Music Academy	2319	1/11/2024	9:51:00 AM	1111	0.2	70.9	18.8	0	
Saint Paul Music Academy	2205A	1/11/2024	10:03:00 AM	853	0.2	72	15.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Saint Paul Music Academy	2205B	1/11/2024	9:55:00 AM	791	0.2	71.1	15.1	3	
Saint Paul Music Academy	2300B	1/11/2024	9:49:00 AM	946	0.2	70.9	18.2	0	
Saint Paul Music Academy	OUTDOORS	1/11/2024		293	0.3	17	76		
Saint Paul Music Academy	PRINCIPAL	1/11/2024	10:24:00 AM	675	0.2	69.8	14.5	0	Plants: Kept Away From Return And Supply Vents
Student Placement Center	1106	1/11/2024	12:38:00 PM	612		67.5	17.1	8	
Student Placement Center	1110	1/11/2024	12:39:00 PM	637		67.6	15.2	2	
Student Placement Center	1112	1/11/2024	12:40:00 PM	761		67.8	18.7	4	
Student Placement Center	1113	1/11/2024	12:42:00 PM	690		68	17.9	0	
Student Placement Center	1118	1/11/2024	12:44:00 PM	623		67.6	16.4	0	
Student Placement Center	1119	1/11/2024	12:45:00 PM	628		67.1	17.1	0	
Student Placement Center	1120	1/11/2024	12:46:00 PM	635		67.8	17	0	
Student Placement Center	1121	1/11/2024	12:47:00 PM	619		68.5	16.4	0	
Student Placement Center	1122	1/11/2024	12:43:00 PM	618		68.2	15.8	1	
Student Placement Center	1123	1/11/2024	12:49:00 PM	634		69.3	15.2	1	
Student Placement Center	1124	1/11/2024	12:48:00 PM	646		68.9	15.4	1	
Student Placement Center	2201	1/11/2024	1:04:00 PM	634		68.4	15.1	3	
Student Placement Center	2205	1/11/2024	1:10:00 PM	638		69.1	15.2	1	
Student Placement Center	2206	1/11/2024	1:05:00 PM	683		68.7	15.5	4	Plants: Kept Away From Return And Supply Vents
Student Placement Center	2211	1/11/2024	1:03:00 PM	633		68.2	15.2	1	
Student Placement Center	2213	1/11/2024	1:03:00 PM	655		67.8	15	1	Stained Ceiling Tiles
Student Placement Center	2216	1/11/2024	1:01:00 PM	664		68.2	14.6	5	Stained Ceiling Tiles
Student Placement Center	2217	1/11/2024	12:59:00 PM	657		70.2	13.7	1	Stained Ceiling Tiles
Student Placement Center	2218	1/11/2024	1:19:00 PM	671		68.9	14.1	0	Stained Ceiling Tiles
Student Placement Center	2219	1/11/2024	1:20:00 PM	633		68	14.3	0	
Student Placement Center	2220	1/11/2024	12:57:00 PM	687		74.7	12.6	1	
Student Placement Center	2221	1/11/2024	12:58:00 PM	760		73.2	13.4	1	Fragrance Odor
Student Placement Center	2222	1/11/2024	12:55:00 PM	640		69.3	13.8	0	
Student Placement Center	2223	1/11/2024	12:55:00 PM	617		69.8	14.1	0	
Student Placement Center	2229	1/11/2024	12:53:00 PM	660		70.3	15.8	1	
Student Placement Center	2230	1/11/2024	1:26:00 PM	784		70.2	16.7	3	Plants: Kept Away From Return And Supply Vents
Student Placement Center	2232	1/11/2024	1:21:00 PM	667		68.5	15.2	1	
Student Placement Center	2233	1/11/2024	1:25:00 PM	663		69.6	15.1	1	
Student Placement Center	2234	1/11/2024	12:51:00 PM	684		69.8	16.1	4	Plants: Kept Away From Return And Supply Vents
Student Placement Center	3301	1/11/2024	1:11:00 PM	701		68.9	16.2	2	
Student Placement Center	3303	1/11/2024	1:15:00 PM	653		68.2	14.8	0	
Student Placement Center	3306	1/11/2024	1:17:00 PM	724		69.8	15.2	0	
Student Placement Center	3308	1/11/2024	1:13:00 PM	753		68.5	17.7	1	Stained Ceiling Tiles
Student Placement Center	1101A	1/11/2024	12:31:00 PM	631		66.4	18.1	1	
Student Placement Center	1101B	1/11/2024	12:33:00 PM	618		67.8	16.9	1	
Student Placement Center	2215A	1/11/2024	1:02:00 PM	652		68	14.8	6	Stained Ceiling Tiles
Student Placement Center	2215B	1/11/2024	1:00:00 PM	662		68.9	14.1	3	Stained Ceiling Tiles
Student Placement Center	3301B	1/11/2024	1:12:00 PM	701		69.4	14.9	3	
Student Placement Center	OUTDOORS	1/11/2024		462		16	68		
The Heights Community School	1102	12/4/2023	10:56:00 AM	656	0.2	71.4	26.7	3	
The Heights Community School	1105	12/4/2023	11:06:00 AM	545	0.2	71.1	20.1	7	
The Heights Community School	1107	12/4/2023	11:04:00 AM	405	0.2	70.2	19.4	2	
The Heights Community School	1108	12/4/2023	11:00:00 AM	422	0.2	68.4	20.1	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
The Heights Community School	1109	12/4/2023	11:08:00 AM	388	0.2	70.5	18.3	0	
The Heights Community School	1110	12/4/2023	10:49:00 AM	632	0.2	71.2	22.2	40	
The Heights Community School	1111	12/4/2023	11:10:00 AM	432	0.2	70.3	20	1	Plants: Kept Away From Return And Supply Vents
The Heights Community School	1114	12/4/2023	10:58:00 AM	459	0.2	70	19.8	1	Stained Ceiling Tiles
The Heights Community School	1248	12/4/2023	8:25:00 AM	574	0.2	74.8	19	1	
The Heights Community School	1251	12/4/2023	8:19:00 AM	606	0.2	74.5	19.2	35	Stained Ceiling Tiles
The Heights Community School	1253	12/4/2023	8:26:00 AM	660	0.2	76.6	18.4	0	
The Heights Community School	1346	12/4/2023	10:35:00 AM	457	0.2	77.7	14.4	0	Stained Ceiling Tiles
The Heights Community School	1353	12/4/2023	8:16:00 AM	555	0.2	70.5	25	1	
The Heights Community School	2000	12/4/2023	9:05:00 AM	478	0.2	70.5	19.8	2	
The Heights Community School	2002	12/4/2023	10:34:00 AM	528	0.2	72	19.2	0	
The Heights Community School	2003	12/4/2023	10:32:00 AM	509	0.2	72.9	18.5	1	
The Heights Community School	2004	12/4/2023	9:07:00 AM	506	0.2	70.5	20.6	1	
The Heights Community School	2102	12/4/2023	8:33:00 AM	859	0.3	77	18.5	30	
The Heights Community School	2104	12/4/2023	8:41:00 AM	656	0.2	74.7	17.5	25	
The Heights Community School	2109	12/4/2023	8:47:00 AM	625	0.2	72.7	18.3	8	
The Heights Community School	2111	12/4/2023	9:00:00 AM	639	0.2	72.1	19.4	20	
The Heights Community School	2113	12/4/2023	9:01:00 AM	647	0.2	71.1	19.4	30	
The Heights Community School	2114	12/4/2023	9:02:00 AM	725	0.2	70	21.3	25	
The Heights Community School	2115	12/4/2023	9:03:00 AM	417	0.2	69.3	18.8	8	
The Heights Community School	2241	12/4/2023	10:42:00 AM	427	0.2	74.8	16.3	0	Stained Ceiling Tiles
The Heights Community School	2244	12/4/2023	10:13:00 AM	446	0.2	71.6	18.6	1	Stained Ceiling Tiles
The Heights Community School	2245	12/4/2023	9:12:00 AM	925	0.2	73	22.3	25	Stained Ceiling Tiles, Aquariums (fish), Plants: Kept Away From Return Ar
The Heights Community School	2250	12/4/2023	10:45:00 AM	438	0.2	72.7	16.7	0	
The Heights Community School	2254	12/4/2023	9:09:00 AM	473	0.2	72.1	18.9	5	
The Heights Community School	2255	12/4/2023	10:11:00 AM	443	0.2	72.1	18.2	1	Stained Ceiling Tiles
The Heights Community School	2301	12/4/2023	11:11:00 AM	515	0.2	71.4	19.8	0	
The Heights Community School	2303	12/4/2023	10:29:00 AM	482	0.2	78.1	14.3	1	
The Heights Community School	2304	12/4/2023	10:08:00 AM	458	0.2	76.1	15.7	1	
The Heights Community School	2307	12/4/2023	10:22:00 AM	515	0.2	78.3	15.6	2	
The Heights Community School	2309	12/4/2023	8:39:00 AM	489	0.2	75.9	16	1	Stained Ceiling Tiles
The Heights Community School	3243	12/4/2023	9:24:00 AM	515	0.2	72.7	18.6	7	
The Heights Community School	3244	12/4/2023	9:25:00 AM	435	0.2	71.2	18.6	1	
The Heights Community School	3245	12/4/2023	9:21:00 AM	769	0.2	74.1	19.1	30	
The Heights Community School	3248	12/4/2023	9:16:00 AM	702	0.2	74.5	18.1	20	Plants: Kept Away From Return And Supply Vents
The Heights Community School	3251	12/4/2023	11:17:00 AM	521	0.2	72.1	20.3	1	
The Heights Community School	3252	12/4/2023	9:26:00 AM	501	0.2	72.5	18.2	2	Plants: Kept Away From Return And Supply Vents
The Heights Community School	3253	12/4/2023	10:03:00 AM	621	0.2	73.9	18.4	20	Stained Ceiling Tiles
The Heights Community School	3254	12/4/2023	10:09:00 AM	420	0.2	73.4	17	2	
The Heights Community School	3257	12/4/2023	9:30:00 AM	433	0.2	72	17.2	7	
The Heights Community School	4244	12/4/2023	10:03:00 AM	430	0.2	70.7	18.8	0	
The Heights Community School	4245	12/4/2023	8:51:00 AM	503	0.2	73.8	18.2	4	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
The Heights Community School	4247	12/4/2023	9:43:00 AM	802	0.2	72.3	21	30	
The Heights Community School	4250	12/4/2023	9:44:00 AM	770	0.2	74.5	20.5	20	
The Heights Community School	4252	12/4/2023	9:45:00 AM	925	0.2	73.2	24	25	Food Odor, Plants: Kept Away From Return And Supply Vents
The Heights Community School	4255	12/4/2023	11:20:00 AM	535	0.2	72.7	18.8	1	Stained Ceiling Tiles
The Heights Community School	4256	12/4/2023	11:23:00 AM	475	0.2	72	19.1	0	Plants: Kept Away From Return And Supply Vents

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
The Heights Community School	4257	12/4/2023	9:56:00 AM	553	0.2	73.6	18.2	0	
The Heights Community School	4258	12/4/2023	9:52:00 AM	428	0.2	73.2	17.7	1	Bubbling/Peeling Paint, Plants: Kept Away From Return And Supply Vents
The Heights Community School	4259	12/4/2023	9:46:00 AM	465	0.2	72.7	17.6	4	
The Heights Community School	204A/2116	12/4/2023	9:02:00 AM	680	0.2	69.4	21.3	6	
The Heights Community School	2102A	12/4/2023	10:25:00 AM	1203	0.2	80.1	19.8	2	Food Odor
The Heights Community School	2104A	12/4/2023	8:44:00 AM	1198	0.2	73.9	23.4	5	Fragrance Odor
The Heights Community School	2109A	12/4/2023	8:38:00 AM	478	0.4	74.8	16	3	
The Heights Community School	3250A	12/4/2023	9:31:00 AM	463	0.2	72.5	17.2	1	
The Heights Community School	4250A	12/4/2023	11:26:00 AM	430	0.2	68.9	19.6	0	
The Heights Community School	OUTDOORS	12/4/2023		363	0.2	33	85		
Transportation Department	1001	11/29/2023	3:34:00 PM	507	0.4	69.6	19.9	0	
Transportation Department	1002	11/29/2023	3:25:00 PM	599		68.9	28.9	1	
Transportation Department	1002	11/29/2023	3:43:00 PM	513	0.4	71.4	18.4	0	
Transportation Department	1003	11/29/2023	3:33:00 PM	522	0.4	69.1	20.5	0	
Transportation Department	1009	11/29/2023	3:35:00 PM	517	0.4	69.4	19.9	0	
Transportation Department	1105	11/29/2023	3:41:00 PM	557	0.4	70.7	19.5	3	
Transportation Department	1106	11/29/2023	3:36:00 PM	528	0.3	70.2	19.6	0	
Transportation Department	1107	11/29/2023	3:38:00 PM	540	0.4	70.3	19.6	0	Fragrance Odor
Transportation Department	1108	11/29/2023	3:40:00 PM	593	0.4	70.5	20	1	
Transportation Department	1200	11/29/2023	3:42:00 PM	514	4	70.7	19	0	
Transportation Department	OUTDOORS	11/29/2023		480	0.7	45	34.8		
Txuj Ci Hmong Lower	4	1/18/2024	10:00:00 AM	849		68	10.4	0	
Txuj Ci Hmong Lower	5	1/18/2024	12:23:00 PM	446		59.7	6.6	0	
Txuj Ci Hmong Lower	1001	1/18/2024	12:10:00 PM	1140		70.2	12	3	
Txuj Ci Hmong Lower	1002	1/18/2024	12:10:00 PM	1222		69.8	10.5	0	
Txuj Ci Hmong Lower	1003	1/18/2024	12:06:00 PM	868		69.6	10.8	0	
Txuj Ci Hmong Lower	1006	1/18/2024	11:59:00 AM	776		70.3	9.5	1	
Txuj Ci Hmong Lower	1007	1/18/2024	11:57:00 AM	809		70	9.2	0	
Txuj Ci Hmong Lower	1010	1/18/2024	12:00:00 PM	794		69.8	9.6	1	
Txuj Ci Hmong Lower	1011	1/18/2024	12:08:00 PM	929		69.6	10.5	0	Fragrance Odor
Txuj Ci Hmong Lower	1014	1/18/2024	12:03:00 PM	1130		69.3	12	1	
Txuj Ci Hmong Lower	1102	1/18/2024	10:24:00 AM	687		68.2	8.2	40	
Txuj Ci Hmong Lower	1104	1/18/2024	10:25:00 AM	685		67.8	8.9	0	
Txuj Ci Hmong Lower	1104	1/18/2024	12:05:00 PM	820		69.4	9.3	0	
Txuj Ci Hmong Lower	1107	1/18/2024	10:17:00 AM	832		68.7	68.7	24	
Txuj Ci Hmong Lower	1108	1/18/2024	10:23:00 AM	760		68.9	9.9	0	
Txuj Ci Hmong Lower	1110	1/18/2024	11:50:00 AM	1125		70.2	14.6	100	
Txuj Ci Hmong Lower	1111	1/18/2024	11:53:00 AM	1085		71.6	18.6	4	
Txuj Ci Hmong Lower	1112	1/18/2024	11:55:00 AM	926		71.1	13.6	1	Plants: Kept Away From Return And Supply Vents
Txuj Ci Hmong Lower	1203	1/18/2024	10:29:00 AM	1118		69.1	12.6	20	
Txuj Ci Hmong Lower	1204	1/18/2024	10:31:00 AM	1023		70.7	7.7	2	
Txuj Ci Hmong Lower	1205	1/18/2024	10:33:00 AM	895		70	11.8	10	
Txuj Ci Hmong Lower	1206	1/18/2024	10:34:00 AM	970		69.6	10.4	20	
Txuj Ci Hmong Lower	1207	1/18/2024	10:36:00 AM	1129		69.4	14.2	20	
Txuj Ci Hmong Lower	1208	1/18/2024	10:55:00 AM	944		69.6	12	20	
Txuj Ci Hmong Lower	1209	1/18/2024	10:32:00 AM	798		70	8.4	3	
Txuj Ci Hmong Lower	1210	1/18/2024	10:27:00 AM	1022		68.7	11	22	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Txuj Ci Hmong Lower	1213	1/18/2024	10:45:00 AM	836		69.3	8.7	0	
Txuj Ci Hmong Lower	1214	1/18/2024	10:46:00 AM	791		69.6	8.9	2	
Txuj Ci Hmong Lower	1215	1/18/2024	10:44:00 AM	701		69.1	7.7	7	
Txuj Ci Hmong Lower	1216	1/18/2024	11:02:00 AM	1003		70.5	12	25	
Txuj Ci Hmong Lower	1217	1/18/2024	11:08:00 AM	1061		71.1	10.5	22	
Txuj Ci Hmong Lower	1218	1/18/2024	11:09:00 AM	839		70.9	8.9	20	
Txuj Ci Hmong Lower	1219	1/18/2024	11:09:00 AM	651		70.3	7.5	4	
Txuj Ci Hmong Lower	1220	1/18/2024	11:37:00 AM	710		70.3	9.1	0	
Txuj Ci Hmong Lower	1221	1/18/2024	11:10:00 AM	863		69.6	11.1	20	
Txuj Ci Hmong Lower	1222	1/18/2024	11:45:00 AM	604		69.6	7.8	24	
Txuj Ci Hmong Lower	1223	1/18/2024	11:49:00 AM	720		69.6	10.4	25	
Txuj Ci Hmong Lower	1301	1/18/2024	11:13:00 AM	870		70	11.5	20	
Txuj Ci Hmong Lower	1302	1/18/2024	11:16:00 AM	1030		70.3	11.2	20	
Txuj Ci Hmong Lower	1303	1/18/2024	11:17:00 AM	1447		71.1	14.6	25	Fragrance Odor
Txuj Ci Hmong Lower	1304	1/18/2024	11:15:00 AM	882		70.3	10.4	20	
Txuj Ci Hmong Lower	1401	1/18/2024	11:44:00 AM	692		70.7	8.1	0	
Txuj Ci Hmong Lower	1402	1/18/2024	11:43:00 AM	743		70.7	9.1	0	
Txuj Ci Hmong Lower	1403	1/18/2024	11:41:00 AM	845		70.9	9.7	20	
Txuj Ci Hmong Lower	1404	1/18/2024	11:39:00 AM	1032		70.5	11.1	20	
Txuj Ci Hmong Lower	1405	1/18/2024	10:53:00 AM	1082		71.8	12.7	20	
Txuj Ci Hmong Lower	1406	1/18/2024	10:51:00 AM	840		71.6	8.4	4	Stuffy Odor
Txuj Ci Hmong Lower	1407	1/18/2024	11:34:00 AM	803		71.2	8.8	25	
Txuj Ci Hmong Lower	1409	1/18/2024	11:32:00 AM	943		72.1	10.1	20	
Txuj Ci Hmong Lower	1410	1/18/2024	11:28:00 AM	954		72.3	8.5	25	
Txuj Ci Hmong Lower	1411	1/18/2024	11:27:00 AM	906		72.1	9.4	22	
Txuj Ci Hmong Lower	1412	1/18/2024	11:26:00 AM	1125		72.7	12.2	20	
Txuj Ci Hmong Lower	1413	1/18/2024	11:24:00 AM	953		71.8	10.2	1	
Txuj Ci Hmong Lower	1414	1/18/2024	10:50:00 AM	825		71.1	7.8	3	
Txuj Ci Hmong Lower	1415	1/18/2024	11:23:00 AM	922		71.5	10	25	
Txuj Ci Hmong Lower	1416	1/18/2024	11:22:00 AM	873		71.4	9.8	30	
Txuj Ci Hmong Lower	1417	1/18/2024	11:20:00 AM	855		71.2	10.9	20	
Txuj Ci Hmong Lower	1418	1/18/2024	11:36:00 AM	642		71.1	7	20	
Txuj Ci Hmong Lower	1503	1/18/2024	10:47:00 AM	1165		70.2	11.2	4	Food Odor
Txuj Ci Hmong Lower	1504	1/18/2024	10:49:00 AM	762		70.5	8.2	5	
Txuj Ci Hmong Lower	1505	1/18/2024	10:54:00 AM	744		71.1	8	1	Fragrance Odor
Txuj Ci Hmong Lower	2001	1/18/2024	11:01:00 AM	997		69.1	12.8	22	
Txuj Ci Hmong Lower	2002	1/18/2024	11:00:00 AM	1100		69.1	12.4	25	
Txuj Ci Hmong Lower	2003	1/18/2024	10:59:00 AM	1216		69.1	13.3	25	Plants: Kept Away From Return And Supply Vents
Txuj Ci Hmong Lower	2004	1/18/2024	10:16:00 AM	1166		69.1	12.2	20	
Txuj Ci Hmong Lower	2005	1/18/2024	10:10:00 AM	1808		64.5	17.5	2	
Txuj Ci Hmong Lower	2007	1/18/2024	10:56:00 AM	1126		68.7	13	25	
Txuj Ci Hmong Lower	2008	1/18/2024	10:15:00 AM	1008		68	13.8	2	
Txuj Ci Hmong Lower	2009	1/18/2024	10:14:00 AM	1158		67.6	12.4	0	
Txuj Ci Hmong Lower	1006A	1/18/2024	11:59:00 AM	814		70.5	9.8	0	
Txuj Ci Hmong Lower	1110B	1/18/2024	11:52:00 AM	954		70.7	15.5	0	
Txuj Ci Hmong Lower	1111 OFFICE	1/18/2024	11:56:00 AM	1204	0.1	71.1	19.2	1	
Txuj Ci Hmong Lower	1215 OFFICE	1/18/2024	10:38:00 AM	665		69.1	8.2	1	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Txuj Ci Hmong Lower	1218A	1/18/2024	11:13:00 AM	903		70.3	10.6	2	
Txuj Ci Hmong Lower	1404A	1/18/2024	11:33:00 AM	860		71.8	9.5	0	
Txuj Ci Hmong Lower	OUTDOORS	1/18/2024		425		3	67		
Txuj Ci Hmong Upper	1001	12/11/2023	10:45:00 AM	408		69.6	15.5	1	
Txuj Ci Hmong Upper	1003	12/11/2023	12:50:00 PM	410		68.7	16.5	0	
Txuj Ci Hmong Upper	1004	12/11/2023	10:46:00 AM	444		69.4	16	2	
Txuj Ci Hmong Upper	1005	12/11/2023	12:55:00 PM	423		68.2	17	0	
Txuj Ci Hmong Upper	1101	12/11/2023	1:16:00 PM	416		68.5	17.2	1	Plants: Kept Away From Return And Supply Vents
Txuj Ci Hmong Upper	1102	12/11/2023	1:06:00 PM	380		70.2	15.1	1	
Txuj Ci Hmong Upper	1103	12/11/2023	1:18:00 PM	377		68.9	16	1	
Txuj Ci Hmong Upper	1107	12/11/2023	10:51:00 AM	410		70.2	14.5	1	
Txuj Ci Hmong Upper	1109	12/11/2023	10:57:00 AM	651		69.4	17.8	15	Plants: Kept Away From Return And Supply Vents
Txuj Ci Hmong Upper	1110	12/11/2023	1:12:00 PM	446		69.1	17.1	1	
Txuj Ci Hmong Upper	1111	12/11/2023	10:55:00 AM	678		69.6	17.6	30	
Txuj Ci Hmong Upper	1112	12/11/2023	1:11:00 PM	572		68.9	18.1	2	
Txuj Ci Hmong Upper	1113	12/11/2023	10:54:00 AM	668		70.2	18.2	20	
Txuj Ci Hmong Upper	1114	12/11/2023	10:52:00 AM	589		69.8	17.1	25	
Txuj Ci Hmong Upper	1115	12/11/2023	1:09:00 PM	363		69.6	15.2	0	
Txuj Ci Hmong Upper	1116	12/11/2023	10:48:00 AM	663		69.8	18.6	25	
Txuj Ci Hmong Upper	1119	12/11/2023	1:15:00 PM	473		69.1	17	0	
Txuj Ci Hmong Upper	1203	12/11/2023	11:04:00 AM	418		68	16.2	0	
Txuj Ci Hmong Upper	1204	12/11/2023	11:03:00 AM	473		69.3	16.6	0	
Txuj Ci Hmong Upper	1207	12/11/2023	11:00:00 AM	478		69.4	16.2	1	
Txuj Ci Hmong Upper	1208	12/11/2023	12:58:00 PM	495		69.4	17.3	1	
Txuj Ci Hmong Upper	1215	12/11/2023	1:03:00 PM	606		71.6	18.3	0	
Txuj Ci Hmong Upper	1223	12/11/2023	1:02:00 PM	545		70.3	19.3	1	
Txuj Ci Hmong Upper	1224	12/11/2023	1:01:00 PM	554		69.1	18.6	0	
Txuj Ci Hmong Upper	1301	12/11/2023	12:31:00 PM	395		70	16.2	1	Fragrance Odor, Plants: Kept Away From Return And Supply Vents
Txuj Ci Hmong Upper	1302	12/11/2023	10:44:00 AM	387		70.3	16	0	
Txuj Ci Hmong Upper	1303	12/11/2023	10:41:00 AM	400		70.3	16.5	1	Stained Ceiling Tiles
Txuj Ci Hmong Upper	1304	12/11/2023	12:27:00 PM	395		71.1	15.5	0	
Txuj Ci Hmong Upper	1308	12/11/2023	12:33:00 PM	466		72	17	0	Stained Ceiling Tiles
Txuj Ci Hmong Upper	1309	12/11/2023	12:45:00 PM	498		72	18.7	1	Plants: Kept Away From Return And Supply Vents
Txuj Ci Hmong Upper	1310	12/11/2023	12:44:00 PM	501		70.7	18.1	0	
Txuj Ci Hmong Upper	1311	12/11/2023	12:47:00 PM	440		71.6	16.6	1	
Txuj Ci Hmong Upper	1312	12/11/2023	12:48:00 PM	379		70.9	15.6	0	
Txuj Ci Hmong Upper	1314	12/11/2023	12:50:00 PM	359		70.3	15.1	0	
Txuj Ci Hmong Upper	1315	12/11/2023	12:56:00 PM	453		69.6	17.7	70	
Txuj Ci Hmong Upper	2101	12/11/2023	12:00:00 PM	369		70.2	14.9	0	Stained Ceiling Tiles: Looks like dripping from ceiling stained floors
Txuj Ci Hmong Upper	2102	12/11/2023	11:58:00 AM	451		69.4	15.9	0	
Txuj Ci Hmong Upper	2103	12/11/2023	11:14:00 AM	470		70.9	15.1	11	
Txuj Ci Hmong Upper	2107	12/11/2023	11:49:00 AM	522		70.2	15.9	0	
Txuj Ci Hmong Upper	2109	12/11/2023	11:44:00 AM	361		68.5	15.4	0	
Txuj Ci Hmong Upper	2110	12/11/2023	11:47:00 AM	384		69.6	15	0	
Txuj Ci Hmong Upper	2111	12/11/2023	11:40:00 AM	384		68.2	15.5	0	
Txuj Ci Hmong Upper	2112	12/11/2023	11:13:00 AM	500	0.2	70.3	15.8	15	
Txuj Ci Hmong Upper	2113	12/11/2023	11:26:00 AM	462		69.6	16	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Txuj Ci Hmong Upper	2114	12/11/2023	11:37:00 AM	461		68.9	16.4	0	
Txuj Ci Hmong Upper	2115	12/11/2023	11:52:00 AM	448		69.4	16	0	
Txuj Ci Hmong Upper	2116	12/11/2023	11:54:00 AM	442		69.3	16.3	0	
Txuj Ci Hmong Upper	2117	12/11/2023	12:05:00 PM	440		69.6	16	0	
Txuj Ci Hmong Upper	2118	12/11/2023	12:09:00 PM	442		69.6	16.2	0	
Txuj Ci Hmong Upper	2301	12/11/2023	12:14:00 PM	390		72.3	14.9	0	
Txuj Ci Hmong Upper	2303	12/11/2023	12:19:00 PM	390		69.8	16.2	0	Bubbling/Peeling Paint
Txuj Ci Hmong Upper	2307	12/11/2023	12:11:00 PM	372		69.6	15.3	0	Stained Ceiling Tiles
Txuj Ci Hmong Upper	3301	12/11/2023	12:23:00 PM	390		71.4	16.4	0	
Txuj Ci Hmong Upper	3303	12/11/2023	11:18:00 AM	388		72.7	14.5	0	
Txuj Ci Hmong Upper	1312A	12/11/2023	8:15:00 AM	709		66.6	21.6	1	
Txuj Ci Hmong Upper	OUTDOORS	12/11/2023		325		23	82		
Washington Technology Magnet	1000	12/15/2023	10:49:00 AM	447	0.2	71.2	21.9	30	
Washington Technology Magnet	1023	12/15/2023	10:52:00 AM	454	0.2	72.7	22.2	0	Stained Ceiling Tiles
Washington Technology Magnet	1033	12/15/2023	10:46:00 AM	451	0.3	70.5	23.8	1	Stained Ceiling Tiles
Washington Technology Magnet	1035	12/15/2023	10:48:00 AM	498		71.1	24.6	1	
Washington Technology Magnet	1050	12/15/2023	10:42:00 AM	509	0.2	71.1	24.3	30	
Washington Technology Magnet	1064	12/15/2023	10:55:00 AM	442	0.2	74.8	33.3	1	
Washington Technology Magnet	1170	12/15/2023	10:26:00 AM	659	0.2	70.9	23.6	5	Stained Ceiling Tiles, Plants: Kept Away From Return And Supply Vents
Washington Technology Magnet	1171	12/15/2023	10:24:00 AM	491	0.2	70.3	22.1	0	Stained Ceiling Tiles
Washington Technology Magnet	1201	12/15/2023	10:21:00 AM	1164	0.2	70.7	28.3	30	
Washington Technology Magnet	1270	12/15/2023	12:01:00 PM	671		70.3	24.8	15	Stained Ceiling Tiles
Washington Technology Magnet	1271	12/15/2023	9:44:00 AM	469	0.2	71.1	21.3	1	Stained Ceiling Tiles
Washington Technology Magnet	1301	12/15/2023	9:42:00 AM	511	0.2	71.2	21.5	1	
Washington Technology Magnet	1602	12/15/2023	10:27:00 AM	477	0.2	71.4	27.1	1	
Washington Technology Magnet	1604	12/15/2023	10:30:00 AM	460	0.2	70.3	24.4	1	
Washington Technology Magnet	1607	12/15/2023	10:41:00 AM	605	0.2	72.1	28.5	3	
Washington Technology Magnet	1610	12/15/2023	10:39:00 AM	831		70.2	26.5	5	
Washington Technology Magnet	1611	12/15/2023	10:40:00 AM	480		70.9	24.4	0	
Washington Technology Magnet	1613	12/15/2023	10:40:00 AM	583		71.2	26.8	1	
Washington Technology Magnet	1620	12/15/2023	10:08:00 AM	625	0.2	70.3	23.6	30	
Washington Technology Magnet	1621	12/15/2023	10:16:00 AM	627	0.2	69.9	23	20	
Washington Technology Magnet	1622	12/15/2023	10:19:00 AM	471	0.2	70	23.2	0	
Washington Technology Magnet	1626	12/15/2023	10:17:00 AM	480		70	22.1	0	
Washington Technology Magnet	1630	12/15/2023	9:59:00 AM	641	0.2	71.2	24.3	1	Stained Ceiling Tiles
Washington Technology Magnet	1631	12/15/2023	10:13:00 AM	523	0.2	69.6	22.7	0	
Washington Technology Magnet	1632	12/15/2023	10:06:00 AM	481	0.3	70.7	21.8	0	Plants: Kept Away From Return And Supply Vents
Washington Technology Magnet	1633	12/15/2023	10:04:00 AM	479	0.2	70.9	21.6	0	Stained Ceiling Tiles
Washington Technology Magnet	1640	12/15/2023	9:57:00 AM	490		70.9	21.8	0	
Washington Technology Magnet	1651	12/15/2023	10:03:00 AM	486	0.2	71.2	21.4	0	Stained Ceiling Tiles
Washington Technology Magnet	1652	12/15/2023	10:01:00 AM	494		71.2	21.3	0	
Washington Technology Magnet	1653	12/15/2023	9:56:00 AM	516	0.2	70.9	22.3	1	
Washington Technology Magnet	1654	12/15/2023	9:55:00 AM	483	0.3	70.9	21.8	1	
Washington Technology Magnet	1660	12/15/2023	9:45:00 AM	557	0.2	70.9	23.6	15	
Washington Technology Magnet	1662	12/15/2023	9:53:00 AM	511	0.2	71.2	22.6	1	
Washington Technology Magnet	1669	12/15/2023	9:52:00 AM	584	0.2	70.9	22.9	1	Fragrance Odor, Stained Ceiling Tiles
Washington Technology Magnet	1670	12/15/2023	9:50:00 AM	469		70.3	21.8	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	1671	12/15/2023	9:47:00 AM	570	0.2	70.7	22.7	1	Stained Ceiling Tiles
Washington Technology Magnet	1672	12/15/2023	9:49:00 AM	501	0.2	70.5	22.4	1	
Washington Technology Magnet	1710	12/15/2023	9:39:00 AM	825	0.2	72	24.7	20	Stained Ceiling Tiles
Washington Technology Magnet	1720	12/15/2023	9:41:00 AM	573	0.2	71.6	22	1	
Washington Technology Magnet	1730	12/15/2023	9:34:00 AM	771		71.4	24.3	15	
Washington Technology Magnet	1731	12/15/2023	9:36:00 AM	699		72	22.3	1	
Washington Technology Magnet	1740	12/15/2023	9:33:00 AM	681		70.3	24.2	15	
Washington Technology Magnet	1750	12/15/2023	9:37:00 AM	552		71.8	21.3	1	
Washington Technology Magnet	1760	12/15/2023	9:17:00 AM	694		69.6	25	11	Stained Ceiling Tiles
Washington Technology Magnet	2001	12/15/2023	11:03:00 AM	480	0.3	71.1	22.1	5	
Washington Technology Magnet	2050	12/15/2023	10:57:00 AM	472	0.4	73.2	23.5	0	Stained Ceiling Tiles
Washington Technology Magnet	2110	12/15/2023	11:54:00 AM	470		70.7	21.8	0	
Washington Technology Magnet	2120	12/15/2023	11:54:00 AM	573		71.4	22.7	30	
Washington Technology Magnet	2121	12/15/2023	11:59:00 AM	597		70.7	24.6	0	
Washington Technology Magnet	2130	12/15/2023	11:56:00 AM	574		70.9	23	0	
Washington Technology Magnet	2140	12/15/2023	10:46:00 AM	827		70.5	26.3	30	
Washington Technology Magnet	2141	12/15/2023	10:47:00 AM	757		70	25	0	
Washington Technology Magnet	2150	12/15/2023	10:45:00 AM	979		70.5	28.2	30	
Washington Technology Magnet	2170	12/15/2023	10:43:00 AM	516		70	22.4	0	Stained Ceiling Tiles
Washington Technology Magnet	2173	12/15/2023	10:41:00 AM	548		70.3	22.5	1	Stained Ceiling Tiles
Washington Technology Magnet	2210	12/15/2023	10:37:00 AM	950		70.7	26.6	25	Plants: Kept Away From Return And Supply Vents
Washington Technology Magnet	2220	12/15/2023	10:34:00 AM	944		71.6	24.7	20	Plants: Kept Away From Return And Supply Vents
Washington Technology Magnet	2222	12/15/2023	10:36:00 AM	840		70.9	24.5	0	
Washington Technology Magnet	2240	12/15/2023	10:33:00 AM	756		72.1	23.4	20	
Washington Technology Magnet	2241	12/15/2023	10:32:00 AM	698		71.6	23.5	1	Stained Ceiling Tiles
Washington Technology Magnet	2250	12/15/2023	10:29:00 AM	623		70.7	22.5	1	
Washington Technology Magnet	2270	12/15/2023	10:28:00 AM	794		71.4	23.8	0	Stained Ceiling Tiles
Washington Technology Magnet	2273	12/15/2023	10:23:00 AM	757		69.8	24.7	2	Stained Ceiling Tiles
Washington Technology Magnet	2274	12/15/2023	10:26:00 AM	717		72	22.8	0	
Washington Technology Magnet	2308	12/15/2023	10:21:00 AM	1087		70.3	27.8	18	
Washington Technology Magnet	2310	12/15/2023	10:19:00 AM	725		70.2	23.3	0	
Washington Technology Magnet	2311	12/15/2023	10:20:00 AM	672		70.2	23	0	
Washington Technology Magnet	2320	12/15/2023	10:18:00 AM	822		70	24.1	9	
Washington Technology Magnet	2321	12/15/2023	10:17:00 AM	731		70.3	23.4	0	
Washington Technology Magnet	2330	12/15/2023	10:16:00 AM	727		70.5	24.8	2	Stained Ceiling Tiles
Washington Technology Magnet	2330	12/15/2023	10:34:00 AM	895		72	24.4	28	
Washington Technology Magnet	2340	12/15/2023	10:15:00 AM	753		70.5	23.6	0	
Washington Technology Magnet	2341	12/15/2023	10:14:00 AM	698		70.5	23.3	0	
Washington Technology Magnet	2350	12/15/2023	10:13:00 AM	706		70.3	23.4	0	
Washington Technology Magnet	2360	12/15/2023	10:09:00 AM	718		69.4	24.3	0	
Washington Technology Magnet	2361	12/15/2023	10:07:00 AM	582		69.4	22.9	0	
Washington Technology Magnet	2362	12/15/2023	10:08:00 AM	606		68.9	23.5	0	
Washington Technology Magnet	2370	12/15/2023	10:12:00 AM	712		70.2	23.2	0	Stained Ceiling Tiles
Washington Technology Magnet	2373	12/15/2023	10:11:00 AM	794		69.8	24.9	2	
Washington Technology Magnet	2410	12/15/2023	10:07:00 AM	643		70.3	22.5	1	
Washington Technology Magnet	2410	12/15/2023	12:05:00 PM	660		69.3	24.5	5	
Washington Technology Magnet	2420	12/15/2023	10:02:00 AM	662		70	24.8	6	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	2421	12/15/2023	10:01:00 AM	585		70	22.5	0	
Washington Technology Magnet	2422	12/15/2023	10:03:00 AM	651		69.8	23.7	0	
Washington Technology Magnet	2423	12/15/2023	10:04:00 AM	676		69.8	23.9	1	
Washington Technology Magnet	2430	12/15/2023	10:00:00 AM	732		70.2	23.6	1	
Washington Technology Magnet	2440	12/15/2023	9:57:00 AM	769		71.1	23.6	8	
Washington Technology Magnet	2441	12/15/2023	9:58:00 AM	636		71.1	23.3	1	
Washington Technology Magnet	2450	12/15/2023	9:59:00 AM	664		70.5	23	7	Stained Ceiling Tiles
Washington Technology Magnet	2460	12/15/2023	9:48:00 AM	592		70.7	21.9	0	
Washington Technology Magnet	2470	12/15/2023	9:32:00 AM	661	0.1	70	23.2	2	Stained Ceiling Tiles
Washington Technology Magnet	2473	12/15/2023	9:35:00 AM	561	0.1	70.5	22.3	0	
Washington Technology Magnet	2503	12/15/2023	9:38:00 AM	603	0.1	69.4	24.3	0	Stained Ceiling Tiles
Washington Technology Magnet	2510	12/15/2023	9:36:00 AM	593	0.2	70.3	22.2	0	
Washington Technology Magnet	2520	12/15/2023	9:40:00 AM	606		69.1	23.4	0	Stained Ceiling Tiles
Washington Technology Magnet	2530	12/15/2023	9:41:00 AM	751		68.7	25.1	5	
Washington Technology Magnet	2540	12/15/2023	9:42:00 AM	603		69.4	24.3	0	
Washington Technology Magnet	2550	12/15/2023	9:46:00 AM	578	0.1	70	22.4	0	
Washington Technology Magnet	2560	12/15/2023	9:45:00 AM	599		70.3	22.2	0	
Washington Technology Magnet	2570	12/15/2023	9:43:00 AM	599		69.8	22.7	0	
Washington Technology Magnet	2600	12/15/2023	11:14:00 AM	534	0.2	70.9	22.9	1	
Washington Technology Magnet	2601	12/15/2023	10:48:00 AM	640		70.5	24.3	1	
Washington Technology Magnet	2607	12/15/2023	11:31:00 AM	425		70.9	21.9	0	
Washington Technology Magnet	2608	12/15/2023	11:33:00 AM	489		71.1	24	0	
Washington Technology Magnet	2609	12/15/2023	11:18:00 AM	588		70.9	23.4	0	
Washington Technology Magnet	2610	12/15/2023	11:51:00 AM	460		70.3	22.8	0	
Washington Technology Magnet	2611	12/15/2023	11:30:00 AM	876		71.1	26.3	4	Stained Ceiling Tiles
Washington Technology Magnet	2612	12/15/2023	11:41:00 AM	635		71.6	23.3	2	
Washington Technology Magnet	2613	12/15/2023	11:41:00 AM	576		71.6	22.6	1	
Washington Technology Magnet	2616	12/15/2023	11:38:00 AM	526		71.1	24.5	1	
Washington Technology Magnet	2617	12/15/2023	11:17:00 AM	528		71.2	22.6	1	
Washington Technology Magnet	2618	12/15/2023	11:37:00 AM	541		71.1	22.9	1	
Washington Technology Magnet	2619	12/15/2023	11:39:00 AM	527		71.2	22.3	1	Stained Ceiling Tiles
Washington Technology Magnet	2620	12/15/2023	11:40:00 AM	495		71.6	21.9	1	Stained Ceiling Tiles
Washington Technology Magnet	2621	12/15/2023	11:45:00 AM	414		69.3	22.5	0	
Washington Technology Magnet	2623	12/15/2023	11:39:00 AM	513		71.4	22.2	1	
Washington Technology Magnet	2624	12/15/2023	11:35:00 AM	439		70.7	21.9	0	
Washington Technology Magnet	2626	12/15/2023	11:45:00 AM	506		71.2	22.6	1	
Washington Technology Magnet	2626	12/15/2023	10:50:00 AM	619		71.1	23.5	0	
Washington Technology Magnet	2629	12/15/2023	11:33:00 AM	604		70.5	23.6	1	
Washington Technology Magnet	2630	12/15/2023	11:32:00 AM	481		70.7	22	0	Stained Ceiling Tiles
Washington Technology Magnet	2634	12/15/2023	11:31:00 AM	619		70.5	24	1	Stained Ceiling Tiles
Washington Technology Magnet	2635	12/15/2023	11:28:00 AM	487		70.7	22.2	0	
Washington Technology Magnet	2636	12/15/2023	11:30:00 AM	494		70.5	21.8	0	
Washington Technology Magnet	2637	12/15/2023	11:29:00 AM	634		70.9	23.6	0	
Washington Technology Magnet	2639	12/15/2023	11:25:00 AM	498		70.9	21.8	0	
Washington Technology Magnet	2640	12/15/2023	11:26:00 AM	489		70.5	21.8	0	
Washington Technology Magnet	2641	12/15/2023	11:24:00 AM	501		71.1	21.9	0	
Washington Technology Magnet	2642	12/15/2023	11:23:00 AM	504		71.4	21.5	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	2643	12/15/2023	11:21:00 AM	973		72	26.2	2	
Washington Technology Magnet	2644	12/15/2023	11:22:00 AM	496		71.8	21.4	0	
Washington Technology Magnet	2645	12/15/2023	11:19:00 AM	789		71.4	27.1	2	
Washington Technology Magnet	2646	12/15/2023	11:20:00 AM	824		71.6	24.7	2	
Washington Technology Magnet	2647	12/15/2023	11:17:00 AM	502		71.2	21.8	0	
Washington Technology Magnet	2650	12/15/2023	10:53:00 AM	480		70.2	22.1	0	
Washington Technology Magnet	2658	12/15/2023	11:04:00 AM	566		70.7	22.6	0	
Washington Technology Magnet	2659	12/15/2023	11:06:00 AM	533		70.5	22.4	0	
Washington Technology Magnet	2660	12/15/2023	11:07:00 AM	531		70.3	22.3	0	
Washington Technology Magnet	2661	12/15/2023	10:51:00 AM	520		70.9	22.3	0	
Washington Technology Magnet	2662	12/15/2023	10:56:00 AM	682		70.2	24	2	
Washington Technology Magnet	2663	12/15/2023	10:57:00 AM	552		69.6	23.2	0	
Washington Technology Magnet	2664	12/15/2023	10:58:00 AM	523		69.4	23.1	0	
Washington Technology Magnet	2665	12/15/2023	10:59:00 AM	756		69.8	25.9	3	
Washington Technology Magnet	2666	12/15/2023	11:00:00 AM	552		70.5	22.7	0	
Washington Technology Magnet	2667	12/15/2023	11:08:00 AM	689		70.3	23.7	1	Stained Ceiling Tiles
Washington Technology Magnet	2670	12/15/2023	11:09:00 AM	705		70.3	24	1	
Washington Technology Magnet	2671	12/15/2023	11:12:00 AM	660		71.1	23.4	2	
Washington Technology Magnet	2672	12/15/2023	11:16:00 AM	606		71.8	22.3	1	
Washington Technology Magnet	2674	12/15/2023	11:14:00 AM	704		72.3	23.2	3	
Washington Technology Magnet	2675	12/15/2023	11:16:00 AM	595		72.1	21.9	0	
Washington Technology Magnet	2677	12/15/2023	11:15:00 AM	640		72.5	21.9	0	
Washington Technology Magnet	2678	12/15/2023	11:10:00 AM	694		70.5	23.9	0	
Washington Technology Magnet	2679	12/15/2023	11:11:00 AM	547		70.9	22.6	0	
Washington Technology Magnet	2710	12/15/2023	11:41:00 AM	662		69.6	24.6	0	
Washington Technology Magnet	2720	12/15/2023	11:34:00 AM	747		70.3	23.9	8	
Washington Technology Magnet	2721	12/15/2023	11:37:00 AM	687		70.5	23.5	0	
Washington Technology Magnet	2724	12/15/2023	11:38:00 AM	679		70.7	23.3	0	Stained Ceiling Tiles
Washington Technology Magnet	2725	12/15/2023	11:39:00 AM	654		70.5	23.3	0	
Washington Technology Magnet	2727	12/15/2023	11:40:00 AM	654		70.3	23.2	0	
Washington Technology Magnet	2730	12/15/2023	11:43:00 AM	675		70	24.1	3	Stained Ceiling Tiles
Washington Technology Magnet	2731	12/15/2023	11:44:00 AM	661		70.2	25.7	0	
Washington Technology Magnet	2733	12/15/2023	11:45:00 AM	690		70	24	1	
Washington Technology Magnet	2740	12/15/2023	11:47:00 AM	878		70.7	24.8	12	
Washington Technology Magnet	2750	12/15/2023	11:51:00 AM	1121		70.7	28.6	25	Stained Ceiling Tiles
Washington Technology Magnet	2751	12/15/2023	11:48:00 AM	996		70.5	26.4	0	
Washington Technology Magnet	2752	12/15/2023	11:45:00 AM	658		70.2	23.5	0	
Washington Technology Magnet	2760	12/15/2023	11:51:00 AM	875		70.7	25.1	0	
Washington Technology Magnet	2761	12/15/2023	11:53:00 AM	664		70.2	23.8	0	
Washington Technology Magnet	2762	12/15/2023	11:54:00 AM	887		70	24.5	0	
Washington Technology Magnet	2764	12/15/2023	11:55:00 AM	828		69.8	25.6	0	
Washington Technology Magnet	2765	12/15/2023	11:56:00 AM	760		69.6	25	0	
Washington Technology Magnet	2810	12/15/2023	12:03:00 PM	755		70	26	0	
Washington Technology Magnet	2811	12/15/2023	11:57:00 AM	685		69.3	24.7	9	
Washington Technology Magnet	2813	12/15/2023	11:58:00 AM	671		69.8	24.3	0	
Washington Technology Magnet	2834	12/15/2023	12:08:00 PM	501	0.2	69.8	25.3	1	Fragrance Odor
Washington Technology Magnet	2854	12/15/2023	9:21:00 AM	542		66.6	26.9	2	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	2864	12/15/2023	9:30:00 AM	582		68.3	26.1	2	
Washington Technology Magnet	3110	12/15/2023	11:39:00 AM	800		71.2	23.7	1	
Washington Technology Magnet	3120	12/15/2023	11:39:00 AM	1158		71.6	30.1	22	
Washington Technology Magnet	3121	12/15/2023	11:40:00 AM	849	0.2	71.4	22.8	0	
Washington Technology Magnet	3130	12/15/2023	11:41:00 AM	865	0.2	71.1	23.8	15	
Washington Technology Magnet	3140	12/15/2023	11:42:00 AM	757		71.8	22.7	12	
Washington Technology Magnet	3150	12/15/2023	11:43:00 AM	947	0.2	71.7	25.4	15	
Washington Technology Magnet	3160	12/15/2023	11:36:00 AM	874		70.2	26.1	20	Stained Ceiling Tiles
Washington Technology Magnet	3170	12/15/2023	11:38:00 AM	728	0.2	70.5	23.8	2	Food Odor
Washington Technology Magnet	3174	12/15/2023	11:32:00 AM	605	0.2	69.6	22	0	
Washington Technology Magnet	3208	12/15/2023	11:25:00 AM	910	0.3	69.9	26.9	20	Stained Ceiling Tiles
Washington Technology Magnet	3210	12/15/2023	11:20:00 AM	909	0.1	71.4	24.3	15	
Washington Technology Magnet	3212	12/15/2023	11:31:00 AM	846	0.1	70.1	23	0	Stained Ceiling Tiles
Washington Technology Magnet	3220	12/15/2023	11:21:00 AM	1005	0.1	71.5	27.5	20	
Washington Technology Magnet	3221	12/15/2023	11:22:00 AM	857	0.1	71.4	24	0	Stained Ceiling Tiles
Washington Technology Magnet	3230	12/15/2023	11:55:00 AM	886	0.1	70.3	24.6	0	Fragrance Odor
Washington Technology Magnet	3240	12/15/2023	11:23:00 AM	894	0.2	71.4	24.3	20	
Washington Technology Magnet	3241	12/15/2023	11:24:00 AM	893	0.2	71.2	23.8	2	Food Odor
Washington Technology Magnet	3250	12/15/2023	11:59:00 AM	998	0.1	70.5	26	30	
Washington Technology Magnet	3260	12/15/2023	11:19:00 AM	900		71.2	25.8	20	
Washington Technology Magnet	3261	12/15/2023	11:14:00 AM	910	0.1	71.1	22.9	0	
Washington Technology Magnet	3270	12/15/2023	11:17:00 AM	715	0.2	71.1	21.6	1	
Washington Technology Magnet	3273	12/15/2023	11:15:00 AM	684	0.3	70.5	21.1	0	
Washington Technology Magnet	3274	12/15/2023	11:16:00 AM	1052	0.1	71.3	26.1	0	Fragrance Odor
Washington Technology Magnet	3308	12/15/2023	11:13:00 AM	998	0.2	71.4	26.1	18	Fragrance Odor, Plants
Washington Technology Magnet	3309	12/15/2023	11:12:00 AM	798	0.3	71.4	22.2	0	Fragrance Odor, Stained Ceiling Tiles
Washington Technology Magnet	3310	12/15/2023	11:10:00 AM	1041	0.2	71.8	26.3	18	Musty Odor
Washington Technology Magnet	3320	12/15/2023	11:08:00 AM	1180	0.3	71.8	28.3	18	Fragrance Odor
Washington Technology Magnet	3321	12/15/2023	11:06:00 AM	819	0.1	71.5	22.4	0	
Washington Technology Magnet	3330	12/15/2023	11:54:00 AM	920		70.6	23.9	5	
Washington Technology Magnet	3340	12/15/2023	11:54:00 AM	832		70.7	23	1	
Washington Technology Magnet	3341	12/15/2023	11:03:00 AM	839	0.3	71	22.6	0	
Washington Technology Magnet	3350	12/15/2023	11:07:00 AM	1223	0.2	71.5	27.5	18	
Washington Technology Magnet	3360	12/15/2023	11:09:00 AM	955	0.1	71.5	24.4	16	
Washington Technology Magnet	3361	12/15/2023	10:56:00 AM	830	0.1	71.7	22.5	5	
Washington Technology Magnet	3370	12/15/2023	11:01:00 AM	745	0.2	71.3	22.3	0	
Washington Technology Magnet	3373	12/15/2023	10:59:00 AM	837	0.2	71.8	21.9	0	
Washington Technology Magnet	3374	12/15/2023	10:58:00 AM	1167	0.3	72.1	26.2	2	Fragrance Odor
Washington Technology Magnet	3408	12/15/2023	10:55:00 AM	788	0.4	71.3	22.6	7	Fragrance Odor
Washington Technology Magnet	3409	12/15/2023	10:53:00 AM	748		71.5	21.3	0	
Washington Technology Magnet	3410	12/15/2023	10:50:00 AM	1066	0.2	74.5	26.7	18	
Washington Technology Magnet	3420	12/15/2023	10:48:00 AM	1060	0.3	70.8	25.9	20	Fragrance Odor
Washington Technology Magnet	3421	12/15/2023	10:47:00 AM	885	0.3	70.6	23.6	0	Fragrance Odor
Washington Technology Magnet	3430	12/15/2023	10:43:00 AM	1068	0.1	70	27.3	20	
Washington Technology Magnet	3440	12/15/2023	10:45:00 AM	1109	0.2	70.5	27.8	20	
Washington Technology Magnet	3441	12/15/2023	10:46:00 AM	863	0.3	70.3	22.6	0	
Washington Technology Magnet	3450	12/15/2023	10:49:00 AM	1064	0.2	71.2	26.4	20	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	3460	12/15/2023	10:51:00 AM	840	0.3	71.3	23	0	
Washington Technology Magnet	3470	12/15/2023	10:38:00 AM	669	0.3	69.4	22.3	1	
Washington Technology Magnet	3473	12/15/2023	10:42:00 AM	744	0.2	69.4	24.1	1	Food Odor, Stained Ceiling Tiles
Washington Technology Magnet	4110	12/15/2023	10:27:00 AM	916		70.3	24.8	20	
Washington Technology Magnet	4120	12/15/2023	10:32:00 AM	798	0.2	70.2	25.1	3	
Washington Technology Magnet	4121	12/15/2023	10:29:00 AM	896	0.1	70.5	25.5	1	Fragrance Odor
Washington Technology Magnet	4130	12/15/2023	10:31:00 AM	865	0.2	70.3	25.1	20	
Washington Technology Magnet	4140	12/15/2023	10:33:00 AM	887	0.1	70.3	27.3	22	Musty Odor
Washington Technology Magnet	4141	12/15/2023	10:33:00 AM	910	0.3	70.4	24.9	0	
Washington Technology Magnet	4150	12/15/2023	10:35:00 AM	847	0.3	70.3	25.8	20	
Washington Technology Magnet	4160	12/15/2023	10:28:00 AM	595		70.4	26.8	15	
Washington Technology Magnet	4170	12/15/2023	10:26:00 AM	689	0.2	70.2	23.2	0	Stained Ceiling Tiles
Washington Technology Magnet	4173	12/15/2023	10:24:00 AM	600	0.2	69.1	22.1	0	Stained Ceiling Tiles
Washington Technology Magnet	4208	12/15/2023	10:22:00 AM	917	0.1	70.5	25	10	Fragrance Odor
Washington Technology Magnet	4210	12/15/2023	10:21:00 AM	1082	0.3	71	27.3	20	Plants: Kept Away From Return And Supply Vents
Washington Technology Magnet	4220	12/15/2023	10:18:00 AM	1019	0.2	70.8	26.6	22	Plants: Kept Away From Return And Supply Vents
Washington Technology Magnet	4221	12/15/2023	10:17:00 AM	1069	0.3	70.9	26.8	2	Stained Ceiling Tiles
Washington Technology Magnet	4230	12/15/2023	10:13:00 AM	1156	0.4	70.4	29	20	Fragrance Odor
Washington Technology Magnet	4240	12/15/2023	10:15:00 AM	1077	0.3	70.4	27.9	20	
Washington Technology Magnet	4241	12/15/2023	10:16:00 AM	725	0.2	70.6	22.8	0	
Washington Technology Magnet	4250	12/15/2023	10:20:00 AM	882	0.2	70.9	25.1	20	Fragrance Odor
Washington Technology Magnet	4260	12/15/2023	10:12:00 AM	758	0.3	70.1	23.3	0	
Washington Technology Magnet	4261	12/15/2023	10:07:00 AM	835	0.2	70.9	22.3	0	
Washington Technology Magnet	4270	12/15/2023	10:12:00 AM	668	0.5	70	20.9	0	
Washington Technology Magnet	4273	12/15/2023	10:10:00 AM	721	0.1	71	21.3	3	Stained Ceiling Tiles
Washington Technology Magnet	4308	12/15/2023	10:03:00 AM	1100	0.3	70.4	26.1	20	Musty Odor
Washington Technology Magnet	4310	12/15/2023	9:53:00 AM	770	0.2	70.3	23	10	
Washington Technology Magnet	4320	12/15/2023	9:54:00 AM	907	0.2	70.4	25.2	18	
Washington Technology Magnet	4321	12/15/2023	9:55:00 AM	852	0.4	70.4	22.9	0	
Washington Technology Magnet	4330	12/15/2023	9:57:00 AM	1122	0.6	70.8	27.4	22	Fragrance Odor
Washington Technology Magnet	4340	12/15/2023	9:58:00 AM	1005	0.2	71	24.5	30	Fragrance, Food Odor
Washington Technology Magnet	4341	12/15/2023	9:56:00 AM	1072	0.3	70.6	27.1	2	
Washington Technology Magnet	4350	12/15/2023	9:59:00 AM	1129	0.6	70.9	26.1	20	
Washington Technology Magnet	4360	12/15/2023	10:02:00 AM	780	0.3	70.6	22.6	0	
Washington Technology Magnet	4370	12/15/2023	9:52:00 AM	733	0.3	70.4	22.5	1	
Washington Technology Magnet	4373	12/15/2023	9:48:00 AM	733	0.6	70.5	22.1	0	
Washington Technology Magnet	4408	12/15/2023	10:35:00 AM	847		70.8	24.2	20	
Washington Technology Magnet	4410	12/15/2023	9:42:00 AM	753	0.3	69.7	23.9	5	
Washington Technology Magnet	4420	12/15/2023	9:40:00 AM	981	0.3	69.5	27.7	25	Fragrance Odor
Washington Technology Magnet	4421	12/15/2023	9:39:00 AM	747	0.4	69.3	23.1	0	
Washington Technology Magnet	4430	12/15/2023	9:31:00 AM	977	0.4	69.2	27.9	25	
Washington Technology Magnet	4440	12/15/2023	9:37:00 AM	921	0.5	69.2	26.1	20	
Washington Technology Magnet	4441	12/15/2023	9:38:00 AM	731	0.5	69.7	22.9	0	
Washington Technology Magnet	4450	12/15/2023	9:41:00 AM	1091	0.4	69.8	28.8	20	
Washington Technology Magnet	4460	12/15/2023	9:43:00 AM	692	0.1	69.4	23.4	3	
Washington Technology Magnet	4470	12/15/2023	9:44:00 AM	653	0.6	69.7	23	0	Fragrance Odor
Washington Technology Magnet	4473	12/15/2023	9:47:00 AM	640	0.2	70.1	21.6	0	Stained Ceiling Tiles

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Washington Technology Magnet	2208A	12/15/2023	10:40:00 AM	1148		71.1	27.3	25	
Washington Technology Magnet	2208B	12/15/2023	10:38:00 AM	1083		71.1	28.3	25	
Washington Technology Magnet	2818A	12/15/2023	11:59:00 AM	672		70.3	24.8	0	
Washington Technology Magnet	2819A	12/15/2023	12:02:00 PM	700		70.3	24.1	0	
Washington Technology Magnet	CAFETERIA	12/15/2023	12:07:00 PM	850		70.3	29	150	
Washington Technology Magnet	OUTDOORS	12/15/2023		469	0.4	37	75		
Wellstone Elementary School	45	1/17/2024	8:15:00 AM	681	0.4	71.4	71.2	5	
Wellstone Elementary School	46	1/17/2024	8:19:00 AM	732	0.6	71.4	13.2	3	Plants
Wellstone Elementary School	47	1/17/2024	8:21:00 AM	733	0.5	71.6	11.9	0	
Wellstone Elementary School	111	1/17/2024	8:34:00 AM	588	0.4	70.9	7.3	1	
Wellstone Elementary School	118	1/17/2024	8:28:00 AM	587	0.3	70	7.5	0	
Wellstone Elementary School	119	1/17/2024	8:31:00 AM	706	0.3	0.4	70.9	2	
Wellstone Elementary School	120	1/17/2024	8:32:00 AM	514	0.3	70.9	5.7	0	
Wellstone Elementary School	121	1/17/2024	8:33:00 AM	550	0.4	72.3	5.4	4	
Wellstone Elementary School	122	1/17/2024	8:34:00 AM	490	0.3	69.8	5.9	0	
Wellstone Elementary School	123	1/17/2024	8:46:00 AM	523	0.2	70.5	5.7	0	Stained Ceiling Tiles
Wellstone Elementary School	124	1/17/2024	8:45:00 AM	520	0.2	70.9	7.3	0	
Wellstone Elementary School	125	1/17/2024	8:44:00 AM	536	0.2	71.1	6.5	1	
Wellstone Elementary School	126	1/17/2024	8:43:00 AM	484	0.2	69.4	5.7	0	
Wellstone Elementary School	127	1/17/2024	8:42:00 AM	628	0.2	68.9	6.7	0	
Wellstone Elementary School	130	1/17/2024	8:40:00 AM	527	0.2	68.5	8.4	0	
Wellstone Elementary School	131	1/17/2024	8:36:00 AM	538	0.3	69.8	7	0	
Wellstone Elementary School	135	1/17/2024	8:39:00 AM	525	0.2	68.5	6.1	0	
Wellstone Elementary School	136	1/17/2024	8:39:00 AM	554	0.3	68.5	7.2	1	
Wellstone Elementary School	137	1/17/2024	8:37:00 AM	592	0.3	68.9	6.5	0	
Wellstone Elementary School	1005	1/17/2024	11:47:00 AM	612		72.1	7.3	2	Fragrance Odor
Wellstone Elementary School	1006	1/17/2024	11:47:00 AM	542		71.8	6	0	
Wellstone Elementary School	1007	1/17/2024	11:42:00 AM	668		70.9	7.4	4	
Wellstone Elementary School	1012	1/17/2024	11:30:00 AM	654		70.7	6.9	2	
Wellstone Elementary School	1014	1/17/2024	11:31:00 AM	767		70.5	7.2	1	Fragrance Odor
Wellstone Elementary School	1017	1/17/2024	11:31:00 AM	678		70.7	7	0	
Wellstone Elementary School	1019	1/17/2024	11:39:00 AM	677		71.1	7.4	1	
Wellstone Elementary School	1020	1/17/2024	11:40:00 AM	569		71.1	7.7	0	
Wellstone Elementary School	1021	1/17/2024	11:41:00 AM	530		71.4	7.2	0	
Wellstone Elementary School	1022	1/17/2024	11:36:00 AM	501		70.9	7.2	0	
Wellstone Elementary School	1023	1/17/2024	11:34:00 AM	1011		71.2	12.4	2	Food Odor, Bubbling/Peeling Paint
Wellstone Elementary School	1024	1/17/2024	11:33:00 AM	573		70.7	7.8	0	
Wellstone Elementary School	1025	1/17/2024	11:32:00 AM	534		70.9	6.1	0	
Wellstone Elementary School	1026	1/17/2024	11:24:00 AM	615		70.9	8.9	3	
Wellstone Elementary School	1027	1/17/2024	11:28:00 AM	569		70.9	6.4	0	
Wellstone Elementary School	1028	1/17/2024	11:22:00 AM	770		70	7.1	0	
Wellstone Elementary School	1033	1/17/2024	11:21:00 AM	578		69.6	5.9	0	
Wellstone Elementary School	1034	1/17/2024	11:18:00 AM	500		70.2	5.7	1	
Wellstone Elementary School	1036	1/17/2024	8:22:00 AM	720	0.3	70.5	6.3	0	
Wellstone Elementary School	1043	1/17/2024	11:00:00 AM	507		69.4	7.4	0	
Wellstone Elementary School	1051	1/17/2024	10:52:00 AM	643		70.5	7.5	1	
Wellstone Elementary School	1053	1/17/2024	10:53:00 AM	734		70.3	6.8	0	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Wellstone Elementary School	1059	1/17/2024	10:49:00 AM	782		70.2	9.6	0	Fragrance Odor
Wellstone Elementary School	1062	1/17/2024	10:56:00 AM	687		70.7	8.3	0	
Wellstone Elementary School	1064	1/17/2024	10:55:00 AM	905		69.8	7.9	0	
Wellstone Elementary School	1065	1/17/2024	10:53:00 AM	902		67.8	12.5	35	
Wellstone Elementary School	1070	1/17/2024	7:59:00 AM	485	0.1	74.5	7.1	0	
Wellstone Elementary School	1071	1/17/2024	10:40:00 AM	592		68.7	6.3	4	
Wellstone Elementary School	1103	1/17/2024	10:57:00 AM	536		69.3	8.4	0	
Wellstone Elementary School	1110	1/17/2024	10:45:00 AM	621		70.2	5.9	0	
Wellstone Elementary School	1111	1/17/2024	10:47:00 AM	567		71.4	6.1	0	Fragrance Odor
Wellstone Elementary School	1113	1/17/2024	10:43:00 AM	953		70.2	10.6	20	
Wellstone Elementary School	1130	1/17/2024	10:36:00 AM	456		69.1	4.6	0	
Wellstone Elementary School	1139	1/17/2024	10:41:00 AM	580		68	6.5	0	
Wellstone Elementary School	1150	1/17/2024	10:38:00 AM	558		69.3	5.8	1	
Wellstone Elementary School	1203	1/17/2024	11:02:00 AM	880		72.1	9.4	18	
Wellstone Elementary School	1207	1/17/2024	11:05:00 AM	964		73.2	10.4	22	
Wellstone Elementary School	1211	1/17/2024	11:06:00 AM	1020		71.8	9.8	20	
Wellstone Elementary School	1215	1/17/2024	11:07:00 AM	655		71.1	6.3	2	
Wellstone Elementary School	1216	1/17/2024	11:12:00 AM	542		70	6.3	0	
Wellstone Elementary School	1217	1/17/2024	11:08:00 AM	648		70.7	8.3	1	
Wellstone Elementary School	1220	1/17/2024	11:10:00 AM	638		70.9	8.4	0	
Wellstone Elementary School	2005	1/17/2024	10:02:00 AM	727		69.1	9.9	20	
Wellstone Elementary School	2005	1/17/2024	10:03:00 AM	715		69.6	10.3	0	
Wellstone Elementary School	2027	1/17/2024	10:22:00 AM	794		68.2	8.6	0	
Wellstone Elementary School	2028	1/17/2024	9:58:00 AM	713		69.3	9.7	20	
Wellstone Elementary School	2050	1/17/2024	10:05:00 AM	622		68.5	8.6	0	
Wellstone Elementary School	2052	1/17/2024	10:30:00 AM	624		67.6	9	0	
Wellstone Elementary School	2058	1/17/2024	10:31:00 AM	662		67.5	9.3	0	
Wellstone Elementary School	2063	1/17/2024	10:33:00 AM	653		67.6	9.6	2	
Wellstone Elementary School	2106	1/17/2024	9:47:00 AM	644		68.9	6.8	20	Fragrance Odor
Wellstone Elementary School	2108	1/17/2024	9:53:00 AM	622		69.1	7.4	0	
Wellstone Elementary School	2110	1/17/2024	10:29:00 AM	642		68.5	7.4	0	Fragrance Odor
Wellstone Elementary School	2115	1/17/2024	10:13:00 AM	933		71.6	11.2	15	
Wellstone Elementary School	2120	1/17/2024	9:56:00 AM	670		69.6	8	16	
Wellstone Elementary School	2130	1/17/2024	9:55:00 AM	590		70	6	0	
Wellstone Elementary School	2132	1/17/2024	9:57:00 AM	818		69.3	7.3	0	
Wellstone Elementary School	2203	1/17/2024	10:20:00 AM	953		69.3	11.6	25	
Wellstone Elementary School	2206	1/17/2024	10:18:00 AM	673		69.6	7.8	0	
Wellstone Elementary School	2207	1/17/2024	10:15:00 AM	707		70	8.1	0	
Wellstone Elementary School	2208	1/17/2024	10:17:00 AM	791		69.8	9.9	3	
Wellstone Elementary School	2211	1/17/2024	10:14:00 AM	1066		71.1	70.9	18	
Wellstone Elementary School	2217	1/17/2024	10:11:00 AM	898		70.7	9.1	0	
Wellstone Elementary School	2220	1/17/2024	10:07:00 AM	1050		70	11.3	12	
Wellstone Elementary School	3002	1/17/2024	9:16:00 AM	1182		69.6	11.3	0	
Wellstone Elementary School	3005	1/17/2024	9:41:00 AM	1028	0.1	68.5	11	22	
Wellstone Elementary School	3015	1/17/2024	9:43:00 AM	943		69.6	9.5	0	
Wellstone Elementary School	3016	1/17/2024	9:10:00 AM	577		69.8	8	0	
Wellstone Elementary School	3027	1/17/2024	9:45:00 AM	749		69.8	12	24	

Building Name	Room Name	Date	Time	Carbon Dioxide ppm	Carbon Monoxide ppm	Temperature °F	Relative Humidity %RH	Number of Occupants	Notes
Wellstone Elementary School	3028	1/17/2024	9:06:00 AM	594	0.1	68.2	8	0	
Wellstone Elementary School	3030	1/17/2024	9:46:00 AM	745		70	12	22	
Wellstone Elementary School	3031	1/17/2024	9:09:00 AM	633		69.3	11	0	
Wellstone Elementary School	3050	1/17/2024	9:12:00 AM	803	0.1	68.7	8.8	5	
Wellstone Elementary School	3051	1/17/2024	9:15:00 AM	829	0.1	68.4	12.2	20	
Wellstone Elementary School	3052	1/17/2024	9:18:00 AM	829	0.1	70.5	10.6	20	
Wellstone Elementary School	3054	1/17/2024	9:37:00 AM	669	0.2	69.6	7.8	0	
Wellstone Elementary School	3055	1/17/2024	9:21:00 AM	560	0.1	69.4	34.5	0	
Wellstone Elementary School	3058	1/17/2024	9:28:00 AM	713		66.2	9.3	0	
Wellstone Elementary School	3060	1/17/2024	9:27:00 AM	811		65.7	11	0	Food Odor
Wellstone Elementary School	3063	1/17/2024	9:23:00 AM	714		67.1	13.3	20	
Wellstone Elementary School	3110	1/17/2024	9:29:00 AM	675		69.3	8.1	28	
Wellstone Elementary School	3112	1/17/2024	9:03:00 AM	980	0.2	70.2	11.1	0	Fragrance Odor
Wellstone Elementary School	3113	1/17/2024	9:05:00 AM	970	0.1	70	10.7	20	
Wellstone Elementary School	3115	1/17/2024	9:36:00 AM	574		72.3	5.3	0	
Wellstone Elementary School	3117	1/17/2024	9:34:00 AM	686		70.3	7	0	
Wellstone Elementary School	3203	1/17/2024	9:02:00 AM	873	0.2	70.7	70	10	
Wellstone Elementary School	3205	1/17/2024	9:01:00 AM	958	0.2	71.4	9.8	20	
Wellstone Elementary School	3207	1/17/2024	8:59:00 AM	974	0.2	71.6	10.1	18	
Wellstone Elementary School	3214	1/17/2024	8:47:00 AM	640	0.6	75.7	5.4	0	
Wellstone Elementary School	3215	1/17/2024	8:56:00 AM	903	0.3	73.2	9.7	24	
Wellstone Elementary School	3216	1/17/2024	8:58:00 AM	781	0.3	72	8.2	0	
Wellstone Elementary School	3220	1/17/2024	8:54:00 AM	853	0.5	74.1	8.3	20	
Wellstone Elementary School	2217A	1/17/2024	10:12:00 AM	826		71.1	9.3	0	
Wellstone Elementary School	OUTDOORS	1/17/2024		423	0.1	3	68		
Wheelock Early Education	1001	11/29/2023	9:12:00 AM	439	0.2	74.7	15.4	1	
Wheelock Early Education	1002	11/29/2023	10:12:00 AM	488	0.2	72.1	17.5	1	
Wheelock Early Education	1003	11/29/2023	9:30:00 AM	474	0.2	74.7	15.8	1	Plants: Kept Away From Return And Supply Vents
Wheelock Early Education	1004	11/29/2023	9:32:00 AM	449	0.2	74.5	15.6	1	
Wheelock Early Education	1006	11/29/2023	10:08:00 AM	490	0.2	72.5	17.5	0	
Wheelock Early Education	1100	11/29/2023	9:34:00 AM	509	0.2	73.4	17.2	15	
Wheelock Early Education	1103	11/29/2023	10:36:00 AM	451	0.2	71.8	17.9	0	
Wheelock Early Education	1203	11/29/2023	10:20:00 AM	589	0.2	72.1	19.4	12	
Wheelock Early Education	1204	11/29/2023	10:00:00 AM	506	0.2	74.5	16.6	30	
Wheelock Early Education	1205	11/29/2023	10:23:00 AM	496	0.2	71.8	18.3	10	
Wheelock Early Education	1206	11/29/2023	10:24:00 AM	466	0.2	72.3	17.1	0	
Wheelock Early Education	1301	11/29/2023	10:28:00 AM	504	0.2	72.5	17.9	10	
Wheelock Early Education	1302	11/29/2023	10:34:00 AM	443	0.2	71.1	18	0	
Wheelock Early Education	1303	11/29/2023	10:29:00 AM	507	0.2	71.6	18.4	9	
Wheelock Early Education	1304	11/29/2023	10:03:00 AM	716	0.3	72.1	20.1	25	
Wheelock Early Education	OUTDOORS	11/29/2023		323	0.5	29	87		