
June 24, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave,
Kansas City, MO 64153

RE: Drinking Water Sampling – Renner Elementary
8804 NW 45 Highway, Parkville, MO 64152
Project Number: 923386

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Renner Elementary in Kansas City, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the “Get the Lead Out of School Drinking Water Act”.

METHODOLOGY

On 5/11/2024 Mr. Jay Hurst of OCCU-TEC completed testing of forty-three (43) sources throughout Renner Elementary. Samples were collected as ‘First Draw’ samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, one (1) of the forty-three (43) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
386-RE-29	Health Room	Sink	12.1

LIMITATIONS

At the request of PHSD, Lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
All Identified Sources Were Operational		

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.

- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst
Vice President of Operations




Jeff Smith
Senior Project Manager (QA/QC)


ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-01	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Left kitchen sink, RN Sink 042		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				


ID:	386-RE-02	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Right Kitchen Dish sprayer, RN Sink 042		
		Result:	1.2	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				

ID:	386-RE-03	Location:	Kitchen	
Photo:		Manufacturer:	Fischer	
		Description:		
		RN Tilt 001, Kitchen Dish Sprayer		
		Result:	<1.0	ppb
Date Sampled:		5/11/2024	By:	JH
Recommended Action:				

Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-04	Location:	Kitchen		
Photo:		Manufacturer:	Peerless		
		Description:			
		RN sink 045, Kitchen Sink			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	5/11/2024	By:	JH


ID:	386-RE-05	Location:	Kitchen		
Photo:		Manufacturer:	Hoshizaki		
		Description:			
		Ice machine			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	5/11/2024	By:	JH

ID:	386-RE-06	Location:	Kitchen		
Photo:		Manufacturer:	Unknown		
		Description:			
		RN Sink 043, Handwashing Sink			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	5/11/2024	By:	JH


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-07	Location:	Dish Line		
Photo:		Manufacturer:	T&S Brass		
		Description:			
		Kitchen Dish Sprayer, RN sink 044			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	5/11/2024	By:	JH


ID:	386-RE-08	Location:	Cafeteria		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		RN DF 005, Drinking Fountain Bubbler			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	5/11/2024	By:	JH

ID:	386-RE-09	Location:	Cafeteria		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		RN DF 005, Drinking fountain bottle filler			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	5/11/2024	By:	JH


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-10	Location:	Room 117	
Photo:		Manufacturer:	Unknown	
		Description:		
		RN Sink 016		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-RE-11	Location:	Room 117 Restroo	
Photo:		Manufacturer:	Kohler	
		Description:		
		RN Sink 017, Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-RE-12	Location:	Room 119	
Photo:		Manufacturer:	Delta	
		Description:		
		Rn Sink 018, Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-13	Location:	Room 119 Restroom		
Photo:		Manufacturer:	Kohler		
		Description:			
		RN Sink 019, Handwashing Sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


ID:	386-RE-14	Location:	Hall by Gym		
Photo:		Manufacturer:	Elkay		
		Description:			
		RN DF 001, Drinking Fountain Bubbler			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

ID:	386-RE-15	Location:	Hall by Gym		
Photo:		Manufacturer:	Elkay		
		Description:			
		RN DF 002, Drinking Fountain Bubbler			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-16	Location:	Hall by Gym		
Photo:		Manufacturer:	Unknown		
		Description:			
		RN Sink 041, left sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


ID:	386-RE-17	Location:	Hall by Gym		
Photo:		Manufacturer:	Unknown		
		Description:			
		RN Sink 041, center sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

ID:	386-RE-18	Location:	Hall by Gym		
Photo:		Manufacturer:	Unknown		
		Description:			
		RN Sink 041, right sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-19	Location:	Girls Restroom			
Photo:		Manufacturer:	Sloan			
		Description:				
		Left handwashing Sink				
		Result:	<1.0	ppb		
		Date Sampled:	5/11/2024	By:	JH	
Recommended Action:						


ID:	386-RE-20	Location:	Girls Restroom			
Photo:		Manufacturer:	Sloan			
		Description:				
		Center handwashing Sink				
		Result:	<1.0	ppb		
		Date Sampled:	5/11/2024	By:	JH	
Recommended Action:						

ID:	386-RE-21	Location:	Girls Restroom			
Photo:		Manufacturer:	Sloan			
		Description:				
		Right handwashing sink				
		Result:	<1.0	ppb		
		Date Sampled:	5/11/2024	By:	JH	
Recommended Action:						


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-22	Location:	Boys Restroom		
Photo:		Manufacturer:	Sloan		
		Description:			
		Left handwashing sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


ID:	386-RE-23	Location:	Boys Restroom Sink		
Photo:		Manufacturer:	Sloan		
		Description:			
		Center handwashing sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

ID:	386-RE-24	Location:	Boys Restroom Sink		
Photo:		Manufacturer:	Sloan		
		Description:			
		Right handwashing sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-25	Location:	Room 103 RR		
Photo:		Manufacturer:	Unknown		
		Description:			
		Handwashing Sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


ID:	386-RE-26	Location:	Room 107 RR		
Photo:		Manufacturer:	Delta		
		Description:			
		Handwashing Sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

ID:	386-RE-27	Location:	Hall by Room 110		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		RN DF 003, Drinking Fountain Bubbler			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-28	Location:	Hall by Room 110	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		RN DF 003, Drinking fountain bottle filler		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-RE-29	Location:	Health Room	
Photo:		Manufacturer:	Elkay	
		Description:		
		RN Sink 014, Sink		
		Result:	12.1	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:		Replace Fixture/Unit and Resample		

ID:	386-RE-30	Location:	Health Room Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		RN Sink 015, Handwashing sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-31	Location:	Faculty Restroom	
Photo:		Manufacturer:	Delta	
		Description:		
		RN Sink 039, Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


ID:	386-RE-32	Location:	Faculty Restroom	
Photo:		Manufacturer:	Delta	
		Description:		
		RN Sink 040, Handwashing Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				

ID:	386-RE-33	Location:	Media Specialist	
Photo:		Manufacturer:	Delta	
		Description:		
		RN Sink 047, Sink		
		Result:	<1.0	ppb
		Date Sampled:	5/11/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-34	Location:	Faculty Dining		
Photo:		Manufacturer:	Delta		
		Description:			
		RN Sink 046, Sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


ID:	386-RE-35	Location:	Faculty Dining		
Photo:		Manufacturer:	Fridgidaire		
		Description:			
		Ice Maker			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

ID:	386-RE-36	Location:	Hall by Room 208		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		Drinking Fountain Bubbler			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					


Drinking Water Assessment
Renner Elementary
Park Hill School District


ID:	386-RE-37	Location:	Hall by Room 208		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		Drinking Fountain Bottle Filler			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	5/11/2024	By:	JH


ID:	386-RE-38	Location:	2nd Floor Boy's RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Left handwashing Sink			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	5/11/2024	By:	JH

ID:	386-RE-39	Location:	2nd Floor Boy's RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Center handwashing Sink			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	5/11/2024	By:	JH


Drinking Water Assessment
Renner Elementary
Park Hill School District

ID:	386-RE-40	Location:	2nd Floor Boy's RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Right handwashing Sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

ID:	386-RE-41	Location:	2nd Floor Women's RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Rn Sink 035, Left handwashing sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

ID:	386-RE-42	Location:	2nd Floor Women's RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Rn Sink 035, Center handwashing sink			
		Result:	<1.0	ppb	
		Date Sampled:	5/11/2024	By:	JH
Recommended Action:					

Drinking Water Assessment
Renner Elementary
Park Hill School District

ID:	386-RE-43	Location:	2nd Floor Women's RR			
Photo:		Manufacturer:	Sloan			
		Description:				
		Rn Sink 035, Right handwashing sink				
		Result:	<1.0	ppb		
		Date Sampled:	5/11/2024	By:	JH	
Recommended Action:						



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

May 31, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: 923386-Renner Elementary School

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **43** sample(s) the laboratory received on **5/17/24 9:55 am** and logged in under work order **HE03271**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read "Chenise Lambert-Sykes".

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order HE03271

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: HE03271-01
Name: 386-RE-01
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:18
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-02
Name: 386-RE-02
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:19
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.20	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:29	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-03
Name: 386-RE-03
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:20
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:31	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-04
Name: 386-RE-04
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:21
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:35	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE03271-05
Name: 386-RE-05
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:22
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:36	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-06
Name: 386-RE-06
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:23
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:38	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-07
Name: 386-RE-07
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:24
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:39	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-08
Name: 386-RE-08
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:27
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:41	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE03271-09
Name: 386-RE-09
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:27
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:42	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-10
Name: 386-RE-10
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:31
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:46	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-11
Name: 386-RE-11
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:31
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:48	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-12
Name: 386-RE-12
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:33
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:52	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE03271-13
Name: 386-RE-13
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:33
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:53	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-14
Name: 386-RE-14
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:34
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:55	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-15
Name: 386-RE-15
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:35
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:56	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-16
Name: 386-RE-16
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:36
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:57	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE03271-17
Name: 386-RE-17
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:36
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 12:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-18
Name: 386-RE-18
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:36
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:00	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-19
Name: 386-RE-19
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:42
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:02	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-20
Name: 386-RE-20
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:42
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE03271-21
Name: 386-RE-21
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:42
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:10	BRS	EPA 200.8 REV 5.4

Sample: HE03271-22
Name: 386-RE-22
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:45
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:11	BRS	EPA 200.8 REV 5.4

Sample: HE03271-23
Name: 386-RE-23
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:45
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:13	BRS	EPA 200.8 REV 5.4

Sample: HE03271-24
Name: 386-RE-24
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:45
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:14	BRS	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: HE03271-25
Name: 386-RE-25
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:39
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:16	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-26
Name: 386-RE-26
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:40
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:17	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-27
Name: 386-RE-27
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:54
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-28
Name: 386-RE-28
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:54
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:20	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE03271-29
Name: 386-RE-29
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:55
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	12.1	ug/L		05/20/24 11:09	1	1.00	05/20/24 13:21	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-30
Name: 386-RE-30
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:56
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:03	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-31
Name: 386-RE-31
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:58
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-32
Name: 386-RE-32
Matrix: Drinking Water - Grab

Sampled: 05/11/24 07:58
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:06	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE03271-33
Name: 386-RE-33
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:00
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:08	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-34
Name: 386-RE-34
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:03
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-35
Name: 386-RE-35
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:03
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/21/24 12:36	1	1.00	05/22/24 10:02	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-36
Name: 386-RE-36
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:07
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:10	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE03271-37
Name: 386-RE-37
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:07
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-38
Name: 386-RE-38
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:09
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:16	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-39
Name: 386-RE-39
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:09
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:17	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-40
Name: 386-RE-40
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:09
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:22	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HE03271-41
Name: 386-RE-41
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:11
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:23	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-42
Name: 386-RE-42
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:11
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:24	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HE03271-43
Name: 386-RE-43
Matrix: Drinking Water - Grab

Sampled: 05/11/24 08:11
Received: 05/17/24 09:55
PO #: 24006088

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		05/22/24 09:07	1	1.00	05/22/24 15:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Renner Elementary School		PURCHASE ORDER # 24006088		3 ANALYSIS REQUESTED <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <input checked="" type="checkbox"/> DW Lead <input checked="" type="checkbox"/> Turb Check </div> <div style="width: 45%;"></div> </div>				4 (FOR LAB USE ONLY) LOGIN # <u>A1E03271</u> LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____		
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 5/14/2024								
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAB- NON AQUEOUS SOLID LCH- LEACHATE OIL- OIL SO- SOIL SOL- SOLID								
CONTACT PERSON Jeremie Kahler														
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED					REMARKS	
386-RE-01		5/11/2024	718	X		DW	1	6	X					
386-RE-02		5/11/2024	719	X		DW	1	6	X					
386-RE-03		5/11/2024	720	X		DW	1	6	X					
386-RE-04		5/11/2024	721	X		DW	1	6	X					
386-RE-05		5/11/2024	722	X		DW	1	6	X					
386-RE-06		5/11/2024	723	X		DW	1	6	X					
386-RE-07		5/11/2024	724	X		DW	1	6	X					
386-RE-08		5/11/2024	727	X		DW	1	6	X					
386-RE-09		5/11/2024	727	X		DW	1	6	X					
386-RE-10		5/11/2024	731	X		DW	1	6	X					
386-RE-11		5/11/2024	731	X		DW	1	6	X					
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER														
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: _____ PHONE # IF DIFFERENT FROM ABOVE: _____				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____								
7 RELINQUISHED BY: (SIGNATURE) 		DATE 5/13/24	RECEIVED BY: (SIGNATURE) 				DATE 5/13/24		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT 20.0 °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____					
RELINQUISHED BY: (SIGNATURE) _____		DATE _____	RECEIVED BY: (SIGNATURE) _____				DATE _____							
RELINQUISHED BY: (SIGNATURE) _____		DATE _____	RECEIVED BY: (SIGNATURE) 				DATE 5/13/24 TIME 9:55							

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Renner Elementary School		PURCHASE ORDER # 24006088		3 ANALYSIS REQUESTED <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <input checked="" type="checkbox"/> DW Lead <input checked="" type="checkbox"/> Turb Check </div> <div style="width: 45%;"></div> </div>				4 (FOR LAB USE ONLY) LOGIN # <u>KE03271</u> LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 5/14/2024							
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID							
CONTACT PERSON Jeremie Kahler													

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE		MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check							REMARKS
			GRAB	COMP												
386-RE-12	5/11/2024	733	X		DW	1	6	X								
386-RE-13	5/11/2024	733	X		DW	1	6	X								
386-RE-14	5/11/2024	734	X		DW	1	6	X								
386-RE-15	5/11/2024	735	X		DW	1	6	X								
386-RE-16	5/11/2024	736	X		DW	1	6	X								
386-RE-17	5/11/2024	736	X		DW	1	6	X								
386-RE-18	5/11/2024	736	X		DW	1	6	X								
386-RE-19	5/11/2024	742	X		DW	1	6	X								
386-RE-20	5/11/2024	742	X		DW	1	6	X								
386-RE-21	5/11/2024	742	X		DW	1	6	X								
386-RE-22	5/11/2024	745	X		Dw	1	6	X								

CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER



5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL <input checked="" type="radio"/> RUSH <input type="radio"/> RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL <input type="radio"/> PHONE <input type="radio"/> EMAIL IF DIFFERENT FROM ABOVE: _____ PHONE # IF DIFFERENT FROM ABOVE: _____		DATE RESULTS NEEDED _____	6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____
--	--	-------------------------------------	---

7 RELINQUISHED BY: (SIGNATURE) 		DATE 5/13/24	TIME 500pm	RECEIVED BY: (SIGNATURE) 		DATE 5/17/24	TIME 955	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT 20.0 °C CHILL PROCESS STARTED PRIOR TO RECEIPT <input type="radio"/> Y <input checked="" type="radio"/> N SAMPLE(S) RECEIVED ON ICE <input type="radio"/> Y <input checked="" type="radio"/> N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED <input type="radio"/> Y <input checked="" type="radio"/> N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____	
RELINQUISHED BY: (SIGNATURE) _____		DATE _____	TIME _____	RECEIVED BY: (SIGNATURE) _____		DATE _____	TIME _____		
RELINQUISHED BY: (SIGNATURE) _____		DATE _____	TIME _____	RECEIVED BY: (SIGNATURE) _____		DATE _____	TIME _____		

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS: 9501 N. Seymour Ave. CITY STATE ZIP: Kansas City, MO 64153 CONTACT PERSON: Jeremie Kahler		PROJECT NUMBER 923386	PROJECT LOCATION Renner Elementary School E-MAIL KahlerJ@parkhill.k12.mo.us	PURCHASE ORDER # 24006088 DATE SHIPPED 5/14/2024	3 ANALYSIS REQUESTED + DW Lead + Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>HE03271</u> LOGGED BY: _____ CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____			
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS		
386-RE- 23		5/11/2024	745	X	DW	1	6	X		
386-RE- 24		5/11/2024	745	X	DW	1	6	X		
386-RE- 25		5/11/2024	739	X	DW	1	6	X		
386-RE- 26		5/11/2024	740	X	DW	1	6	X		
386-RE- 27		5/11/2024	754	X	DW	1	6	X		
386-RE- 28		5/11/2024	754	X	DW	1	6	X		
386-RE- 29		5/11/2024	755	X	DW	1	6	X		
386-RE- 30		5/11/2024	756	X	DW	1	6	X		
386-RE- 31		5/11/2024	758	X	DW	1	6	X		
386-RE- 32		5/11/2024	759	X	DW	1	6	X		
386-RE- 33		5/11/2024	800	X	DW	1	6	X		
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER										
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____				
7 RELINQUISHED BY: (SIGNATURE) 		DATE 5/13/24 TIME 5:00pm	RECEIVED BY: (SIGNATURE) 			DATE 5/17/24 TIME 955	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT <u>20.0</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 PHONE NUMBER 8163596731		PROJECT LOCATION Renner Elementary School E-MAIL KahlerJ@parkhill.k12.mo.us		PURCHASE ORDER # 24006088 DATE SHIPPED 5/14/2024		3 ANALYSIS REQUESTED <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">+ DW Lead</div> <div style="text-align: center;">+ Turb Check</div> </div>		4 (FOR LAB USE ONLY) LOGIN # <u>HE03271</u> LOGGED BY: _____ CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP		MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead Turb Check	REMARKS	
				SAMPLER (PLEASE PRINT) Jay Hurst SAMPLER'S SIGNATURE	MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAB- NON AQUEOUS SOLID LCLT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID						
386-RE- <u>34</u>		5/11/2024	8:03	X		DW	1	6	X		
386-RE- <u>35</u>		5/11/2024	8:03	X		DW	1	6	X		
386-RE- <u>36</u>		5/11/2024	8:09	X		DW	1	6	X		
386-RE- <u>37</u>		5/11/2024	8:09	X		DW	1	6	X		
386-RE- <u>38</u>		5/11/2024	8:09	X		DW	1	6	X		
386-RE- <u>39</u>		5/11/2024	8:09	X		DW	1	6	X		
386-RE- <u>40</u>		5/11/2024	8:09	X		DW	1	6	X		
386-RE- <u>41</u>		5/11/2024	8:11	X		DW	1	6	X		
386-RE- <u>42</u>		5/11/2024	8:11	X		DW	1	6	X		
386-RE- <u>43</u>		5/11/2024	8:11	X		DW	1	6	X		
386-RE-		5/11/2024		X		Dw	1	6	X		
CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE <u>5/13/24</u> TIME <u>5:00pm</u> DATE TIME DATE TIME		RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE)		DATE TIME DATE TIME DATE <u>5/17/24</u> TIME <u>955</u>		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT <u>20.0</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			