
January 30, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave,
Kansas City, MO 64153

RE: Drinking Water Sampling – Southeast Elementary
5704 NW Northwood Road, Kansas City, MO 64151
Project Number: 923386

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Southeast Elementary in Kansas City, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the "Get the Lead Out of School Drinking Water Act".

METHODOLOGY

On 12/21/2023 Mr. Jay Hurst and Mr. Cole Dugan of OCCU-TEC completed testing of eighty (80) sources throughout Southeast Elementary. Samples were collected as 'First Draw' samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, nine (9) of the eighty (80) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
386-SEE-26	Room 121	Sink	8.22
386-SEE-28	Room 125	Sink	5.98
386-SEE-29	Room 124	Sink	7.54
386-SEE-30	Room 122	Sink	14.3
386-SEE-37	Room 114	Sink	6.24
386-SEE-51	Room 103	Sink	9.79
386-SEE-52	Room 105	Sink	9.66
386-SEE-53	Room 107	Sink	7.45
386-SEE-71	Room 3	Sink – Faucet	12.3

LIMITATIONS

At the request of PHSD, Lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
All Identified Sources Were Operational		

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the

federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random "Flush" sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst
Vice President of Operations





Jeff Smith
Senior Project Manager (QA/QC)


ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-01	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		SE Sink 009		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-02	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		SE Sink 010 (Food Prep)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-03	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		SE Sink 013 (Left Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-04	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		SE Sink 013 (Right Fixture)		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


ID:	386-SEE-05	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		SE Skillet 001 (Faucet)		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				

ID:	386-SEE-06	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		SE Skillet 001 (Sprayer)		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-07	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		SE Sink 012 (Sprayer)		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


ID:	386-SEE-08	Location:	Kitchen	
Photo:		Manufacturer:	Delta	
		Description:		
		SE Sink 011		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				

ID:	386-SEE-09	Location:	Kitchen	
Photo:		Manufacturer:	Delta	
		Description:		
		SE Sink 014		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-10	Location:	Kitchen Restroom	
Photo:		Manufacturer:	Delta	
		Description:		
		SE Sink 033		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


ID:	386-SEE-11	Location:	Multipurpose Room	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 003 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				

ID:	386-SEE-12	Location:	Room 109	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 043		
		Result:	4.35	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-13	Location:	Room 111	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 032		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-14	Location:	Gym Hall Boys RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 007 (Left Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-15	Location:	Gym Hall Boys RR	
Photo:		Manufacturer:	Sload	
		Description:		
		SE Sink 007 (Center Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-16	Location:	Gym Hall Boys RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 007 (Right Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-17	Location:	Gym Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		SE DF 005 - Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-18	Location:	Gym Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		SE DF 005 - Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-19	Location:	Gym Hall	
Photo:		Manufacturer:	Murdock	
		Description:		
		SE DF 005 - Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-20	Location:	Room 113	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 044		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-21	Location:	Room 115	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 031		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-22	Location:	Room 117	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 030		
		Result:	4.09	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


ID:	386-SEE-23	Location:	Hall Outside Rm 119	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 007 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				

ID:	386-SEE-24	Location:	Hall Outside Rm 119	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 007 - Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-25	Location:	Room 119	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		SE Sink 029		
		Result:	2.24	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


ID:	386-SEE-26	Location:	Room 121	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 045		
		Result:	8.22	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:		Remove from Service / Label		

ID:	386-SEE-27	Location:	Room 123	
Photo:		Manufacturer:	Unknown	
		Description:		
		NO QR Code - Sink		
		Result:	4.88	ppb
Date Sampled:		12/21/2023	By:	JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-28	Location:	Room 125	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 047		
		Result:	5.98	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:		Remove from Service / Label		


ID:	386-SEE-29	Location:	Room 124	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 028		
		Result:	7.54	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:		Remove from Service / Label		

ID:	386-SEE-30	Location:	Room 122	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 027		
		Result:	14.3	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:		Remove from Service / Label		


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-31	Location:	Room 120	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		Se Sink 046		
		Result:	3.07	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-32	Location:	Room 118	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 025		
		Result:	3.33	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-33	Location:	Room 116	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 024		
		Result:	4.8	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-34	Location:	Hall Outside Rm 114	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 006 - Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-35	Location:	Hall Outside Rm 114	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 006 - Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-36	Location:	Hall Outside Rm 114	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 006 - Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-37	Location:	Room 114	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 023		
		Result:	6.24	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:		Remove from Service / Label		


ID:	386-SEE-38	Location:	Girls RR by Rm 114	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 008 (Left Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-39	Location:	Girls RR by Rm 114	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 008 (Center Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-40	Location:	Girls RR by Rm 114	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 008 (Right Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-41R	Location:	Room 112	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 022		
		Result:	3.89	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-42	Location:	Room 110	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 021		
		Result:	2.88	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-43	Location:	Girls RR By Fire Doors	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 006 (Left Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-44	Location:	Girls RR by Fire Doors	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 006 (Center Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-45	Location:	Girls RR by Fire Doors	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 006 (Right Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-46	Location:	Boys RR by Fire Doors	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 005 (Left Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-47	Location:	Boys RR by Fire Doors	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 005 (Center Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-48	Location:	Boys RR by Fire Doors	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 005 (Right Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-49	Location:	Hall Outside Rm 101	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 002 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-50	Location:	Hall Outside Rm 101	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 002 - Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-51	Location:	Room 103	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 020		
		Result:	9.79	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:		Remove from Service / Label		


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-52	Location:	Room 105	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 034		
		Result:	9.66	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:		Remove from Service / Label		


ID:	386-SEE-53	Location:	Room 107	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 019		
		Result:	7.45	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:		Remove from Service / Label		

ID:	386-SEE-54	Location:	Room 108	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 036		
		Result:	3.35	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-55	Location:	Room 106	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 035		
		Result:	3.63	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-56	Location:	Girls RR by Counselor	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 004 (Left Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-57	Location:	Girls RR by Counselor	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 004 (Center Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-58	Location:	Girls RR by Counselor	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 004 (Right Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-59	Location:	Hall by Counselor	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 001 - Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-60	Location:	Hall by Counselor	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 001 - Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-61	Location:	Hall by Counselor	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		SE DF 001 - Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-62	Location:	Boys RR by Counselor	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 003 (Left Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-63	Location:	Boys RR by Counselor	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 003 (Center Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-64	Location:	Boys RR by Counselor	
Photo:		Manufacturer:	Sloan	
		Description:		
		SE Sink 003 (Right Fixture)		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-65	Location:	Health Room RR	
Photo:		Manufacturer:	Delta	
		Description:		
		SE Sink 038		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-66	Location:	Health Room	
Photo:		Manufacturer:	Delta	
		Description:		
		SE Sink 037		
		Result:	1.09	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Southeast Elementary School
Park Hill School District

ID:	386-SEE-67	Location:	Room 4	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 017 - Drinking Fountain Bubbler		
		Result:	1.09	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				


ID:	386-SEE-68	Location:	Room 4	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 017 - Faucet		
		Result:	2.67	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-69	Location:	Room 4 Restroom	
Photo:		Manufacturer:	Delta	
		Description:		
		SE Sink 018		
		Result:	1.33	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

Drinking Water Assessment
Southeast Elementary School
Park Hill School District


ID:	386-SEE-70	Location:	Room 3	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 041 - Drinking Fountain Bubbler		
		Result:	2.14	ppb
		Date Sampled:	12/21/2023	By: JH

Recommended Action:

ID:	386-SEE-71	Location:	Room 3	
Photo:		Manufacturer:	Central	
		Description:		
		SE Sink 041 - Faucet		
		Result:	12.3	ppb
		Date Sampled:	12/21/2023	By: JH


Recommended Action:

Remove from Service / Label


ID:	386-SEE-72	Location:	Room 3 Restroom	
Photo:		Manufacturer:	Delta	
		Description:		
		SE Sink 042		
		Result:	1.87	ppb
		Date Sampled:	12/21/2023	By: JH

Recommended Action:


Drinking Water Assessment
Southeast Elementary School
Park Hill School District

ID:	386-SEE-73	Location:	Room 2	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 015 - Drinking Fountain Bubbler		
		Result:	3.14	ppb
		Date Sampled:	12/21/2023	By: JH

Recommended Action:


ID:	386-SEE-74	Location:	Room 2	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 015 - Faucet		
		Result:	1.1	ppb
		Date Sampled:	12/21/2023	By: JH

Recommended Action:


ID:	386-SEE-75	Location:	Room 2 Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		SE Sink 016		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH

Recommended Action:


Drinking Water Assessment
Southeast Elementary School
Park Hill School District

ID:	386-SEE-76	Location:	Room 1 Restroom	
Photo:		Manufacturer:	American Standard	
		Description:		
		SE Sink 040		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH

Recommended Action:


ID:	386-SEE-77	Location:	Room 1	
Photo:		Manufacturer:	Unknown	
		Description:		
		SE Sink 039		
		Result:	3.98	ppb
		Date Sampled:	12/21/2023	By: JH


Recommended Action:

ID:	386-SEE-78	Location:	Staff Restroom	
Photo:		Manufacturer:	Delta	
		Description:		
		SE Sink 002		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH

Recommended Action:

Drinking Water Assessment
Southeast Elementary School
Park Hill School District

ID:	386-SEE-79	Location:	Staff Dining	
Photo:		Manufacturer:	Delta	
		Description:		
		SE Sink 001		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				

ID:	386-SEE-80	Location:	Staff Dining	
Photo:		Manufacturer:	Hoshizaki	
		Description:		
		SE Ice 001		
		Result:	<1.0	ppb
		Date Sampled:	12/21/2023	By: JH
Recommended Action:				



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

January 11, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: 923386 - Southeast Elementary School

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **80** sample(s) the laboratory received on **12/27/23 9:10 am** and logged in under work order **GL04392**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order GL04392

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

Case Narrative

Sample 386-SEE-041 arrived uncapped and volume spilled into the cooler. Therefore, this sample could not be analyzed or reported.



ANALYTICAL RESULTS

Sample: GL04392-01
Name: 386-SEE-001
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:46
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-02
Name: 386-SEE-002
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:47
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:29	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-03
Name: 386-SEE-003
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:48
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:31	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-04
Name: 386-SEE-004
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:49
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:32	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-05
Name: 386-SEE-005
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:50
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:34	BRS	EPA 200.8 REV 5.4

Sample: GL04392-06
Name: 386-SEE-006
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:53
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:36	BRS	EPA 200.8 REV 5.4

Sample: GL04392-07
Name: 386-SEE-007
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:55
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:40	BRS	EPA 200.8 REV 5.4

Sample: GL04392-08
Name: 386-SEE-008
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:56
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:42	BRS	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GL04392-09
Name: 386-SEE-009
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:57
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:43	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-10
Name: 386-SEE-010
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:58
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:48	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-11
Name: 386-SEE-011
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:02
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:50	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-12
Name: 386-SEE-012
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:04
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.35	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:51	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-13
Name: 386-SEE-013
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:07
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:53	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-14
Name: 386-SEE-014
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:08
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:54	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-15
Name: 386-SEE-015
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:08
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 09:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-16
Name: 386-SEE-016
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:08
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-17
Name: 386-SEE-017
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:12
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:02	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-18
Name: 386-SEE-018
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:12
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-19
Name: 386-SEE-019
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:12
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-20
Name: 386-SEE-020
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:16
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:10	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-21
Name: 386-SEE-021
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:17
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:11	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-22
Name: 386-SEE-022
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:19
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.09	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:13	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-23
Name: 386-SEE-023
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:21
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-24
Name: 386-SEE-024
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:21
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:19	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-25
Name: 386-SEE-025
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:23
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.24	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:21	BRS	EPA 200.8 REV 5.4

Sample: GL04392-26
Name: 386-SEE-026
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:26
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	8.22	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:22	BRS	EPA 200.8 REV 5.4

Sample: GL04392-27
Name: 386-SEE-027
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:27
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.88	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:24	BRS	EPA 200.8 REV 5.4

Sample: GL04392-28
Name: 386-SEE-028
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:29
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	5.98	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:25	BRS	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GL04392-29
Name: 386-SEE-029
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:30
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	7.54	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:27	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-30
Name: 386-SEE-030
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:33
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	14.3	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:32	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-31
Name: 386-SEE-031
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:34
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.07	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:36	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-32
Name: 386-SEE-032
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:38
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.33	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:38	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-33
Name: 386-SEE-033
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:39
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.80	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:40	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-34
Name: 386-SEE-034
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:41
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:41	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-35
Name: 386-SEE-035
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:41
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:43	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-36
Name: 386-SEE-036
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:41
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-37
Name: 386-SEE-037
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:44
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	6.24	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:46	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-38
Name: 386-SEE-038
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:46
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-39
Name: 386-SEE-039
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:46
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:49	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-40
Name: 386-SEE-040
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:46
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:57	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-42
Name: 386-SEE-042
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:50
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.88	ug/L		01/10/24 07:13	1	1.00	01/10/24 10:58	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-43
Name: 386-SEE-043
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:52
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:00	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-44
Name: 386-SEE-044
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:52
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-45
Name: 386-SEE-045
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:52
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:03	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-46
Name: 386-SEE-046
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:56
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-47
Name: 386-SEE-047
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:56
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:06	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-48
Name: 386-SEE-048
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:56
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:08	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-49
Name: 386-SEE-049
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:00
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-50
Name: 386-SEE-050
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:00
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-51
Name: 386-SEE-051
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:02
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	9.79	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:19	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-52
Name: 386-SEE-052
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:03
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	9.66	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:20	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-53
Name: 386-SEE-053
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:04
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	7.45	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:22	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-54
Name: 386-SEE-054
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:06
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.35	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:23	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-55
Name: 386-SEE-055
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:07
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.63	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:25	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-56
Name: 386-SEE-056
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:10
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-57
Name: 386-SEE-057
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:10
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-58
Name: 386-SEE-058
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:10
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:33	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-59
Name: 386-SEE-059
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:12
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:34	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-60
Name: 386-SEE-060
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:12
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:36	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-61
Name: 386-SEE-061
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:12
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:40	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-62
Name: 386-SEE-062
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:15
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:42	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-63
Name: 386-SEE-063
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:15
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-64
Name: 386-SEE-064
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:15
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:45	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-65
Name: 386-SEE-065
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:17
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-66
Name: 386-SEE-066
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:19
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.09	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:51	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-67
Name: 386-SEE-067
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:21
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.09	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:53	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-68
Name: 386-SEE-068
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:22
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.67	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:54	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-69
Name: 386-SEE-069
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:23
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.33	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:56	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-70
Name: 386-SEE-070
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:25
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.14	ug/L		01/10/24 07:13	1	1.00	01/10/24 11:58	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-71
Name: 386-SEE-071
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:26
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	12.3	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:02	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-72
Name: 386-SEE-072
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:27
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.87	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:04	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-73
Name: 386-SEE-073
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:28
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.14	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:05	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-74
Name: 386-SEE-074
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:29
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.10	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:10	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-75
Name: 386-SEE-075
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:30
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-76
Name: 386-SEE-076
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:32
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:13	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-77
Name: 386-SEE-077
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:33
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.98	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:15	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GL04392-78
Name: 386-SEE-078
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:34
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:16	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-79
Name: 386-SEE-079
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:37
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GL04392-80
Name: 386-SEE-080
Matrix: Drinking Water - Grab

Sampled: 12/21/23 09:38
Received: 12/27/23 09:10
PO #: SE2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/10/24 07:13	1	1.00	01/10/24 12:19	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050






Certified by: Chenise Lambert-Sykes, Project Manager

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Southeast Elementary School		PURCHASE ORDER # SE2324		3 ANALYSIS REQUESTED <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">+ DW Lead</div> <div style="text-align: center;">+ Turb Check</div> </div>		4 (FOR LAB USE ONLY) LOGIN # <u>6L04392</u> LOGGED BY: <u>705</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 12/22/2023					
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst				MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE 									
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS	
386-SEE- 001		12/21/2023	0746	X	DW	1	6	X			
386-SEE- 002		12/21/2023	0747	X	DW	1	6	X			
386-SEE- 003		12/21/2023	0748	X	DW	1	6	X			
386-SEE- 004		12/21/2023	0749	X	DW	1	6	X			
386-SEE- 005		12/21/2023	0750	X	DW	1	6	X			
386-SEE- 006		12/21/2023	0753	X	DW	1	6	X			
386-SEE- 007		12/21/2023	0755	X	DW	1	6	X			
386-SEE- 008		12/21/2023	0756	X	DW	1	6	X			
386-SEE- 009		12/21/2023	0757	X	DW	1	6	X			
386-SEE- 010		12/21/2023	0758	X	DW	1	6	X			
386-SEE- 011		12/21/2023	0802	X	Dw	1	6	X			
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		(NORMAL) RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample performance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) 		DATE 12/21/23 TIME 1700		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT <u>10.7</u> °C			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE) 		DATE 12/27/23 TIME 0910		CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Southeast Elementary School		PURCHASE ORDER # SE2324		3 ANALYSIS REQUESTED <input checked="" type="checkbox"/> DW Lead <input checked="" type="checkbox"/> Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>6104397</u> LOGGED BY: <u>2024</u> CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 12/22/2023					
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		MATRICES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LGHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID							
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE									
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead <input checked="" type="checkbox"/>	Turb Check <input checked="" type="checkbox"/>	REMARKS	
386-SEE-012		12/21/2023	0804	X		DW	1 6	X			
386-SEE-013		12/21/2023	0807	X		DW	1 6	X			
386-SEE-014		12/21/2023	0808	X		DW	1 6	X			
386-SEE-015		12/21/2023	0808	X		DW	1 6	X			
386-SEE-016		12/21/2023	0808	X		DW	1 6	X			
386-SEE-017		12/21/2023	0812	X		DW	1 6	X			
386-SEE-018		12/21/2023	0812	X		DW	1 6	X			
386-SEE-019		12/21/2023	0812	X		DW	1 6	X			
386-SEE-020		12/21/2023	0816	X		DW	1 6	X			
386-SEE-021		12/21/2023	0817	X		DW	1 6	X			
386-SEE-022		12/21/2023	0819	X		DW	1 6	X			
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		NORMAL RUSH DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____							
7 RELINQUISHED BY: (SIGNATURE) 		DATE TIME 12/21/23 1700		RECEIVED BY: (SIGNATURE)		DATE TIME		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)		DATE TIME		SAMPLE TEMPERATURE UPON RECEIPT _____ °C			
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)		DATE TIME 12/27/27 0910		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Southeast Elementary School		PURCHASE ORDER # SE2324		3 ANALYSIS REQUESTED + +		4 (FOR LAB USE ONLY) LOGIN # <u>CL04392</u> LOGGED BY: <u>MSA</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 12/22/2023		DW Lead Turb Check			
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler											
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead Turb Check		REMARKS	
386-SEE- 023		12/21/2023	0821	X	DW	1	6	X			
386-SEE- 024		12/21/2023	0821	X	DW	1	6	X			
386-SEE- 025		12/21/2023	0823	X	DW	1	6	X			
386-SEE- 026		12/21/2023	0826	X	DW	1	6	X			
386-SEE- 027		12/21/2023	0827	X	DW	1	6	X			
386-SEE- 028		12/21/2023	0829	X	DW	1	6	X			
386-SEE- 029		12/21/2023	0836	X	DW	1	6	X			
386-SEE- 030		12/21/2023	0833	X	DW	1	6	X			
386-SEE- 031		12/21/2023	0834	X	DW	1	6	X			
386-SEE- 032		12/21/2023	0838	X	DW	1	6	X			
386-SEE- 033		12/21/2023	0839	X	DW	1	6	X			
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) 		DATE 12/21/23 TIME 1700		RECEIVED BY: (SIGNATURE) _____				DATE _____ TIME _____		8 COMMENTS: (FOR LAB USE ONLY) _____ _____ SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____	
RELINQUISHED BY: (SIGNATURE) _____		DATE _____ TIME _____		RECEIVED BY: (SIGNATURE) _____				DATE _____ TIME _____			
RELINQUISHED BY: (SIGNATURE) _____		DATE _____ TIME _____		RECEIVED BY: (SIGNATURE) 				DATE 12/27/23 TIME 0910			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Southeast Elementary School		PURCHASE ORDER # SE2324		3 ANALYSIS REQUESTED + DW Lead + Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>660 4392</u> LOGGED BY: <u>7054</u> CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 12/22/2023					
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler											
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS	
386-SEE- 034		12/21/2023	0841	X	DW	1	6	X			
386-SEE- 035		12/21/2023	0841	X	DW	1	6	X			
386-SEE- 036		12/21/2023	0841	X	DW	1	6	X			
386-SEE- 037		12/21/2023	0844	X	DW	1	6	X			
386-SEE- 038		12/21/2023	0846	X	DW	1	6	X			
386-SEE- 039		12/21/2023	0846	X	DW	1	6	X			
386-SEE- 040		12/21/2023	0846	X	DW	1	6	X			
386-SEE- 041		12/21/2023	0848	X	DW	1	6	X			
386-SEE- 042		12/21/2023	0850	X	DW	1	6	X			
386-SEE- 043		12/21/2023	0852	X	DW	1	6	X			
386-SEE- 044		12/21/2023	0852	X	DW	1	6	X			
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		NORMAL RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) 		DATE 12/21/23 TIME 1700		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT _____ °C			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE) 		DATE 12/27/27 TIME 0910		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Southeast Elementary School		PURCHASE ORDER # SE2324		3 ANALYSIS REQUESTED <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">+ DW Lead</div> <div style="text-align: center;">+ Turb Check</div> </div>		4 (FOR LAB USE ONLY) LOGIN # <u>6604392</u> LOGGED BY: <u>7051</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 12/22/2023					
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst				MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE 									
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS	
386-SEE- 045		12/21/2023	0852	X		DW	1	6	X		
386-SEE- 046		12/21/2023	0856	X		DW	1	6	X		
386-SEE- 047		12/21/2023	0856	X		DW	1	6	X		
386-SEE- 048		12/21/2023	0856	X		DW	1	6	X		
386-SEE- 049		12/21/2023	0900	X		DW	1	6	X		
386-SEE- 050		12/21/2023	0900	X		DW	1	6	X		
386-SEE- 051		12/21/2023	0902	X		DW	1	6	X		
386-SEE- 052		12/21/2023	0903	X		DW	1	6	X		
386-SEE- 053		12/21/2023	0904	X		DW	1	6	X		
386-SEE- 054		12/21/2023	0906	X		DW	1	6	X		
386-SEE- 055		12/21/2023	0907	X		Dw	1	6	X		
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: _____ PHONE # IF DIFFERENT FROM ABOVE: _____				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample performance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) 		DATE 12/21/23 TIME 1700		RECEIVED BY: (SIGNATURE) 				DATE TIME 		8 COMMENTS: (FOR LAB USE ONLY) 	
RELINQUISHED BY: (SIGNATURE) 		DATE TIME 		RECEIVED BY: (SIGNATURE) 				DATE TIME 		SAMPLE TEMPERATURE UPON RECEIPT _____ °C	
RELINQUISHED BY: (SIGNATURE) 		DATE TIME 		RECEIVED BY: (SIGNATURE) 				DATE 12/27/23 TIME 0910		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____	



Pace Analytical Services
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 PHONE NUMBER 8163596731	PROJECT LOCATION Southeast Elementary School E-MAIL KahlerJ@parkhill.k12.mo.us	PURCHASE ORDER # SE2324 DATE SHIPPED 12/22/2023	3 ANALYSIS REQUESTED <table border="1"> <tr> <td><input checked="" type="checkbox"/></td> <td><input checked="" type="checkbox"/></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																			4 (FOR LAB USE ONLY) LOGIN # <u>CL04392</u> LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>																										
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check											REMARKS							
386-SEE- 056		12/21/2023	0910	X		DW	1	6	X																		
386-SEE- 057		12/21/2023	0910	X		DW	1	6	X																		
386-SEE- 058		12/21/2023	0910	X		DW	1	6	X																		
386-SEE- 059		12/21/2023	0912	X		DW	1	6	X																		
386-SEE- 060		12/21/2023	0912	X		DW	1	6	X																		
386-SEE- 061		12/21/2023	0912	X		DW	1	6	X																		
386-SEE- 062		12/21/2023	0915	X		DW	1	6	X																		
386-SEE- 063		12/21/2023	0915	X		DW	1	6	X																		
386-SEE- 064		12/21/2023	0915	X		DW	1	6	X																		
386-SEE- 065		12/21/2023	0917	X		DW	1	6	X																		
386-SEE- 066		12/21/2023	0919	X		Dw	1	6	X																		
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER																			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		NORMAL RUSH DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____																							
7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE 12/21/23 TIME 1700	RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE)		DATE 12/27/23 TIME 0910	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____																					



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

January 19, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: 923386-Southeast Elementary School

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **2** sample(s) the laboratory received on **1/4/24 12:00 pm** and logged in under work order **HA00882**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes', is written over a faint, larger signature.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order HA00882

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: HA00882-01
Name: 386-SEE-019R
Matrix: Drinking Water - Grab

Sampled: 12/28/23 15:56
Received: 01/04/24 12:00

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/16/24 08:53	1	1.00	01/16/24 13:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00882-02
Name: 386-SEE-041R
Matrix: Drinking Water - Grab

Sampled: 12/28/23 15:58
Received: 01/04/24 12:00

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.89	ug/L		01/16/24 08:53	1	1.00	01/16/24 13:49	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager

