
January 30, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave,
Kansas City, MO 64153

RE: Drinking Water Sampling – Union Chapel Elementary
7100 NW Hampton Road, Kansas City, MO 64152
Project Number: 923386

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Union Chapel Elementary in Kansas City, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the "Get the Lead Out of School Drinking Water Act".

METHODOLOGY

On 12/22/2023 Mr. Jay Hurst of OCCU-TEC completed testing of sixty-six (66) sources throughout Union Chapel Elementary. Samples were collected as 'First Draw' samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, one (1) of the sixty-six (66) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
368-UCE-11	Kitchen	Skillet Dish Sprayer	6.7

LIMITATIONS

At the request of PHSD, Lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
All Identified Sources Were Operational		

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.

- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst
Vice President of Operations





Jeff Smith
Senior Project Manager (QA/QC)


ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-01	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 034 (Left Faucet)		
		Result:	1.7	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-02	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 034 (Right Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-03	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 034 (Dish Sprayer)		
		Result:	1.3	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-04	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 027		
		Result:	3.7	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-05	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 028		
		Result:	3.3	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-06	Location:	Kitchen	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		UC Sink 029		
		Result:	1.6	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-07	Location:	Kitchen	
Photo:		Manufacturer:	Powers	
		Description:		
		UC Sink 030 (Dish Sprayer)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-08	Location:	Kitchen	
Photo:		Manufacturer:	Delta	
		Description:		
		UC Sink 032 (Faucet)		
		Result:	1.5	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-09	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 032 (Dish Sprayer)		
		Result:	1.2	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-10	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 033		
		Result:	1.3	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-11	Location:	Kitchen	
Photo:		Manufacturer:	Cleveland	
		Description:		
		UC Skillet 001		
		Result:	6.7	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:		Remove from Service		

ID:	386-UCE-12	Location:	Kitchen Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 031		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-13	Location:	Cafeteria	
Photo:		Manufacturer:	Scotsman	
		Description:		
		UC Ice 001		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-14	Location:	Cafeteria	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		UC DF 002 Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-15	Location:	Cafeteria	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		UC DF 002 Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-16	Location:	Copy / Mail Room	
Photo:		Manufacturer:	Unknown	
		Description:		
		No QR Code - Sink		
		Result:	<1.0	ppb
Date Sampled:		12/22/2023	By:	JH
Recommended Action:				


ID:	386-UCE-17	Location:	Health Room	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		UC Sink 025		
		Result:	<1.0	ppb
Date Sampled:		12/22/2023	By:	JH
Recommended Action:				

ID:	386-UCE-18	Location:	Health Restroom	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 026		
		Result:	<1.0	ppb
Date Sampled:		12/22/2023	By:	JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-19	Location:	Restroom By Pod 1	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 024		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-20	Location:	Hall By 51	
Photo:		Manufacturer:	Elkay	
		Description:		
		UC DF 006		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-21	Location:	Outside Girls RR By 52	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 017		
		Result:	4.9	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-22	Location:	Girls RR By 52	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 018 (Left Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-23	Location:	Girls RR By 52	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 018 (Center Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-24	Location:	Girls RR By 52	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 018 (Right Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-25	Location:	Outside Boys RR	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 015		
		Result:	2.8	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-26	Location:	Boys RR By 57	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 016 (Left Faucet)		
		Result:	2.2	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-27	Location:	Boys RR By 57	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 016 (Center Faucet)		
		Result:	1.6	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-28	Location:	Boys RR By 57	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 016 (Right Faucet)		
		Result:	1.2	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-29	Location:	Hall By 57	
Photo:		Manufacturer:	Elkay	
		Description:		
		UC DF 005		
		Result:	1.5	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-30	Location:	Room 36	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 013		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-31	Location:	Room 36 Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 014		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-32	Location:	Room 35	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 011		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-33	Location:	Room 35 Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 012		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-34	Location:	Room 31	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 009		
		Result:	1.8	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-35	Location:	Hall By KA	
Photo:		Manufacturer:	Murdock	
		Description:		
		UC DF 004 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-36	Location:	Hall By KA	
Photo:		Manufacturer:	Murdock	
		Description:		
		UC DF 004 Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-37	Location:	KA	
Photo:		Manufacturer:	Central	
		Description:		
		UC Sink 004		
		Result:	1.6	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-38	Location:	KA Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 005		
		Result:	1.6	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-39	Location:	Girls RR By KA	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 003 (Left Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-40	Location:	Girls RR By KA	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 003 (Center Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-41	Location:	Girls RR By KA	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 003 (Right Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-42	Location:	Boys RR By KB	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 002 (Left Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-43	Location:	Boys RR By KB	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 002 (Center Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-44	Location:	Boys RR By KB	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 002 (Right Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-45	Location:	KB	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 007 - Drinking Fountain Bubbler		
		Result:	1.2	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-46	Location:	KB	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 007 - Faucet		
		Result:	4	ppb
Date Sampled:		12/22/2023	By:	JH
Recommended Action:				


ID:	386-UCE-47	Location:	KB Restroom	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 006		
		Result:	2.7	ppb
Date Sampled:		12/22/2023	By:	JH
Recommended Action:				

ID:	386-UCE-48	Location:	Gym Vestibule	
Photo:		Manufacturer:	Elkay	
		Description:		
		UC DF 001		
		Result:	<1.0	ppb
Date Sampled:		12/22/2023	By:	JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-49	Location:	Staff Restroom By Gym	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 001		
		Result:	1.2	ppb
Date Sampled:		12/22/2023	By:	JH
Recommended Action:				


ID:	386-UCE-50	Location:	Room 14	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 008		
		Result:	2.7	ppb
Date Sampled:		12/22/2023	By:	JH
Recommended Action:				

ID:	386-UCE-51	Location:	Hall By 11	
Photo:		Manufacturer:	Murdock	
		Description:		
		UC DF 003 Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Date Sampled:		12/22/2023	By:	JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-52	Location:	Hall By 11	
Photo:		Manufacturer:	Murdock	
		Description:		
		UC DF 003 Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-53	Location:	Room 21	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 010		
		Result:	4.9	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-54	Location:	Library Private Reading	
Photo:		Manufacturer:	Unknown	
		Description:		
		No QR Code - Sink		
		Result:	3.4	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-55	Location:	Outside Boys RR By 45	
Photo:		Manufacturer:	Unknown	
		Description:		
		UC Sink 020		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-56	Location:	Boys RR By 45	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 021 (Left Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-57	Location:	Boys RR By 45	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 021 (Center Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-58	Location:	Boys RR By 45	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 021 (Right Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-59	Location:	Outside Boys RR By 45	
Photo:		Manufacturer:	Elkay	
		Description:		
		UC DF 007		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-60	Location:	Outside Girls RR By 42	
Photo:		Manufacturer:	Elkay	
		Description:		
		UC DF 009 Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District


ID:	386-UCE-61	Location:	Outside Girls RR By 42	
Photo:		Manufacturer:	Elkay	
		Description:		
		UC DF 008 Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				


ID:	386-UCE-62	Location:	Girls RR By 42	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 019 (Left Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-63	Location:	Girls RR By 42	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 019 (Center Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

Drinking Water Assessment
Union Chapel Elementary School
Park Hill School District

ID:	386-UCE-64	Location:	Girls RR By 42	
Photo:		Manufacturer:	Sloan	
		Description:		
		UC Sink 019 (Right Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-65	Location:	Art	
Photo:		Manufacturer:	Delta	
		Description:		
		UC Sink 022		
		Result:	1.5	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				

ID:	386-UCE-66	Location:	Art	
Photo:		Manufacturer:	Delta	
		Description:		
		UC Sink 023		
		Result:	1.9	ppb
		Date Sampled:	12/22/2023	By: JH
Recommended Action:				



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

January 18, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: Drinking Water Lead 923386 Union Chapel Elementary School

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **66** sample(s) the laboratory received on **12/27/23 9:10 am** and logged in under work order **GL04343**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order GL04343

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

Case Narrative

The drinking water lead analysis was performed at Pace-Ormond Beach, FL. Please refer to the subcontract section of the report for details.



ANALYTICAL RESULTS

Sample: GL04343-01
Name: 386-UCE-001
Matrix: Drinking Water - Grab

Sampled: 12/22/23 07:57
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.7	ug/L		12/22/23 07:57	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-02
Name: 386-UCE-002
Matrix: Drinking Water - Grab

Sampled: 12/22/23 07:58
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 07:58	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-03
Name: 386-UCE-003
Matrix: Drinking Water - Grab

Sampled: 12/22/23 07:58
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.3	ug/L		12/22/23 07:58	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-04
Name: 386-UCE-004
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:03
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	3.7	ug/L		12/22/23 08:03	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-05
Name: 386-UCE-005
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:04
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	3.3	ug/L		12/22/23 08:04	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-06
Name: 386-UCE-006
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:05
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.6	ug/L		12/22/23 08:05	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-07
Name: 386-UCE-007
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:07
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:07	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-08
Name: 386-UCE-008
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:08
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.5	ug/L		12/22/23 08:08	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-09
Name: 386-UCE-009
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:08
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.2	ug/L		12/22/23 08:08	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-10
Name: 386-UCE-010
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:10
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.3	ug/L		12/22/23 08:10	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-11
Name: 386-UCE-011
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:11
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	6.7	ug/L		12/22/23 08:11	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-12
Name: 386-UCE-012
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:13
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:13	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-13
Name: 386-UCE-013
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:15
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:15	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-14
Name: 386-UCE-014
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:17
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:17	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-15
Name: 386-UCE-015
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:17
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:17	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-16
Name: 386-UCE-016
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:23
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:23	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-17
Name: 386-UCE-017
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:25
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:25	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-18
Name: 386-UCE-018
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:25
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:25	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-19
Name: 386-UCE-019
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:27
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:27	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-20
Name: 386-UCE-020
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:29
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:29	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-21
Name: 386-UCF-021
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:30
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	4.9	ug/L		12/22/23 08:30	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-22
Name: 386-UCF-022
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:32
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:32	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-23
Name: 386-UCF-023
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:32
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:32	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-24
Name: 386-UCF-024
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:32
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:32	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-25
Name: 386-UCE-025
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:34
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.8	ug/L		12/22/23 08:34	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-26
Name: 386-UCE-026
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:36
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.2	ug/L		12/22/23 08:36	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-27
Name: 386-UCE-027
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:36
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.6	ug/L		12/22/23 08:36	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-28
Name: 386-UCE-028
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:36
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.2	ug/L		12/22/23 08:36	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-29
Name: 386-UCE-029
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:38
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.5	ug/L		12/22/23 08:38	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-30
Name: 386-UCE-030
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:40
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:40	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-31
Name: 386-UCE-031
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:41
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:41	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-32
Name: 386-UCE-032
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:43
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:43	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-33
Name: 386-UCE-033
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:44
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:44	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-34
Name: 386-UCE-034
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:48
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.8	ug/L		12/22/23 08:48	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-35
Name: 386-UCE-035
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:49
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:49	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-36
Name: 386-UCE-036
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:50
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:50	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-37
Name: 386-UCE-037
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:52
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.6	ug/L		12/22/23 08:52	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-38
Name: 386-UCE-038
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:54
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.6	ug/L		12/22/23 08:54	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-39
Name: 386-UCE-039
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:56
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:56	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-40
Name: 386-UCE-040
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:56
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:56	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-41
Name: 386-UCE-041
Matrix: Drinking Water - Grab

Sampled: 12/22/23 08:56
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 08:56	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-42
Name: 386-UCE-042
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:00
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:00	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-43
Name: 386-UCE-043
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:00
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:00	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-44
Name: 386-UCE-044
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:00
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:00	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-45
Name: 386-UCE-045
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:02
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.2	ug/L		12/22/23 09:02	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-46
Name: 386-UCE-046
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:02
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	4.0	ug/L		12/22/23 09:02	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-47
Name: 386-UCE-047
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:04
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.7	ug/L		12/22/23 09:04	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-48
Name: 386-UCE-048
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:05
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:05	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-49
Name: 386-UCE-049
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:06
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.2	ug/L		12/22/23 09:06	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-50
Name: 386-UCE-050
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:07
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.7	ug/L		12/22/23 09:07	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-51
Name: 386-UCE-051
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:09
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:09	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-52
Name: 386-UCE-052
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:09
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:09	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-53
Name: 386-UCE-053
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:12
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	4.9	ug/L		12/22/23 09:12	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-54
Name: 386-UCE-054
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:13
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	3.4	ug/L		12/22/23 09:13	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-55
Name: 386-UCE-055
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:16
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:16	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-56
Name: 386-UCE-056
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:18
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:18	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-57
Name: 386-UCE-057
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:18
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:18	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-58
Name: 386-UCE-058
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:18
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:18	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-59
Name: 386-UCE-059
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:21
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:21	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-60
Name: 386-UCE-060
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:23
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:23	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-61
Name: 386-UCE-061
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:23
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:23	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-62
Name: 386-UCE-062
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:26
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:26	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-63
Name: 386-UCE-063
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:26
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:26	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-64
Name: 386-UCE-064
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:26
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		12/22/23 09:26	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GL04343-65
Name: 386-UCE-065
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:31
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.5	ug/L		12/22/23 09:31	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GL04343-66
Name: 386-UCE-066
Matrix: Drinking Water - Grab

Sampled: 12/22/23 09:32
Received: 12/27/23 09:10
PO #: UC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.9	ug/L		12/22/23 09:32	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager



January 08, 2024

Chenise Lambert-Sykes
Pace Analytical Services, Inc - IL/MO
944 Anglum Road
Hazelwood, MO 63042

RE: Project: GL04343
Pace Project No.: 35851676

Dear Chenise Lambert-Sykes:

Enclosed are the analytical results for sample(s) received by the laboratory on January 04, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Ormond Beach

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Brad Smith
brad.smith@pacelabs.com
(386) 672-5668
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: GL04343

Pace Project No.: 35851676

Pace Analytical Services Ormond Beach

8 East Tower Circle, Ormond Beach, FL 32174

Alaska DEC- CS/UST/LUST

Alabama Certification #: 41320

California Certification# 3096

Colorado Certification: FL NELAC Reciprocity

Connecticut Certification #: PH-0216

Delaware Certification: FL NELAC Reciprocity

DoD-ANAB #:ADE-3199

Florida Certification #: E83079

Georgia Certification #: 955

Guam Certification: FL NELAC Reciprocity

Hawaii Certification: FL NELAC Reciprocity

Illinois Certification #: 200068

Indiana Certification: FL NELAC Reciprocity

Kansas Certification #: E-10383

Kentucky Certification #: 90050

Louisiana Certification #: FL NELAC Reciprocity

Louisiana Environmental Certificate #: 05007

Maine Certification #: FL01264

Maryland Certification: #346

Massachusetts Certification #: M-FL1264

Michigan Certification #: 9911

Mississippi Certification: FL NELAC Reciprocity

Missouri Certification #: 236

Montana Certification #: Cert 0074

Nebraska Certification: NE-OS-28-14

New Hampshire Certification #: 2958

New Jersey Certification #: FL022

New York Certification #: 11608

North Carolina Environmental Certificate #: 667

North Carolina Certification #: 12710

North Dakota Certification #: R-216

Ohio DEP 87780

Oklahoma Certification #: D9947

Pennsylvania Certification #: 68-00547

Puerto Rico Certification #: FL01264

South Carolina Certification: #96042001

Tennessee Certification #: TN02974

Texas Certification: FL NELAC Reciprocity

US Virgin Islands Certification: FL NELAC Reciprocity

Virginia Environmental Certification #: 460165

West Virginia Certification #: 9962C

Wisconsin Certification #: 399079670

Wyoming (EPA Region 8): FL NELAC Reciprocity

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: GL04343
Pace Project No.: 35851676

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
35851676001	GL04343-01	EPA 200.8	EAP	1	PASI-O
35851676002	GL04343-02	EPA 200.8	EAP	1	PASI-O
35851676003	GL04343-03	EPA 200.8	EAP	1	PASI-O
35851676004	GL04343-04	EPA 200.8	EAP	1	PASI-O
35851676005	GL04343-05	EPA 200.8	EAP	1	PASI-O
35851676006	GL04343-06	EPA 200.8	EAP	1	PASI-O
35851676007	GL04343-07	EPA 200.8	EAP	1	PASI-O
35851676008	GL04343-08	EPA 200.8	EAP	1	PASI-O
35851676009	GL04343-09	EPA 200.8	EAP	1	PASI-O
35851676010	GL04343-10	EPA 200.8	EAP	1	PASI-O
35851676011	GL04343-11	EPA 200.8	EAP	1	PASI-O
35851676012	GL04343-12	EPA 200.8	EAP	1	PASI-O
35851676013	GL04343-13	EPA 200.8	EAP	1	PASI-O
35851676014	GL04343-14	EPA 200.8	EAP	1	PASI-O
35851676015	GL04343-15	EPA 200.8	EAP	1	PASI-O
35851676016	GL04343-16	EPA 200.8	EAP	1	PASI-O
35851676017	GL04343-17	EPA 200.8	EAP	1	PASI-O
35851676018	GL04343-18	EPA 200.8	EAP	1	PASI-O
35851676019	GL04343-19	EPA 200.8	EAP	1	PASI-O
35851676020	GL04343-20	EPA 200.8	EAP	1	PASI-O
35851676021	GL04343-21	EPA 200.8	EAP	1	PASI-O
35851676022	GL04343-22	EPA 200.8	EAP	1	PASI-O
35851676023	GL04343-23	EPA 200.8	EAP	1	PASI-O
35851676024	GL04343-24	EPA 200.8	EAP	1	PASI-O
35851676025	GL04343-25	EPA 200.8	EAP	1	PASI-O
35851676026	GL04343-26	EPA 200.8	EAP	1	PASI-O
35851676027	GL04343-27	EPA 200.8	EAP	1	PASI-O
35851676028	GL04343-28	EPA 200.8	EAP	1	PASI-O
35851676029	GL04343-29	EPA 200.8	EAP	1	PASI-O
35851676030	GL04343-30	EPA 200.8	EAP	1	PASI-O
35851676031	GL04343-31	EPA 200.8	EAP	1	PASI-O
35851676032	GL04343-32	EPA 200.8	EAP	1	PASI-O
35851676033	GL04343-33	EPA 200.8	EAP	1	PASI-O
35851676034	GL04343-34	EPA 200.8	EAP	1	PASI-O
35851676035	GL04343-35	EPA 200.8	EAP	1	PASI-O
35851676036	GL04343-36	EPA 200.8	EAP	1	PASI-O
35851676037	GL04343-37	EPA 200.8	EAP	1	PASI-O

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: GL04343
Pace Project No.: 35851676

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
35851676038	GL04343-38	EPA 200.8	EAP	1	PASI-O
35851676039	GL04343-39	EPA 200.8	EAP	1	PASI-O
35851676040	GL04343-40	EPA 200.8	EAP	1	PASI-O
35851676041	GL04343-41	EPA 200.8	EAP	1	PASI-O
35851676042	GL04343-42	EPA 200.8	EAP	1	PASI-O
35851676043	GL04343-43	EPA 200.8	EAP	1	PASI-O
35851676044	GL04343-44	EPA 200.8	EAP	1	PASI-O
35851676045	GL04343-45	EPA 200.8	EAP	1	PASI-O
35851676046	GL04343-46	EPA 200.8	EAP	1	PASI-O
35851676047	GL04343-47	EPA 200.8	EAP	1	PASI-O
35851676048	GL04343-48	EPA 200.8	EAP	1	PASI-O
35851676049	GL04343-49	EPA 200.8	EAP	1	PASI-O
35851676050	GL04343-50	EPA 200.8	EAP	1	PASI-O
35851676051	GL04343-51	EPA 200.8	EAP	1	PASI-O
35851676052	GL04343-52	EPA 200.8	EAP	1	PASI-O
35851676053	GL04343-53	EPA 200.8	EAP	1	PASI-O
35851676054	GL04343-54	EPA 200.8	EAP	1	PASI-O
35851676055	GL04343-55	EPA 200.8	EAP	1	PASI-O
35851676056	GL04343-56	EPA 200.8	EAP	1	PASI-O
35851676057	GL04343-57	EPA 200.8	EAP	1	PASI-O
35851676058	GL04343-58	EPA 200.8	EAP	1	PASI-O
35851676059	GL04343-59	EPA 200.8	EAP	1	PASI-O
35851676060	GL04343-60	EPA 200.8	EAP	1	PASI-O
35851676061	GL04343-61	EPA 200.8	EAP	1	PASI-O
35851676062	GL04343-62	EPA 200.8	EAP	1	PASI-O
35851676063	GL04343-63	EPA 200.8	EAP	1	PASI-O
35851676064	GL04343-64	EPA 200.8	EAP	1	PASI-O
35851676065	GL04343-65	EPA 200.8	EAP	1	PASI-O
35851676066	GL04343-66	EPA 200.8	EAP	1	PASI-O

PASI-O = Pace Analytical Services - Ormond Beach

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-01		Lab ID: 35851676001	Collected: 12/22/23 08:57	Received: 01/04/24 10:25	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.7	ug/L	1.0	1		01/06/24 11:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-02		Lab ID: 35851676002		Collected: 12/22/23 08:58		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 11:37	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-03		Lab ID: 35851676003		Collected: 12/22/23 08:58		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	1.3	ug/L	1.0	1		01/06/24 11:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-04		Lab ID: 35851676004		Collected: 12/22/23 09:03		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	3.7	ug/L	1.0	1		01/06/24 11:40	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-05		Lab ID: 35851676005		Collected: 12/22/23 09:04		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	3.3	ug/L	1.0	1		01/06/24 11:41	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-06		Lab ID: 35851676006	Collected: 12/22/23 09:05	Received: 01/04/24 10:25	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.6	ug/L	1.0	1		01/06/24 11:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-07		Lab ID: 35851676007		Collected: 12/22/23 09:07		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 11:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-08		Lab ID: 35851676008		Collected: 12/22/23 09:08		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	1.5	ug/L	1.0	1		01/06/24 11:45	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-09		Lab ID: 35851676009	Collected: 12/22/23 09:08	Received: 01/04/24 10:25	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.2	ug/L	1.0	1		01/06/24 11:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-10		Lab ID: 35851676010		Collected: 12/22/23 09:10		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	1.3	ug/L	1.0	1		01/06/24 11:51	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-11		Lab ID: 35851676011	Collected: 12/22/23 09:11	Received: 01/04/24 10:25	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	6.7	ug/L	1.0	1		01/06/24 11:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-12		Lab ID: 35851676012		Collected: 12/22/23 09:13		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 11:54	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-13		Lab ID: 35851676013		Collected: 12/22/23 09:15		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 11:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-14		Lab ID: 35851676014		Collected: 12/22/23 09:17		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 11:57	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-15		Lab ID: 35851676015		Collected: 12/22/23 09:17		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 11:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-16		Lab ID: 35851676016		Collected: 12/22/23 09:23		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:00	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-17		Lab ID: 35851676017		Collected: 12/22/23 09:25		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-18		Lab ID: 35851676018		Collected: 12/22/23 09:25		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-19		Lab ID: 35851676019		Collected: 12/22/23 09:27		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-20		Lab ID: 35851676020		Collected: 12/22/23 09:29		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:08	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-21		Lab ID: 35851676021	Collected: 12/22/23 09:30	Received: 01/04/24 10:25	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	4.9	ug/L	1.0	1		01/06/24 12:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343

Pace Project No.: 35851676

Sample: GL04343-22		Lab ID: 35851676022		Collected: 12/22/23 09:32		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-23		Lab ID: 35851676023		Collected: 12/22/23 09:32		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:24	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-24		Lab ID: 35851676024		Collected: 12/22/23 09:32		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:25	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-25		Lab ID: 35851676025	Collected: 12/22/23 09:34	Received: 01/04/24 10:25	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	2.8	ug/L	1.0	1		01/06/24 12:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-26		Lab ID: 35851676026		Collected: 12/22/23 09:36		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	2.2	ug/L	1.0	1		01/06/24 12:28	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-27		Lab ID: 35851676027	Collected: 12/22/23 09:36	Received: 01/04/24 10:25	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.6	ug/L	1.0	1		01/06/24 12:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-28		Lab ID: 35851676028		Collected: 12/22/23 09:36		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	1.2	ug/L	1.0	1		01/06/24 12:31	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-29		Lab ID: 35851676029		Collected: 12/22/23 09:38		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.5	ug/L	1.0	1		01/06/24 12:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-30		Lab ID: 35851676030		Collected: 12/22/23 09:40		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:34	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-31		Lab ID: 35851676031		Collected: 12/22/23 09:41		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:35	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-32		Lab ID: 35851676032		Collected: 12/22/23 09:43		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-33		Lab ID: 35851676033		Collected: 12/22/23 09:44		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:41	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-34		Lab ID: 35851676034		Collected: 12/22/23 09:48		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.8	ug/L	1.0	1		01/06/24 12:42	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-35		Lab ID: 35851676035		Collected: 12/22/23 09:49		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-36		Lab ID: 35851676036		Collected: 12/22/23 09:50		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:45	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-37		Lab ID: 35851676037		Collected: 12/22/23 09:52		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	1.6	ug/L	1.0	1		01/06/24 12:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-38		Lab ID: 35851676038		Collected: 12/22/23 09:54		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.6	ug/L	1.0	1		01/06/24 12:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-39		Lab ID: 35851676039		Collected: 12/22/23 09:56		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-40		Lab ID: 35851676040		Collected: 12/22/23 09:56		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 12:51	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-41		Lab ID: 35851676041		Collected: 12/22/23 09:56		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-42		Lab ID: 35851676042		Collected: 12/22/23 10:00		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:05	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-43		Lab ID: 35851676043		Collected: 12/22/23 10:00		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-44		Lab ID: 35851676044		Collected: 12/22/23 10:00		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:08	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-45		Lab ID: 35851676045		Collected: 12/22/23 10:02		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	1.2	ug/L	1.0	1		01/06/24 13:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-46		Lab ID: 35851676046	Collected: 12/22/23 10:02	Received: 01/04/24 10:25	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	4.0	ug/L	1.0	1		01/06/24 13:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-47		Lab ID: 35851676047		Collected: 12/22/23 10:04		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	2.7	ug/L	1.0	1		01/06/24 13:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-48		Lab ID: 35851676048		Collected: 12/22/23 10:05		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:16	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-49		Lab ID: 35851676049		Collected: 12/22/23 10:06		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.2	ug/L	1.0	1		01/06/24 13:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-50		Lab ID: 35851676050		Collected: 12/22/23 10:07		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	2.7	ug/L	1.0	1		01/06/24 13:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-51		Lab ID: 35851676051		Collected: 12/22/23 10:09		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:20	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-52		Lab ID: 35851676052		Collected: 12/22/23 10:09		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:22	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-53		Lab ID: 35851676053		Collected: 12/22/23 10:12		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	4.9	ug/L	1.0	1		01/06/24 13:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-54		Lab ID: 35851676054		Collected: 12/22/23 10:13		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	3.4	ug/L	1.0	1		01/06/24 13:25	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-55		Lab ID: 35851676055		Collected: 12/22/23 10:16		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:26	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-56		Lab ID: 35851676056		Collected: 12/22/23 10:18		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-57		Lab ID: 35851676057		Collected: 12/22/23 10:18		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-58		Lab ID: 35851676058		Collected: 12/22/23 10:18		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-59		Lab ID: 35851676059		Collected: 12/22/23 10:21		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:35	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-60		Lab ID: 35851676060		Collected: 12/22/23 10:23		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-61		Lab ID: 35851676061		Collected: 12/22/23 10:23		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-62		Lab ID: 35851676062		Collected: 12/22/23 10:26		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:50	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-63		Lab ID: 35851676063		Collected: 12/22/23 10:26		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:52	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-64		Lab ID: 35851676064		Collected: 12/22/23 10:26		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		01/06/24 13:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-65		Lab ID: 35851676065		Collected: 12/22/23 10:31		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.5	ug/L	1.0	1		01/06/24 13:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GL04343
Pace Project No.: 35851676

Sample: GL04343-66		Lab ID: 35851676066		Collected: 12/22/23 10:32		Received: 01/04/24 10:25		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.9	ug/L	1.0	1		01/06/24 13:56	7439-92-1		

REPORT OF LABORATORY ANALYSIS



QUALITY CONTROL DATA

Project: GL04343
Pace Project No.: 35851676

QC Batch:	978555	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Ormond Beach
Associated Lab Samples:	35851676001, 35851676002, 35851676003, 35851676004, 35851676005, 35851676006, 35851676007, 35851676008, 35851676009, 35851676010, 35851676011, 35851676012, 35851676013, 35851676014, 35851676015, 35851676016, 35851676017, 35851676018, 35851676019, 35851676020		

METHOD BLANK:	5383391	Matrix:	Water
Associated Lab Samples:	35851676001, 35851676002, 35851676003, 35851676004, 35851676005, 35851676006, 35851676007, 35851676008, 35851676009, 35851676010, 35851676011, 35851676012, 35851676013, 35851676014, 35851676015, 35851676016, 35851676017, 35851676018, 35851676019, 35851676020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	01/06/24 12:12	

LABORATORY CONTROL SAMPLE:	5383392					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5383387			5383388							
Parameter	Units	35851676001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	1.7	50	50	50.1	50.7	97	98	70-130	1	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5383389			5383390							
Parameter	Units	35851676020 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	ND	50	50	49.9	50.1	98	99	70-130	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: GL04343
Pace Project No.: 35851676

QC Batch:	978557	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Ormond Beach
Associated Lab Samples:	35851676021, 35851676022, 35851676023, 35851676024, 35851676025, 35851676026, 35851676027, 35851676028, 35851676029, 35851676030, 35851676031, 35851676032, 35851676033, 35851676034, 35851676035, 35851676036, 35851676037, 35851676038, 35851676039, 35851676040		

METHOD BLANK:	5383402	Matrix:	Water
Associated Lab Samples:	35851676021, 35851676022, 35851676023, 35851676024, 35851676025, 35851676026, 35851676027, 35851676028, 35851676029, 35851676030, 35851676031, 35851676032, 35851676033, 35851676034, 35851676035, 35851676036, 35851676037, 35851676038, 35851676039, 35851676040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	01/06/24 12:58	

LABORATORY CONTROL SAMPLE:	5383403					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.6	93	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5383398			5383399							
Parameter	Units	35851676021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	4.9	50	50	53.9	54.2	98	99	70-130	1	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5383400			5383401							
Parameter	Units	35851676040 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	ND	50	50	48.4	49.3	96	98	70-130	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: GL04343
Pace Project No.: 35851676

QC Batch:	978558	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Ormond Beach
Associated Lab Samples:	35851676041, 35851676042, 35851676043, 35851676044, 35851676045, 35851676046, 35851676047, 35851676048, 35851676049, 35851676050, 35851676051, 35851676052, 35851676053, 35851676054, 35851676055, 35851676056, 35851676057, 35851676058, 35851676059, 35851676060		

METHOD BLANK:	5383415	Matrix:	Water
Associated Lab Samples:	35851676041, 35851676042, 35851676043, 35851676044, 35851676045, 35851676046, 35851676047, 35851676048, 35851676049, 35851676050, 35851676051, 35851676052, 35851676053, 35851676054, 35851676055, 35851676056, 35851676057, 35851676058, 35851676059, 35851676060		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	01/06/24 13:40	

LABORATORY CONTROL SAMPLE:	5383416					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.6	93	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5383411			5383412							
Parameter	Units	35851676041 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	ND	50	50	49.4	49.1	98	98	70-130	1	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5383413			5383414							
Parameter	Units	35851676060 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	ND	50	50	49.5	49.0	98	97	70-130	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: GL04343
Pace Project No.: 35851676

QC Batch: 978589 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Ormond Beach
Associated Lab Samples: 35851676061, 35851676062, 35851676063, 35851676064, 35851676065, 35851676066

METHOD BLANK: 5383704 Matrix: Water
Associated Lab Samples: 35851676061, 35851676062, 35851676063, 35851676064, 35851676065, 35851676066

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	01/06/24 14:26	

LABORATORY CONTROL SAMPLE: 5383705

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.8	94	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 5383700 5383701

Parameter	Units	35851676061 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	ND	50	50	49.6	49.6	98	98	70-130	0	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 5383702 5383703

Parameter	Units	35851679014 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	1.6	50	50	50.5	50.0	98	97	70-130	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: GL04343
Pace Project No.: 35851676

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: GL04343

Pace Project No.: 35851676

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
35851676001	GL04343-01	EPA 200.8	978555		
35851676002	GL04343-02	EPA 200.8	978555		
35851676003	GL04343-03	EPA 200.8	978555		
35851676004	GL04343-04	EPA 200.8	978555		
35851676005	GL04343-05	EPA 200.8	978555		
35851676006	GL04343-06	EPA 200.8	978555		
35851676007	GL04343-07	EPA 200.8	978555		
35851676008	GL04343-08	EPA 200.8	978555		
35851676009	GL04343-09	EPA 200.8	978555		
35851676010	GL04343-10	EPA 200.8	978555		
35851676011	GL04343-11	EPA 200.8	978555		
35851676012	GL04343-12	EPA 200.8	978555		
35851676013	GL04343-13	EPA 200.8	978555		
35851676014	GL04343-14	EPA 200.8	978555		
35851676015	GL04343-15	EPA 200.8	978555		
35851676016	GL04343-16	EPA 200.8	978555		
35851676017	GL04343-17	EPA 200.8	978555		
35851676018	GL04343-18	EPA 200.8	978555		
35851676019	GL04343-19	EPA 200.8	978555		
35851676020	GL04343-20	EPA 200.8	978555		
35851676021	GL04343-21	EPA 200.8	978557		
35851676022	GL04343-22	EPA 200.8	978557		
35851676023	GL04343-23	EPA 200.8	978557		
35851676024	GL04343-24	EPA 200.8	978557		
35851676025	GL04343-25	EPA 200.8	978557		
35851676026	GL04343-26	EPA 200.8	978557		
35851676027	GL04343-27	EPA 200.8	978557		
35851676028	GL04343-28	EPA 200.8	978557		
35851676029	GL04343-29	EPA 200.8	978557		
35851676030	GL04343-30	EPA 200.8	978557		
35851676031	GL04343-31	EPA 200.8	978557		
35851676032	GL04343-32	EPA 200.8	978557		
35851676033	GL04343-33	EPA 200.8	978557		
35851676034	GL04343-34	EPA 200.8	978557		
35851676035	GL04343-35	EPA 200.8	978557		
35851676036	GL04343-36	EPA 200.8	978557		
35851676037	GL04343-37	EPA 200.8	978557		
35851676038	GL04343-38	EPA 200.8	978557		
35851676039	GL04343-39	EPA 200.8	978557		
35851676040	GL04343-40	EPA 200.8	978557		
35851676041	GL04343-41	EPA 200.8	978558		
35851676042	GL04343-42	EPA 200.8	978558		
35851676043	GL04343-43	EPA 200.8	978558		
35851676044	GL04343-44	EPA 200.8	978558		
35851676045	GL04343-45	EPA 200.8	978558		
35851676046	GL04343-46	EPA 200.8	978558		
35851676047	GL04343-47	EPA 200.8	978558		
35851676048	GL04343-48	EPA 200.8	978558		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: GL04343
Pace Project No.: 35851676

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
35851676049	GL04343-49	EPA 200.8	978558		
35851676050	GL04343-50	EPA 200.8	978558		
35851676051	GL04343-51	EPA 200.8	978558		
35851676052	GL04343-52	EPA 200.8	978558		
35851676053	GL04343-53	EPA 200.8	978558		
35851676054	GL04343-54	EPA 200.8	978558		
35851676055	GL04343-55	EPA 200.8	978558		
35851676056	GL04343-56	EPA 200.8	978558		
35851676057	GL04343-57	EPA 200.8	978558		
35851676058	GL04343-58	EPA 200.8	978558		
35851676059	GL04343-59	EPA 200.8	978558		
35851676060	GL04343-60	EPA 200.8	978558		
35851676061	GL04343-61	EPA 200.8	978589		
35851676062	GL04343-62	EPA 200.8	978589		
35851676063	GL04343-63	EPA 200.8	978589		
35851676064	GL04343-64	EPA 200.8	978589		
35851676065	GL04343-65	EPA 200.8	978589		
35851676066	GL04343-66	EPA 200.8	978589		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

WO# : 35851676



35851676

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-01
Name: 386-UCE-001

Sampled: 12/22/23 07:57
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 07:57	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 07:57	

Sample: GL04343-02
Name: 386-UCE-002

Sampled: 12/22/23 07:58
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 07:58	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 07:58	

Sample: GL04343-03
Name: 386-UCE-003

Sampled: 12/22/23 07:58
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 07:58	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 07:58	

Sample: GL04343-04
Name: 386-UCE-004

Sampled: 12/22/23 08:03
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:03	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:03	

**SUBCONTRACT ORDER
Transfer Chain of Custody**

Pace Analytical Services, LLC

GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-05
Name: 386-UCE-005

Sampled: 12/22/23 08:04
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
-----------------	------------	----------------	-----------------

01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:04	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:04	

Sample: GL04343-06
Name: 386-UCE-006

Sampled: 12/22/23 08:05
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
-----------------	------------	----------------	-----------------

01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:05	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:05	

Sample: GL04343-07
Name: 386-UCE-007

Sampled: 12/22/23 08:07
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
-----------------	------------	----------------	-----------------

01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:07	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:07	

Sample: GL04343-08
Name: 386-UCE-008

Sampled: 12/22/23 08:08
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
-----------------	------------	----------------	-----------------

01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:08	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:08	

**SUBCONTRACT ORDER
Transfer Chain of Custody**

Pace Analytical Services, LLC

GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-09
Name: 386-UCE-009

Sampled: 12/22/23 08:08
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:08	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:08	

Sample: GL04343-10
Name: 386-UCE-010

Sampled: 12/22/23 08:10
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:10	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:10	

Sample: GL04343-11
Name: 386-UCE-011

Sampled: 12/22/23 08:11
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:11	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:11	

Sample: GL04343-12
Name: 386-UCE-012

Sampled: 12/22/23 08:13
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:13	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:13	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-13
Name: 386-UCE-013

Sampled: 12/22/23 08:15
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:15	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:15	

Sample: GL04343-14
Name: 386-UCE-014

Sampled: 12/22/23 08:17
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:17	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:17	

Sample: GL04343-15
Name: 386-UCE-015

Sampled: 12/22/23 08:17
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:17	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:17	

Sample: GL04343-16
Name: 386-UCE-016

Sampled: 12/22/23 08:23
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:23	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:23	

**SUBCONTRACT ORDER
Transfer Chain of Custody**

Pace Analytical Services, LLC

GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-17
Name: 386-UCE-017

Sampled: 12/22/23 08:25
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:25	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:25	

Sample: GL04343-18
Name: 386-UCE-018

Sampled: 12/22/23 08:25
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:25	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:25	

Sample: GL04343-19
Name: 386-UCE-019

Sampled: 12/22/23 08:27
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:27	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:27	

Sample: GL04343-20
Name: 386-UCE-020

Sampled: 12/22/23 08:29
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:29	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:29	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-21
Name: 386-UCE-021

Sampled: 12/22/23 08:30
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:30	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:30	

Sample: GL04343-22
Name: 386-UCE-022

Sampled: 12/22/23 08:32
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:32	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:32	

Sample: GL04343-23
Name: 386-UCE-023

Sampled: 12/22/23 08:32
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:32	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:32	

Sample: GL04343-24
Name: 386-UCE-024

Sampled: 12/22/23 08:32
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:32	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:32	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-25
Name: 386-UCE-025

Sampled: 12/22/23 08:34
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:34	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:34	

Sample: GL04343-26
Name: 386-UCE-026

Sampled: 12/22/23 08:36
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:36	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:36	

Sample: GL04343-27
Name: 386-UCE-027

Sampled: 12/22/23 08:36
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:36	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:36	

Sample: GL04343-28
Name: 386-UCE-028

Sampled: 12/22/23 08:36
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:36	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:36	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-29
Name: 386-UCE-029

Sampled: 12/22/23 08:38
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:38	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:38	

Sample: GL04343-30
Name: 386-UCE-030

Sampled: 12/22/23 08:40
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:40	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:40	

Sample: GL04343-31
Name: 386-UCE-031

Sampled: 12/22/23 08:41
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:41	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:41	

Sample: GL04343-32
Name: 386-UCE-032

Sampled: 12/22/23 08:43
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:43	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:43	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-33
Name: 386-UCE-033

Sampled: 12/22/23 08:44
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:44	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:44	

Sample: GL04343-34
Name: 386-UCE-034

Sampled: 12/22/23 08:48
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:48	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:48	

Sample: GL04343-35
Name: 386-UCE-035

Sampled: 12/22/23 08:49
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:49	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:49	

Sample: GL04343-36
Name: 386-UCE-036

Sampled: 12/22/23 08:50
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:50	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:50	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-37
Name: 386-UCE-037

Sampled: 12/22/23 08:52
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:52	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:52	

Sample: GL04343-38
Name: 386-UCE-038

Sampled: 12/22/23 08:54
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:54	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:54	

Sample: GL04343-39
Name: 386-UCE-039

Sampled: 12/22/23 08:56
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:56	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:56	

Sample: GL04343-40
Name: 386-UCE-040

Sampled: 12/22/23 08:56
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:56	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:56	

SUBCONTRACT ORDER
Transfer Chain of Custody

Pace Analytical Services, LLC

GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-41
Name: 386-UCE-041

Sampled: 12/22/23 08:56
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:56	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 08:56	

Sample: GL04343-42
Name: 386-UCE-042

Sampled: 12/22/23 09:00
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:00	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:00	

Sample: GL04343-43
Name: 386-UCE-043

Sampled: 12/22/23 09:00
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:00	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:00	

Sample: GL04343-44
Name: 386-UCE-044

Sampled: 12/22/23 09:00
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:00	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:00	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-45
Name: 386-UCE-045

Sampled: 12/22/23 09:02
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:02	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:02	

Sample: GL04343-46
Name: 386-UCE-046

Sampled: 12/22/23 09:02
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:02	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:02	

Sample: GL04343-47
Name: 386-UCE-047

Sampled: 12/22/23 09:04
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:04	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:04	

Sample: GL04343-48
Name: 386-UCE-048

Sampled: 12/22/23 09:05
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:05	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:05	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-49
Name: 386-UCE-049

Sampled: 12/22/23 09:06
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:06	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:06	

Sample: GL04343-50
Name: 386-UCE-050

Sampled: 12/22/23 09:07
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:07	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:07	

Sample: GL04343-51
Name: 386-UCE-051

Sampled: 12/22/23 09:09
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:09	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:09	

Sample: GL04343-52
Name: 386-UCE-052

Sampled: 12/22/23 09:09
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:09	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:09	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-53
Name: 386-UCE-053

Sampled: 12/22/23 09:12
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:12	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:12	

Sample: GL04343-54
Name: 386-UCE-054

Sampled: 12/22/23 09:13
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:13	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:13	

Sample: GL04343-55
Name: 386-UCE-055

Sampled: 12/22/23 09:16
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:16	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:16	

Sample: GL04343-56
Name: 386-UCE-056

Sampled: 12/22/23 09:18
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:18	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:18	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-57
Name: 386-UCE-057

Sampled: 12/22/23 09:18
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:18	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:18	

Sample: GL04343-58
Name: 386-UCE-058

Sampled: 12/22/23 09:18
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:18	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:18	

Sample: GL04343-59
Name: 386-UCE-059

Sampled: 12/22/23 09:21
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:21	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:21	

Sample: GL04343-60
Name: 386-UCE-060

Sampled: 12/22/23 09:23
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:23	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:23	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-61
Name: 386-UCE-061

Sampled: 12/22/23 09:23
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:23	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:23	

Sample: GL04343-62
Name: 386-UCE-062

Sampled: 12/22/23 09:26
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:26	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:26	

Sample: GL04343-63
Name: 386-UCE-063

Sampled: 12/22/23 09:26
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:26	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:26	

Sample: GL04343-64
Name: 386-UCE-064

Sampled: 12/22/23 09:26
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:26	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:26	

**SUBCONTRACT ORDER
Transfer Chain of Custody**

Pace Analytical Services, LLC

GL04343

SENDING LABORATORY

PDC Laboratories, Inc.
2231 W Altorfer Dr
Peoria, IL 61615
(800) 752-6651

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GL04343-65
Name: 386-UCE-065

Sampled: 12/22/23 09:31
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:31	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:31	

Sample: GL04343-66
Name: 386-UCE-066

Sampled: 12/22/23 09:32
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:32	
01-Pb 200.8 DW Schools	01/09/24 16:00	06/19/24 09:32	

Please email results to Chenise Lambert-Sykes at Chenise.Lambert-Sykes@pacelabs.com

Date Shipped: 1/3/24 Total # of Containers: 66 Sample Origin (State): _____ PO #: _____
Turn-Around Time Requested ☒ NORMAL ☒ RUSH Date Results Needed: 1/8/24

1023		Sample Temperature Upon Receipt _____ °C	
Relinquished By <u>[Signature]</u>	Date/Time <u>1/3/24</u>	Received By <u>Nora</u>	Date/Time <u>1-4-24 1025</u>
		Sample(s) Received on Ice Y or N	
		Proper Bottles Received in Good Condition Y or N	
		Bottles Filled with Adequate Volume Y or N	
		Samples Received Within Hold Time Y or N	
Relinquished By	Date/Time	Received By	Date/Time
			Date/Time Taken From Sample Bottle Y or N

Sample Condition Upon Receipt Form (SCUR)

WO#: 35851676

PM: BTS

Due Date: 01/11/24

CLIENT: PACHAZ

Pace

Project #
Project Manager:
Client:

Date and Initials of person:

Examining contents:

Label:

Deliver:

pH:

Initials:

Thermometer Used:

Date:

Time:

State of Origin:

☐ For WV projects, all containers verified to $\pm 5^{\circ}\text{C}$

Cooler #1 Temp. $^{\circ}\text{C}$ 13.7 (Visual)

-0.1

(Correction Factor)

13.6

(Actual)

Cooler #2 Temp. $^{\circ}\text{C}$ 13.5 (Visual)

(Correction Factor)

13.4

(Actual)

Cooler #3 Temp. $^{\circ}\text{C}$ 14.8 (Visual)

(Correction Factor)

14.7

(Actual)

Cooler #4 Temp. $^{\circ}\text{C}$ 15.3 (Visual)

(Correction Factor)

15.2

(Actual)

Cooler #5 Temp. $^{\circ}\text{C}$ 16.0 (Visual)

(Correction Factor)

15.9

(Actual)

Cooler #6 Temp. $^{\circ}\text{C}$ 15.7 (Visual)

(Correction Factor)

15.6

(Actual)

Recheck for OOT $^{\circ}\text{C}$ 14.4 (Visual)

(Correction Factor)

14.3

(Actual)

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

Time: Initials:

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Shipping Method: ☐ Standard Overnight ☐ First Overnight ☐ Priority Overnight ☐ Ground ☐ International Priority

Billing: ☐ Recipient ☒ Sender ☐ Third Party ☐ Credit Card ☐ Unknown

Tracking # 700378110010 / 700378110020

Custody Seal Present: ☐ Yes ☐ No Seal properly placed and intact: ☐ Yes ☐ No

Packing Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other:

Ice: ☐ Wet ☐ Blue ☐ Dry ☒ None ☐ Melted

Samples shorted to lab: ☐ Yes ☐ No (If yes, complete the following)

Shorted Date:

Bottle Quantity / Type:

Shorted Time:

Chain of Custody:	Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Sampler Name: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A
	Relinquished To Pace: <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Sampling Date(s): <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Sampling Time(s): <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Samples Arrived within Hold Time.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Rush Turnaround Requested on COC.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Sufficient Volume.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments: 1/8/24
Correct Containers Used.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Containers Intact.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Sample Labels Match COC (Sample ID, Date/Time of Collection).	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
If containers needing acid / base preservation have been checked.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
containers needing preservation are found to be in compliance with A recommendation:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Exceptions: Vials, Microbiology, O&G, PFAS	
adspace in Volatile Vials? (>6mm):	
Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
ments / Resolutions (use back for additional comments):	

Preservative:

Date:

Lot / Trace:

Time:

Amount added (mL):

Initials:



Sample Condition Upon Receipt Form (SCUR)

Date and Initials of person: _____

Examining contents: _____

Label: _____

Deliver: Not

pH: _____

Initials: ZAB

Project # _____

Project Manager: _____

Client: _____

1025

Thermometer Used: T-409

Date: 11/4/24

Time: 1027

State of Origin: _____

☐ For WV projects, all containers verified to $\pm 6^{\circ}\text{C}$

Cooler #1 Temp. $^{\circ}\text{C}$ 14.9 (Visual) 0.1 (Correction Factor) 14.8 (Actual)

Cooler #2 Temp. $^{\circ}\text{C}$ 15.9 (Visual) _____ (Correction Factor) 15.8 (Actual)

Cooler #3 Temp. $^{\circ}\text{C}$ 13.7 (Visual) _____ (Correction Factor) 13.6 (Actual)

Cooler #4 Temp. $^{\circ}\text{C}$ 14.2 (Visual) _____ (Correction Factor) 14.1 (Actual)

Cooler #5 Temp. $^{\circ}\text{C}$ 14.8 (Visual) _____ (Correction Factor) 14.7 (Actual)

Cooler #6 Temp. $^{\circ}\text{C}$ 15.1 (Visual) _____ (Correction Factor) 15.0 (Actual)

Recheck for OOT $^{\circ}\text{C}$ 16.2 (Visual) _____ (Correction Factor) 16.1 (Actual)

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

Time: _____ Initials: _____

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other: _____

Shipping Method: ☐ Standard Overnight ☐ First Overnight ☐ Priority Overnight ☐ Ground ☐ International Priority ☐ Other: _____

Billing: ☐ Recipient ☐ Sender ☐ Third Party ☐ Credit Card ☐ Unknown

Tracking # _____

Custody Seal Present: ☒ Yes ☐ No Seal properly placed and intact: ☐ Yes ☐ No

Ice: ☐ Wet ☐ Blue ☐ Dry ☐ None ☐ Melted

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other: _____

Samples shorted to lab: ☐ Yes ☐ No (If yes, complete the following)

Shorted Date: _____

Shorted Time: _____

Bottle Quantity / Type: _____

Chain of Custody:

Present: ☐ Yes ☐ No | Filled Out: ☐ Yes ☐ No ☐ N/A | Sampler Name: ☐ Yes ☐ No ☐ N/A

Relinquished To Pace: ☐ Yes ☐ No ☐ N/A | Sampling Date(s): ☐ Yes ☐ No ☐ N/A | Sampling Time(s): ☐ Yes ☐ No ☐ N/A

Samples Arrived within Hold Time. ☐ Yes ☐ No ☐ N/A

Comments: _____

Rush Turnaround Requested on COC. ☐ Yes ☐ No ☐ N/A

Comments: _____

Sufficient Volume. ☐ Yes ☐ No ☐ N/A

Comments: _____

Correct Containers Used. ☐ Yes ☐ No ☐ N/A

Comments: _____

Containers Intact. ☐ Yes ☐ No ☐ N/A

Comments: _____

Sample Labels Match COC (Sample ID, Date/Time of Collection). ☐ Yes ☐ No ☐ N/A

Comments: _____

All containers needing acid / base preservation have been checked. ☐ Yes ☐ No ☐ N/A

Preservation Information

Preservative: _____

Date: _____

Lot / Trace: _____

Time: _____

Amount added (mL): _____

Initials: _____

All containers needing preservation are found to be in compliance with EPA recommendation: ☐ Yes ☐ No ☐ N/A

Exceptions: Vials, Microbiology, O&G, PFAS

Headspace in Volatile Vials? (>6mm): ☐ Yes ☐ No ☐ N/A

Trip Blank Present: ☐ Yes ☐ No ☐ N/A

Comments / Resolutions (use back for additional comments):

SCUR continued



Sample Condition Upon Receipt Form (SCUR)

WO#: 35851676

PM: BTS

Due Date: 01/11/24

CLIENT: PACHAZ

Project #

Project Manager:

Client:

Date and Initials of person:

Examining contents:

Label:

Deliver:

pH:

Initials:

Thermometer Used: T-409

Date: 1/4/24

Time: 1027

State of Origin:

☐ For WV projects, all containers verified to $\leq 6^{\circ}\text{C}$

Cooler #1 Temp. $^{\circ}\text{C}$ 16.4 (Visual) -0.1 (Correction Factor) 16.3 (Actual)

Cooler #2 Temp. $^{\circ}\text{C}$ 17.2 (Visual) (Correction Factor) 17.1 (Actual)

Cooler #3 Temp. $^{\circ}\text{C}$ 15.6 (Visual) (Correction Factor) 15.5 (Actual)

Cooler #4 Temp. $^{\circ}\text{C}$ 14.5 (Visual) (Correction Factor) 14.4 (Actual)

Cooler #5 Temp. $^{\circ}\text{C}$ 15.8 (Visual) (Correction Factor) 15.7 (Actual)

Cooler #6 Temp. $^{\circ}\text{C}$ 16.3 (Visual) (Correction Factor) 16.2 (Actual)

Recheck for OOT $^{\circ}\text{C}$ (Visual) (Correction Factor) (Actual)

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other:

Shipping Method: ☐ Standard Overnight ☐ First Overnight ☐ Priority Overnight ☐ Ground ☐ International Priority ☐ Other:

Billing: ☐ Recipient ☐ Sender ☐ Third Party ☐ Credit Card ☐ Unknown

Tracking #

Custody Seal Present: ☐ Yes ☐ No Seal properly placed and intact: ☐ Yes ☐ No

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other:

Ice: ☐ Wet ☐ Blue ☐ Dry ☐ None ☐ Melted

Samples shorted to lab: ☐ Yes ☐ No (If yes, complete the following)

Shorted Date:

Bottle Quantity / Type:

Shorted Time:

Chain of Custody:

Present: ☐ Yes ☐ No | Filled Out: ☐ Yes ☐ No ☐ N/A | Sampler Name: ☐ Yes ☐ No ☐ N/A

Relinquished To Pace: ☐ Yes ☐ No ☐ N/A | Sampling Date(s): ☐ Yes ☐ No ☐ N/A | Sampling Time(s): ☐ Yes ☐ No ☐ N/A

Samples Arrived within Hold Time.

☐ Yes ☐ No ☐ N/A

Comments:

Rush Turnaround Requested on COC.

☐ Yes ☐ No ☐ N/A

Comments:

Sufficient Volume.

☐ Yes ☐ No ☐ N/A

Comments:

Correct Containers Used.

☐ Yes ☐ No ☐ N/A

Comments:

Containers Intact.

☐ Yes ☐ No ☐ N/A

Comments:

Sample Labels Match COC (Sample ID, Date/Time of Collection).

☐ Yes ☐ No ☐ N/A

Comments:

All containers needing acid / base preservation have been checked.

☐ Yes ☐ No ☐ N/A

Preservation Information

Preservative:

Date:

Lot / Trace:

Time:

Amount added (mL):

Initials:

All containers needing preservation are found to be in compliance with EPA recommendation:

☐ Yes ☐ No ☐ N/A

Exceptions: Vials, Microbiology, O&G, PFAS

Headspace in Volatile Vials? (>6mm):

☐ Yes ☐ No ☐ N/A

Trip Blank Present:

☐ Yes ☐ No ☐ N/A

Comments / Resolutions (use back for additional comments):

SCUR continued

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 PHONE NUMBER 8163596731		PROJECT LOCATION Union Chapel Elementary School E-MAIL Kahler.J@parkhill.k12.mo.us		PURCHASE ORDER # UC2324 DATE SHIPPED 12/22/2023		3 ANALYSIS REQUESTED + + DW Lead Turb Check		4 (FOR LAB USE ONLY) LOGIN # 6L04343 LOGGED BY: 7031 CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED			REMARKS	
386-UCE-001		12/22/2023	0757	X	DW	1	6	X			
386-UCE-002		12/22/2023	0758	X	DW	1	6	X			
386-UCE-003		12/22/2023	0758	X	DW	1	6	X			
386-UCE-004		12/22/2023	0803	X	DW	1	6	X			
386-UCE-005		12/22/2023	0804	X	DW	1	6	X			
386-UCE-006		12/22/2023	0805	X	DW	1	6	X			
386-UCE-007		12/22/2023	0807	X	DW	1	6	X			
386-UCE-008		12/22/2023	0808	X	DW	1	6	X			
386-UCE-009		12/22/2023	0808	X	DW	1	6	X			
386-UCE-010		12/22/2023	0810	X	DW	1	6	X			
386-UCE-011		12/22/2023	0811	X	DW	1	6	X			
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)					
7 RELINQUISHED BY: (SIGNATURE) DATE 12/22/23 TIME 1300		RECEIVED BY: (SIGNATURE)				DATE TIME		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)				DATE TIME		SAMPLE TEMPERATURE UPON RECEIPT 12.2 °C	
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)				DATE 12/27/23 TIME 0910		CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 PHONE NUMBER 8163596731		PROJECT LOCATION Union Chapel Elementary School E-MAIL KahlerJ@parkhill.k12.mo.us		PURCHASE ORDER # UC2324 DATE SHIPPED 12/22/2023		3 ANALYSIS REQUESTED + + DW Lead Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>6LO4343</u> LOGGED BY: <u>JDS</u> CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS			
386-UCE- 012		12/22/2023	0813	X	DW	1	6	X			
386-UCE- 013		12/22/2023	0815	X	DW	1	6	X			
386-UCE- 014		12/22/2023	0817	X	DW	1	6	X			
386-UCE- 015		12/22/2023	0817	X	DW	1	6	X			
386-UCE- 016		12/22/2023	0823	X	DW	1	6	X			
386-UCE- 017		12/22/2023	0825	X	DW	1	6	X			
386-UCE- 018		12/22/2023	0825	X	DW	1	6	X			
386-UCE- 019		12/22/2023	0827	X	DW	1	6	X			
386-UCE- 020		12/22/2023	0829	X	DW	1	6	X			
386-UCE- 021		12/22/2023	0830	X	DW	1	6	X			
386-UCE- 022		12/22/2023	0832	X	Dw	1	6	X			
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample performance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) 		DATE 12/22/23 TIME 1300		RECEIVED BY: (SIGNATURE) 			DATE TIME		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____		
RELINQUISHED BY: (SIGNATURE) 		DATE TIME		RECEIVED BY: (SIGNATURE) 			DATE TIME				
RELINQUISHED BY: (SIGNATURE) 		DATE TIME		RECEIVED BY: (SIGNATURE) 			DATE 12/27/23 TIME 0910				

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 PHONE NUMBER 8163596731		PROJECT LOCATION Union Chapel Elementary School E-MAIL KahlerJ@parkhill.k12.mo.us		PURCHASE ORDER # UC2324 DATE SHIPPED 12/22/2023		3 ANALYSIS REQUESTED + + DW Lead Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>6L04343</u> LOGGED BY: <u>7021</u> CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS		
386-UCE- 023		12/22/2023	0832	X		DW	1	6	X		
386-UCE- 024		12/22/2023	0832	X		DW	1	6	X		
386-UCE- 025		12/22/2023	0834	X		DW	1	6	X		
386-UCE- 026		12/22/2023	0836	X		DW	1	6	X		
386-UCE- 027		12/22/2023	0836	X		DW	1	6	X		
386-UCE- 028		12/22/2023	0836	X		DW	1	6	X		
386-UCE- 029		12/22/2023	0838	X		DW	1	6	X		
386-UCE- 030		12/22/2023	0840	X		DW	1	6	X		
386-UCE- 031		12/22/2023	0841	X		DW	1	6	X		
386-UCE- 032		12/22/2023	0843	X		DW	1	6	X		
386-UCE- 033		12/22/2023	0844	X		DW	1	6	X		
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) [Signature] DATE 12/22/23 TIME 1300		RECEIVED BY: (SIGNATURE) [Signature]				DATE TIME		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			
RELINQUISHED BY: (SIGNATURE) DATE TIME		RECEIVED BY: (SIGNATURE) [Signature]				DATE TIME					
RELINQUISHED BY: (SIGNATURE) DATE TIME		RECEIVED BY: (SIGNATURE) [Signature]				DATE 12/22/23 TIME 0910					

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 PHONE NUMBER 8163596731		PROJECT LOCATION Union Chapel Elementary School E-MAIL KahlerJ@parkhill.k12.mo.us		PURCHASE ORDER # UC2324 DATE SHIPPED 12/22/2023		3 ANALYSIS REQUESTED + + DW Lead Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>6204343</u> LOGGED BY: <u>2054</u> CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS			
386-UCE-034		12/22/2023	0848	X	DW	1	6	X			
386-UCE-035		12/22/2023	0849	X	DW	1	6	X			
386-UCE-036		12/22/2023	0850	X	DW	1	6	X			
386-UCE-037		12/22/2023	0852	X	DW	1	6	X			
386-UCE-038		12/22/2023	0854	X	DW	1	6	X			
386-UCE-039		12/22/2023	0856	X	DW	1	6	X			
386-UCE-040		12/22/2023	0856	X	DW	1	6	X			
386-UCE-041		12/22/2023	0856	X	DW	1	6	X			
386-UCE-042		12/22/2023	0900	X	DW	1	6	X			
386-UCE-043		12/22/2023	0900	X	DW	1	6	X			
386-UCE-044		12/22/2023	0900	X	Dw	1	6	X			
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) 		DATE 12/22/23 TIME 1300		RECEIVED BY: (SIGNATURE) 		DATE 12/27/23 TIME 0910		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT _____ Y OR N SAMPLE(S) RECEIVED ON ICE _____ Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED _____ Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 PHONE NUMBER 8163596731 PROJECT LOCATION Union Chapel Elementary School E-MAIL KahlerJ@parkhill.k12.mo.us PURCHASE ORDER # UC2324 DATE SHIPPED 12/22/2023		3 ANALYSIS REQUESTED + + DW Lead Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>G204343</u> LOGGED BY: <u>7031</u> CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____			
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS	
386-UCE-045		12/22/2023	0902	X	DW	1	6	X	
386-UCE-046		12/22/2023	0902	X	DW	1	6	X	
386-UCE-047		12/22/2023	0904	X	DW	1	6	X	
386-UCE-048		12/22/2023	0905	X	DW	1	6	X	
386-UCE-049		12/22/2023	0906	X	DW	1	6	X	
386-UCE-050		12/22/2023	0907	X	DW	1	6	X	
386-UCE-051		12/22/2023	0909	X	DW	1	6	X	
386-UCE-052		12/22/2023	0909	X	DW	1	6	X	
386-UCE-053		12/22/2023	0912	X	DW	1	6	X	
386-UCE-054		12/22/2023	0913	X	DW	1	6	X	
386-UCE-055		12/22/2023	0916	X	Dw	1	6	X	
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE) DATE 12/22/23 TIME 1300		RECEIVED BY: (SIGNATURE)		DATE TIME		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)		DATE TIME		SAMPLE TEMPERATURE UPON RECEIPT _____ °C	
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)		DATE 12/21/27 TIME 0910		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____	

