
December 12, 2023

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave,
Kansas City, MO 64153

RE: Drinking Water Sampling – Tiffany Ridge Elementary
8804 NW 45 Highway, Parkville, MO 64152
Project Number: 923386

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Tiffany Ridge Elementary in Kansas City, Missouri. The sampling was performed by Park Hill School District (PHSD) internal staff. PHSD completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the “Get the Lead Out of School Drinking Water Act”.

METHODOLOGY

On 9/21/2023 Mr. Jeremie Kahler and Mr. Joe Rogers of PHSD completed testing of seventy-five (75) sources throughout Tiffany Ridge Elementary. Samples were collected as ‘First Draw’ samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, three (3) of the seventy-five (75) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
8696599	Exterior	Spigot	10.6
8596577	Kitchen	Sink	5.79
8696802	Exterior	Spigot	53.9

LIMITATIONS

The following table identifies sources which were not operational at the time of sampling and therefore not sampled or sample were collected but results contained errors or were not reported. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
All Identified Sources Were Operational		

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst
Vice President of Operations





Jeff Smith
Senior Project Manager (QA/QC)


ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation

Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District

ID:	8696812/GI04551-01	Location:	K/1 Pod		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 007			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696473/GI04551-02	Location:	K/1 Commons		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 008			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696467/GI04551-03	Location:	Commons Café		
Photo:		Manufacturer:	Halsey-Taylor		
		Description:			
		TR DF 002-01			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


Drinking Water Assessment

Tiffany Ridge Elementary

Park Hill School District


ID:	8696467/GI04551-04	Location:	Commons Café		
Photo:		Manufacturer:	Halsey-Taylor		
		Description:			
		TR DF 002-02			
		Result:	<1.0	ppb	
Date Sampled:		9/21/2023	By:	JK	
Recommended Action:					


ID:	8696467/GI04551-05	Location:	Commons Café		
Photo:		Manufacturer:	Halsey-Taylor		
		Description:			
		TR DF 002-03			
		Result:	<1.0	ppb	
Date Sampled:		9/21/2023	By:	JK	
Recommended Action:					

ID:	8696587/GI04551-06	Location:	Exterior, West Center		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Spigot 002			
		Result:	1.06	ppb	
Date Sampled:		9/21/2023	By:	JK	
Recommended Action:					


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696598/GI04551-07	Location:	Exterior, Northwest		
Photo:	No Photo Taken	Manufacturer:	Unknown		
		Description:			
		TR Spigot 001			
		Result:	4.26	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					


ID:	8696585/GI04551-08	Location:	Exterior, Southwest		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Spigot 003			
		Result:	2.52	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					

ID:	8696521/GI04551-09	Location:	Near Media Center		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR DF-01			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696521/GI04551-10	Location:	Near Media Center		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR DF 003-02			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					


ID:	8696520/GI04551-11	Location:	Near Media Center		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 011			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					

ID:	8696511/GI04551-12	Location:	Nurse Restroom		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 037			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696508/GI04551-13	Location:	Nurse Office		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 036			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					


ID:	8696506/GI04551-14	Location:	Office Staff Restroom		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 035			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					

ID:	8696439/GI04551-15	Location:	K/1 Commons		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Slop Sink 003			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District

ID:	8696478/GI04551-16	Location:	2/3 Pod	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 009		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				

ID:	8696463/GI04551-17	Location:	K/1 Pod	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 010		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				

ID:	8696745/GI04551-18	Location:	2/3 Pod	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 003-01		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696745/GI04551-19	Location:	2/3 Pod	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 003-02		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				


ID:	8696751/GI04551-20	Location:	2/3 Pod	
Photo:	Photo Not Taken	Manufacturer:	Unknown	
		Description:		
		TR Sink 004-01		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				

ID:	8696751/GI04551-21	Location:	2/3 Pod	
Photo:	Photo Not Taken	Manufacturer:	Unknown	
		Description:		
		TR Sink 004-02		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696489/GI04551-22	Location:	Commons Café		
Photo:		Manufacturer:	Halsey-Taylor		
		Description:			
		TR DF 001-01			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696489/GI04551-23	Location:	Commons Café		
Photo:		Manufacturer:	Halsey-Taylor		
		Description:			
		TR DF 001-02			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK

ID:	8696489/GI04551-24	Location:	Commons Café		
Photo:		Manufacturer:	Halsey-Taylor		
		Description:			
		TR DF 001-03			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696488/GI04551-25	Location:	2/3 Pod	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 001		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				


ID:	8696487/GI04551-26	Location:	2/3 Pod	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 002		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				

ID:	8696466/GI04551-27	Location:	K/1 Pod	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 005-01		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				

Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District

ID:	8696466/GI04551-28	Location:	K/1 Pod		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 005-02			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696465/GI04551-29	Location:	K/1 Commons		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 006-01			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696465/GI04551-30	Location:	K/1 Commons		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 006-02			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


Drinking Water Assessment

Tiffany Ridge Elementary


Park Hill School District


ID:	8696527/GI04551-31	Location:	4/5 Pod		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 016-02			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					


ID:	8696528/GI04551-32	Location:	4/5 Pod		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 015-01			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					

ID:	8696528/GI04551-33	Location:	4/5 Pod		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 015-02			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					

Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District

ID:	8696525/GI04551-34	Location:	4/5 Pod	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR sink 017		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By: JK
Recommended Action:				


ID:	8696546/GI04551-35	Location:	Staff Lounge	
Photo:		Manufacturer:	Manitowoc	
		Description:		
		TR Ice 001		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By: JK
Recommended Action:				


ID:	8696544/GI04551-36	Location:	Staff Lounge	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 021		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By: JK
Recommended Action:				


Drinking Water Assessment

Tiffany Ridge Elementary


Park Hill School District

ID:	8696548/GI04551-37	Location:	Gym	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 032		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				


ID:	8696553/GI04551-38	Location:	Gym	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 031		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				

ID:	8696518/GI04551-39	Location:	Library	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 012		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696595/GI04551-40	Location:	South Veranda	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Spigot 004		
		Result:	4.84	ppb
		Date Sampled:	9/21/2023	By: JK
Recommended Action:				


ID:	8696599/GI04551-41	Location:	Exterior	
Photo:	Photo Not Taken	Manufacturer:	Unknown	
		Description:		
		TR Spigot 005		
		Result:	10.6	ppb
		Date Sampled:	9/21/2023	By: JK
Recommended Action:		Label as Non-Drinking Water		

ID:	8696578/GI04551-42	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 026		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By: JK
Recommended Action:				


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696562/GI04551-43	Location:	Kitchen		
Photo:		Manufacturer:	Unknown		
Description:					
TR Sink 024					
Result:		<1.0	ppb		
Date Sampled:		9/21/2023	By:	JK	
Recommended Action:					


ID:	8696561/GI04551-44	Location:	Kitchen		
Photo:		Manufacturer:	Unknown		
Description:					
TR Sink 025					
Result:		2.58	ppb		
Date Sampled:		9/21/2023	By:	JK	
Recommended Action:					

ID:	8696559/GI04551-45	Location:	Kitchen		
Photo:		Manufacturer:	Unknown		
Description:					
TR Sink 023					
Result:		<1.0	ppb		
Date Sampled:		9/21/2023	By:	JK	
Recommended Action:					


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696563/GI04551-46	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Skillet 001		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				


ID:	8696564/GI04551-47	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 022		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				

ID:	8696566/GI04551-48	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 027-01		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696566/GI04551-49	Location:	Kitchen		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 027-02			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696566/GI04551-50	Location:	Kitchen		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 027-03			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK

ID:	8696569/GI04551-51	Location:	Kitchen		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 028			
		Result:	2.09	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696576/GI04551-52	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Slop Sink B01		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	9/21/2023	By: JK


ID:	8696568/GI04551-53	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 029		
		Result:	1.58	ppb
Recommended Action:		Date Sampled:	9/21/2023	By: JK

ID:	8696577/GI04551-54	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 030		
		Result:	5.79	ppb
Recommended Action:		Date Sampled:	9/21/2023	By: JK
		Replace Fixture/Unit and Resample		


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696557/GI04551-55	Location:	Commons Café	
Photo:		Manufacturer:	Halsey-Taylor	
		Description:		
		TR DF 006-01		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				


ID:	8696557/GI04551-56	Location:	Commons Café	
Photo:		Manufacturer:	Halsey-Taylor	
		Description:		
		TR DF 006-02		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				

ID:	8696557/GI04551-57	Location:	Commons Café	
Photo:		Manufacturer:	Halsey-Taylor	
		Description:		
		TR DF 006-03		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696539/GI04551-58	Location:	Across from Gym	
Photo:		Manufacturer:	Halsey-Taylor	
		Description:		
		TR DF 005-01		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				


ID:	8696539/GI04551-59	Location:	Across from Gym	
Photo:		Manufacturer:	Halsey-Taylor	
		Description:		
		TR DF 005-02		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				

ID:	8696539/GI04551-60	Location:	Across From Gym	
Photo:		Manufacturer:	Halsey-Taylor	
		Description:		
		TR DF 005-03		
		Result:	<1.0	ppb
Date Sampled:		9/21/2023	By:	JK
Recommended Action:				


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696787/GI04551-61	Location:	Restrooms Near Gym		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 019-01			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696787/GI04551-62	Location:	Restrooms Near Gym		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 019-02			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK

ID:	8696799/GI04551-63	Location:	Restrooms Near Gym		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 20-01			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK

Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District

ID:	8696799/GI04551-64	Location:	Restrooms Near Gym		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 020-02			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696537/GI04551-65	Location:	Adventure Club		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 018			
		Result:	1.39	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696535/GI04551-66	Location:	Art Room		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 034			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


Drinking Water Assessment

Tiffany Ridge Elementary


Park Hill School District


ID:	8696534/GI04551-67	Location:	Art Room		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 033			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


ID:	8696532/GI04551-68	Location:	Art Room		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Slop Sink 004			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK

ID:	8696531/GI04551-69	Location:	4/5 Pod		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 014			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	9/21/2023	By:	JK


Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District


ID:	8696530/GI04551-70	Location:	4/5 Pod		
Photo:		Manufacturer:	Unknown		
		Description:			
		TR Sink 013			
		Result:	<1.0	ppb	
		Date Sampled:	1/15/2024	By:	JK
Recommended Action:					


ID:	8696529/GI04551-71	Location:	4/5 Pod		
Photo:		Manufacturer:	Halsey-Taylor		
		Description:			
		TR DF 004-01			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					

ID:	8696529/GI04551-72	Location:	4/5 Pod		
Photo:		Manufacturer:	Halsey-Taylor		
		Description:			
		TR DF 004-02			
		Result:	<1.0	ppb	
		Date Sampled:	9/21/2023	By:	JK
Recommended Action:					

Drinking Water Assessment
Tiffany Ridge Elementary
Park Hill School District

ID:	8696529/GI04551-73	Location:	4/5 Pod	
Photo:		Manufacturer:	Halsey-Taylor	
		Description:		
		TR DF 004-03		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				

ID:	8696527/GI04551-74	Location:	4/5 Pod	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Sink 016-01		
		Result:	<1.0	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:				

ID:	8696802/GI04551-75	Location:	Exterior	
Photo:		Manufacturer:	Unknown	
		Description:		
		TR Spigot 006		
		Result:	53.9	ppb
		Date Sampled:	9/21/2023	By:
Recommended Action:		Label as Non-Drinking Water		



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

October 12, 2023

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: Tiffany Ridge Elementary

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **75** sample(s) the laboratory received on **9/26/23 10:30 am** and logged in under work order **GI04551**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order GI04551

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: GI04551-01
Name: TR Sink 007 8696812
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:37
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:38	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-02
Name: TR Sink 008 8696473
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:40
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:39	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-03
Name: TR DF 002-01 8696467
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:45
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:41	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-04
Name: TR DF 002-02 8696467
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:45
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:42	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-05
Name: TR DF 002-03 8696467
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:45
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:44	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-06
Name: TR Spigot 002 8696587
Matrix: Drinking Water - Grab

Sampled: 09/21/23 08:02
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.06	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:49	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-07
Name: TR Spigot 001 8696598
Matrix: Drinking Water - Grab

Sampled: 09/21/23 08:06
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.26	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:50	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-08
Name: TR Spigot 003 8696585
Matrix: Drinking Water - Grab

Sampled: 09/21/23 08:13
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.52	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:52	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-09
Name: TR DF 003-01 8696521
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:22
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:53	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-10
Name: TR DF 003-02 8696521
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:22
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 11:58	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-11
Name: TR Sink 011 8696520
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:27
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:00	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-12
Name: TR Sink 037 8696511
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:32
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:01	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-13
Name: TR Sink 036 8696508
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:35
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:03	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-14
Name: TR Sink 035 8696506
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:39
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:07	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-15
Name: TR Slop Sink 003 8696439
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:44
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:09	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-16
Name: TR Sink 009 8696478
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:49
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:10	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-17
Name: TR Sink 010 8696463
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:51
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:12	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-18
Name: TR Sink 003-01 8696745
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:59
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:14	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-19
Name: TR Sink 003-02 8696745
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:59
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:15	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-20
Name: TR Sink 004-01 8696751
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:06
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:20	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-21
Name: TR Sink 004-02 8696751
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:06
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 12:21	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-22
Name: TR DF001-01 8696489
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:11
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:25	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-23
Name: TR DF001-02 8696489
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:11
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:26	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-24
Name: TR DF001-03 8696489
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:11
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:28	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-25
Name: TR Sink 001 8696488
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:16
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:29	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-26
Name: TR Sink 002 8696487
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:20
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:31	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-27
Name: TR Sink 005-01 8696466
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:27
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:33	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-28
Name: TR Sink 005-02 8696466
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:27
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:34	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-29
Name: TR Sink 006-01 8696465
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:31
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:36	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-30
Name: TR Sink 006-02 8696465
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:31
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:44	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-31
Name: TR Sink 016-02 8696527
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:10
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:45	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-32
Name: TR Sink 015-01 8696528
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:13
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:47	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-33
Name: TR Sink 015-02 8696528
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:15
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:48	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-34
Name: TR Sink 017 8696525
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:18
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:50	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-35
Name: TR Ice 001 8696546
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:23
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:51	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-36
Name: TR Sink 021 8696544
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:25
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:53	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-37
Name: TR Sink 032 8696548
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:28
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:54	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-38
Name: TR Sink 031 8696553
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:35
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:56	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-39
Name: TR Sink 012 8696518
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:41
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 13:58	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-40
Name: TR Spigot 004 8696595
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:46
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.84	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:05	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-41
Name: TR Spigot 005 8696599
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:50
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	10.6	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:07	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-42
Name: TR Sink 026 8696578
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:22
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:09	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-43
Name: TR Sink 024 8696562
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:25
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:10	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-44
Name: TR Sink 025 8696561
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:30
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.58	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:12	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-45
Name: TR Sink 023 8696559
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:32
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:13	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-46
Name: TR Skillet 001 8696563
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:35
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:15	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-47
Name: TR Sink 022 8696564
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:38
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:16	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-48
Name: TR Sink 027-01 8696566
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:44
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:21	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-49
Name: TR Sink 027-02 8696566
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:45
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:23	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-50
Name: TR Sink 027-03 8696566
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:46
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:27	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-51
Name: TR Sink 028 8696569
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:50
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.09	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:29	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-52
Name: TR Slop Sink B01 8696576
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:53
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:30	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-53
Name: TR Sink 029 8696568
Matrix: Drinking Water - Grab

Sampled: 09/21/23 05:58
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.58	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:32	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-54
Name: TR Sink 030 8696577
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:00
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	5.79	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:34	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-55
Name: TR DF 006-01 8696557
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:06
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:35	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-56
Name: TR DF 006-02 8696557
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:07
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:40	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-57
Name: TR DF 006-03 8696557
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:09
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:41	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-58
Name: TR DF 005-01 8696539
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:17
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:43	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-59
Name: TR DF 005-02 8696539
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:18
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:45	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-60
Name: TR DF 005-03 8696539
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:21
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:49	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-61
Name: TR Sink 019-01 8696787
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:26
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:51	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-62
Name: TR Sink 019-02 8696787
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:27
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:52	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-63
Name: TR Sink 020-01 8696799
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:31
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:54	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-64
Name: TR Sink 020-02 8696799
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:33
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 14:59	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-65
Name: TR Sink 018 8696537
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:37
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.39	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:00	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-66
Name: TR Sink 034 8696535
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:43
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:02	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-67
Name: TR Sink 033 8696534
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:45
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:03	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-68
Name: TR Slop Sink 004 8696532
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:50
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:05	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-69
Name: TR Sink 014 8696531
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:55
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:06	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-70
Name: TR Sink 013 8696530
Matrix: Drinking Water - Grab

Sampled: 09/21/23 06:58
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:11	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-71
Name: TR DF 004-01 8696529
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:01
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:13	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-72
Name: TR DF 004-02 8696529
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:02
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:17	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GI04551-73
Name: TR DF 004-03 8696529
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:03
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:19	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-74
Name: TR Sink 016-01 8696527
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:07
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:20	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GI04551-75
Name: TR Spigot 006 8696802
Matrix: Drinking Water - Grab

Sampled: 09/21/23 07:54
Received: 09/26/23 10:30
PO #: 24005354

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	53.9	ug/L		10/09/23 08:54	1	1.00	10/09/23 15:22	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager



CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED *MO*

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

[illegible]

1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.

REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

4 To be completed by laboratory personnel.

5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.

RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.

6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.

8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.



Pace Analytical Services
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER Tiffany Ridge Elementary		PROJECT LOCATION		PURCHASE ORDER #		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED		<div><div>DW Lead</div><div>Turb Check</div></div>		LOGIN # <u>6164551</u> LOGGED BY: <u>gds</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Tiffany Ridge Elementary</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #:	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Joe Rogers		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID							
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE 									
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP		MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS		
TR DF003-01 8696521		9/21	5:22am	X		DW					
TR DF003-02 8696521		9/21	5:22am	X		DW					
TR Sink 011 8696520		9/21	5:22am	X		DW					
TR Sink 037 8696511		9/21	5:32am	X		DW					
TR Sink 036 8696508		9/21	5:35am	X		DW					
TR Sink 035 8696506		9/21	5:39am	X		DW					
TR Sink Sink 003 8696459		9/21	5:44am	X		DW					
TR Sink 009 8696478		9/21	5:49am	X		DW					
TR Sink 010 8696463		9/21	5:51am	X		DW					
TR Sink 003-01 8696745		9/21	5:59am	X		DW					
TR Sink 003-02 8696745		9/21	5:59am	X		DW					
CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) <u>Y</u>					
7 RELINQUISHED BY: (SIGNATURE) 		DATE 9-22 TIME 9:58 AM		RECEIVED BY: (SIGNATURE) 				DATE TIME		8 COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)				DATE TIME		SAMPLE TEMPERATURE UPON RECEIPT <u>23.7</u> °C	
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)				DATE 9/26/23 TIME 1030		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE	

1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.

REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

4 To be completed by laboratory personnel.

5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.
RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.

6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.

8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.



Pace Analytical Services
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER Tiffany Ridge Elementary		PROJECT LOCATION		PURCHASE ORDER #		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY)			
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED		<div>DW Lead</div> <div>Turb Check</div>				LOGIN # <u>6104551</u> LOGGED BY: <u>gk</u> CLIENT: Park Hill School District PROJECT: Tiffany Ridge Elementary PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:			
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Joe Rogers		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID									
CONTACT PERSON Jeremie Kahler		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT		PRES CODE CLIENT PROVIDED		REMARKS	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		9/21		6:06am		X		DW							
TR Sink 004-01 8696751		9/21		6:06am		X		DW							
TR Sink 004-02 8696751		9/21		6:11am		X		DW							
TR DFC01-01 8696489		9/21		6:11am		X		DW							
TR DFC01-02 8696489		9/21		6:11am		X		DW							
TR DFC01-03 8696489		9/21		6:16am		X		DW							
TR Sink 001 8696488		9/21		6:20am		X		DW							
TR Sink 002 8696487		9/21		6:27am		X		DW							
TR Sink 005-01 8696466		9/21		6:27am		X		DW							
TR Sink 005-02 8696466		9/21		6:31am		X		DW							
TR Sink 006-01 8696465		9/21		6:31am		X		DW							
TR Sink 006-02 8696465															
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3		6 - UNPRESERVED		7 - OTHER	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.							
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE								PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) <u>L</u>							
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:													
7 RELINQUISHED BY: (SIGNATURE) 		DATE 9-22		TIME 9:58AM		RECEIVED BY: (SIGNATURE)		DATE		TIME		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE) 		DATE 9/26/23		TIME 1030		SAMPLE TEMPERATURE UPON RECEIPT <u>23.7</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE B			

FedEx

1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.

REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

4 To be completed by laboratory personnel.

5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.
RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.

6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.

8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER Tiffany Ridge Elementary PHONE NUMBER 8163596731 E-MAIL KahlerJ@parkhill.k12.mo.us SAMPLER (PLEASE PRINT) Jeremie Kahler SAMPLER'S SIGNATURE 		PROJECT LOCATION PURCHASE ORDER # DATE SHIPPED MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID		3 ANALYSIS REQUESTED DW Lead Turb Check		4 (FOR LAB USE ONLY) LOGIN # 6104551 LOGGED BY: gk CLIENT: Park Hill School District PROJECT: Tiffany Ridge Elementary PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: 	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS
TR Sink 016-02		8696527	9-21	7:10AM	X	DW			
TR Sink 015-01		8696528	9-21	7:13AM	X	DW			
TR Sink 015-02		8696528	9-21	7:15AM	X	DW			
TR Sink 017		8696525	9-21	7:18AM	X	DW			
TR Ice 001		8696546	9-21	7:23AM	X	DW			
TR Sink 021		8696544	9-21	7:25AM	X	DW			
TR Sink 032		8696548	9-21	7:28AM	X	DW			
TR Sink 031		8696553	9-21	7:35AM	X	DW			
TR Sink 012		8696518	9-21	7:41AM	X	DW			
TR Spring 004		8696595	9-21	7:46AM	X	DW			
TR Spring 005		8696599	9-21	7:50AM	X	DW			
CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER									
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) J			
7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT 23.7 °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE	
		9-22	9:59AM	grace jacob		9/26/23	1030		

FedEx

1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.

REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

4 To be completed by laboratory personnel.

5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.

RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.

6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.

8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.



Pace Analytical Services
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER Tiffany Ridge Elementary		PROJECT LOCATION		PURCHASE ORDER #		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY)		
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED		<div>DW Lead</div> <div>Turb Check</div>				LOGIN # <u>6104551</u>		
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jeremie Kahler		MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID		DATE SHIPPED						LOGGED BY: <u>gls</u>		
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE										CLIENT: Park Hill School District		
												PROJECT: Tiffany Ridge Elementary		
												PROJ. MGR.: Chenise Lambert-Sykes		
												CUSTODY SEAL #:		
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	<div>DW Lead</div> <div>Turb Check</div>				REMARKS	
TR Sink 026		8696578	9-21	5:22AM	X	DW								
TR Sink 024		8696562	9-21	5:25AM	X	DW								
TR Sink 025		8696561	9-21	5:30AM	X	DW								
TR Sink 023		8696559	9-21	5:32AM	X	DW								
TR Skillet 001		8696563	9-21	5:35AM	X	DW								
TR Sink 022		8696564	9-21	5:38AM	X	DW								
TR Sink 027-01		8696566	9-21	5:44AM	X	DW								
TR Sink 027-02		8696566	9-21	5:45AM	X	DW								
TR Sink 027-03		8696566	9-21	5:46AM	X	DW								
TR Sink 028		8696569	9-21	5:50AM	X	DW								
TR Slop Sink 001		8696576	9-21	5:53AM	X	DW								
CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER														
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)				DATE RESULTS NEEDED				6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities.						
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE				PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) <u>J</u>										
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:														
7 RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	8 COMMENTS: (FOR LAB USE ONLY)						
		9-22	9:59AM					SAMPLE TEMPERATURE UPON RECEIPT <u>23.7</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE B						
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME							
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME							
						9/26/23	10:30							

FeDeX

1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.

REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

4 To be completed by laboratory personnel.

5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.
RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.

6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.

8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER Tiffany Ridge Elementary		PROJECT LOCATION		PURCHASE ORDER #		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED		+		LOGIN # <u>6104551</u>	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jeremie Kahler		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID						LOGGED BY: <u>987</u>	
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE								CLIENT: Park Hill School District	
										PROJECT: Tiffany Ridge Elementary	
										PROJ. MGR.: Chenise Lambert-Sykes	
										CUSTODY SEAL #:	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP		MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS
TR Sink 029		9-21	5:58AM	X		DW					
TR Sink 030		9-21	6:00AM	X		DW					
TR DF 006-01		9-21	6:06AM	X		DW					
TR DF 006-02		9-21	6:07AM	X		DW					
TR DF 006-03		9-21	6:09AM	X		DW					
TR DF 005-01		9-21	6:17AM	X		DW					
TR DF 005-02		9-21	6:18AM	X		DW					
TR DF 005-03		9-21	6:21AM	X		DW					
TR Sink 019-01		9-21	6:26AM	X		DW					
TR Sink 019-02		9-21	6:27AM	X		DW					
TR Sink 020-01		9-21	6:31AM	X		DW					
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.			
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE								PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) <u>J</u>			
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:									
7 RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	8 COMMENTS: (FOR LAB USE ONLY)			
		9-22	10:00 AM								
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	SAMPLE TEMPERATURE UPON RECEIPT <u>23.7</u> °C			
								CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N <u>N</u>			
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N <u>N</u>			
						9/26/23	1030	DATE AND TIME TAKEN FROM SAMPLE B			

1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.

REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

4 To be completed by laboratory personnel.

5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.

RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.

6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.

8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER Tiffany Ridge Elementary PHONE NUMBER 8163596731 E-MAIL KahlerJ@parkhill.k12.mo.us SAMPLER (PLEASE PRINT) Jeremie Kahler SAMPLER'S SIGNATURE 		PROJECT LOCATION E-MAIL DATE SHIPPED MATRIX TYPES: WW-WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL-SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID		3 ANALYSIS REQUESTED <div style="display: flex;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">DW Lead</div> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">Turb Check</div> </div>		4 (FOR LAB USE ONLY) LOGIN # <u>G104551</u> LOGGED BY: <u>AK</u> CLIENT: Park Hill School District PROJECT: Tiffany Ridge Elementary PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____		
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS	
TR Sink 020-02		869 6799	9-21 6:33AM	X		DW				
TR Sink 018		869 6537	9-21 6:37AM	X		DW				
TR Sink 034		869 6535	9-21 6:43AM	X		DW				
TR Sink 033		869 6534	9-21 6:45AM	X		DW				
TR Sink 004		869 6532	9-21 6:50AM	X		DW				
TR Sink 014		869 6531	9-21 6:55AM	X		DW				
TR Sink 013		869 6530	9-21 6:58AM	X		DW				
TR DF 004-01		869 6529	9-21 7:01AM	X		DW				
TR DF 004-02		869 6529	9-21 7:02AM	X		DW				
TR DF 004-03		869 6529	9-21 7:03AM	X		DW				
TR Sink 016-01		869 6527	9-21 7:07AM	X		DW				
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER		
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) <u>AK</u>						
7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE 9-22 TIME 10:00 AM	RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE)		DATE TIME DATE TIME DATE TIME DATE TIME	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT <u>23.7</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N <u>N</u> SAMPLE(S) RECEIVED ON ICE Y OR N <u>N</u> SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N <u>N</u> DATE AND TIME TAKEN FROM SAMPLE _____				

1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.
REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

4 To be completed by laboratory personnel.

5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.
RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.

6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.

8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.