

---

April 8, 2024

Jeremie Kahler  
Park Hill School District  
9501 N. Seymour Ave,  
Kansas City, MO 64153

**RE:    Drinking Water Sampling – Congress Middle School**  
8150 N Congress Avenue, Kansas City, MO 64152  
**Project Number: 923386**

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Congress Middle School in Kansas City, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the "Get the Lead Out of School Drinking Water Act".

## **METHODOLOGY**

On 1/2/2024 and 3/22/2024 Mr. Jay Hurst of OCCU-TEC completed testing of ninety-two (92) sources throughout Congress Middle School. Samples were collected as 'First Draw' samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

## RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, one (1) of the ninety-two (92) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
386-CMS-26	Kiln Room	Sink – Right Faucet	13.8
386-CMS-26R	Kiln Room	Sink – Right Faucet	5.92

## LIMITATIONS

At the request of PHSD, Lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
All Identified Sources Were Operational		

## RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

### **SIGNATURE(S)**

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst  
Vice President of Operations





Jeff Smith  
Senior Project Manager (QA/QC)


### **ATTACHMENTS**

Outlet Inventory with Analytical Results Summary  
Laboratory Analytical Results and COC Documentation


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-01	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CMS Sink 013 - Faucet		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-02	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CMS Sink 013 - Dish Sprayer		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-03	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CMS Sink 012 - Left Faucet		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-04	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CMS Sink 012 - Right Faucet		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-05	Location:	Kitchen	
Photo:		Manufacturer:	Advance Tabco	
		Description:		
		CMS Sink 010 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-06	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CMS Sink 011 - Prep		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-07	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CMS Skillet 001 - Dish Sprayer		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-08	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CMS Sink 015 - Faucet		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-09	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		CMS Sink 015 - Dish Sprayer		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				




Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-10	Location:	Kitchen	
Photo:		Manufacturer:	Advance Tabco	
		Description:		
		CMS Sink 014 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-11	Location:	Serving	
Photo:		Manufacturer:	Advance Tabco	
		Description:		
		CMS Sink 016 - Hand Washing Sink		
		Result:	1.54	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-12	Location:	Serving	
Photo:		Manufacturer:	Advance Tabco	
		Description:		
		CMS Sink 017 - Hand Washing Sink		
		Result:	1.22	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-13	Location:	Kitchen RR	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 018 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-14	Location:	Rm 314	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		CMS Sink 019 - Kitchen 6		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-15	Location:	Rm 314	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		CMS Sink 020 - Kitchen 1		
		Result:	1.57	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH




Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-16	Location:	Rm 314	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		CMS Sink 021 - Kitchen 2		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-17	Location:	Rm 314	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		CMS Sink 022 - Kitchen 3		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

ID:	386-CMS-18	Location:	Rm 314	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		CMS Sink 023 - Kitchen 4		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-19	Location:	Rm 314	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		CMS Sink 024 - Kitchen 5		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-20	Location:	Rm 315	
Photo:		Manufacturer:	Chicago Faucet	
		Description:		
		CMS Sink 025		
		Result:	2.57	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

ID:	386-CMS-21	Location:	Rm 312	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 026		
		Result:	3.67	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-22	Location:	Rm 107	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 027		
		Result:	2.1	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-23	Location:	Rm 105	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS Sink 028 - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

ID:	386-CMS-24	Location:	Rm 105	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS Sink 028 - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-25	Location:	Kiln Room	
Photo:		Manufacturer:	Elkay	
		Description:		
		No QR Code - Hand Washing Sink - Left Faucet		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-26	Location:	Kiln Room	
Photo:		Manufacturer:	Elkay	
		Description:		
		No QR Code - Hand Washing Sink - Right Faucet		
		<b>Additional sample collected on 3/22/2024 with a result of 5.92 ppb</b>		
		Result:	<b>13.8</b>	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:		<b>Replace Fixture/Unit and Resample</b>		

ID:	386-CMS-27	Location:	Rm 103	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS Sink 029 - Left Faucet		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-28	Location:	Rm 103	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS Sink 029 - Right Faucet		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-29	Location:	LMC Copy Room	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 009		
		Result:	3.6	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-30	Location:	Womens RR By 112	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 007 - Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				




Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-31	Location:	Womens RR By 112	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 007 - Hand Washing Sink - Center		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-32	Location:	Womens RR By 112	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 007 - Hand Washing Sink -Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-33	Location:	RRs By Rm 112	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 002 - Drinking Fountain Bubbler - Left		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-34	Location:	RRs By Rm 112		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		CMS DF 002 - Drinking Fountain Bubbler - Right			
		Result:	<1.0	ppb	
		Date Sampled:	1/2/2024	By:	JH
Recommended Action:					


ID:	386-CMS-35	Location:	RRs By Rm 112		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		CMS DF 002 - Drinking Fountain Bottle Filler			
		Result:	<1.0	ppb	
		Date Sampled:	1/2/2024	By:	JH
Recommended Action:					

ID:	386-CMS-36	Location:	Mens RR By 112		
Photo:		Manufacturer:	Sloan		
		Description:			
		CMS Sink 008 - Hand Washing Sink - Left			
		Result:	<1.0	ppb	
		Date Sampled:	1/2/2024	By:	JH
Recommended Action:					


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-37	Location:	Mens RR By 112	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 008 - Hand Washing Sink - Center		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-38	Location:	Mens RR By 112	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 008 - Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

ID:	386-CMS-39	Location:	Teacher Lounge	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 056		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-40	Location:	Teacher Lounge	
Photo:		Manufacturer:	Hoshizaki	
		Description:		
		CMS Ice 001 - Ice Machine		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-41	Location:	Mens RR By 307	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 006 - Hand Washing Sink - Left		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-42	Location:	Mens RR By 307	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 006 - Hand Washing Sink - Center		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH



Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-43	Location:	Mens RR By 307	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 006 - Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-44	Location:	RRs By 307	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 003 - Drinking Fountain Bubbler - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-45	Location:	RRs By 307	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 003 - Drinking Fountain Bubbler - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				




Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-46	Location:	RRs By 307	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 003 - Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-47	Location:	Womens RR By 307	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 005 - Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

ID:	386-CMS-48	Location:	Womens RR By 307	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 005 - Hand Washing Sink - Center		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-49	Location:	Womens RR By 307	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 005 - Hand Washing Sink - Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-50	Location:	Commons Womens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 004 - Hand Washing Sink - Left		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-51	Location:	Commons Womens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 004 - Hand Washing Sink - Center		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-52	Location:	Commons Womens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 004 - Hand Washing Sink - Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-53	Location:	Commons	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 012 - Drinking Fountain Bubbler		
		Result:	1.26	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-54	Location:	Commons	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 012 - Drinking Fountain Bottle Filler		
		Result:	1.11	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-55	Location:	Commons	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS DF 011 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-56	Location:	Commons	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS DF 010 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

ID:	386-CMS-57	Location:	Commons	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS DF 009 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-58	Location:	Commons Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 003 - Hand Washing Sink - Left		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-59	Location:	Commons Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 003 - Hand Washing Sink - Center		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-60	Location:	Commons Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		CMS Sink 003 - Hand Washing Sink - Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH




Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-61	Location:	Health Room 102	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 001		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-62	Location:	Health Room 102 RR	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 002 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-63	Location:	Administrative RR	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 055 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-64	Location:	Work Room	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 054 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-65	Location:	Office RR By Work Rm	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 053 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-66	Location:	Mothers Room	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 052		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-67	Location:	Hall RR Behind Stage	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 051 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-68	Location:	Womens LR West Side	
Photo:		Manufacturer:	Halsey Tayler	
		Description:		
		CMS DF 005 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-69	Location:	Womens LR West Side	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 033 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-70	Location:	Womens LR West Side	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 032 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-71	Location:	Womens LR East Side	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 036 - Hand Washing Sink		
		Result:	1.2	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-72	Location:	Womens LR East Side	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 035 - Hand Washing Sink		
		Result:	1.06	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-73	Location:	Womens LR East Side	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 004 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-74	Location:	Womens LR East Side	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 004 - Drinking Fountain Bottle Filler		
		Result:	1.04	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-75	Location:	Womens LR Office RR	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 034 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH




Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-76	Location:	Gym	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS DF 007 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-77	Location:	Gym	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS DF 008 - Drinking Fountain Bubbler		
		Result:	1.98	ppb
		Date Sampled:	3/22/2024	By: JH
Recommended Action:				

ID:	386-CMS-78	Location:	Gym Mezz Weight Rm	
Photo:		Manufacturer:	Elkay	
		Description:		
		CMS DF 006 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-79	Location:	Mens LR West Side	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 003 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-80	Location:	Mens LR West Side	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 003 - Drinking Fountain Bottle Filler		
		Result:	1.22	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-81	Location:	Mens LR West Side	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 037 - Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-82	Location:	Mens LR West Side	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 038 - Hand Washing Sink		
		Result:	1.16	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-83	Location:	Mens LR East Side	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 039 - Hand Washing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

ID:	386-CMS-84	Location:	Mens LR East Side	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 040 - Hand Washing Sink		
		Result:	1.1	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-85	Location:	Mens LR East Side	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 001 - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH


ID:	386-CMS-86	Location:	Mens LR East Side	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		CMS DF 001 - Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

ID:	386-CMS-87	Location:	Mens LR Office RR	
Photo:		Manufacturer:	Unknown	
		Description:		
		No QR Code - Hand Washing Sink		
		Result:	1.62	ppb
Recommended Action:		Date Sampled:	1/2/2024	By: JH

Drinking Water Assessment  
Congress Middle School  
Park Hill School District


ID:	386-CMS-88	Location:	Rm 505	
Photo:		Manufacturer:	Unknown	
		Description:		
		CMS Sink 042 - Hand Washing Sink		
		Result:	2.04	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				


ID:	386-CMS-89	Location:	Rm 506	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		No QR Code - Drinking Fountain Bubbler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

ID:	386-CMS-90	Location:	Rm 506	
Photo:		Manufacturer:	Central	
		Description:		
		CMS Sink 057 - Hand Washing Sink		
		Result:	1.35	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				



Drinking Water Assessment  
Congress Middle School  
Park Hill School District

ID:	386-CMS-91	Location:	Rm 502	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 031		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				

ID:	386-CMS-92	Location:	Rm 501	
Photo:		Manufacturer:	Delta	
		Description:		
		CMS Sink 030		
		Result:	2.94	ppb
		Date Sampled:	1/2/2024	By: JH
Recommended Action:				



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

January 24, 2024

Jeremie Kahler  
Park Hill School District  
9501 N. Seymour Ave  
MO, MO 64153

RE: 923386 CONGRESS MIDDLE SCHOOL

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **91** sample(s) the laboratory received on **1/8/24 10:45 am** and logged in under work order **HA01130**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or [lisa.grant@pacelabs.com](mailto:lisa.grant@pacelabs.com).

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes', is positioned above the contact information for the project manager.

Chenise Lambert-Sykes  
Project Manager  
(314)432-0550  
[Chenise.Lambert-Sykes@pacelabs.com](mailto:Chenise.Lambert-Sykes@pacelabs.com)

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

---

---

Work Order      HA01130

---

---

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



## ANALYTICAL RESULTS

**Sample:** HA01130-01  
**Name:** 386-CMS-001  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:22  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-02  
**Name:** 386-CMS-002  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:22  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:19	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-03  
**Name:** 386-CMS-003  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:24  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:21	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-04  
**Name:** 386-CMS-004  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:24  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:22	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-05  
Name: 386-CMS-005  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:25  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:24	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-06  
Name: 386-CMS-006  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:26  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:29	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-07  
Name: 386-CMS-007  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:27  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:30	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-08  
Name: 386-CMS-008  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:29  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:32	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------





## ANALYTICAL RESULTS

Sample: HA01130-09  
Name: 386-CMS-009  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:29  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:33	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-10  
Name: 386-CMS-010  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:31  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:35	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-11  
Name: 386-CMS-011  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:32  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.54	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:40	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-12  
Name: 386-CMS-012  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:32  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.22	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:41	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA01130-13  
**Name:** 386-CMS-013  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:40  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:43	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-14  
**Name:** 386-CMS-014  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:42  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-15  
**Name:** 386-CMS-015  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:42  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.57	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:49	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-16  
**Name:** 386-CMS-016  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:45  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:51	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA01130-17  
**Name:** 386-CMS-017  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:45  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:52	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-18  
**Name:** 386-CMS-018  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:45  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:54	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-19  
**Name:** 386-CMS-019  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:46  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:55	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-20  
**Name:** 386-CMS-020  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 14:50  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	2.57	ug/L		01/22/24 09:04	1	1.00	01/22/24 13:57	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-21  
Name: 386-CMS-021  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:53  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.67	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:02	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-22  
Name: 386-CMS-022  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:56  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.10	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:06	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-23  
Name: 386-CMS-023  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:58  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:08	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-24  
Name: 386-CMS-024  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 14:58  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:10	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-25  
Name: 386-CMS-025  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:00  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:11	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-26  
Name: 386-CMS-026  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:00  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	13.8	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:13	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-27  
Name: 386-CMS-027  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:02  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-28  
Name: 386-CMS-028  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:02  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:16	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------





## ANALYTICAL RESULTS

**Sample:** HA01130-29  
**Name:** 386-CMS-029  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:06  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	3.60	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:17	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-30  
**Name:** 386-CMS-030  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:08  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:19	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-31  
**Name:** 386-CMS-031  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:08  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:27	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-32  
**Name:** 386-CMS-032  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:08  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-33  
Name: 386-CMS-033  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:12  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:30	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-34  
Name: 386-CMS-034  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:12  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:31	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-35  
Name: 386-CMS-035  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:12  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:33	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-36  
Name: 386-CMS-036  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:14  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:35	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-37  
Name: 386-CMS-037  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:14  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:36	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-38  
Name: 386-CMS-038  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:14  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:38	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-39  
Name: 386-CMS-039  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:26  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:39	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-40  
Name: 386-CMS-040  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:26  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-41  
Name: 386-CMS-041  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:28  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:49	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-42  
Name: 386-CMS-042  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:28  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:50	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-43  
Name: 386-CMS-043  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:28  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:52	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-44  
Name: 386-CMS-044  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:31  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:53	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA01130-45  
**Name:** 386-CMS-045  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:31  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:55	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-46  
**Name:** 386-CMS-046  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:31  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:57	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-47  
**Name:** 386-CMS-047  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:33  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 14:58	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-48  
**Name:** 386-CMS-048  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:33  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:03	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------





## ANALYTICAL RESULTS

**Sample:** HA01130-49  
**Name:** 386-CMS-049  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:33  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-50  
**Name:** 386-CMS-050  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:36  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:06	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-51  
**Name:** 386-CMS-051  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:36  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:11	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-52  
**Name:** 386-CMS-052  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:36  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-53  
Name: 386-CMS-053  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:40  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.26	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:14	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-54  
Name: 386-CMS-054  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:40  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.11	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:15	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-55  
Name: 386-CMS-055  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:41  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:17	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-56  
Name: 386-CMS-056  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:41  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:22	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA01130-57  
**Name:** 386-CMS-057  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:41  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:23	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-58  
**Name:** 386-CMS-058  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:44  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:25	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-59  
**Name:** 386-CMS-059  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:44  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-60  
**Name:** 386-CMS-060  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:44  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-61  
Name: 386-CMS-061  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:48  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:33	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-62  
Name: 386-CMS-062  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:48  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:34	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-63  
Name: 386-CMS-063  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:51  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:36	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-64  
Name: 386-CMS-064  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 15:53  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:40	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA01130-65  
**Name:** 386-CMS-065  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:54  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:42	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-66  
**Name:** 386-CMS-066  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:55  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:43	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-67  
**Name:** 386-CMS-067  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 15:56  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:45	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-68  
**Name:** 386-CMS-068  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 16:20  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-69  
Name: 386-CMS-069  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:20  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:48	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-70  
Name: 386-CMS-070  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:22  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:50	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-71  
Name: 386-CMS-071  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:22  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.20	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:54	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-72  
Name: 386-CMS-072  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:23  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.06	ug/L		01/22/24 09:04	1	1.00	01/22/24 15:59	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------





## ANALYTICAL RESULTS

**Sample:** HA01130-73  
**Name:** 386-CMS-073  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 16:23  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-74  
**Name:** 386-CMS-074  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 16:25  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	1.04	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:02	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-75  
**Name:** 386-CMS-075  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 16:25  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-76  
**Name:** 386-CMS-076  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 16:30  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-77  
Name: 386-CMS-078  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:32  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:07	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-78  
Name: 386-CMS-079  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:35  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:08	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-79  
Name: 386-CMS-080  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:35  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.22	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:10	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-80  
Name: 386-CMS-081  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:35  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-81  
Name: 386-CMS-082  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:36  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	1.16	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:19	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-82  
Name: 386-CMS-083  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:38  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:21	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-83  
Name: 386-CMS-084  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:38  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	1.10	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:22	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-84  
Name: 386-CMS-085  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:38  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:24	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA01130-85  
Name: 386-CMS-086  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:40  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:25	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-86  
Name: 386-CMS-087  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:40  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.62	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:27	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-87  
Name: 386-CMS-088  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:47  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.04	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:29	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA01130-88  
Name: 386-CMS-089  
Matrix: Drinking Water - Regular Sample

Sampled: 01/02/24 16:49  
Received: 01/08/24 10:45  
PO #: 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:30	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA01130-89  
**Name:** 386-CMS-090  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 16:50  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	1.35	ug/L		01/22/24 09:04	1	1.00	01/22/24 16:32	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-90  
**Name:** 386-CMS-091  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 16:52  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/22/24 09:04	1	1.00	01/23/24 08:56	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA01130-91  
**Name:** 386-CMS-092  
**Matrix:** Drinking Water - Regular Sample

**Sampled:** 01/02/24 16:54  
**Received:** 01/08/24 10:45  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	2.94	ug/L		01/22/24 09:04	1	1.00	01/23/24 09:00	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



## NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

\* Not a TNI accredited analyte

### Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager







REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Congress Middle School		PURCHASE ORDER # 24002052		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) HA01130	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 1/4/2024		+ +		LOGIN #	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead		Turb Check	
CONTACT PERSON Jeremie Kahler		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)											
386-CMS-001		1/2/2024		1422		X		DW		1 6	
386-CMS-002		1/2/2024		1422		X		DW		1 6	
386-CMS-003		1/2/2024		1424		X		DW		1 6	
386-CMS-004		1/2/2024		1424		X		DW		1 6	
386-CMS-005		1/2/2024		1425		X		DW		1 6	
386-CMS-006		1/2/2024		1426		X		DW		1 6	
386-CMS-007		1/2/2024		1427		X		DW		1 6	
386-CMS-008		1/2/2024		1429		X		DW		1 6	
386-CMS-009		1/2/2024		1429		X		DW		1 6	
386-CMS-010		1/2/2024		1431		X		DW		1 6	
386-CMS-011		1/2/2024		1432		X		Dw		1 6	
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3	
		6 - UNPRESERVED		7 - OTHER							
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.			
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE								PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)			
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:									
7 RELINQUISHED BY: (SIGNATURE) 		DATE 1/4/24		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
		TIME 1700				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT		7.0 °C	
		TIME				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE 1/8/24		CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED		Y OR N Y OR N	
		TIME				TIME 1045		DATE AND TIME TAKEN FROM SAMPLE BOTTLE			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

<b>1</b> CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Congress Middle School		PURCHASE ORDER # 24002052		<b>3</b> ANALYSIS REQUESTED				<b>4</b> (FOR LAB USE ONLY) LOGIN # <u>HA 01130</u>	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 1/4/2024		+ +				LOGGED BY: _____	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead Turb Check				CLIENT: <u>Park Hill School District</u>	
CONTACT PERSON Jeremie Kahler		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT		PRES CODE CLIENT PROVIDED	
<b>2</b> SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)												REMARKS	
386-CMS- 012		1/2/2024		1432		X		DW		1		6	
386-CMS- 013		1/2/2024		1440		X		DW		1		6	
386-CMS- 014		1/2/2024		1442		X		DW		1		6	
386-CMS- 015		1/2/2024		1442		X		DW		1		6	
386-CMS- 016		1/2/2024		1445		X		DW		1		6	
386-CMS- 017		1/2/2024		1445		X		DW		1		6	
386-CMS- 018		1/2/2024		1445		X		DW		1		6	
386-CMS- 019		1/2/2024		1446		X		DW		1		6	
386-CMS- 020		1/2/2024		1450		X		DW		1		6	
386-CMS- 021		1/2/2024		1453		X		DW		1		6	
386-CMS- 022		1/2/2024		1456		X		Dw		1		6	
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3		6 - UNPRESERVED	
7 - OTHER													
<b>5</b> TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		<b>6</b> I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities.					
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE								PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:											
RELINQUISHED BY: (SIGNATURE) 		DATE 1/4/24		TIME 1700		RECEIVED BY: (SIGNATURE)		DATE		<b>8</b> COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT <u>7.0</u> °C			
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE) 		DATE 1/8/24		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED			
								TIME 1045		DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			



Pace Analytical Services  
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

## CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

<b>1</b> CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Congress Middle School		PURCHASE ORDER # 24002052		<b>3</b> ANALYSIS REQUESTED		<b>4</b> (FOR LAB USE ONLY) LOGIN # <u>HA01130</u> LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____					
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 1/4/2024		<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>							
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAB- NON AQUEOUS SOLID LCIL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead		Turb Check					
<b>2</b> SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT		PRES CODE CLIENT PROVIDED		REMARKS	
386-CMS- 023		1/2/2024		1458		X		DW		1		6		X	
386-CMS- 024		1/2/2024		1458		X		DW		1		6		X	
386-CMS- 025		1/2/2024		1500		X		DW		1		6		X	
386-CMS- 026		1/2/2024		1500		X		DW		1		6		X	
386-CMS- 027		1/2/2024		1502		X		DW		1		6		X	
386-CMS- 028		1/2/2024		1502		X		DW		1		6		X	
386-CMS- 029		1/2/2024		1506		X		DW		1		6		X	
386-CMS- 030		1/2/2024		1508		X		DW		1		6		X	
386-CMS- 031		1/2/2024		1508		X		DW		1		6		X	
386-CMS- 032		1/2/2024		1508		X		DW		1		6		X	
386-CMS- 033		1/2/2024		1512		X		Dw		1		6		X	
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3		6 - UNPRESERVED		7 - OTHER	
<b>5</b> TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		<b>6</b> I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____											
<b>7</b> RELINQUISHED BY: (SIGNATURE) 		DATE 1/4/24 TIME 1700		RECEIVED BY: (SIGNATURE) 		DATE TIME		<b>8</b> COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT <u>7.0</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT Y OR N REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE <u>1/8/24 1045</u>							
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)		DATE TIME									
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE) 		DATE 1/8/24 TIME 1045									



REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD  
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)





<b>1 CLIENT</b> Park Hill School District <b>ADDRESS</b> 9501 N. Seymour Ave. <b>CITY STATE ZIP</b> Kansas City, MO 64153 <b>CONTACT PERSON</b> Jeremie Kahler		<b>PROJECT NUMBER</b> 923386 <b>PHONE NUMBER</b> 8163596731		<b>PROJECT LOCATION</b> Congress Middle School <b>E-MAIL</b> Kahler.J@parkhill.k12.mo.us		<b>PURCHASE ORDER #</b> 24002052 <b>DATE SHIPPED</b> 1/4/2024		<b>3 ANALYSIS REQUESTED</b> <div style="display: flex; justify-content: space-between;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">DW Lead</div> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">Turb Check</div> </div>				<b>4 (FOR LAB USE ONLY)</b> LOGIN # <u>HA01130</u> LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
<b>2 SAMPLE DESCRIPTION</b> (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED					REMARKS	
386-CMS-034		1/2/2024	1512	X	DW	1	6						
386-CMS-035		1/2/2024	1512	X	DW	1	6						
386-CMS-036		1/2/2024	1514	X	DW	1	6						
386-CMS-037		1/2/2024	1514	X	DW	1	6						
386-CMS-038		1/2/2024	1514	X	DW	1	6						
386-CMS-039		1/2/2024	1526	X	DW	1	6						
386-CMS-040		1/2/2024	1526	X	DW	1	6						
386-CMS-041		1/2/2024	1528	X	DW	1	6						
386-CMS-042		1/2/2024	1528	X	DW	1	6						
386-CMS-043		1/2/2024	1528	X	DW	1	6						
386-CMS-044		1/2/2024	1531	X	DW	1	6						
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER					
<b>5</b> TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: _____ PHONE # IF DIFFERENT FROM ABOVE: _____		<b>6</b> I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.  PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____		<b>DATE RESULTS NEEDED</b> _____		<b>8 COMMENTS: (FOR LAB USE ONLY)</b> _____ SAMPLE TEMPERATURE UPON RECEIPT <u>20</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____							
<b>7 RELINQUISHED BY: (SIGNATURE)</b> 		<b>DATE</b> 1/4/24 <b>TIME</b> 1700		<b>RECEIVED BY: (SIGNATURE)</b> _____		<b>DATE</b> <b>TIME</b>							
<b>RELINQUISHED BY: (SIGNATURE)</b> _____		<b>DATE</b> <b>TIME</b>		<b>RECEIVED BY: (SIGNATURE)</b> _____		<b>DATE</b> <b>TIME</b>							
<b>RELINQUISHED BY: (SIGNATURE)</b> _____		<b>DATE</b> <b>TIME</b>		<b>RECEIVED BY: (SIGNATURE)</b> 		<b>DATE</b> 1/8/24 <b>TIME</b> 1045							

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)



<b>1</b> CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Congress Middle School		PURCHASE ORDER # 24002052		<b>3</b> ANALYSIS REQUESTED		<b>4</b> (FOR LAB USE ONLY) LOGIN # <u>HA01130</u>	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 1/4/2024		+ +		LOGGED BY: _____	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead		Turb Check	
CONTACT PERSON Jeremie Kahler		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB		MATRIX TYPE		BOTTLE COUNT	
<b>2</b> SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)											
386-CMS- 045		1/2/2024		1531		X		DW		1 6	
386-CMS- 046		1/2/2024		1531		X		DW		1 6	
386-CMS- 047		1/2/2024		1533		X		DW		1 6	
386-CMS- 048		1/2/2024		1533		X		DW		1 6	
386-CMS- 049		1/2/2024		1533		X		DW		1 6	
386-CMS- 050		1/2/2024		1536		X		DW		1 6	
386-CMS- 051		1/2/2024		1536		X		DW		1 6	
386-CMS- 052		1/2/2024		1536		X		DW		1 6	
386-CMS- 053		1/2/2024		1540		X		DW		1 6	
386-CMS- 054		1/2/2024		1540		X		DW		1 6	
386-CMS- 055		1/2/2024		1541		X		Dw		1 6	
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
<b>5</b> TURNAROUND TIME REQUESTED (PLEASE CIRCLE) <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)				DATE RESULTS NEEDED		<b>6</b> I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities.					
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE						PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:											
<b>7</b> RELINQUISHED BY: (SIGNATURE) 		DATE 1/4/24 TIME 1700		RECEIVED BY: (SIGNATURE) 		DATE TIME		<b>8</b> COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE)		DATE TIME		SAMPLE TEMPERATURE UPON RECEIPT <u>7.0</u> °C			
RELINQUISHED BY: (SIGNATURE)		DATE TIME		RECEIVED BY: (SIGNATURE) 		DATE 1/8/24 TIME 1045		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Congress Middle School		PURCHASE ORDER # 24002052		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) H401130	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 1/4/2024		+ +		LOGIN #	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead		Turb Check	
CONTACT PERSON Jeremie Kahler		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		PRES CODE CLIENT PROVIDED	
386-CMS- 056		1/2/2024		1541		X		DW		1 6	
386-CMS- 057		1/2/2024		1541		X		DW		1 6	
386-CMS- 058		1/2/2024		1544		X		DW		1 6	
386-CMS- 059		1/2/2024		1544		X		DW		1 6	
386-CMS- 060		1/2/2024		1544		X		DW		1 6	
386-CMS- 061		1/2/2024		1548		X		DW		1 6	
386-CMS- 062		1/2/2024		1548		X		DW		1 6	
386-CMS- 063		1/2/2024		1551		X		DW		1 6	
386-CMS- 064		1/2/2024		1553		X		DW		1 6	
386-CMS- 065		1/2/2024		1554		X		DW		1 6	
386-CMS- 066		1/2/2024		1555		X		Dw		1 6	
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3	
		6 - UNPRESERVED		7 - OTHER							
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.			
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE								PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)			
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:									
7 RELINQUISHED BY: (SIGNATURE) 		DATE 1/4/24		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
		TIME 1700				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT		7.0 °C	
		TIME				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE 1/10/27		CHILL PROCESS STARTED PRIOR TO RECEIPT		Y OR N	
		TIME				TIME 1045		SAMPLE(S) RECEIVED ON ICE		Y OR N	
								SAMPLE ACCEPTANCE NONCONFORMANT		Y OR N	
								REPORT IS NEEDED			
								DATE AND TIME TAKEN FROM SAMPLE BOTTLE			






REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Congress Middle School		PURCHASE ORDER # 24002052		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 1/4/2024		+ +		LOGIN # <u>H1401130</u>	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead		Turb Check	
CONTACT PERSON Jeremie Kahler										LOGGED BY: _____ CLIENT: Park Hill School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
										PRES CODE CLIENT PROVIDED	
386-CMS-067		1/2/2024		1556		X		DW		1 6 X	
386-CMS-068		1/2/2024		1620		X		DW		1 6 X	
386-CMS-069		1/2/2024		1620		X		DW		1 6 X	
386-CMS-070		1/2/2024		1622		X		DW		1 6 X	
386-CMS-071		1/2/2024		1622		X		DW		1 6 X	
386-CMS-072		1/2/2024		1623		X		DW		1 6 X	
386-CMS-073		1/2/2024		1623		X		DW		1 6 X	
386-CMS-074		1/2/2024		1625		X		DW		1 6 X	
386-CMS-075		1/2/2024		1625		X		DW		1 6 X	
386-CMS-076		1/2/2024		1630		X		DW		1 6 X	
386-CMS-078		1/2/2024		1632		X		Dw		1 6 X	
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3	
										6 - UNPRESERVED	
										7 - OTHER	
										NO SAMPLE 077	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____	
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE											
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:											
7 RELINQUISHED BY: (SIGNATURE)		DATE 1/4/24		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
		TIME 1700				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE					
		TIME				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE 1/8/24					
		TIME				TIME 1045					
								SAMPLE TEMPERATURE UPON RECEIPT		2.0 °C	
								CHILL PROCESS STARTED PRIOR TO RECEIPT		Y OR N	
								SAMPLE(S) RECEIVED ON ICE		Y OR N	
								SAMPLE ACCEPTANCE NONCONFORMANT		Y OR N	
								REPORT IS NEEDED		Y OR N	
								DATE AND TIME TAKEN FROM SAMPLE BOTTLE			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Congress Middle School		PURCHASE ORDER # 24002052		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # <u>HAD1130</u>	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 1/4/2024		+ +		LOGGED BY: _____	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LC/LT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID		DW Lead		Turb Check	
CONTACT PERSON Jeremie Kahler		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
PRES CODE CLIENT PROVIDED		DW Lead		Turb Check		REMARKS					
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
386-CMS-079		1/2/2024		1635		X		DW		1 6	
386-CMS-080		1/2/2024		1635		X		DW		1 6	
386-CMS-081		1/2/2024		1635		X		DW		1 6	
386-CMS-082		1/2/2024		1636		X		DW		1 6	
386-CMS-083		1/2/2024		1638		X		DW		1 6	
386-CMS-084		1/2/2024		1638		X		DW		1 6	
386-CMS-085		1/2/2024		1638		X		DW		1 6	
386-CMS-086		1/2/2024		1640		X		DW		1 6	
386-CMS-087		1/2/2024		1640		X		DW		1 6	
386-CMS-088		1/2/2024		1647		X		DW		1 6	
386-CMS-089		1/2/2024		1649		X		Dw		1 6	
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)				DATE RESULTS NEEDED				6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.			
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE				PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)							
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:											
7 RELINQUISHED BY: (SIGNATURE) 		DATE 1/4/24 TIME 1700		RECEIVED BY: (SIGNATURE)		DATE		TIME		8 COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		TIME		SAMPLE TEMPERATURE UPON RECEIPT	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE) 		DATE 1/8/24 TIME 1025		TIME		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Congress Middle School		PURCHASE ORDER # 24002052		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 1/4/2024		+ +		LOGIN # <u>HA01130</u>	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAB- NON AQUEOUS SOLID LHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead		Turb Check	
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE								LOGGED BY: _____ CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
										PRES CODE CLIENT PROVIDED	
386-CMS-090		1/2/2024		1650		X		DW		1 6	
386-CMS-091		1/2/2024		1652		X		DW		1 6	
386-CMS-092		1/2/2024		1654		X		DW		1 6	
386-CMS-		1/2/2024				X		DW		1 6	
386-CMS-		1/2/2024				X		DW		1 6	
386-CMS-		1/2/2024				X		DW		1 6	
386-CMS-		1/2/2024				X		DW		1 6	
386-CMS-		1/2/2024				X		DW		1 6	
386-CMS-		1/2/2024				X		DW		1 6	
386-CMS-		1/2/2024				X		DW		1 6	
386-CMS-		1/2/2024				X		DW		1 6	
386-CMS-		1/2/2024				X		Dw		1 6	
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.					
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE						PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
7 RELINQUISHED BY: (SIGNATURE)		DATE 1/4/2024		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
		TIME 1700				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT <u>7.0</u> °C			
		TIME				TIME					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE 1/8/24		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N			
		TIME				TIME 1045		SAMPLE(S) RECEIVED ON ICE Y OR N			
								SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED			
								DATE AND TIME TAKEN FROM SAMPLE BOTTLE			



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

April 05, 2024

Jeremie Kahler  
Park Hill School District  
9501 N. Seymour Ave  
MO, MO 64153

RE: 923386 - Congress Middle School

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **2** sample(s) the laboratory received on **3/26/24 3:00 pm** and logged in under work order **HC04234**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or [lisa.grant@pacelabs.com](mailto:lisa.grant@pacelabs.com).

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes  
Project Manager  
(314)432-0550  
[Chenise.Lambert-Sykes@pacelabs.com](mailto:Chenise.Lambert-Sykes@pacelabs.com)



**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

---

Work Order      HC04234

---

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



## ANALYTICAL RESULTS

**Sample:** HC04234-01  
**Name:** 386-CMS-26R  
**Matrix:** Drinking Water - Grab

**Sampled:** 03/22/24 06:04  
**Received:** 03/26/24 15:00  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	5.92	ug/L		04/02/24 08:59	1	1.00	04/02/24 12:00	tjj	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HC04234-02  
**Name:** 386-CMS-77  
**Matrix:** Drinking Water - Grab

**Sampled:** 03/22/24 06:07  
**Received:** 03/26/24 15:00  
**PO #:** 24002052

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.98	ug/L		04/02/24 08:59	1	1.00	04/02/24 12:04	tjj	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------





## NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

\* Not a TNI accredited analyte

### Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager

