

---

June 24, 2024

Jeremie Kahler  
Park Hill School District  
9501 N. Seymour Ave,  
Kansas City, MO 64153

**RE: Drinking Water Sampling – Walden Middle School**  
4701 NW 56<sup>th</sup> Street, Kansas City, MO 64151  
**Project Number: 923386**

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Walden Middle School in Kansas City, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the “Get the Lead Out of School Drinking Water Act”.

## **METHODOLOGY**

On 12/30/2023 and 5/30/2024 Mr. Jay Hurst of OCCU-TEC completed testing of one hundred and four (104) sources throughout Walden Middle School. Samples were collected as ‘First Draw’ samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

## RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, zero (0) of the one hundred and four (104) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
No samples collected contained results above 5 ug/L (ppb)			

## LIMITATIONS

At the request of PHSD, Lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
All Identified Sources Were Operational		

## RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.

- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

**SIGNATURE(S)**

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst  
Vice President of Operations





Jeff Smith  
Senior Project Manager (QA/QC)


**ATTACHMENTS**

Outlet Inventory with Analytical Results Summary  
Laboratory Analytical Results and COC Documentation


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-01	Location:	Kitchen RR	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


ID:	386-WMS-02	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-03	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink - East Wall		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-04	Location:	Kitchen	
Photo:		Manufacturer:	Unknown	
		Description:		
		Dish Sprayer - South Wall		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-05	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Sink - South Wall - Left Faucet		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-06	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Sink - South Wall - Right Faucet		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-07	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink - Southwest Center		
		Result:	1.5	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-08	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Skillet Faucet		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-09	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Skillet Dish Sprayer		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-10	Location:	Kitchen	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink - Northeast Center		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-11	Location:	Kitchen Serving	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-12	Location:	Cafetorium C100	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Left - By Gym Doors		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-13	Location:	Cafetorium C100	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Right - By Gym Doors		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-14	Location:	Cafetorium C100	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler - By Gym Doors		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-15	Location:	C124 Lounge	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-16	Location:	C124 Lounge	
Photo:		Manufacturer:	Hoshizaki	
		Description:		
		Ice Machine		
		Result:	<1.0	ppb
Date Sampled:		1/2/2023	By:	JH
Recommended Action:				


ID:	386-WMS-17	Location:	By C116	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Left		
		Result:	<1.0	ppb
Date Sampled:		1/2/2023	By:	JH
Recommended Action:				

ID:	386-WMS-18	Location:	By C116	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Right		
		Result:	<1.0	ppb
Date Sampled:		1/2/2023	By:	JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-19	Location:	By C116	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-20	Location:	Girls Locker Room	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-21	Location:	Girls Locker Room	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-22	Location:	Staff RR By LR	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-23	Location:	Hall By D108B	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Left		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-24	Location:	Hall By D108B	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-25	Location:	Hall By D108B	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-26	Location:	Boys Locker Room	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-27	Location:	Boys Locker Room	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-28	Location:	Rm D121	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink - Kitchen 5		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


ID:	386-WMS-29	Location:	Rm D121	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink - Kitchen 6		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-30	Location:	Rm D121	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink - Teacher's Demonstration		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-31	Location:	Rm D121	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink - Kitchen 1		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


ID:	386-WMS-32	Location:	Rm D121	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink - Kitchen 2		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-33	Location:	Rm D121	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink - Kitchen 3		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District

ID:	386-WMS-34	Location:	Rm D121	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink - Kitchen 4		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


ID:	386-WMS-35	Location:	A106 Nurse	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-36	Location:	A106 Nurse RR	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-37	Location:	A108 Copy	
Photo:		Manufacturer:	Delta	
		Description:		
		Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


ID:	386-WMS-38	Location:	A108 Restroom	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	2.37	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-39	Location:	Hall Staff RR By A117	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	2.97	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-40	Location:	Pod A122-130 Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-41	Location:	Pod A122-130 Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-42	Location:	Pod A122-130 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-43	Location:	Pod A122-130 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-44	Location:	Pod A122-130 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-45	Location:	Pod A122-130 Wmns RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

Drinking Water Assessment  
Walden Middle School  
Park Hill School District

ID:	386-WMS-46	Location:	Pod A122-130 Wmns RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-47	Location:	Pod A122-130 Staff RR	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-48	Location:	Pod A131-137 Staff RR	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment

Walden Middle School


Park Hill School District


ID:	386-WMS-49	Location:	Pod A31-137 Wmns RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Hand Washing Sink - Left			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH


ID:	386-WMS-50	Location:	Pod A31-137 Wmns RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Hand Washing Sink - Right			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH

ID:	386-WMS-51	Location:	Pod A131-137 RR		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		Drinking Fountain Bubbler - Left			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-52	Location:	Pod A122-130 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-53	Location:	Pod A131-137 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-54	Location:	Pod A131-137 Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-55	Location:	Pod A131-137 Mens RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Hand Washing Sink - Right			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH


ID:	386-WMS-56	Location:	A155		
Photo:		Manufacturer:	Masco		
		Description:			
		Sink - Left Faucet			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH

ID:	386-WMS-57	Location:	A155		
Photo:		Manufacturer:	Masco		
		Description:			
		Sink - Right Faucet			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-58	Location:	A155	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink		
		Result:	<1.0	ppb
Date Sampled:		1/2/2023	By:	JH
Recommended Action:				


ID:	386-WMS-59	Location:	B100	
Photo:		Manufacturer:	Masco	
		Description:		
		Sink - Left Faucet		
		Result:	<1.0	ppb
Date Sampled:		1/2/2023	By:	JH
Recommended Action:				

ID:	386-WMS-60	Location:	B100	
Photo:		Manufacturer:	Masco	
		Description:		
		Sink - Right Faucet		
		Result:	<1.0	ppb
Date Sampled:		1/2/2023	By:	JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-61	Location:	Pod B104-110 Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-62	Location:	Pod B104-110 Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-63	Location:	Pod B104-110 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-64	Location:	Pod B104-110 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-65	Location:	Pod B104-110 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-66	Location:	Pod B104-110 Wmns RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-67	Location:	Pod B104-110 Wmns RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


ID:	386-WMS-68	Location:	Pod B104-110 Staff RR	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-69	Location:	Pod B111-118 Staff RR	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-70	Location:	Pod B111-118 Wmns RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Hand Washing Sink - Left			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH


ID:	386-WMS-71	Location:	Pod B111-118 Wmns RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Hand Washing Sink - Right			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH

ID:	386-WMS-72	Location:	Pod B111-118 RR		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		Drinking Fountain Bubbler - Left			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-73	Location:	Pod B111-118 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-74	Location:	Pod B111-118 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-75	Location:	Pod B111-118 Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-76	Location:	Pod B111-118 Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


ID:	386-WMS-77	Location:	Cafetorium C100	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler - Left - By C127		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-78	Location:	Cafetorium C100	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bubbler - Right - By C127		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-79	Location:	Cafetorium C100	
Photo:		Manufacturer:	Murdock	
		Description:		
		Drinking Fountain Bottle Filler - By C127		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-80	Location:	C127	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-81	Location:	Womens RR By C127	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District

ID:	386-WMS-82	Location:	Womens RR By C127	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-83	Location:	Mens RR By C127	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-84	Location:	Mens RR By C127	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-85	Location:	Pod A216-224 Staff RR	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-86	Location:	Pod A216-224 Wmns RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-87	Location:	Pod A216-224 Wmns RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

Drinking Water Assessment  
Walden Middle School  
Park Hill School District

ID:	386-WMS-88	Location:	Pod A216-224 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Left		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


ID:	386-WMS-89	Location:	Pod A216-224 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


ID:	386-WMS-90	Location:	Pod A216-224 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH


Drinking Water Assessment

Walden Middle School


Park Hill School District


ID:	386-WMS-91	Location:	Pod A216-224 Mens RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Hand Washing Sink - Left			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH


ID:	386-WMS-92	Location:	Pod A216-224 Mens RR		
Photo:		Manufacturer:	Sloan		
		Description:			
		Hand Washing Sink - Right			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH

ID:	386-WMS-93	Location:	Pod A225-231 Staff RR		
Photo:		Manufacturer:	Delta		
		Description:			
		Hand Washing Sink			
		Result:	<1.0	ppb	
Recommended Action:		Date Sampled:	1/2/2023	By:	JH


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-94	Location:	Pod A225-231 Wmns RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-95	Location:	Pod A225-231 Wmns RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-96	Location:	Pod A225-231 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-97	Location:	Pod A225-231 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler - Right		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


ID:	386-WMS-98	Location:	Pod A225-231 RR	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				

ID:	386-WMS-99	Location:	Pod A225-231 Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Left		
		Result:	<1.0	ppb
		Date Sampled:	1/2/2023	By: JH
Recommended Action:				


Drinking Water Assessment  
Walden Middle School  
Park Hill School District


ID:	386-WMS-100	Location:	Pod A225-231 Mens RR	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink - Right		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-101	Location:	Library A203	
Photo:		Manufacturer:	Delta	
		Description:		
		Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

ID:	386-WMS-102	Location:	A108	
Photo:		Manufacturer:	Summit	
		Description:		
		Ice Machine		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/2/2023	By: JH

Drinking Water Assessment  
Walden Middle School  
Park Hill School District

ID:	386-WMS-103	Location:	Ext Soccer Field	
Photo:		Manufacturer:	Woodford	
		Description:		
		Yard Hydrant		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	5/30/2024	By: JH

ID:	386-WMS-104	Location:	Ext. Track Bleachers	
Photo:		Manufacturer:	Woodford	
		Description:		
		Yard Hydrant		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	5/30/2024	By: JH



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

January 20, 2024

Jeremie Kahler  
Park Hill School District  
9501 N. Seymour Ave  
MO, MO 64153

RE: 923386-Walden Middle School

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **99** sample(s) the laboratory received on **1/4/24 12:00 pm** and logged in under work order **HA00766**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or [lisa.grant@pacelabs.com](mailto:lisa.grant@pacelabs.com).

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes', is positioned above the printed name and contact information.

Chenise Lambert-Sykes  
Project Manager  
(314)432-0550  
[Chenise.Lambert-Sykes@pacelabs.com](mailto:Chenise.Lambert-Sykes@pacelabs.com)

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

---

---

Work Order      HA00766

---

---

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



## ANALYTICAL RESULTS

**Sample:** HA00766-01  
**Name:** 386-WMS-001  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 07:52  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:15	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-02  
**Name:** 386-WMS-002  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 07:53  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:17	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-03  
**Name:** 386-WMS-003  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 07:54  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-04  
**Name:** 386-WMS-004  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 07:55  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:20	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-05  
Name: 386-WMS-005  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 07:56  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:22	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-06  
Name: 386-WMS-006  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 07:56  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-07  
Name: 386-WMS-007  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 07:59  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.50	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:28	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-08  
Name: 386-WMS-008  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:00  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:29	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-09  
Name: 386-WMS-009  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:00  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:31	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-10  
Name: 386-WMS-010  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:03  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:36	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-11  
Name: 386-WMS-011  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:04  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:37	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-12  
Name: 386-WMS-012  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:06  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:39	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA00766-13  
**Name:** 386-WMS-013  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 08:06  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:40	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-14  
**Name:** 386-WMS-014  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 08:06  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:45	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-15  
**Name:** 386-WMS-015  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 08:10  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-16  
**Name:** 386-WMS-016  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 08:11  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:48	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-17  
Name: 386-WMS-017  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:15  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:50	BRS	EPA 200.8 REV 5.4

Sample: HA00766-18  
Name: 386-WMS-018  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:15  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:51	BRS	EPA 200.8 REV 5.4

Sample: HA00766-19  
Name: 386-WMS-019  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:15  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:56	BRS	EPA 200.8 REV 5.4

Sample: HA00766-20  
Name: 386-WMS-020  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:18  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>									
Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:58	BRS	EPA 200.8 REV 5.4



## ANALYTICAL RESULTS

Sample: HA00766-21  
Name: 386-WMS-021  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:18  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 14:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-22  
Name: 386-WMS-022  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:20  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-23  
Name: 386-WMS-023  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:21  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-24  
Name: 386-WMS-024  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:21  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:07	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-25  
Name: 386-WMS-025  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:21  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:08	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-26  
Name: 386-WMS-026  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:26  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:10	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-27  
Name: 386-WMS-027  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:26  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-28  
Name: 386-WMS-028  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:29  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:13	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-29  
Name: 386-WMS-029  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:29  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-30  
Name: 386-WMS-030  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:29  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:22	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-31  
Name: 386-WMS-031  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:31  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:24	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-32  
Name: 386-WMS-032  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:31  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-33  
Name: 386-WMS-033  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:31  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:27	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-34  
Name: 386-WMS-034  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:31  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:29	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-35  
Name: 386-WMS-035  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:38  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:30	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-36  
Name: 386-WMS-036  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:38  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:32	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-37  
Name: 386-WMS-037  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:40  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:33	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-38  
Name: 386-WMS-038  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:41  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.37	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:35	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-39  
Name: 386-WMS-039  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:44  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.97	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:43	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-40  
Name: 386-WMS-040  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:46  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-41  
Name: 386-WMS-041  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:46  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:46	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-42  
Name: 386-WMS-042  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:48  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-43  
Name: 386-WMS-043  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:48  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:49	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-44  
Name: 386-WMS-044  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:48  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:50	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-45  
Name: 386-WMS-045  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:50  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:52	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-46  
Name: 386-WMS-046  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:50  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:53	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-47  
Name: 386-WMS-047  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 08:56  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 15:55	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-48  
Name: 386-WMS-048  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:00  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:00	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-49  
Name: 386-WMS-049  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:02  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-50  
Name: 386-WMS-050  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:02  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:06	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-51  
Name: 386-WMS-051  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:05  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:07	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-52  
Name: 386-WMS-052  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:05  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-53  
Name: 386-WMS-053  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:05  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:10	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-54  
Name: 386-WMS-054  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:07  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-55  
Name: 386-WMS-055  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:07  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-56  
Name: 386-WMS-056  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:11  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-57  
Name: 386-WMS-057  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:11  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:20	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-58  
Name: 386-WMS-058  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:11  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:21	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-59  
Name: 386-WMS-059  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:13  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-60  
Name: 386-WMS-060  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:13  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-61  
Name: 386-WMS-061  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:17  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:29	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-62  
Name: 386-WMS-062  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:17  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:31	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-63  
Name: 386-WMS-063  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:19  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:32	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-64  
Name: 386-WMS-064  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:19  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:37	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA00766-65  
**Name:** 386-WMS-065  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 09:19  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:38	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-66  
**Name:** 386-WMS-066  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 09:21  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:40	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-67  
**Name:** 386-WMS-067  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 09:21  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:41	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-68  
**Name:** 386-WMS-068  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 09:23  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:43	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-69  
Name: 386-WMS-069  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:42  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:48	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-70  
Name: 386-WMS-070  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:43  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:49	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-71  
Name: 386-WMS-071  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:43  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:51	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-72  
Name: 386-WMS-072  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:45  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:55	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-73  
Name: 386-WMS-073  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:45  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:57	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-74  
Name: 386-WMS-074  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:45  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 16:58	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-75  
Name: 386-WMS-075  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:47  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:00	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-76  
Name: 386-WMS-076  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:47  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:02	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-77  
Name: 386-WMS-077  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:49  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:03	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-78  
Name: 386-WMS-078  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:49  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-79  
Name: 386-WMS-079  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:49  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-80  
Name: 386-WMS-080  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:53  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

Sample: HA00766-81  
Name: 386-WMS-081  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:55  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:16	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-82  
Name: 386-WMS-082  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:55  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:17	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-83  
Name: 386-WMS-083  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:57  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:19	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA00766-84  
Name: 386-WMS-084  
Matrix: Drinking Water - Grab

Sampled: 12/30/23 09:57  
Received: 01/04/24 12:00  
PO #: WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:20	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA00766-85  
**Name:** 386-WMS-085  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:00  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:22	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-86  
**Name:** 386-WMS-086  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:02  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:23	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-87  
**Name:** 386-WMS-087  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:02  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:25	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-88  
**Name:** 386-WMS-088  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:04  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA00766-89  
**Name:** 386-WMS-089  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:04  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:34	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-90  
**Name:** 386-WMS-090  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:04  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:36	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-91  
**Name:** 386-WMS-091  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:06  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:37	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-92  
**Name:** 386-WMS-092  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:06  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:39	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA00766-93  
**Name:** 386-WMS-093  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:11  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:40	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-94  
**Name:** 386-WMS-094  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:12  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:42	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-95  
**Name:** 386-WMS-095  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:12  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-96  
**Name:** 386-WMS-096  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:14  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:45	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## ANALYTICAL RESULTS

**Sample:** HA00766-97  
**Name:** 386-WMS-097  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:14  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-98  
**Name:** 386-WMS-098  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:14  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:51	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00766-99  
**Name:** 386-WMS-099  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:16  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

**Total Metals - PIA**

Lead	< 1.00	ug/L		01/15/24 11:05	1	1.00	01/15/24 17:56	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

\* Not a TNI accredited analyte

### Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager



REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Walden Middle School		PURCHASE ORDER # WMS2324		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 12/30/2023		+ +		LOGIN # <u>HA00766</u>	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE <u>[Signature]</u>		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHL- LEACHATE LO- OIL SO- SOIL SOL- SOLID		DW Lead Turb Check		LOGGED BY: <u>gex</u>	
CONTACT PERSON Jeremie Kahler										CLIENT: <u>Park Hill School District</u>	
										PROJECT: <u>Drinking Water Lead</u>	
										PROJ. MGR.: <u>Chenise Lambert-Sykes</u>	
										CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS
386-WMS- 001		12/30/2023	0752	X		DW	1	6	X		
386-WMS- 002		12/30/2023	0753	X		DW	1	6	X		
386-WMS- 003		12/30/2023	0754	X		DW	1	6	X		
386-WMS- 004		12/30/2023	0755	X		DW	1	6	X		
386-WMS- 005		12/30/2023	0756	X		DW	1	6	X		
386-WMS- 006		12/30/2023	0756	X		DW	1	6	X		
386-WMS- 007		12/30/2023	0759	X		DW	1	6	X		
386-WMS- 008		12/30/2023	0800	X		DW	1	6	X		
386-WMS- 009		12/30/2023	0806	X		DW	1	6	X		
386-WMS- 010		12/30/2023	0803	X		DW	1	6	X		
386-WMS- 011		12/30/2023	0804	X		DW	1	6	X		
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)				NORMAL RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.			
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE								PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____			
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:											
7 RELINQUISHED BY: (SIGNATURE)		DATE 12/30/23	RECEIVED BY: (SIGNATURE)		DATE	8 COMMENTS: (FOR LAB USE ONLY)					
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE	SAMPLE TEMPERATURE UPON RECEIPT _____ °C					
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE	CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N					
		TIME			TIME	SAMPLE(S) RECEIVED ON ICE Y OR N					
		TIME			TIME	SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N					
		TIME			TIME	DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____					



REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

<b>1 CLIENT</b> Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 PHONE NUMBER 8163596731		PROJECT LOCATION Walden Middle School E-MAIL KahlerJ@parkhill.k12.mo.us		PURCHASE ORDER # WMS2324 DATE SHIPPED 12/30/2023		<b>3 ANALYSIS REQUESTED</b> + + DW Lead Turb Check		<b>4 (FOR LAB USE ONLY)</b> LOGIN # <u>HA00766</u> LOGGED BY: <u>[Signature]</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
<b>2 SAMPLE DESCRIPTION</b> (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead Turb Check		REMARKS	
386-WMS- <u>012</u>		12/30/2023	<u>0806</u>	X		DW	1	6	X		
386-WMS- <u>013</u>		12/30/2023	<u>0806</u>	X		DW	1	6	X		
386-WMS- <u>014</u>		12/30/2023	<u>0806</u>	X		DW	1	6	X		
386-WMS- <u>015</u>		12/30/2023	<u>0810</u>	X		DW	1	6	X		
386-WMS- <u>016</u>		12/30/2023	<u>0811</u>	X		DW	1	6	X		
386-WMS- <u>017</u>		12/30/2023	<u>0815</u>	X		DW	1	6	X		
386-WMS- <u>018</u>		12/30/2023	<u>0815</u>	X		DW	1	6	X		
386-WMS- <u>019</u>		12/30/2023	<u>0815</u>	X		DW	1	6	X		
386-WMS- <u>020</u>		12/30/2023	<u>0818</u>	X		DW	1	6	X		
386-WMS- <u>021</u>		12/30/2023	<u>0818</u>	X		DW	1	6	X		
386-WMS- <u>022</u>		12/30/2023	<u>0820</u>	X		Dw	1	6	X		
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
<b>5</b> TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		<b>6</b> I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____							
<b>7</b> RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE TIME 12/30/23 1400		RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE)		DATE TIME DATE TIME DATE TIME 1/4/24 1200		<b>8</b> COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			



REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

<b>1 CLIENT</b> Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		<b>PROJECT NUMBER</b> 923386 <b>PHONE NUMBER</b> 8163596731		<b>PROJECT LOCATION</b> Walden Middle School <b>E-MAIL</b> KahlerJ@parkhill.k12.mo.us		<b>PURCHASE ORDER #</b> WMS2324 <b>DATE SHIPPED</b> 12/30/2023		<b>3 ANALYSIS REQUESTED</b> + + DW Lead Turb Check		<b>4 (FOR LAB USE ONLY)</b> LOGIN # <u>H400766</u> LOGGED BY: <u>[Signature]</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
<b>2 SAMPLE DESCRIPTION</b> (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		<b>DATE COLLECTED</b>	<b>TIME COLLECTED</b>	<b>SAMPLE TYPE</b> GRAB COMP	<b>MATRIX TYPE</b>	<b>BOTTLE COUNT</b>	<b>PRE CODE</b> CLIENT PROVIDED	<b>REMARKS</b>			
386-WMS-023		12/30/2023	0821	X	DW	1	6	X			
386-WMS-024		12/30/2023	0821	X	DW	1	6	X			
386-WMS-025		12/30/2023	0821	X	DW	1	6	X			
386-WMS-026		12/30/2023	0826	X	DW	1	6	X			
386-WMS-027		12/30/2023	0826	X	DW	1	6	X			
386-WMS-028		12/30/2023	0829	X	DW	1	6	X			
386-WMS-029		12/30/2023	0829	X	DW	1	6	X			
386-WMS-030		12/30/2023	0829	X	DW	1	6	X			
386-WMS-031		12/30/2023	0831	X	DW	1	6	X			
386-WMS-032		12/30/2023	0831	X	DW	1	6	X			
386-WMS-033		12/30/2023	0831	X	DW	1	6	X			
<b>CHEMICAL PRESERVATION CODES:</b> 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
<b>5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE)</b> (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				<b>DATE RESULTS NEEDED</b>		<b>6</b> I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
<b>7 RELINQUISHED BY: (SIGNATURE)</b> <u>[Signature]</u>		<b>DATE</b> 12/30/23 <b>TIME</b> 1400		<b>RECEIVED BY: (SIGNATURE)</b> _____				<b>DATE</b> _____ <b>TIME</b> _____		<b>8 COMMENTS: (FOR LAB USE ONLY)</b> SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____	
<b>RELINQUISHED BY: (SIGNATURE)</b> _____		<b>DATE</b> _____ <b>TIME</b> _____		<b>RECEIVED BY: (SIGNATURE)</b> _____				<b>DATE</b> _____ <b>TIME</b> _____			
<b>RELINQUISHED BY: (SIGNATURE)</b> _____		<b>DATE</b> _____ <b>TIME</b> _____		<b>RECEIVED BY: (SIGNATURE)</b> <u>grace</u>				<b>DATE</b> 1/4/24 <b>TIME</b> 1200			



REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Walden Middle School		PURCHASE ORDER # WMS2324		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 12/30/2023		+		LOGIN # <u>HAC00762</u>	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOL SOL- SOLID		DW Lead		Turb Check	
CONTACT PERSON Jeremie Kahler										LOGGED BY: <u>gjs</u>	
										CLIENT: <u>Park Hill School District</u>	
										PROJECT: <u>Drinking Water Lead</u>	
										PROJ. MGR.: <u>Chenise Lambert-Sykes</u>	
										CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead		Turb Check	
386-WMS- <u>034</u>		12/30/2023	<u>0831</u>	X	DW	1	6	X			
386-WMS- <u>035</u>		12/30/2023	<u>0838</u>	X	DW	1	6	X			
386-WMS- <u>036</u>		12/30/2023	<u>0838</u>	X	DW	1	6	X			
386-WMS- <u>037</u>		12/30/2023	<u>0840</u>	X	DW	1	6	X			
386-WMS- <u>038</u>		12/30/2023	<u>0841</u>	X	DW	1	6	X			
386-WMS- <u>039</u>		12/30/2023	<u>0844</u>	X	DW	1	6	X			
386-WMS- <u>040</u>		12/30/2023	<u>0846</u>	X	DW	1	6	X			
386-WMS- <u>041</u>		12/30/2023	<u>0846</u>	X	DW	1	6	X			
386-WMS- <u>042</u>		12/30/2023	<u>0848</u>	X	DW	1	6	X			
386-WMS- <u>043</u>		12/30/2023	<u>0848</u>	X	DW	1	6	X			
386-WMS- <u>044</u>		12/30/2023	<u>0848</u>	X	DW	1	6	X			
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.					
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE						PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:									
7 RELINQUISHED BY: (SIGNATURE) 		DATE 12/30/23 TIME 1400		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT _____ °C			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE) 		DATE 114124 TIME 1200		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N			
								DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			

FedEx



REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

<b>1 CLIENT</b> Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		PROJECT NUMBER 923386 PHONE NUMBER 8163596731		PROJECT LOCATION Walden Middle School E-MAIL Kahler.J@parkhill.k12.mo.us		PURCHASE ORDER # WMS2324 DATE SHIPPED 12/30/2023		<b>3 ANALYSIS REQUESTED</b> + + DW Lead Turb Check		<b>4 (FOR LAB USE ONLY)</b> LOGIN # <u>HA00766</u> LOGGED BY: <u>gls</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
<b>2 SAMPLE DESCRIPTION</b> (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS		
386-WMS-045		12/30/2023	0850	X		DW	1	6	X		
386-WMS-046		12/30/2023	0850	X		DW	1	6	X		
386-WMS-047		12/30/2023	0852	X		DW	1	6	X		
386-WMS-048		12/30/2023	0900	X		DW	1	6	X		
386-WMS-049		12/30/2023	0902	X		DW	1	6	X		
386-WMS-050		12/30/2023	0902	X		DW	1	6	X		
386-WMS-051		12/30/2023	0905	X		DW	1	6	X		
386-WMS-052		12/30/2023	0905	X		DW	1	6	X		
386-WMS-053		12/30/2023	0905	X		DW	1	6	X		
386-WMS-054		12/30/2023	0907	X		DW	1	6	X		
386-WMS-055		12/30/2023	0907	X		Dw	1	6	X		
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
<b>5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE)</b> (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		<b>6</b> I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____							
<b>7 RELINQUISHED BY: (SIGNATURE)</b> <u>Jeremie Kahler</u> RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	<b>8 COMMENTS: (FOR LAB USE ONLY)</b> SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			
		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME				
		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME				







REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Walden Middle School		PURCHASE ORDER # WMS2324		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL Kahler.J@parkhill.k12.mo.us		DATE SHIPPED 12/30/2023		+ +		LOGIN # <u>HA00766</u>	
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE <i>[Signature]</i>		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead		CLIENT	
CONTACT PERSON Jeremie Kahler								Turb Check		LOGGED BY: <i>[Signature]</i>	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED			REMARKS
386-WMS- 067	12/30/2023	0921	X		DW	1	6	X			
386-WMS- 068	12/30/2023	0923	X		DW	1	6	X			
386-WMS- 069	12/30/2023	0942	X		DW	1	6	X			
386-WMS- 070	12/30/2023	0943	X		DW	1	6	X			
386-WMS- 071	12/30/2023	0943	X		DW	1	6	X			
386-WMS- 072	12/30/2023	0945	X		DW	1	6	X			
386-WMS- 073	12/30/2023	0945	X		DW	1	6	X			
386-WMS- 074	12/30/2023	0945	X		DW	1	6	X			
386-WMS- 075	12/30/2023	0947	X		DW	1	6	X			
386-WMS- 076	12/30/2023	0947	X		DW	1	6	X			
386-WMS- 077	12/30/2023	0949	X		Dw	1	6	X			0949
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.					
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE						PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:											
7 RELINQUISHED BY: (SIGNATURE)		DATE 12/30/23	TIME 1400	RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT _____ °C			
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N			
		DATE	TIME			DATE		SAMPLE(S) RECEIVED ON ICE Y OR N			
		DATE	TIME			DATE		SAMPLE ACCEPTANCE NONCONFORMANT Y OR N			
		DATE	TIME			DATE		REPORT IS NEEDED Y OR N			
		DATE	TIME			DATE		DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			



REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

# CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

<b>1 CLIENT</b> Park Hill School District ADDRESS 9501 N. Seymour Ave. CITY STATE ZIP Kansas City, MO 64153 CONTACT PERSON Jeremie Kahler		<b>PROJECT NUMBER</b> 923386 <b>PHONE NUMBER</b> 8163596731		<b>PROJECT LOCATION</b> Walden Middle School <b>E-MAIL</b> KahlerJ@parkhill.k12.mo.us		<b>PURCHASE ORDER #</b> WMS2324 <b>DATE SHIPPED</b> 12/30/2023		<b>3 ANALYSIS REQUESTED</b> + + DW Lead Turb Check		<b>4 (FOR LAB USE ONLY)</b> LOGIN # <u>HA00766</u> LOGGED BY: <u>[Signature]</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
<b>2 SAMPLE DESCRIPTION</b> (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		<b>DATE COLLECTED</b>	<b>TIME COLLECTED</b>	<b>SAMPLE TYPE</b> GRAB COMP	<b>MATRIX TYPE</b>	<b>BOTTLE COUNT</b>	<b>PRES CODE</b> CLIENT PROVIDED	<b>REMARKS</b>			
386-WMS-078		12/30/2023	0949	X	DW	1	6	X			
386-WMS-079		12/30/2023	0949	X	DW	1	6	X			
386-WMS-080		12/30/2023	0953	X	DW	1	6	X			
386-WMS-081		12/30/2023	0955	X	DW	1	6	X			
386-WMS-082		12/30/2023	0955	X	DW	1	6	X			
386-WMS-083		12/30/2023	0957	X	DW	1	6	X			
386-WMS-084		12/30/2023	0957	X	DW	1	6	X			
386-WMS-085		12/30/2023	1000	X	DW	1	6	X			
386-WMS-086		12/30/2023	1002	X	DW	1	6	X			
386-WMS-087		12/30/2023	1002	X	DW	1	6	X			
386-WMS-088		12/30/2023	1004	X	Dw	1	6	X			
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER											
<b>5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE)</b> <u>NORMAL</u> RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				<b>DATE RESULTS NEEDED</b>		<b>6</b> I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____					
<b>7 RELINQUISHED BY: (SIGNATURE)</b> <u>[Signature]</u>		<b>DATE</b> 12/30/2023 <b>TIME</b> 1400		<b>RECEIVED BY: (SIGNATURE)</b> _____		<b>DATE</b> _____ <b>TIME</b> _____		<b>8 COMMENTS: (FOR LAB USE ONLY)</b> SAMPLE TEMPERATURE UPON RECEIPT _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT <u>Y OR N</u> SAMPLE(S) RECEIVED ON ICE <u>Y OR N</u> SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED <u>Y OR N</u> DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____			
<b>RELINQUISHED BY: (SIGNATURE)</b> _____		<b>DATE</b> _____ <b>TIME</b> _____		<b>RECEIVED BY: (SIGNATURE)</b> _____		<b>DATE</b> _____ <b>TIME</b> _____					
<b>RELINQUISHED BY: (SIGNATURE)</b> _____		<b>DATE</b> _____ <b>TIME</b> _____		<b>RECEIVED BY: (SIGNATURE)</b> <u>[Signature]</u>		<b>DATE</b> 1/4/24 <b>TIME</b> 1200					









Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

January 20, 2024

Jeremie Kahler  
Park Hill School District  
9501 N. Seymour Ave  
MO, MO 64153

RE: 923389-Walden Middle School

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **3** sample(s) the laboratory received on **1/4/24 12:00 pm** and logged in under work order **HA00769**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or [lisa.grant@pacelabs.com](mailto:lisa.grant@pacelabs.com).

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes  
Project Manager  
(314)432-0550  
[Chenise.Lambert-Sykes@pacelabs.com](mailto:Chenise.Lambert-Sykes@pacelabs.com)

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

---

Work Order      HA00769

---

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



## ANALYTICAL RESULTS

**Sample:** HA00769-01  
**Name:** 386-WMS-100  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:16  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/16/24 08:53	1	1.00	01/16/24 09:10	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00769-02  
**Name:** 386-WMS-101  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:20  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/16/24 08:53	1	1.00	01/16/24 09:11	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HA00769-03  
**Name:** 386-WMS-102  
**Matrix:** Drinking Water - Grab

**Sampled:** 12/30/23 10:24  
**Received:** 01/04/24 12:00  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/16/24 08:53	1	1.00	01/16/24 09:13	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

\* Not a TNI accredited analyte

### Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager







Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

June 07, 2024

Jeremie Kahler  
Park Hill School District  
9501 N. Seymour Ave  
MO, MO 64153

RE: 923386-Walden Middle School

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **2** sample(s) the laboratory received on **6/3/24 10:45 am** and logged in under work order **HF00109**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or [lisa.grant@pacelabs.com](mailto:lisa.grant@pacelabs.com).

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes', is positioned above the printed name and contact information.

Chenise Lambert-Sykes  
Project Manager  
(314)432-0550  
[Chenise.Lambert-Sykes@pacelabs.com](mailto:Chenise.Lambert-Sykes@pacelabs.com)



**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

---

Work Order      HF00109

---

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



## ANALYTICAL RESULTS

**Sample:** HF00109-01  
**Name:** 386-WMS-103  
**Matrix:** Drinking Water - Grab

**Sampled:** 05/30/24 06:37  
**Received:** 06/03/24 10:45  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		06/05/24 11:29	1	1.00	06/05/24 18:22	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

**Sample:** HF00109-02  
**Name:** 386-WMS-104  
**Matrix:** Drinking Water - Grab

**Sampled:** 05/30/24 06:40  
**Received:** 06/03/24 10:45  
**PO #:** WMS2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		06/05/24 11:29	1	1.00	06/05/24 18:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



## NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

\* Not a TNI accredited analyte

### Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager



