
February 6, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave,
Kansas City, MO 64153

RE: Drinking Water Sampling – Lead Innovation Studio
7201 N Line Creek Parkway, Kansas City, MO 64151
Project Number: 923386

Mr. Kahler,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Lead Innovation Studio in Kansas City, Missouri. The sampling was requested and approved by Mr. Jeremie Kahler of Park Hill School District (PHSD). OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the "Get the Lead Out of School Drinking Water Act".

METHODOLOGY

On 1/15/2024 Mr. Jay Hurst of OCCU-TEC completed testing of sixty-one (61) sources throughout Lead Innovation Studio. Samples were collected as 'First Draw' samples after the fixtures had remained unused for a minimum period of eight (8) hours while not exceeding a maximum period of eighteen (18) hours. Samples were collected in dedicated 250 milliliter laboratory-provided plastic sample containers.

Samples were shipped to Pace Analytical Services, LLC (Pace) of Peoria, Illinois for analysis using Environmental Protection Agency (EPA) method 200.8. Pace is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification numbers 00236 and 00870. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) outlined in Missouri Senate Bill 681/662. Of the samples collected, zero (0) of the Sixty-one (61) contained lead concentrations at or above 5 ppb. Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
No samples collected contained results above 5 ug/L (ppb)			

LIMITATIONS

At the request of PHSD, Lab sinks, janitorial sinks, eyewash stations, showers, and exterior spigots not identified as drinking water were excluded from sampling. In addition to the excluded sources, the following table identifies sources which were not operational at the time of sampling and therefore not sampled. In accordance with the requirements set forth in Missouri Bill 681/662, all sources not sampled during this assessment should be labeled to indicate that the source is not to be used for drinking water or sampled and compared to the regulatory limit of 5 ppb prior to bringing back into service.

Sample ID	Location	Type
All Identified Sources Were Operational		

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662:

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days after receiving test results exceeding 5 ppb. The notification shall include the following:

- Test results and a summary explaining the results.

- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25 percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to PHSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Jay W. Hurst
Vice President of Operations





Jeff Smith
Senior Project Manager (QA/QC)


ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-01	Location:	Kitchen Restroom	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-02	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-03	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Skillet Faucet		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-04	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Skillet Sprayer		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-05	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink		
		Result:	4.99	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-06	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Sink Faucet		
		Result:	2.43	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-07	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Dish Sprayer		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-08	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Sink (Left Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-09	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Sink (Right Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-10	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Dish Sprayer		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-11	Location:	Kitchen A108	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-12	Location:	Serving A105	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Sink		
		Result:	4.03	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-13	Location:	Serving A105	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink		
		Result:	1.75	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-14	Location:	Serving A105	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Hand Washing Sink		
		Result:	1.88	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-15	Location:	Serving A105	
Photo:		Manufacturer:	T&S Brass	
		Description:		
		Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-16	Location:	Hall By A113	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				


ID:	386-LI-17	Location:	Hall By A113	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				

ID:	386-LI-18	Location:	Hall By A113	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-19	Location:	A116	
Photo:		Manufacturer:	Unknown	
		Description:		
		Hand Washing Sink (Left Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				


ID:	386-LI-20	Location:	A116	
Photo:		Manufacturer:	Unknown	
		Description:		
		Hand Washing Sink (Right Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				

ID:	386-LI-21	Location:	A119	
Photo:		Manufacturer:	Unknown	
		Description:		
		Hand Washing Sink (Left Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-22	Location:	A119	
Photo:		Manufacturer:	Unknown	
		Description:		
		Hand Washing Sink (Right Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-23	Location:	Kitchen A108	
Photo:		Manufacturer:	Bunn	
		Description:		
		Hot Water Dispenser		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-24	Location:	Coffee Bar A104	
Photo:		Manufacturer:	Franke	
		Description:		
		Coffee Maker		
		Result:	3.13	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-25	Location:	Staff Restroom By B103		
Photo:		Manufacturer:	Delta		
		Description:			
		Hand Washing Sink			
		Result:	<1.0	ppb	
		Date Sampled:	1/15/2024	By:	JH
Recommended Action:					


ID:	386-LI-26	Location:	B103		
Photo:		Manufacturer:	Unknown		
		Description:			
		Sink			
		Result:	<1.0	ppb	
		Date Sampled:	1/15/2024	By:	JH
Recommended Action:					

ID:	386-LI-27	Location:	B103		
Photo:		Manufacturer:	Samsung		
		Description:			
		Ice Maker			
		Result:	<1.0	ppb	
		Date Sampled:	1/15/2024	By:	JH
Recommended Action:					


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-28	Location:	Restroom By B118	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Left Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-29	Location:	Restroom By B118	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Center Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-30	Location:	Restroom By B118	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Right Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-31	Location:	Hall By B118		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		Drinking Fountain Bubbler (Left)			
		Result:	<1.0	ppb	
		Date Sampled:	1/15/2024	By:	JH
Recommended Action:					


ID:	386-LI-32	Location:	Hall By B118		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		Drinking Fountain Bubbler (Right)			
		Result:	<1.0	ppb	
		Date Sampled:	1/15/2024	By:	JH
Recommended Action:					

ID:	386-LI-33	Location:	Hall By B118		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		Drinking Fountain Bottle Filler			
		Result:	<1.0	ppb	
		Date Sampled:	1/15/2024	By:	JH
Recommended Action:					


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-34	Location:	Staff Restroom By A213	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-35	Location:	Hall By A218	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-36	Location:	Hall By A218	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-37	Location:	Hall By A218
Photo:		Manufacturer:	Halsey Taylor
		Description:	
		Drinking Fountain Bottle Filler	
		Result:	<1.0
Date Sampled:		1/15/2024	By: JH
Recommended Action:			


ID:	386-LI-38	Location:	A232 Health
Photo:		Manufacturer:	Unknown
		Description:	
		Sink	
		Result:	<1.0
Date Sampled:		1/15/2024	By: JH
Recommended Action:			

ID:	386-LI-39	Location:	A232 Health
Photo:		Manufacturer:	Delta
		Description:	
		Hand Washing Sink	
		Result:	<1.0
Date Sampled:		1/15/2024	By: JH
Recommended Action:			


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-40	Location:	A225 Hospitality	
Photo:		Manufacturer:	Delta	
		Description:		
		Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-41	Location:	A225 Hospitality	
Photo:		Manufacturer:	Samsung	
		Description:		
		Ice Maker		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-42	Location:	Reception By A225	
Photo:		Manufacturer:	Unknown	
		Description:		
		Sink		
		Result:	1.28	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District

ID:	386-LI-43	Location:	B207	
Photo:		Manufacturer:	Unknown	
		Description:		
		Hand Washing Sink (Left Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				

ID:	386-LI-44	Location:	B207	
Photo:		Manufacturer:	Unknown	
		Description:		
		Hand Washing Sink (Right Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				

ID:	386-LI-45	Location:	B210	
Photo:		Manufacturer:	Unknown	
		Description:		
		Hand Washing Sink (Left Faucet)		
		Result:	1.49	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-46	Location:	B210	
Photo:		Manufacturer:	Unknown	
		Description:		
		Hand Washing Sink (Right Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-47	Location:	Restroom By B202	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Left Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-48	Location:	Restroom By B202	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Right Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-49	Location:	Hall By B202	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-50	Location:	Hall By B202	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-51	Location:	Hall By B202	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-52	Location:	Staff Restroom By A315		
Photo:		Manufacturer:	Delta		
		Description:			
		Hand Washing Sink			
		Result:	<1.0	ppb	
		Date Sampled:	1/15/2024	By:	JH
Recommended Action:					


ID:	386-LI-53	Location:	A314 Mother's Room		
Photo:		Manufacturer:	Unknown		
		Description:			
		Sink			
		Result:	1.46	ppb	
		Date Sampled:	1/15/2024	By:	JH
Recommended Action:					

ID:	386-LI-54	Location:	A315		
Photo:		Manufacturer:	Unknown		
		Description:			
		Sink			
		Result:	<1.0	ppb	
		Date Sampled:	1/15/2024	By:	JH
Recommended Action:					


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District


ID:	386-LI-55	Location:	A315	
Photo:		Manufacturer:	Hoshizaki	
		Description:		
		Ice Machine		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


ID:	386-LI-56	Location:	Staff Restroom By B302	
Photo:		Manufacturer:	Delta	
		Description:		
		Hand Washing Sink		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH

ID:	386-LI-57	Location:	Restroom By B302	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Left Faucet)		
		Result:	<1.0	ppb
Recommended Action:		Date Sampled:	1/15/2024	By: JH


Drinking Water Assessment
Lead Innovation Studio
Park Hill School District

ID:	386-LI-58	Location:	Restroom By B302	
Photo:		Manufacturer:	Sloan	
		Description:		
		Hand Washing Sink (Right Faucet)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				

ID:	386-LI-59	Location:	Hall By B302	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler (Left)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				

ID:	386-LI-60	Location:	Hall By B302	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bubbler (Right)		
		Result:	<1.0	ppb
		Date Sampled:	1/15/2024	By: JH
Recommended Action:				

Drinking Water Assessment
Lead Innovation Studio
Park Hill School District

ID:	386-LI-61	Location:	Hall By B302	
Photo:		Manufacturer:	Halsey Taylor	
		Description:		
		Drinking Fountain Bottle Filler		
		Result:	<1.0	ppb
Date Sampled:		1/15/2024	By:	JH
Recommended Action:				



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

February 02, 2024

Jeremie Kahler
Park Hill School District
9501 N. Seymour Ave
MO, MO 64153

RE: 923386 LEAD INNOVATION STUDIO

Dear Jeremie Kahler:

Please find enclosed the analytical results for the **61** sample(s) the laboratory received on **1/18/24 10:45 am** and logged in under work order **HA02758**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order HA02758

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: HA02758-01
Name: 386-LI-001
Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:03
Received: 01/18/24 10:45
Matrix: Drinking Water - Grab
PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-02
Name: 386-LI-002
Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:04
Received: 01/18/24 10:45
Matrix: Drinking Water - Grab
PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:29	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-03
Name: 386-LI-003
Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:05
Received: 01/18/24 10:45
Matrix: Drinking Water - Grab
PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:31	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-04
Name: 386-LI-004
Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:05
Received: 01/18/24 10:45
Matrix: Drinking Water - Grab
PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:32	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-05

Name: 386-LI-005

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:08

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.99	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:34	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-06

Name: 386-LI-006

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:09

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.43	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:35	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-07

Name: 386-LI-007

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:10

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:36	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-08

Name: 386-LI-008

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:11

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:38	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-09

Name: 386-LI-009

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:12

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:48	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-10

Name: 386-LI-010

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:13

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:49	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-11

Name: 386-LI-011

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:14

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:54	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-12

Name: 386-LI-012

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:15

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.03	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:55	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-13

Name: 386-LI-013

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:16

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.75	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:56	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-14

Name: 386-LI-014

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:18

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.88	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:58	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-15

Name: 386-LI-015

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:19

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 08:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-16

Name: 386-LI-016

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:20

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-17

Name: 386-LI-017

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:20

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-18

Name: 386-LI-018

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:20

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:06	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-19

Name: 386-LI-019

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:21

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:07	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-20

Name: 386-LI-020

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:21

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-21

Name: 386-LI-021

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:24

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:13	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-22

Name: 386-LI-022

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:24

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-23

Name: 386-LI-023

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:25

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:16	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-24

Name: 386-LI-024

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:26

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.13	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:17	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-25

Name: 386-LI-025

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:30

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:21	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-26

Name: 386-LI-026

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:31

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:23	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-27

Name: 386-LI-027

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:32

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:27	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-28

Name: 386-LI-028

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:34

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-29

Name: 386-LI-029

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:34

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:30	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-30

Name: 386-LI-030

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:34

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:31	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-31

Name: 386-LI-031

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:35

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:32	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-32

Name: 386-LI-032

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:35

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:34	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-33

Name: 386-LI-033

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:35

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:38	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-34

Name: 386-LI-034

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:42

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:39	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-35

Name: 386-LI-035

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:44

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:43	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-36

Name: 386-LI-036

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:44

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:45	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-37

Name: 386-LI-037

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:44

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:46	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-38

Name: 386-LI-038

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:45

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:48	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-39

Name: 386-LI-039

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:46

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:49	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-40

Name: 386-LI-040

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:48

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:50	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-41

Name: 386-LI-041

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:49

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:55	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-42

Name: 386-LI-042

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:50

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.28	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:56	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-43

Name: 386-LI-043

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:52

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:57	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-44

Name: 386-LI-044

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:52

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 09:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-45

Name: 386-LI-045

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:54

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.49	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:03	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-46

Name: 386-LI-046

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:54

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-47

Name: 386-LI-047

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:56

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:06	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-48

Name: 386-LI-048

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:56

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:07	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-49

Name: 386-LI-049

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:57

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:11	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-50

Name: 386-LI-050

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:57

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:13	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-51

Name: 386-LI-051

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:57

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:14	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-52

Name: 386-LI-052

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 07:59

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:15	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-53

Name: 386-LI-053

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 08:00

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.46	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:17	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-54

Name: 386-LI-054

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 08:01

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:18	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-55

Name: 386-LI-055

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 08:02

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:22	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-56

Name: 386-LI-056

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 08:04

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:24	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02758-57

Name: 386-LI-057

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 08:05

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-58

Name: 386-LI-058

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 08:05

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:29	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-59

Name: 386-LI-059

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 08:07

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:31	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02758-60

Name: 386-LI-060

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 08:07

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:32	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: HA02758-61

Name: 386-LI-061

Alias: LEAD INNOVATION STUDIO

Sampled: 01/15/24 08:07

Received: 01/18/24 10:45

Matrix: Drinking Water - Grab

PO #: LIC2324

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>									
Lead	< 1.00	ug/L		02/01/24 07:28	1	1.00	02/01/24 10:34	BRS	EPA 200.8 REV 5.4



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager






REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Lead Innovation Studio		PURCHASE ORDER # LIC2324		3 ANALYSIS REQUESTED + <input checked="" type="checkbox"/> DW Lead + <input checked="" type="checkbox"/> Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>HA02758</u> LOGGED BY: <u>7051</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 1/15/2024					
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID					
CONTACT PERSON Jeremie Kahler											
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS	
386-LI-001		1/15/2024	0703	X	DW	1	6	X			
386-LI-002		1/15/2024	0704	X	DW	1	6	X			
386-LI-003		1/15/2024	0705	X	DW	1	6	X			
386-LI-004		1/15/2024	0705	X	DW	1	6	X			
386-LI-005		1/15/2024	0708	X	DW	1	6	X			
386-LI-006		1/15/2024	0709	X	DW	1	6	X			
386-LI-007		1/15/2024	0710	X	DW	1	6	X			
386-LI-008		1/15/2024	0711	X	DW	1	6	X			
386-LI-009		1/15/2024	0712	X	DW	1	6	X			
386-LI-010		1/15/2024	0713	X	DW	1	6	X			
386-LI-011		1/15/2024	0714	X	DW	1	6	X			
CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER											
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____							
7 RELINQUISHED BY: (SIGNATURE) 		DATE 1/15/24 TIME 1300		RECEIVED BY: (SIGNATURE) 		DATE 1/18/24 TIME 1045		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT <u>3.0</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N <u>Y</u> SAMPLE(S) RECEIVED ON ICE Y OR N <u>Y</u> SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N <u>Y</u> DATE AND TIME TAKEN FROM SAMPLE _____			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES or IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Lead Innovation Studio		PURCHASE ORDER # LIC2324		3 ANALYSIS REQUESTED + +		4 (FOR LAB USE ONLY) LOGIN # <u>HA02758</u> LOGGED BY: <u>TMS</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 1/15/2024					
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT- LEACHATE OIL- OIL SO- SOIL SOL- SOLID					
CONTACT PERSON Jeremie Kahler											
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW Lead	Turb Check	REMARKS	
386-LI-012		1/15/2024	0715	X	DW	1	6	X			
386-LI-013		1/15/2024	0716	X	DW	1	6	X			
386-LI-014		1/15/2024	0718	X	DW	1	6	X			
386-LI-015		1/15/2024	0719	X	DW	1	6	X			
386-LI-016		1/15/2024	0720	X	DW	1	6	X			
386-LI-017		1/15/2024	0720	X	DW	1	6	X			
386-LI-018		1/15/2024	0720	X	DW	1	6	X			
386-LI-019		1/15/2024	0721	X	DW	1	6	X			
386-LI-020		1/15/2024	0721	X	DW	1	6	X			
386-LI-021		1/15/2024	0724	X	DW	1	6	X			
386-LI-022		1/15/2024	0724	X	DW	1	6	X			
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____							
7 RELINQUISHED BY: (SIGNATURE) 		DATE 1/15/24	RECEIVED BY: (SIGNATURE) 		DATE 1/18/24	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT <u>3.0</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE _____					
RELINQUISHED BY: (SIGNATURE) _____		DATE _____	RECEIVED BY: (SIGNATURE) _____		DATE _____						
RELINQUISHED BY: (SIGNATURE) _____		DATE _____	RECEIVED BY: (SIGNATURE) _____		DATE _____						

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Park Hill School District		PROJECT NUMBER 923386		PROJECT LOCATION Lead Innovation Studio		PURCHASE ORDER # LIC2324		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # <u>HA02758</u> LOGGED BY: <u>MSI</u> CLIENT: <u>Park Hill School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #:	
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731		E-MAIL KahlerJ@parkhill.k12.mo.us		DATE SHIPPED 1/15/2024		+ +			
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAB- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID		DW Lead		Turb Check	
CONTACT PERSON Jeremie Kahler		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)											
386-LI- 023		1/15/2024		0725		X		DW		1 6	
386-LI- 024		1/15/2024		0726		X		DW		1 6	
386-LI- 025		1/15/2024		0730		X		DW		1 6	
386-LI- 026		1/15/2024		0731		X		DW		1 6	
386-LI- 027		1/15/2024		0732		X		DW		1 6	
386-LI- 028		1/15/2024		0734		X		DW		1 6	
386-LI- 029		1/15/2024		0734		X		DW		1 6	
386-LI- 030		1/15/2024		0734		X		DW		1 6	
386-LI- 031		1/15/2024		0735		X		DW		1 6	
386-LI- 032		1/15/2024		0735		X		DW		1 6	
386-LI- 033		1/15/2024		0735		X		DW		1 6	
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3	
		6 - UNPRESERVED		7 - OTHER							
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)	
7 RELINQUISHED BY: (SIGNATURE) 		DATE 1/15/24		TIME 1300		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT 3.0 °C	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE) 		DATE 1/18/24		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N	
								TIME 1045		SAMPLE(S) RECEIVED ON ICE Y OR N	
										SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N	
										DATE AND TIME TAKEN FROM SAMPLE	



Pace Analytical Services
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

1 CLIENT		PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #	3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)		
Park Hill School District		923386	Lead Innovation Studio	LIC2324			LOGIN # <u>HA02758</u>		
ADDRESS 9501 N. Seymour Ave.		PHONE NUMBER 8163596731	E-MAIL KahlerJ@parkhill.k12.mo.us	DATE SHIPPED 1/15/2024			LOGGED BY: <u>7051</u>		
CITY STATE ZIP Kansas City, MO 64153		SAMPLER (PLEASE PRINT) Jay Hurst	MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAB- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID				CLIENT: <u>Park Hill School District</u>		
CONTACT PERSON Jeremie Kahler		SAMPLER'S SIGNATURE 					PROJECT: <u>Drinking Water Lead</u>		
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	CUSTODY SEAL #: _____	
386-LI- <u>045</u>		1/15/2024	<u>0754</u>	X	DW	1	6	REMARKS	
386-LI- <u>046</u>		1/15/2024	<u>0754</u>	X	DW	1	6		
386-LI- <u>047</u>		1/15/2024	<u>0756</u>	X	DW	1	6		
386-LI- <u>048</u>		1/15/2024	<u>0756</u>	X	DW	1	6		
386-LI- <u>049</u>		1/15/2024	<u>0757</u>	X	DW	1	6		
386-LI- <u>050</u>		1/15/2024	<u>0757</u>	X	DW	1	6		
386-LI- <u>051</u>		1/15/2024	<u>0757</u>	X	DW	1	6		
386-LI- <u>052</u>		1/15/2024	<u>0759</u>	X	DW	1	6		
386-LI- <u>053</u>		1/15/2024	<u>0800</u>	X	DW	1	6		
386-LI- <u>054</u>		1/15/2024	<u>0801</u>	X	DW	1	6		
386-LI- <u>055</u>		1/15/2024	<u>0802</u>	X	DW	1	6		
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH	DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities.		
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE		EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____			
7 RELINQUISHED BY: (SIGNATURE) 		DATE 1/15/24		RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)		TIME 1300		RECEIVED BY: (SIGNATURE)		TIME		SAMPLE TEMPERATURE UPON RECEIPT <u>3.0</u> °C	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N	
		TIME				TIME		SAMPLE(S) RECEIVED ON ICE Y OR N	
		DATE				DATE		SAMPLE ACCEPTANCE NONCONFORMANT Y OR N	
		TIME				TIME		REPORT IS NEEDED	
								DATE AND TIME TAKEN FROM SAMPLE	

