

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
LHGF-DW-P-34	6/13/2024 06:03	6/18/2024 13:55	70301617001	Lead	<1.0	5	ug/L
LHGF-DW-P-35	6/13/2024 06:04	6/18/2024 14:02	70301617002	Lead	<1.0	5	ug/L
LHS-GF-KPS1-P-37	6/13/2024 06:05	6/18/2024 14:29	70301617003	Lead	<1.0	5	ug/L
LHS-GF-KPS2-P-38	6/13/2024 06:09	6/18/2024 14:37	70301617004	Lead	<1.0	5	ug/L
LHS-GF-KPF-P-40	6/13/2024 06:11	6/18/2024 14:40	70301617005	Lead	<1.0	5	ug/L
LHS-GF-KF-P-41	6/13/2024 06:12	6/18/2024 15:20	70301617006	Lead	<1.0	5	ug/L
LHS-GF-KF1-P-42	6/13/2024 06:13	6/18/2024 15:23	70301617007	Lead	<1.0	5	ug/L
LHS-GF-KF2-P-43	6/13/2024 06:13	6/18/2024 15:28	70301617008	Lead	2.8	5	ug/L
LHS-GF-DW-P-44	6/13/2024 06:15	6/18/2024 15:37	70301617009	Lead	<1.0	5	ug/L
LHS-GF-GIM-P-45	6/13/2024 07:41	6/18/2024 15:44	70301617010	Lead	<1.0	5	ug/L
LHS-GF-DW-P-46	6/13/2024 06:17	6/18/2024 16:05	70301617011	Lead	4.1	5	ug/L
LHS-GF-BIM-P-47	6/13/2024 07:41	6/18/2024 16:11	70301617012	Lead	<1.0	5	ug/L
LHS-GF-DW-P-48	6/13/2024 06:19	6/18/2024 16:19	70301617013	Lead	2.6	5	ug/L
LHS-GF-HC-P-49	6/13/2024 06:21	6/18/2024 16:28	70301617014	Lead	1.6	5	ug/L
LHS-GF-KF-P-50	6/13/2024 06:23	6/18/2024 16:35	70301617015	Lead	4.7	5	ug/L
LHS-GF-DW1-P-51	6/13/2024 06:26	6/18/2024 16:53	70301617016	Lead	<1.0	5	ug/L
LHS-GF-DW2-P-52	6/13/2024 06:26	6/19/2024 13:53	70301617017	Lead	<1.0	5	ug/L
LHS-GF-KF-P-53	6/13/2024 06:28	6/19/2024 13:59	70301617018	Lead	<1.0	5	ug/L
LHS-GF-HC-P-54	6/13/2024 06:31	6/19/2024 14:13	70301617019	Lead	13.6	5	ug/L
LHS-GF-IM-P-55	6/13/2024 07:42	6/19/2024 14:24	70301617020	Lead	<1.0	5	ug/L
LHS-GF-HC-P-56	6/13/2024 06:30	6/19/2024 14:47	70301617021	Lead	11.6	5	ug/L
LHS-GF-DW-P-57	6/13/2024 06:38	6/19/2024 15:01	70301617022	Lead	<1.0	5	ug/L
LHS-01-DW-P-58	6/13/2024 06:39	6/19/2024 15:08	70301617023	Lead	<1.0	5	ug/L
LHS-01-DW-P-59	6/13/2024 06:40	6/19/2024 15:11	70301617024	Lead	<1.0	5	ug/L
LHS-01-DW-P-60	6/13/2024 06:41	6/19/2024 15:30	70301617025	Lead	<1.0	5	ug/L
LHS-01-DW-P-61	6/13/2024 06:42	6/19/2024 15:33	70301617026	Lead	<1.0	5	ug/L
LHS-01-SF-P-62	6/13/2024 06:44	6/19/2024 15:37	70301617027	Lead	<1.0	5	ug/L
LHS-01-DW-P-63	6/13/2024 06:45	6/19/2024 15:39	70301617028	Lead	<1.0	5	ug/L
LHS-02-DW-P-64	6/13/2024 06:47	6/19/2024 15:40	70301617029	Lead	<1.0	5	ug/L
LHS-02-CF-P-65	6/13/2024 06:48	6/19/2024 15:57	70301617030	Lead	2.7	5	ug/L
LHS-02-WD-P-66	6/13/2024 06:50	6/19/2024 16:05	70301617031	Lead	<1.0	5	ug/L
LHS-02-WD-P-67	6/13/2024 06:51	6/19/2024 16:17	70301617032	Lead	1.8	5	ug/L
LHS-02-WD-P-68	6/13/2024 06:52	6/19/2024 16:19	70301617033	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb