



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 21-02-00275

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Received Date: 02/02/2021
Reported Date: 02/19/2021
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020L-159.3; Huth Elementary; 1773 Huth Road; Grand Island, NY 14072

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00275-001	159.3-1	01/25/2021	BLUE HALL RM 1 CLASS SINK	17.5	02/11/2021	
21-02-00275-002	159.3-2	01/25/2021	BLUE HALL RM 1 RESTROOM	4.77	02/10/2021	
21-02-00275-003	159.3-4	01/25/2021	BLUE HALL RM 2 CLASS SINK	18.6	02/11/2021	
21-02-00275-004	159.3-5	01/25/2021	BLUE HALL RM 2 RESTROOM	3.15	02/10/2021	
21-02-00275-005	159.3-7	01/25/2021	BLUE HALL RM 3 CLASS SINK	11.0	02/11/2021	
21-02-00275-006	159.3-10	01/25/2021	BLUE HALL RM 5 CLASS SINK	<1.00	02/10/2021	
21-02-00275-007	159.3-12	01/25/2021	BLUE HALL RM 4 CLASS SINK	<1.00	02/10/2021	
21-02-00275-008	159.3-14	01/25/2021	BLUE HALL RM 7 CLASS SINK	<1.00	02/10/2021	
21-02-00275-009	159.3-16	01/25/2021	BLUE HALL RM 6 CLASS SINK	1.11	02/10/2021	
21-02-00275-010	159.3-18	01/25/2021	BLUE HALL RM 8 CLASS SINK	<1.00	02/10/2021	
21-02-00275-011	159.3-20	01/25/2021	BLUE HALL RM 9 CLASS SINK	1.71	02/10/2021	
21-02-00275-012	159.3-22	01/25/2021	BLUE HALL RM 11 CLASS SINK	1.15	02/10/2021	
21-02-00275-013	159.3-24	01/25/2021	BLUE HALL RM 10 CLASS SINK	<1.00	02/10/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-02-00275

Project/Test Address: 2020L-159.3; Huth Elementary; 1773 Huth Road; Grand Island, NY 14072

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00275-014	159.3-26	01/25/2021	BLUE HALL RM 14 CLASS SINK	4.85	02/11/2021	
21-02-00275-015	159.3-28	01/25/2021	HEALTH OFFICE MAIN	<1.00	02/11/2021	
21-02-00275-016	159.3-29	01/25/2021	HEALTH OFFICE LEFT RESTROOM	7.40	02/11/2021	
21-02-00275-017	159.3-30	01/25/2021	HEALTH OFFICE RIGHT RESTROOM	<1.00	02/11/2021	
21-02-00275-018	159.3-31	01/25/2021	BLUE HALL ALL GENDER RESTROOM	<1.00	02/11/2021	
21-02-00275-019	159.3-32B	01/25/2021	DF NEAR HEALTH OFFICE	<1.00	02/11/2021	
21-02-00275-020	159.3-34	01/25/2021	BOYS LOCKER RM LEFT OF TRIPLE	<1.00	02/11/2021	
21-02-00275-021	159.3-36	01/25/2021	BOYS LOCKER RM RIGHT OF TRIPLE	<1.00	02/11/2021	
21-02-00275-022	159.3-37	01/25/2021	CLOSE STAFF RESTROOM	<1.00	02/11/2021	
21-02-00275-023	159.3-38	01/25/2021	FAR STAFF RESTROOM	<1.00	02/11/2021	
21-02-00275-024	159.3-39	01/25/2021	BLUE HALL WOMENS LEFT	4.86	02/11/2021	
21-02-00275-025	159.3-40	01/25/2021	BLUE HALL WOMENS RIGHT	2.32	02/11/2021	
21-02-00275-026	159.3-41	01/25/2021	BLUE HALL MENS LEFT	4.81	02/11/2021	
21-02-00275-027	159.3-42	01/25/2021	BLUE HALL MENS RIGHT	2.65	02/11/2021	
21-02-00275-028	159.3-43	01/25/2021	CAFE SINK	<1.00	02/11/2021	
21-02-00275-029	159.3-44B	01/25/2021	CAFE DF	<1.00	02/11/2021	
21-02-00275-030	159.3-45	01/25/2021	KITCHEN HANDWASH	1.47	02/11/2021	
21-02-00275-031	159.3-46	01/25/2021	SERVER LINE	<1.00	02/11/2021	
21-02-00275-032	159.3-47	01/25/2021	LEFT SPRAYER	1.03	02/11/2021	
21-02-00275-033	159.3-48	01/25/2021	LEFT DOUBLE KITCHEN	26.8	02/11/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-02-00275

Project/Test Address: 2020L-159.3; Huth Elementary; 1773 Huth Road; Grand Island, NY 14072

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00275-034	159.3-49	01/25/2021	RIGHT DOUBLE KITCHEN	4.29	02/11/2021	
21-02-00275-035	159.3-50	01/25/2021	RIGHT SPRAYER	5.14	02/11/2021	
21-02-00275-036	159.3-51	01/25/2021	MIDDLE HANDWASH	1.19	02/11/2021	
21-02-00275-037	159.3-52	01/25/2021	KITCHEN RESTROOM	1.41	02/11/2021	
21-02-00275-038	159.3-54	01/25/2021	PURPLE HALL RM 38 CLASS SINK	2.87	02/11/2021	
21-02-00275-039	159.3-55	01/25/2021	PURPLE HALL RM 37 CLASS SINK	9.56	02/11/2021	
21-02-00275-040	159.3-56	01/25/2021	PURPLE HALL RM 39 CLASS SINK	9.95	02/11/2021	
21-02-00275-041	159.3-59	01/25/2021	PURPLE HALL BOYS MIDDLE	1.06	02/11/2021	
21-02-00275-042	159.3-60	01/25/2021	PURPLE HALL BOYS RIGHT	<1.00	02/11/2021	
21-02-00275-043	159.3-61	01/25/2021	PURPLE HALL GIRLS LEFT	<1.00	02/11/2021	
21-02-00275-044	159.3-62	01/25/2021	PURPLE HALL GIRLS MIDDLE	<1.00	02/11/2021	
21-02-00275-045	159.3-63	01/25/2021	PURPLE HALL GIRLS RIGHT	<1.00	02/11/2021	
21-02-00275-046	159.3-64	01/25/2021	PURPLE HALL RM 40 CLASS SINK	9.24	02/11/2021	
21-02-00275-047	159.3-66	01/25/2021	PURPLE HALL RM 41 CLASS SINK	5.43	02/16/2021	
21-02-00275-048	159.3-68	01/25/2021	PURPLE HALL RM 42 CLASS SINK	7.64	02/16/2021	
21-02-00275-049	159.3-70	01/25/2021	PURPLE HALL RM 43 CLASS SINK	12.5	02/11/2021	
21-02-00275-050	159.3-73	01/25/2021	PURPLE HALL RM 44 CLASS SINK	7.49	02/11/2021	
21-02-00275-051	159.3-75	01/25/2021	PURPLE HALL RM 45 CLASS SINK	4.43	02/11/2021	
21-02-00275-052	159.3-77	01/25/2021	PURPLE HALL RM 46 CLASS SINK	8.58	02/11/2021	
21-02-00275-053	159.3-79	01/25/2021	PURPLE HALL RM 47 CLASS SINK	7.06	02/11/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-02-00275

Project/Test Address: 2020L-159.3; Huth Elementary; 1773 Huth Road; Grand Island, NY 14072

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00275-054	159.3-80	01/25/2021	PURPLE HALL ADA RESTROOM	<1.00	02/11/2021	
21-02-00275-055	159.3-81	01/25/2021	YELLOW HALL RM 28 CLASS SINK	3.69	02/11/2021	
21-02-00275-056	159.3-83	01/25/2021	YELLOW HALL RM 29 CLASS SINK	1.92	02/11/2021	
21-02-00275-057	159.3-85	01/25/2021	YELLOW HALL RM 27 CLASS SINK	2.26	02/11/2021	
21-02-00275-058	159.3-89	01/25/2021	YELLOW HALL RM 25 CLASS SINK	2.71	02/16/2021	
21-02-00275-059	159.3-91	01/25/2021	YELLOW HALL RM 23 CLASS SINK	27.0	02/16/2021	
21-02-00275-060	159.3-92	01/25/2021	YELLOW HALL BOYS RESTROOM LEFT	15.9	02/16/2021	
21-02-00275-061	159.3-93	01/25/2021	YELLOW HALL BOYS RESTROOM MIDDLE	5.72	02/16/2021	
21-02-00275-062	159.3-94	01/25/2021	YELLOW HALL BOYS RESTROOM RIGHT	19.1	02/16/2021	
21-02-00275-063	159.3-95	01/25/2021	YELLOW HALL GIRLS RESTROOM LEFT	<1.00	02/16/2021	
21-02-00275-064	159.3-96	01/25/2021	YELLOW HALL GIRLS RESTROOM MIDDLE	<1.00	02/16/2021	
21-02-00275-065	159.3-97	01/25/2021	YELLOW HALL GIRLS RESTROOM RIGHT	1.10	02/16/2021	
21-02-00275-066	159.3-98	01/25/2021	LIBRARY	3.12	02/16/2021	
21-02-00275-067	159.3-99	01/25/2021	GIRLS LOCKER ROOM FRONT	<1.00	02/16/2021	
21-02-00275-068	159.3-100	01/25/2021	GIRLS LOCKER ROOM BACK	2.18	02/16/2021	
21-02-00275-069	159.3-102B	01/25/2021	YELLOW HALL DF	<1.00	02/16/2021	
21-02-00275-070	159.3-103	01/25/2021	COACH'S OFFICE	3.56	02/16/2021	
21-02-00275-071	159.3-104	01/25/2021	BAND ROOM	1.27	02/16/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-02-00275

Project/Test Address: 2020L-159.3; Huth Elementary; 1773 Huth Road; Grand Island, NY 14072

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	--------------

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory:



Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-159.3

Client: Grand Island CSD

Contact: James Rozler

Building: Huth Elementary

Location: 1773 Huth Road Grand Island, NY 14072

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.3-1	Blue Hall Rm 1 Class sink	S	11:05			
159.3-2	Blue Hall Rm 1 restroom	S	11:06			
159.3-4	Blue Hall Rm 2 class sink	S	11:07			
159.3-5	Blue Hall Rm 2 restroom	S	11:08			
159.3-7	Blue Hall Rm 3 class sink	S	11:09			
159.3-10	Blue Hall Rm 5 class sink	S	11:10			
159.3-12	Blue Hall Rm 4 class sink	S	11:11			
159.3-14	Blue Hall Rm 7 class sink	S	11:12			
159.3-16	Blue Hall Rm 6 class sink	S	11:13			
159.3-18	Blue Hall Rm 8 class sink	S	11:14			
159.3-20	Blue Hall Rm 9 class sink	S	11:15			
159.3-22	Blue Hall Rm 11 class sink	S	11:16			
159.3-24	Blue Hall Rm 10 class sink	S	11:17			
159.3-26	Blue Hall Rm 14 class sink	S	11:18			
159.3-28	Health Office main	S	11:19			
159.3-29	Health Office left restroom	S	11:20			
159.3-30	Health Office right restroom	S	11:21			
159.3-31	Blue Hall All Gender Restroom	S	11:22			

21-02-00275



Due Date:
 03/02/2021
 (Tuesday)
 AE

Notes:

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 1/25/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 1/28/2021

Received (Name / Lab): K. HARRIS Date: 2-2-21 Time: 11:24 AM

Sample Login (Name / Lab): T. Shon Date: 2/3/21 Time: 4:45p

Analysis (Name / Lab): J. Hestler Date: 2/10/21 Time: 12:40 pm

QA/QC Review (Name / Lab): J. Hestler Date: 2/19/21 Time: 4:55 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-159.3

Client: Grand Island CSD

Contact: James Rozler

Building: Huth Elementary

Location: 1773 Huth Road Grand Island, NY 14072

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.3-32B	DF near Health Office	DFB	11:23			
159.3-34	Boys Locker Rm left of triple	S	11:24			
159.3-36	Boys Locker Rm right of triple	S	11:25			
159.3-37	Close Staff Restroom	S	11:26			
159.3-38	Far Staff Restroom	S	11:27			
159.3-39	Blue Hall Womens Left	S	11:28			
159.3-40	Blue Hall Womens Right	S	11:29			
159.3-41	Blue Hall Mens Left	S	11:30			
159.3-42	Blue Hall Mens Right	S	11:31			
159.3-43	Cafe Sink	S	11:32			
159.3-44B	Cafe DF	DFB	11:33			
159.3-45	Kitchen Handwash	S	11:34			
159.3-46	Server Line	S	11:35			
159.3-47	Left Sprayer	S	11:36			
159.3-48	Left Double Kitchen	S	11:37			
159.3-49	Right Double kitchen	S	11:38			
159.3-50	Right Sprayer	S	11:39			
159.3-51	Middle Handwash	S	11:40			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 1/25/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 1/28/2021

Received (Name / Lab): R. HARRIS / St. Lawrence Date: 2-2-21 Time: 11:24 AM

Sample Login (Name / Lab): T. Hagan Date: 2/3/21 Time: 4:45

Analysis (Name / Lab): J. Hartogler Date: 2/16/21 Time: 12:40 pm

QA/QC Review (Name / Lab): Kisha Eddy Date: 2/19/21 Time: 4:05 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-159.3

Client: Grand Island CSD

Contact: James Rozler

Building: Huth Elementary

Location: 1773 Huth Road Grand Island, NY 14072

LEAD
 Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround
20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.3-52	Kitchen Restroom	S	11:41			
159.3-54	Purple Hall Rm 38 class sink	S	11:42			
159.3-55	Purple Hall Rm 37 class sink	S	11:43			
159.3-56	Purple Hall Rm 39 class sink	S	11:44			
159.3-59	Purple Hall Boys Middle	S	11:45			
159.3-60	Purple Hall Boys Right	S	11:46			
159.3-61	Purple Hall Girls Left	S	11:47			
159.3-62	Purple Hall Girls Middle	S	11:48			
159.3-63	Purple Hall Girls Right	S	11:49			
159.3-64	Purple Hall Rm 40 class sink	S	11:50			
159.3-66	Purple Hall Rm 41 class sink	S	11:51			
159.3-68	Purple Hall Rm 42 class sink	S	11:52			
159.3-70	Purple Hall Rm 43 class sink	S	11:53			
159.3-73	Purple Hall Rm 44 class sink	S	11:54			
159.3-75	Purple Hall Rm 45 class sink	S	11:55			
159.3-77	Purple Hall Rm 46 class sink	S	11:56			
159.3-79	Purple Hall Rm 47 class sink	S	11:57			
159.3-80	Purple Hall ADA Restroom	S	11:58			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 1/25/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 1/28/2021

Received (Name / Lab): KTHAAAIS / J. Rozler Date: 2-2-21 Time: 11:24 AM

Sample Login (Name / Lab): T. Sharma Date: 2/3/21 Time: 4:16p

Analysis (Name / Lab): J. Bertzler Date: 2/16/21 Time: 12:40 pm

QA/QC Review (Name / Lab): Jasha Eddy Date: 2/19/21 Time: 4:55 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-159.3

Client: Grand Island CSD

Contact: James Rozler

Building: Huth Elementary

Location: 1773 Huth Road Grand Island, NY 14072

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.3-81	Yellow Hall Rm 28 class sink	S	11:59			
159.3-83	Yellow Hall Rm 29 class sink	S	12:00			
159.3-85	Yellow Hall Rm 27 class sink	S	12:01			
159.3-89	Yellow Hall Rm 25 class sink	S	12:02			
159.3-91	Yellow Hall Rm 23 class sink	S	12:03			
159.3-92	Yellow Hall Boys Restroom left	S	12:04			
159.3-93	Yellow Hall Boys Restroom middle	S	12:05			
159.3-94	Yellow Hall Boys Restroom right	S	12:06			
159.3-95	Yellow Hall Girls Restroom left	S	12:07			
159.3-96	Yellow Hall Girls Restroom middle	S	12:08			
159.3-97	Yellow Hall Girls Restroom right	S	12:09			
159.3-98	Library	S	12:10			
159.3-99	Girls Locker Room Front	S	12:11			
159.3-100	Girls Locker Room Back	S	12:12			
159.3-102B	Yellow Hall DF	DFB	12:13			
159.3-103	Coach's Office	S	12:14			
159.3-104	Band Room	S	12:15			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Paul Nichols Date: 1/25/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 1/28/2021

Received (Name / Lab): K. Harris / OC James Date: 2-2-21 Time: 11:24 AM

Sample Login (Name / Lab): T. Whanna Date: 2/3/21 Time: 4:45

Analysis (Name / Lab): G. Dertinger Date: 2/16/21 Time: 12:40 pm

QA/QC Review (Name / Lab): Lasha Taddy Date: 2/19/21 Time: 4:55 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____