



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 21-02-00294

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Received Date: 02/02/2021
Reported Date: 02/26/2021
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: Grand Island CSD; William Kaegebein Elementary; 1690 Love Road Grand Island, NY 14072

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00294-001	159.4-1	01/28/2021	RM 1 CLASS	2.44	02/23/2021	
21-02-00294-002	159.4-2	01/28/2021	RM 1 BR	15.1	02/23/2021	
21-02-00294-003	159.4-3	01/28/2021	RM 2 CLASS	3.66	02/23/2021	
21-02-00294-004	159.4-4	01/28/2021	RM 2 BR	8.02	02/23/2021	
21-02-00294-005	159.4-5	01/28/2021	RM 3 CLASS	5.54	02/23/2021	
21-02-00294-006	159.4-6	01/28/2021	RM 3 BR	9.97	02/23/2021	
21-02-00294-007	159.4-7	01/28/2021	RM 4 CLASS	7.40	02/23/2021	
21-02-00294-008	159.4-8	01/28/2021	RM 4 BR	7.60	02/23/2021	
21-02-00294-009	159.4-9	01/28/2021	RM 5 CLASS	7.75	02/23/2021	
21-02-00294-010	159.4-10	01/28/2021	RM 5 BR	27.1	02/24/2021	
21-02-00294-011	159.4-11	01/28/2021	RM 6 CLASS	5.89	02/23/2021	
21-02-00294-012	159.4-12	01/28/2021	RM 6 BR	2.98	02/23/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-02-00294

Project/Test Address: Grand Island CSD; William Kaegebein Elementary;
1690 Love Road Grand Island, NY 14072

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00294-013	159.4-13	01/28/2021	RM 7 CLASS	4.05	02/23/2021	
21-02-00294-014	159.4-15	01/28/2021	RM 9 CLASS	9.82	02/23/2021	
21-02-00294-015	159.4-16	01/28/2021	RM 9 BR	14.4	02/24/2021	
21-02-00294-016	159.4-17	01/28/2021	RM 8 CLASS	9.45	02/23/2021	
21-02-00294-017	159.4-18	01/28/2021	RM 8 BR	4.09	02/23/2021	
21-02-00294-018	159.4-20	01/28/2021	RM 10 CLASS	5.19	02/23/2021	
21-02-00294-019	159.4-21	01/28/2021	RM 10 BR	28.5	02/23/2021	
21-02-00294-020	159.4-22	01/28/2021	FACULTY WORK ROOM	<1.00	02/23/2021	
21-02-00294-021	159.4-23	01/28/2021	RM 12 CLASS	7.44	02/23/2021	
21-02-00294-022	159.4-24	01/28/2021	RM 12 BR	14.8	02/24/2021	
21-02-00294-023	159.4-25	01/28/2021	HEALTH OFFICE BR	<1.00	02/23/2021	
21-02-00294-024	159.4-26	01/28/2021	EXAM ROOM 1 RIGHT	2.63	02/23/2021	
21-02-00294-025	159.4-27	01/28/2021	EXAM ROOM 2 LEFT	<1.00	02/24/2021	
21-02-00294-026	159.4-28	01/28/2021	MED STORAGE ROOM	<1.00	02/24/2021	
21-02-00294-027	159.4-29B	01/28/2021	DF NEAR HEALTH OFFICE	<1.00	02/26/2021	
21-02-00294-028	159.4-30	01/28/2021	BOYS BR NEAR HEALTH OFFICE LEFT SINK	2.54	02/24/2021	
21-02-00294-029	159.4-31	01/28/2021	BOYS BR NEAR HEALTH OFFICE MIDDLE SINK	1.23	02/24/2021	
21-02-00294-030	159.4-32	01/28/2021	BOYS BR NEAR HEALTH OFFICE RIGHT SINK	1.21	02/24/2021	
21-02-00294-031	159.4-33	01/28/2021	GIRLS BR NEAR HEALTH OFFICE LEFT SINK	2.53	02/24/2021	
21-02-00294-032	159.4-34	01/28/2021	GIRLS BR NEAR HEALTH OFFICE MIDDLE SINK	1.77	02/24/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-02-00294

Project/Test Address: Grand Island CSD; William Kaegebein Elementary;
1690 Love Road Grand Island, NY 14072

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00294-033	159.4-35	01/28/2021	GIRLS BR NEAR HEALTH OFFICE RIGHT SINK	1.56	02/24/2021	
21-02-00294-034	159.4-36	01/28/2021	BR NEAR AUDITORIUM	<1.00	02/24/2021	
21-02-00294-035	159.4-37	01/28/2021	BR IN MAIN OFFICE	<1.00	02/24/2021	
21-02-00294-036	159.4-38	01/28/2021	LIBRARY	4.23	02/24/2021	
21-02-00294-037	159.4-40	01/28/2021	SPECIAL ED RM	1.18	02/24/2021	
21-02-00294-038	159.4-41	01/28/2021	RM 50	1.66	02/24/2021	
21-02-00294-039	159.4-42	01/28/2021	BOYS BR NEAR LIBRARY LEFT SINK	5.84	02/24/2021	
21-02-00294-040	159.4-43	01/28/2021	BOYS BR NEAR LIBRARY MIDDLE SINK	5.40	02/24/2021	
21-02-00294-041	159.4-44	01/28/2021	BOYS BR NEAR LIBRARY RIGHT SINK	6.62	02/24/2021	
21-02-00294-042	159.4-45B	01/28/2021	DF NEAR LIBRARY	<1.00	02/26/2021	
21-02-00294-043	159.4-46	01/28/2021	GIRLS BR NEAR LIBRARY LEFT SINK	1.26	02/24/2021	
21-02-00294-044	159.4-47	01/28/2021	GIRLS BR NEAR LIBRARY MIDDLE SINK	3.84	02/24/2021	
21-02-00294-045	159.4-48	01/28/2021	GIRLS BR NEAR LIBRARY RIGHT SINK	10.0	02/24/2021	
21-02-00294-046	159.4-49	01/28/2021	RM 52	4.00	02/24/2021	
21-02-00294-047	159.4-50	01/28/2021	RM 49	1.75	02/24/2021	
21-02-00294-048	159.4-51	01/28/2021	RM 54	7.89	02/24/2021	
21-02-00294-049	159.4-52	01/28/2021	RM 51	1.52	02/24/2021	
21-02-00294-050	159.4-53	01/28/2021	RM 56	3.15	02/24/2021	
21-02-00294-051	159.4-54	01/28/2021	RM 53	2.81	02/24/2021	
21-02-00294-052	159.4-55	01/28/2021	RM 60 CLASS	<1.00	02/24/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-02-00294

Project/Test Address: Grand Island CSD; William Kaegebein Elementary;
1690 Love Road Grand Island, NY 14072

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00294-053	159.4-56	01/28/2021	RM 60 BR	<1.00	02/24/2021	
21-02-00294-054	159.4-57	01/28/2021	BAND ROOM	15.4	02/25/2021	
21-02-00294-055	159.4-58B	01/28/2021	DF NEAR BAND ROOM	<1.00	02/24/2021	
21-02-00294-056	159.4-59	01/28/2021	RM 35	6.74	02/24/2021	
21-02-00294-057	159.4-60	01/28/2021	RM 34 SPEECH	7.12	02/24/2021	
21-02-00294-058	159.4-61	01/28/2021	RM 33	11.1	02/25/2021	
21-02-00294-059	159.4-62	01/28/2021	BREAK ROOM	3.47	02/24/2021	
21-02-00294-060	159.4-63	01/28/2021	RM 31	8.23	02/24/2021	
21-02-00294-061	159.4-64	01/28/2021	RM 29	21.9	02/25/2021	
21-02-00294-062	159.4-65	01/28/2021	RM 27	114	02/25/2021	
21-02-00294-063	159.4-66	01/28/2021	CAFETERIA 2 SINK	2.93	02/24/2021	
21-02-00294-064	159.4-68	01/28/2021	GIRLS BR NEAR CAFE 2	7.12	02/24/2021	
21-02-00294-065	159.4-69	01/28/2021	GIRLS BR NEAR CAFE 2	6.42	02/24/2021	
21-02-00294-066	159.4-70	01/28/2021	GIRLS BR NEAR CAFE 2	6.52	02/24/2021	
21-02-00294-067	159.4-71	01/28/2021	GIRLS BR NEAR CAFE 2	8.03	02/24/2021	
21-02-00294-068	159.4-72B	01/28/2021	DF NEAR CAFE 2	<1.00	02/24/2021	
21-02-00294-069	159.4-73	01/28/2021	BOYS BR NEAR CAFE 2	8.96	02/24/2021	
21-02-00294-070	159.4-74	01/28/2021	BOYS BR NEAR CAFE 2	5.33	02/24/2021	
21-02-00294-071	159.4-75	01/28/2021	BOYS BR NEAR CAFE 2	6.37	02/24/2021	
21-02-00294-072	159.4-76	01/28/2021	BOYS BR NEAR CAFE 2	8.32	02/25/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-02-00294

Project/Test Address: Grand Island CSD; William Kaegebein Elementary;
1690 Love Road Grand Island, NY 14072

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00294-073	159.4-78	01/28/2021	BR NEAR BOILER ROOM	16.3	02/25/2021	
21-02-00294-074	159.4-80	01/28/2021	BOYS LR SINK	3.98	02/25/2021	
21-02-00294-075	159.4-82	01/28/2021	GIRLS LR SINK	3.10	02/25/2021	
21-02-00294-076	159.4-83	01/28/2021	COACH'S OFFICE	2.79	02/25/2021	
21-02-00294-077	159.4-84	01/28/2021	KITCHEN TRIPLE SINK	2.54	02/25/2021	
21-02-00294-078	159.4-85	01/28/2021	DISHWASH SPRAYER	2.22	02/25/2021	
21-02-00294-079	159.4-86	01/28/2021	KITCHEN LR SINK	6.27	02/25/2021	
21-02-00294-080	159.4-88	01/28/2021	CAFETERIA 1 BR	1.18	02/25/2021	

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory:



Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-159.4

Client: Grand Island CSD

Contact: James Rozler

Building: William Kaegebein Elementary

Location: 1690 Love Road Grand Island, NY 14072

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.4-1	Rm 1 Class	S	22:45			
159.4-2	Rm 1 BR	S	22:46			
159.4-3	Rm 2 Class	S	22:47			
159.4-4	Rm 2 BR	S	22:48			
159.4-5	Rm 3 Class	S	22:49			
159.4-6	Rm 3 BR	S	22:50			
159.4-7	Rm 4 Class	S	22:51			
159.4-8	Rm 4 BR	S	22:52			
159.4-9	Rm 5 Class	S	22:53			
159.4-10	Rm 5 BR	S	22:54			
159.4-11	Rm 6 Class	S	22:55			
159.4-12	Rm 6 BR	S	22:56			
159.4-13	Rm 7 Class	S	22:57			
159.4-15	Rm 9 Class	S	22:58			
159.4-16	Rm 9 BR	S	22:59			
159.4-17	Rm 8 Class	S	23:00			
159.4-18	Rm 8 BR	S	23:01			
159.4-20	Rm 10 Class	S	23:02			

21-02-00294



Due Date:
03/02/2021
 (Tuesday)
 AE

Notes:

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 1/28/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 1/29/2021

Received (Name / Lab): K. Harris Date: 2-2-21 Time: 11:40 AM

Sample Login (Name / Lab): T. Harris Date: 2/2/21 Time: 5p

Analysis (Name / Lab): J. Hertler Date: 2/26/21 Time: 10:20 am

QA/QC Review (Name / Lab): J. Eaddy Date: 2/26/21 Time: 6:50 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-159.4

Client: Grand Island CSD

Contact: James Rozler

Building: William Kaegebein Elementary

Location: 1690 Love Road Grand Island, NY 14072

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.4-21	Rm 10 BR	S	23:03			
159.4-22	Faculty Work Room	S	23:04			
159.4-23	Rm 12 Class	S	23:05			
159.4-24	Rm 12 BR	S	23:06			
159.4-25	Health Office BR	S	23:07			
159.4-26	Exam Room 1 Right	S	23:08			
159.4-27	Exam Room 2 Left	S	23:09			
159.4-28	Med Storage Room	S	23:10			
159.4-29B	DF Near Health Office	DFB	23:11			
159.4-30	Boys BR Near Health Office left sink	S	23:12			
159.4-31	Boys BR Near Health Office middle sink	S	23:13			
159.4-32	Boys BR Near Health Office right sink	S	23:14			
159.4-33	Girls BR Near Health Office left sink	S	23:15			
159.4-34	Girls BR Near Health Office middle sink	S	23:16			
159.4-35	Girls BR Near Health Office right sink	S	23:17			
159.4-36	BR Near Auditorium	S	23:18			
159.4-37	BR in Main Office	S	23:19			
159.4-38	Library	S	23:20			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 1/28/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 1/29/2021

Received (Name / Lab): K. Harris Date: 2-2-21 Time: 11:40 AM

Sample Login (Name / Lab): T. Harris Date: 2/2/21 Time: 5p

Analysis (Name / Lab): G. Bertaylor Date: 2/26/21 Time: 10:20 am

QA/QC Review (Name / Lab): Joshua Eddy Date: 2/26/21 Time: 6:50pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-159.4

Client: Grand Island CSD

Contact: James Rozler

Building: William Kaegebein Elementary

Location: 1690 Love Road Grand Island, NY 14072

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.4-40	Special Ed Rm	S	23:21			
159.4-41	Rm 50	S	23:22			
159.4-42	Boys BR Near Library left sink	S	23:23			
159.4-43	Boys BR Near Library middle sink	S	23:24			
159.4-44	Boys BR Near Library right sink	S	23:25			
159.4-45B	DF Near Library	DFB	23:26			
159.4-46	Girls BR Near Library left sink	S	23:27			
159.4-47	Girls BR Near Library middle sink	S	23:28			
159.4-48	Girls BR Near Library right sink	S	23:29			
159.4-49	Rm 52	S	23:30			
159.4-50	Rm 49	S	23:31			
159.4-51	Rm 54	S	23:32			
159.4-52	Rm 51	S	23:33			
159.4-53	Rm 56	S	23:34			
159.4-54	Rm 53	S	23:35			
159.4-55	Rm 60 class	S	23:36			
159.4-56	Rm 60 BR	S	23:37			
159.4-57	Band Room	S	23:38			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 1/28/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 1/29/2021

Received (Name / Lab): KT HAARIS Date: 2-2-21 Time: 11:40 AM

Sample Login (Name / Lab): T. Shoman Date: 2/2/21 Time: 5p

Analysis (Name / Lab): G. Hertzyler Date: 2/26/21 Time: 10:20 am

QA/QC Review (Name / Lab): Jasha Eaddy Date: 2/26/21 Time: 6:50 PM

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS
 STOHL Job # 2020L-159.4

Client: Grand Island CSD Contact: James Rozler
 Building: William Kaegebein Elementary Location: 1690 Love Road Grand Island, NY 14072

LEAD
 Water by SM 19, 21 - 23 3113B (-04, -10) X Turnaround 20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.4-58B	DF Near Band Room	S	23:39			
159.4-59	Rm 35	S	23:40			
159.4-60	Rm 34 Speech	S	23:41			
159.4-61	Rm 33	S	23:42			
159.4-62	Break Room	S	23:43			
159.4-63	Rm 31	S	23:44			
159.4-64	Rm 29	S	23:45			
159.4-65	Rm 27	S	23:46			
159.4-66	Cafeteria 2 sink	S	23:47			
159.4-68	Girls BR Near Cafe 2	S	23:48			
159.4-69	Girls BR Near Cafe 2	S	23:49			
159.4-70	Girls BR Near Cafe 2	S	23:50			
159.4-71	Girls BR Near Cafe 2	S	23:51			
159.4-72B	DF Near Cafe 2	DFB	23:52			
159.4-73	Boys BR near Cafe 2	S	23:53			
159.4-74	Boys BR near Cafe 2	S	23:54			
159.4-75	Boys BR near Cafe 2	S	23:55			
159.4-76	Boys BR near Cafe 2	S	23:56			

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 1/28/2021
 Relinquished By: E. Henderson Jr Print Name Stohl Env: Eric Henderson Jr. Date: 1/29/2021
 Received (Name / Lab): KTHAARIS Date: 2-2-21 Time: 11:40 AM
 Sample Login (Name / Lab): T. Johnson Date: 2/2/21 Time: Sp
 Analysis (Name / Lab): J. Hertzyer Date: 2/26/21 Time: 10:20 am
 QA/QC Review (Name / Lab): Joshua Eaddy Date: 2/20/21 Time: 6:50 pm
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job #: 2020L-159.4

Client: Grand Island CSD

Contact: James Rozler

Building: William Kaegebein Elementary

Location: 1690 Love Road Grand Island, NY 14072

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.4-78	BR Near Boiler Room	S	23:57			
159.4-79	BR Near Locker Rooms	S	23:58			
159.4-80	Boys LR sink	S	23:59			
159.4-82	Girls LR sink	S	0:00			
159.4-84	Coach's Office	S	0:01			
159.4-85	Kitchen Triple Sink	S	0:02			
159.4-86	Dishwash Sprayer	S	0:03			
159.4-87	Kitchen LR sink	S	0:04			
159.4-88	Cafeteria 1 BR	S	0:05			

Notes:
 Please e-mail lab results to labs@stohlenv.com _____

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 1/28/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 1/29/2021

Received (Name / Lab): RTIARRIS Date: 2.2.21 Time: 11:40 AM

Sample Login (Name / Lab): T. Hanna Date: 2/2/21 Time: 3p

Analysis (Name / Lab): G. Hertler Date: 2/26/21 Time: 10:20 am

QA/QC Review (Name/Lab): Jasha Eddy Date: 2/26/21 Time: 6:50 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____