



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 21-02-00248

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Received Date: 02/02/2021
Reported Date: 02/19/2021
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020-159.7; Maintenance Building; 3325 Staley Rd; Grand Island, NY 14072

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00248-001	159.7-1B	01/26/2021	BREAK ROOM KITCHEN DF	<1.00	02/08/2021	
21-02-00248-002	159.7-2A	01/26/2021	BREAK ROOM KITCHEN SINK	<1.00	02/08/2021	
21-02-00248-003	159.7-3	01/26/2021	MENS ROOM SINK	52.4	02/08/2021	
21-02-00248-004	159.7-4	01/26/2021	WOMENS ROOM SINK	40.2	02/08/2021	
21-02-00248-005	159.7-5	01/26/2021	KITCHENETTE NEAR RESTROOMS	46.7	02/08/2021	

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Tasha Eaddy
 QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

Stohl ENVIRONMENTAL

Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020-159.7

Client: Grand Island CSD

Contact: James Rozler

Building: Maintenance Building

Location: 3325 Staley Rd Grand Island, NY 14072

LEAD


Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.7-1B	Break Room Kitchen DF	DFB	7:05			
159.7-2A	Break Room kitchen sink	S	7:06			
159.7-3	Mens room Sink	S	7:07			
159.7-4	Womens Room sink	S	7:08			
159.7-5	Kitchenette near restrooms	S	7:09			

21-02-00248



Due Date:
 03/02/2021
 (Tuesday)
 AE

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name: Paul Nichols Stohl Env: Paul Nichols Date: 1/25/2021

Relinquished By: Eric Henderson Jr. Print Name: Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 1/28/2021

Received (Name / Lab): K. Harris Date: 2-2-21 Time: 10:59 AM

Sample Login (Name / Lab): Tracey Blom Date: 2/11/21 Time: 8:30 AM

Analysis (Name / Lab): J. Hertzler Date: 2/18/21 Time: 2:33 PM

QA/QC Review (Name / Lab): Sasha Haddy Date: 2/19/21 Time: 4:30 PM

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____