



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 21-02-00255

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Received Date: 02/02/2021
Reported Date: 02/19/2021
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020L-159.9; Transportation Building; 2451 Baseline Road, Grand Island, NY 14072

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00255-001	159.9-1	01/27/2021	KITCHENETTE	<1.00	02/10/2021	
21-02-00255-002	159.9-2	01/27/2021	OFFICE LAV	<1.00	02/10/2021	
21-02-00255-003	159.9-3	01/27/2021	WOMEN'S HALL LAV LEFTMOST	<1.00	02/10/2021	
21-02-00255-004	159.9-4	01/27/2021	WOMEN'S HALL LAV 2ND FROM LEFT	<1.00	02/10/2021	
21-02-00255-005	159.9-5	01/27/2021	WOMEN'S HALL LAV 3RD FROM LEFT	<1.00	02/10/2021	
21-02-00255-006	159.9-6	01/27/2021	WOMEN'S HALL LAV 4TH FROM LEFT	<1.00	02/10/2021	
21-02-00255-007	159.9-7	01/27/2021	WOMEN'S HALL LAV 5TH FROM LEFT	<1.00	02/10/2021	
21-02-00255-008	159.9-8	01/27/2021	WOMEN'S HALL LAV RIGHTMOST	<1.00	02/10/2021	
21-02-00255-009	159.9-9B	01/27/2021	HALL DF	<1.00	02/10/2021	
21-02-00255-010	159.9-11	01/27/2021	MEN'S HALL LAV LEFT	<1.00	02/10/2021	
21-02-00255-011	159.9-12	01/27/2021	MEN'S HALL LAV RIGHT	<1.00	02/10/2021	
21-02-00255-012	159.9-13	01/27/2021	BREAK ROOM	<1.00	02/10/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-02-00255

Project/Test Address: 2020L-159.9; Transportation Building; 2451 Baseline Road, Grand Island, NY 14072

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00255-013	159.9-14	01/27/2021	BREAK ROOM LAV	<1.00	02/10/2021	
21-02-00255-014	159.9-15B	01/27/2021	SHOP DF	<1.00	02/10/2021	

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory:



Tasha Eaddy
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-159.9

Client: Grand Island CSD

Contact: James Rozler

Building: Transportation Building

Location: 2451 Baseline Road Grand Island, NY 14072

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
159.9-1	Kitchenette	S	5:00			
159.9-2	Office Lav	S	5:01			
159.9-3	Women's Hall Lav leftmost	S	5:02			
159.9-4	Women's Hall Lav 2nd from left	S	5:03			
159.9-5	Women's Hall Lav 3rd from left	S	5:04			
159.9-6	Women's Hall Lav 4th from left	S	5:05			
159.9-7	Women's Hall Lav 5th from left	S	5:06			
159.9-8	Women's Hall Lav rightmost	S	5:07			
159.9-9B	Hall DF	DFB	5:08			
159.9-11	Men's Hall Lav left	S	5:09			
159.9-12	Men's Hall Lav right	S	5:10			
159.9-13	Break Room	S	5:11			
159.9-14	Break Room Lav	S	5:12			
159.9-15B	Shop DF	DFB	5:13			

21-02-00255



Due Date:
03/02/2021
 (Tuesday)
 AE

Notes:

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 1/26/2021²⁷

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 1/28/2021

Received (Name / Lab): KTHARRIS DEGLACAY Date: 2-2-21 Time: 11:07 AM

Sample Login (Name / Lab): Traci Bloom Fairbrother Date: 2/1/21 Time: 8:38 AM

Analysis (Name / Lab): G. Hertzler Date: 2/10/21 Time: 11:50 am

QA/QC Review (Name / Lab): Jasha Eaddy Date: 2/19/21 Time: 4:47 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____