

Environmental Hazards Services, L.L.C. 7469 Whitepine Rd Richmond, VA 23237 Telephone: 800.347.4010

Lead in Drinking Water **Analysis Report**

Report Number: 21-02-00251

Received Date: 02/02/2021 **Reported Date:** 02/19/2021 Sampled By: Paul Nichols

Tech Certification #:

Client: Stohl Environmental

3860 California Road Orchard Park, NY 14127

Project/Test Address: 2020-159.8; Buildings and Grounds; 2451 Baseline Road, Grand Island, NY

14072

Client Number:

Laboratory Results 33-5980

Fax Number: 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-02-00251-001	159.8-1	01/27/2021	KITCHENETTE SINK	5.30	02/09/2021	
21-02-00251-002	159.8-2	01/27/2021	KITCHENETTE BOTTLE FILL	<1.00	02/09/2021	
21-02-00251-003	159.8-3	01/27/2021	KITCHENETTE SPRAYER	3.78	02/09/2021	
21-02-00251-004	159.8-4	01/27/2021	WOMENS LAV LEFT	10.2	02/09/2021	
21-02-00251-005	159.8-5	01/27/2021	WOMENS LAV RIGHT	4.29	02/09/2021	
21-02-00251-006	159.8-7	01/27/2021	MENS LAV LEFT	11.6	02/09/2021	
21-02-00251-007	159.8-8	01/27/2021	MENS LAV RIGHT	17.9	02/09/2021	
21-02-00251-008	159.8-9	01/27/2021	BREAK ROOM SINK	<1.00	02/09/2021	
21-02-00251-009	159.8-10	01/27/2021	BREAK ROOM BOTTLE FILL	<1.00	02/09/2021	
21-02-00251-010	159.8-11	01/27/2021	BREAK ROOM SPRAYER	<1.00	02/09/2021	
21-02-00251-011	159.8-12A	01/27/2021	SHOP DRINKING FOUNTAIN	<1.00	02/09/2021	
21-02-00251-012	159.8-12B	01/27/2021	SHOP BOTTLE FILL	<1.00	02/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980 **Report Number:** 21-02-00251

Project/Test Address: 2020-159.8; Buildings and Grounds; 2451 Baseline

Road, Grand Island, NY 14072

Lab Sample Client Collection Collection Location Concentration Analysis Narrative
Number Sample ID Date ID

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Tasha Eaddy

Jasha Faddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= microg

ug/L= micrograms per liter

ppb = parts per billion



Chain of Custody Document

Submitted to: (Lab Name)

EHS

3860 California Road, Orchard Park, New York 14127 PHONE (716) 312-0070 FAX (716) 312-8092 WWW.STOHLENVIRONMENTAL.COM STOHL Job # 2020L-159.8

	Client: Grand Island CSD			Contact: James Rozler				
uilding: Building	gs and Grounds		Location:	2451 Baseline Road Gran	d Island, NY 14072			
<u>LEAD</u> Water by SM 19, 21 - 23 3113B (-04, -10)			X 20 Days					
Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Result		
159.8-1	Kitchenette Sink	S	4:30					
159.8-2	Kitchenette Bottle Fill	S	4:31					
159.8-3	Kitchenette Sprayer	S	4:32					
159.8-4	Womens Lav Left	S	4:33					
159.8-5	Womens Lav Right	S	4:34					
159.8-7	Mens Lav Left	S	4:35	***************************************				
159.8-8	Mens Lav Right	S	4:36					
159.8-9	Break Room Sink	S	4:37					
159.8-10	Break Room Bottle Fill	S	4:38	21-02	21-02-00251			
159.8-11	Break Room Sprayer	S	4:39			To the state of th		
159.8-12A	Shop Drinking Fountain	DF	4:40					
159.8-12B	Shop Bottle Fill	DFB	4:41	Due I	Date:			
	·				2/2021			
				(Tuesday)				
				AE		-		

Page

Archived / Released: ____QA/QC InterLAB Use: ____

_1 of _1

_____Date: _____

Time: