

ANALYTICAL REPORT

Job Number: 420-108866-1


SDG Number: East Rambo CSD 2016-090 Summit Park

Job Description: Rockland BOCES

For:

Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Attention: Seth Armstrong



Debra Bayer

Customer Service Manager

dbayer@envirotestlaboratories.com

08/23/2016

cc: John Gulino

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

Envirotest Laboratories, Inc.

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Rockland BOCES

Job Number: 420-108866-1
SDG Number: East Rambo CSD 2016-090 Summit Park

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Rockland BOCES

Job Number: 420-108866-1

SDG Number: East Rambo CSD 2016-090 Summit Park

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Cusack, Renee	RC
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-108866-1

SDG Number: East Rambo CSD 2016-090 Summit Park

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-108866-1	16-90-ER-SPK-SC-001	Drinking Water	08/15/2016 0501	08/15/2016 0945
420-108866-2	16-90-ER-SPK-OT-002	Drinking Water	08/15/2016 0503	08/15/2016 0945
420-108866-3	16-90-ER-SPK-BF-003	Drinking Water	08/15/2016 0513	08/15/2016 0945
420-108866-4	16-90-ER-SPK-BF-004	Drinking Water	08/15/2016 0512	08/15/2016 0945
420-108866-5	16-90-ER-SPK-BF-005	Drinking Water	08/15/2016 0513	08/15/2016 0945
420-108866-6	16-90-ER-SPK-BF-006	Drinking Water	08/15/2016 0514	08/15/2016 0945
420-108866-7	16-90-ER-SPK-DW-007	Drinking Water	08/15/2016 0518	08/15/2016 0945
420-108866-8	16-90-ER-SPK-KF-008	Drinking Water	08/15/2016 0510	08/15/2016 0945
420-108866-9	16-90-ER-SPK-KF-009	Drinking Water	08/15/2016 0509	08/15/2016 0945
420-108866-10	16-90-ER-SPK-BF-010	Drinking Water	08/15/2016 0511	08/15/2016 0945
420-108866-11	16-90-ER-SPK-OT-011	Drinking Water	08/15/2016 0539	08/15/2016 0945
420-108866-12	16-90-ER-SPK-BF-012	Drinking Water	08/15/2016 0540	08/15/2016 0945
420-108866-13	16-90-ER-SPK-NF-013	Drinking Water	08/15/2016 0543	08/15/2016 0945
420-108866-14	16-90-ER-SPK-CF-014	Drinking Water	08/15/2016 0547	08/15/2016 0945
420-108866-15	16-90-ER-SPK-CFF-015	Drinking Water	08/15/2016 0547	08/15/2016 0945
420-108866-16	16-90-ER-SPK-CF-016	Drinking Water	08/15/2016 0545	08/15/2016 0945
420-108866-17	16-90-ER-SPK-CFF-017	Drinking Water	08/15/2016 0545	08/15/2016 0945
420-108866-18	16-90-ER-SPK-BF-018	Drinking Water	08/15/2016 0550	08/15/2016 0945
420-108866-19	16-90-ER-SPK-BF-019	Drinking Water	08/15/2016 0548	08/15/2016 0945
420-108866-20	16-90-ER-SPK-TL-020	Drinking Water	08/15/2016 0548	08/15/2016 0945
420-108866-21	16-90-ER-SPK-CF-021	Drinking Water	08/15/2016 0517	08/15/2016 0945
420-108866-22	16-90-ER-SPK-CFF-022	Drinking Water	08/15/2016 0548	08/15/2016 0945
420-108866-23	16-90-ER-SPK-CF-023	Drinking Water	08/15/2016 0549	08/15/2016 0945
420-108866-24	16-90-ER-SPK-CFF-024	Drinking Water	08/15/2016 0550	08/15/2016 0945
420-108866-25	16-90-ER-SPK-CF-025	Drinking Water	08/15/2016 0545	08/15/2016 0945
420-108866-26	16-90-ER-SPK-CFF-026	Drinking Water	08/15/2016 0546	08/15/2016 0945
420-108866-27	16-90-ER-SPK-CF-027	Drinking Water	08/15/2016 0542	08/15/2016 0945
420-108866-28	16-90-ER-SPK-CFF-028	Drinking Water	08/15/2016 0549	08/15/2016 0945
420-108866-29	16-90-ER-SPK-CF-029	Drinking Water	08/15/2016 0544	08/15/2016 0945
420-108866-30	16-90-ER-SPK-CFF-030	Drinking Water	08/15/2016 0543	08/15/2016 0945
420-108866-31	16-90-ER-SPK-CF-031	Drinking Water	08/15/2016 0540	08/15/2016 0945
420-108866-32	16-90-ER-SPK-CFF-032	Drinking Water	08/15/2016 0541	08/15/2016 0945
420-108866-33	16-90-ER-SPK-CF-033	Drinking Water	08/15/2016 0526	08/15/2016 0945
420-108866-34	16-90-ER-SPK-CFF-034	Drinking Water	08/15/2016 0526	08/15/2016 0945
420-108866-35	16-90-ER-SPK-CF-035	Drinking Water	08/15/2016 0525	08/15/2016 0945
420-108866-36	16-90-ER-SPK-CFF-036	Drinking Water	08/15/2016 0524	08/15/2016 0945
420-108866-37	16-90-ER-SPK-CF-037	Drinking Water	08/15/2016 0522	08/15/2016 0945
420-108866-38	16-90-ER-SPK-CFF-038	Drinking Water	08/15/2016 0522	08/15/2016 0945
420-108866-39	16-90-ER-SPK-CF-039	Drinking Water	08/15/2016 0520	08/15/2016 0945
420-108866-40	16-90-ER-SPK-CFF-040	Drinking Water	08/15/2016 0520	08/15/2016 0945
420-108866-41	16-90-ER-SPK-OT-041	Drinking Water	08/15/2016 0512	08/15/2016 0945
420-108866-42	16-90-ER-SPK-BF-042	Drinking Water	08/15/2016 0511	08/15/2016 0945
420-108866-43	16-90-ER-SPK-CF-043	Drinking Water	08/15/2016 0510	08/15/2016 0945
420-108866-44	16-90-ER-SPK-CFF-044	Drinking Water	08/15/2016 0510	08/15/2016 0945
420-108866-45	16-90-ER-SPK-CF-045	Drinking Water	08/15/2016 0513	08/15/2016 0945
420-108866-46	16-90-ER-SPK-CFF-046	Drinking Water	08/15/2016 0514	08/15/2016 0945

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-108866-1
SDG Number: East Rampo CSD 2016-090 Summit Park

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-108866-47	16-90-ER-SPK-CF-047	Drinking Water	08/15/2016 0516	08/15/2016 0945
420-108866-48	16-90-ER-SPK-CFF-048	Drinking Water	08/15/2016 0516	08/15/2016 0945
420-108866-49	16-90-ER-SPK-CF-049	Drinking Water	08/15/2016 0528	08/15/2016 0945
420-108866-50	16-90-ER-SPK-CFF-050	Drinking Water	08/15/2016 0528	08/15/2016 0945
420-108866-51	16-90-ER-SPK-CF-051	Drinking Water	08/15/2016 0530	08/15/2016 0945
420-108866-52	16-90-ER-SPK-CFF-052	Drinking Water	08/15/2016 0530	08/15/2016 0945
420-108866-53	16-90-ER-SPK-CF-053	Drinking Water	08/15/2016 0534	08/15/2016 0945
420-108866-54	16-90-ER-SPK-CFF-054	Drinking Water	08/15/2016 0533	08/15/2016 0945
420-108866-55	16-90-ER-SPK-CF-055	Drinking Water	08/15/2016 0532	08/15/2016 0945
420-108866-56	16-90-ER-SPK-CFF-056	Drinking Water	08/15/2016 0531	08/15/2016 0945
420-108866-57	16-90-ER-SPK-DW-057	Drinking Water	08/15/2016 0530	08/15/2016 0945
420-108866-58	16-90-ER-SPK-CF-058	Drinking Water	08/15/2016 0529	08/15/2016 0945
420-108866-59	16-90-ER-SPK-CFF-059	Drinking Water	08/15/2016 0528	08/15/2016 0945
420-108866-60	16-90-ER-SPK-CF-060	Drinking Water	08/15/2016 0526	08/15/2016 0945
420-108866-61	16-90-ER-SPK-CFF-061	Drinking Water	08/15/2016 0527	08/15/2016 0945
420-108866-62	16-90-ER-SPK-CF-062	Drinking Water	08/15/2016 0524	08/15/2016 0945
420-108866-63	16-90-ER-SPK-CFF-063	Drinking Water	08/15/2016 0525	08/15/2016 0945
420-108866-64	16-90-ER-SPK-CF-064	Drinking Water	08/15/2016 0523	08/15/2016 0945
420-108866-65	16-90-ER-SPK-CFF-065	Drinking Water	08/15/2016 0524	08/15/2016 0945
420-108866-68	16-90-ER-SPK-CF-068	Drinking Water	08/15/2016 0520	08/15/2016 0945
420-108866-69	16-90-ER-SPK-CFF-069	Drinking Water	08/15/2016 0519	08/15/2016 0945
420-108866-70	16-90-ER-SPK-CF-070	Drinking Water	08/15/2016 0518	08/15/2016 0945
420-108866-71	16-90-ER-SPK-CFF-071	Drinking Water	08/15/2016 0517	08/15/2016 0945
420-108866-72	16-90-ER-SPK-CF-072	Drinking Water	08/15/2016 0515	08/15/2016 0945
420-108866-73	16-90-ER-SPK-CFF-073	Drinking Water	08/15/2016 0516	08/15/2016 0945
420-108866-74	16-90-ER-SPK-CF-074	Drinking Water	08/15/2016 0517	08/15/2016 0945
420-108866-75	16-90-ER-SPK-CFF-075	Drinking Water	08/15/2016 0517	08/15/2016 0945

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-SC-001
Lab Sample ID: 420-108866-1

Date Sampled: 08/15/2016 0501
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1357	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	1.45	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-OT-002
Lab Sample ID: 420-108866-2

Date Sampled: 08/15/2016 0503
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1400	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	64.7 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-BF-003
Lab Sample ID: 420-108866-3

Date Sampled: 08/15/2016 0513
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1404		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	7.76	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-BF-004
Lab Sample ID: 420-108866-4

Date Sampled: 08/15/2016 0512
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1407	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	5.29	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-BF-005
Lab Sample ID: 420-108866-5

Date Sampled: 08/15/2016 0513
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1411		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	35.0 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-BF-006
Lab Sample ID: 420-108866-6

Date Sampled: 08/15/2016 0514
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 1932	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	6.71	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-DW-007
Lab Sample ID: 420-108866-7

Date Sampled: 08/15/2016 0518
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 1935	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	11.8	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-KF-008
Lab Sample ID: 420-108866-8

Date Sampled: 08/15/2016 0510
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1414	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	9.68	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-KF-009
Lab Sample ID: 420-108866-9

Date Sampled: 08/15/2016 0509
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 1946	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	11.5	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-BF-010
Lab Sample ID: 420-108866-10

Date Sampled: 08/15/2016 0511
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1418		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	17.3 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-OT-011
Lab Sample ID: 420-108866-11

Date Sampled: 08/15/2016 0539
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 1949	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	15.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-BF-012
Lab Sample ID: 420-108866-12

Date Sampled: 08/15/2016 0540
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 1953	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	28.0 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-NF-013
Lab Sample ID: 420-108866-13

Date Sampled: 08/15/2016 0543
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1421		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	12.2	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-014
Lab Sample ID: 420-108866-14

Date Sampled: 08/15/2016 0547
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 1956	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	54.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-015
Lab Sample ID: 420-108866-15

Date Sampled: 08/15/2016 0547
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1425		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	51.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-016
Lab Sample ID: 420-108866-16

Date Sampled: 08/15/2016 0545
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2000	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	40.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-017
Lab Sample ID: 420-108866-17

Date Sampled: 08/15/2016 0545
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2003	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	24.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-BF-018
Lab Sample ID: 420-108866-18

Date Sampled: 08/15/2016 0550
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2007	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	8.85	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-BF-019
Lab Sample ID: 420-108866-19

Date Sampled: 08/15/2016 0548
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1435	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	34.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-TL-020
Lab Sample ID: 420-108866-20

Date Sampled: 08/15/2016 0548
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1115		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	7.21	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-021
Lab Sample ID: 420-108866-21

Date Sampled: 08/15/2016 0517
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1129	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	17.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-022
Lab Sample ID: 420-108866-22

Date Sampled: 08/15/2016 0548
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2010	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	10.7	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-023
Lab Sample ID: 420-108866-23

Date Sampled: 08/15/2016 0549
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2014	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	25.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-024
Lab Sample ID: 420-108866-24

Date Sampled: 08/15/2016 0550
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2017	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	7.67	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-025
Lab Sample ID: 420-108866-25

Date Sampled: 08/15/2016 0545
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2028	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	46.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-026
Lab Sample ID: 420-108866-26

Date Sampled: 08/15/2016 0546
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/16/2016 2031		
Prep Method: 200			Date Prepared: 08/16/2016 1300		
Lead	10.8	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-027
Lab Sample ID: 420-108866-27

Date Sampled: 08/15/2016 0542
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/16/2016 2035		
Prep Method: 200			Date Prepared: 08/16/2016 1300		
Lead	17.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-028
Lab Sample ID: 420-108866-28

Date Sampled: 08/15/2016 0549
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2038	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	11.8	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-029
Lab Sample ID: 420-108866-29

Date Sampled: 08/15/2016 0544
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2052	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	14.0	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-030
Lab Sample ID: 420-108866-30

Date Sampled: 08/15/2016 0543
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/16/2016 2056		
Prep Method: 200			Date Prepared: 08/16/2016 1300		
Lead	12.8	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-031
Lab Sample ID: 420-108866-31

Date Sampled: 08/15/2016 0540
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2059	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	6.95	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-032
Lab Sample ID: 420-108866-32

Date Sampled: 08/15/2016 0541
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2110	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	3.62	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-033
Lab Sample ID: 420-108866-33

Date Sampled: 08/15/2016 0526
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1133	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	36.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-034
Lab Sample ID: 420-108866-34

Date Sampled: 08/15/2016 0526
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2114	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	27.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-035
Lab Sample ID: 420-108866-35

Date Sampled: 08/15/2016 0525
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1136		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	31.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-036
Lab Sample ID: 420-108866-36

Date Sampled: 08/15/2016 0524
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2117	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	16.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-037
Lab Sample ID: 420-108866-37

Date Sampled: 08/15/2016 0522
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2121	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	21.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-038
Lab Sample ID: 420-108866-38

Date Sampled: 08/15/2016 0522
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2124	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	23.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-039
Lab Sample ID: 420-108866-39

Date Sampled: 08/15/2016 0520
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1147	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	12.8	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-040
Lab Sample ID: 420-108866-40

Date Sampled: 08/15/2016 0520
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2128	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	20.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-OT-041
Lab Sample ID: 420-108866-41

Date Sampled: 08/15/2016 0512
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1150	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	14.6	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-BF-042
Lab Sample ID: 420-108866-42

Date Sampled: 08/15/2016 0511
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1154	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	7.95	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-043
Lab Sample ID: 420-108866-43

Date Sampled: 08/15/2016 0510
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/16/2016 2131		
Prep Method: 200			Date Prepared: 08/16/2016 1300		
Lead	38.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-044
Lab Sample ID: 420-108866-44

Date Sampled: 08/15/2016 0510
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1157		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	25.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-045
Lab Sample ID: 420-108866-45

Date Sampled: 08/15/2016 0513
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2135	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	17.7 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-046
Lab Sample ID: 420-108866-46

Date Sampled: 08/15/2016 0514
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2138	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	24.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-047
Lab Sample ID: 420-108866-47

Date Sampled: 08/15/2016 0516
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2142	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	30.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-048
Lab Sample ID: 420-108866-48

Date Sampled: 08/15/2016 0516
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2152	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	17.3 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-049
Lab Sample ID: 420-108866-49

Date Sampled: 08/15/2016 0528
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2156	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	10.3	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-050
Lab Sample ID: 420-108866-50

Date Sampled: 08/15/2016 0528
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2159	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	14.2	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-051
Lab Sample ID: 420-108866-51

Date Sampled: 08/15/2016 0530
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2203	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	68.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-052
Lab Sample ID: 420-108866-52

Date Sampled: 08/15/2016 0530
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2206	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	14.6	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-053
Lab Sample ID: 420-108866-53

Date Sampled: 08/15/2016 0534
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2210	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	9.91	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-054
Lab Sample ID: 420-108866-54

Date Sampled: 08/15/2016 0533
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2214	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	19.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-055
Lab Sample ID: 420-108866-55

Date Sampled: 08/15/2016 0532
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2235	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	7.76	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-056
Lab Sample ID: 420-108866-56

Date Sampled: 08/15/2016 0531
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/16/2016 2238		
Prep Method: 200			Date Prepared: 08/16/2016 1300		
Lead	22.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-DW-057
Lab Sample ID: 420-108866-57

Date Sampled: 08/15/2016 0530
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1201	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	11.2	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-058
Lab Sample ID: 420-108866-58

Date Sampled: 08/15/2016 0529
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1204		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	33.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-059
Lab Sample ID: 420-108866-59

Date Sampled: 08/15/2016 0528
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2242	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	92.0 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-060
Lab Sample ID: 420-108866-60

Date Sampled: 08/15/2016 0526
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/19/2016 1208		
Prep Method: 200			Date Prepared: 08/17/2016 0900		
Lead	24.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-061
Lab Sample ID: 420-108866-61

Date Sampled: 08/15/2016 0527
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1211	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	10.1	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-062
Lab Sample ID: 420-108866-62

Date Sampled: 08/15/2016 0524
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2245	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	34.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-063
Lab Sample ID: 420-108866-63

Date Sampled: 08/15/2016 0525
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2249	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	9.14	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-064
Lab Sample ID: 420-108866-64

Date Sampled: 08/15/2016 0523
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2252	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	70.7 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-065
Lab Sample ID: 420-108866-65

Date Sampled: 08/15/2016 0524
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2256	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	30.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-068
Lab Sample ID: 420-108866-68

Date Sampled: 08/15/2016 0520
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1215	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	30.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-069
Lab Sample ID: 420-108866-69

Date Sampled: 08/15/2016 0519
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2300	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	14.1	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-070
Lab Sample ID: 420-108866-70

Date Sampled: 08/15/2016 0518
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1218	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	26.3 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-071
Lab Sample ID: 420-108866-71

Date Sampled: 08/15/2016 0517
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2303	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	32.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-072
Lab Sample ID: 420-108866-72

Date Sampled: 08/15/2016 0515
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2307	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	31.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Ramapo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-073
Lab Sample ID: 420-108866-73

Date Sampled: 08/15/2016 0516
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/19/2016 1229	
Prep Method: 200			Date Prepared:	08/17/2016 0900	
Lead	4.06	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CF-074
Lab Sample ID: 420-108866-74

Date Sampled: 08/15/2016 0517
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/16/2016 2317		
Prep Method: 200			Date Prepared: 08/16/2016 1300		
Lead	69.0 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108866-1
Sdg Number: East Rambo CSD 2016-090 Summit Park

Client Sample ID: 16-90-ER-SPK-CFF-075
Lab Sample ID: 420-108866-75

Date Sampled: 08/15/2016 0517
Date Received: 08/15/2016 0945
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/16/2016 2321	
Prep Method: 200			Date Prepared:	08/16/2016 1300	
Lead	146 g	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Rockland BOCES

Job Number:

Sdg Number: East Ramapo CSD 2016-090 Summit Park

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards

Certification Information

Client: Rockland BOCES

Job Number:

Sdg Number: East Rambo CSD 2016-090 Summit Park

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalien Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Rockland BOCES

Job Number:

Sdg Number: East Rambo CSD 2016-090 Summit Park

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

Kim Sills/ik
5055 1045



CHAIN OF CUSTODY

Lab Name **EnviroTest Laboratories**
Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)

108866

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 5
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER SPECIFY	40ml Vials HCl	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	ACQUOUS (WATER)	Liter Plastic	NORMAL <input checked="" type="checkbox"/>
CLIENT NAME Rockland BOCES	igulino@rboces.org/ sarmstrong@rboces.org/ klewando@rboces.org		SOLID OR SEMISOLID	250ml Plastic Nitric Acid	QUICK <input type="checkbox"/>
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994			COMPOSITE (C) OR GRAB (G) INDICATE	250ml Plastic Sulfuric Acid	VERBAL <input type="checkbox"/>
COMPANY CONTRACTING THIS WORK (if applicable)				Liter Amber HCl	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED										REMARKS		
			Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other			
8/15/2016	501	16-90-ER-SPK-SC-001	1												Lead (DW 200.8)
8/15/2016	503	16-90-ER-SPK-OT-002	1												Lead (DW 200.8)
8/15/2016	513	16-90-ER-SPK-BF-003	1												Lead (DW 200.8)
8/15/2016	512	16-90-ER-SPK-BF-004	1												Lead (DW 200.8)
8/15/2016	513	16-90-ER-SPK-BF-005	1												Lead (DW 200.8)
8/15/2016	514	16-90-ER-SPK-BF-006	1												Lead (DW 200.8)
8/15/2016	518	16-90-ER-SPK-DW-007	1												Lead (DW 200.8)
8/15/2016	510	16-90-ER-SPK-KF-008	1												Lead (DW 200.8)
8/15/2016	509	16-90-ER-SPK-KF-009	1												Lead (DW 200.8)
8/15/2016	511	16-90-ER-SPK-BF-010	1												Lead (DW 200.8)
8/15/2016	539	16-90-ER-SPK-OT-011	1												Lead (DW 200.8)
8/15/2016	540	16-90-ER-SPK-BF-012	1												Lead (DW 200.8)
8/15/2016	5X3	16-90-ER-SPK-NF-013	1												Lead (DW 200.8)
8/15/2016	5Y7	16-90-ER-SPK-CF-014	1												Lead (DW 200.8)
8/15/2016	5Y7	16-90-ER-SPK-CFF-015	1												Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY
<i>John Gulino</i>	8/15/16	0945		<i>John Gulino</i>	8-15-16	0945	
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY
<i>Keith Lewandosky</i>	8-15-16	0945		<i>John Gulino</i>	8-15-16	0945	
RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER Temp (C):	ICE (Y/N)	pH	CL2
<i>John Gulino</i>	8/15/16	0945	YES	25.8			

KM 8/16/16
2 of 5



CHAIN OF CUSTODY

Lab Name **EnviroTest Laboratories**
Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)

108866

PROJECT REFERENCE East Ramapo CSD 2016-090		PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES							PAGE 1 of 5	
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	<input type="checkbox"/> Drinking Water or (Waste Water) Indicate <input type="checkbox"/> SOLID OR SEMISOLID <input type="checkbox"/> OTHER Specify	40ml Vials HCl	1	250ml Plastic Nitric Acid	1	250ml Plastic Sulfuric Acid	1	1	Lead (DW 200.8)	
CLIENT (SITE) / PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX		1	1	1	1	1	1	1	1	Lead (DW 200.8)
CLIENT NAME Rockland BOCES	CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994	CLIENT EMAIL kgulino@iboces.org/ samsstrong@iboces.org klewando@iboces.org	COMPOSITE (C) OR GRAB (G) / MDATE	1	1	1	1	1	1	1	1	Lead (DW 200.8)
COMPANY CONTRACTING THIS WORK (if applicable)												
DATE	TIME	SAMPLE IDENTIFICATION		NUMBER OF CONTAINERS SUBMITTED								REMARKS
8/15/2016	545	16-90-ER-SPK-CF-016		1								Lead (DW 200.8)
8/15/2016	545	16-90-ER-SPK-CFF-017		1								Lead (DW 200.8)
8/15/2016	550	16-90-ER-SPK-BF-018		1								Lead (DW 200.8)
8/15/2016	548	16-90-ER-SPK-BF-019		1								Lead (DW 200.8)
8/15/2016	550	16-90-ER-SPK-TL-020		1								Lead (DW 200.8)
8/15/2016	517	16-90-ER-SPK-CF-021		1								Lead (DW 200.8)
8/15/2016	548	16-90-ER-SPK-CFF-022		1								Lead (DW 200.8)
8/15/2016	549	16-90-ER-SPK-CF-023		1								Lead (DW 200.8)
8/15/2016	550	16-90-ER-SPK-CFF-024		1								Lead (DW 200.8)
8/15/2016	545	16-90-ER-SPK-CF-025		1								Lead (DW 200.8)
8/15/2016	546	16-90-ER-SPK-CFF-026		1								Lead (DW 200.8)
8/15/2016	542	16-90-ER-SPK-CF-027		1								Lead (DW 200.8)
8/15/2016	549	16-90-ER-SPK-CFF-028		1								Lead (DW 200.8)
8/15/2016	544	16-90-ER-SPK-CF-029		1								Lead (DW 200.8)
8/15/2016	543	16-90-ER-SPK-CFF-030		1								Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	COMP. DATE		TIME		
<i>[Signature]</i>		8/15/16	0945	<i>[Signature]</i>		8/15/16	0945					
SAMPLED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	COMP. DATE		TIME		
<i>[Signature]</i>		8/15/16	0815	<i>[Signature]</i>		8/15/16	0815					
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	COMP. DATE		TIME		
<i>[Signature]</i>		8/15/16	0445	<i>[Signature]</i>		8/15/16	0445					
LABORATORY REMARKS: ICE (Y <input type="checkbox"/> N <input checked="" type="checkbox"/>) PH <input type="checkbox"/> CL2 <input type="checkbox"/> Revisited by _____												
RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>[Signature]</i> DATE 8/15/16 TIME 0445 CUSTODY INTACT YES NO												

KM 8/15/16
2015 3015



CHAIN OF CUSTODY

Lab Name **EnviroTest Laboratories**
Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)

108866

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 5
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER SPECIFY	40ml Vials HCl	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	ACQUEOUS (WATER)	Liter Amber HCl	NORMAL <u> </u> X <u> </u>
CLIENT NAME Rockland BOCES	igulino@rboces.org/ sarmstrong@rboces.org/ kiewando@rboces.org		D (Drinking Water) or W (Waste Water) Indicate	Liter Plastic	QUICK <u> </u>
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994			SOLID OR SEMISOLID	250ml Plastic Nitric Acid	VERBAL <u> </u>
COMPANY CONTRACTING THIS WORK (If Applicable)				250ml Plastic Sulfuric Acid	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED							REMARKS
			Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	
8/15/2016	546	16-90-ER-SPK-CF-031	1			1				Lead (DW 200.8)
8/15/2016	541	16-90-ER-SPK-CFF-032	1			1				Lead (DW 200.8)
8/15/2016	526	16-90-ER-SPK-CF-033	1			1				Lead (DW 200.8)
8/15/2016	526	16-90-ER-SPK-CFF-034	1			1				Lead (DW 200.8)
8/15/2016	525	16-90-ER-SPK-CF-035	1			1				Lead (DW 200.8)
8/15/2016	524	16-90-ER-SPK-CFF-036	1			1				Lead (DW 200.8)
8/15/2016	522	16-90-ER-SPK-CF-037	1			1				Lead (DW 200.8)
8/15/2016	522	16-90-ER-SPK-CFF-038	1			1				Lead (DW 200.8)
8/15/2016	520	16-90-ER-SPK-CF-039	1			1				Lead (DW 200.8)
8/15/2016	520	16-90-ER-SPK-CFF-040	1			1				Lead (DW 200.8)
8/15/2016	512	16-90-ER-SPK-OT-041	1			1				Lead (DW 200.8)
8/15/2016	511	16-90-ER-SPK-BF-042	1			1				Lead (DW 200.8)
8/15/2016	510	16-90-ER-SPK-CF-043	1			1				Lead (DW 200.8)
8/15/2016	510	16-90-ER-SPK-CFF-044	1			1				Lead (DW 200.8)
8/15/2016	513	16-90-ER-SPK-CF-045	1			1				Lead (DW 200.8)

RELINQUISHED BY (SIGNATURE)	DATE	TIME	RECEIVED BY (SIGNATURE)	DATE	TIME
<i>[Signature]</i>	8/15/16	0945	<i>[Signature]</i>		
SAMPLED BY (SIGNATURE)	DATE	TIME	RECEIVED BY (SIGNATURE)	DATE	TIME
<i>[Signature]</i>	8-15-16	6:54	<i>[Signature]</i>		
RELINQUISHED BY (SIGNATURE), COMPANY	DATE	TIME	RECEIVED BY (SIGNATURE), COMPANY	DATE	TIME

RECEIVED FOR LABORATORY BY (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP (C)	LABORATORY REMARKS
<i>[Signature]</i>	8/15/16	0945	YES	25.8	ICE (Y/N) <u> </u> PH <u> </u> CL2 <u> </u> Reviewed by <u> </u>

4 of 5

CHAIN OF CUSTODY

EnviroTest Laboratories, Inc.
 Lab Name: **EnviroTest Laboratories**
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)
1088866

PROJECT REFERENCE East Ramapo CSD 2016-090		PROJECT NO.	PROJECT LOCATION
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	
CLIENT (SITE)/PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	
CLIENT NAME Rockland BOCES	igulino@iboces.org/ sarmstrong@iboces.org klewando@iboces.org		
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994			
COMPANY CONTRACTING THIS WORK (if applicable)			

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	REQUIRED ANALYSES										OTHER	REMARKS		
			Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other				
8/15/2016	514	16-90-ER-SPK-CFF-046	1													Lead (DW 200.8)
8/15/2016	516	16-90-ER-SPK-CF-047	1													Lead (DW 200.8)
8/15/2016	516	16-90-ER-SPK-CFF-048	1													Lead (DW 200.8)
8/15/2016	528	16-90-ER-SPK-CF-049	1													Lead (DW 200.8)
8/15/2016	528	16-90-ER-SPK-CFF-050	1													Lead (DW 200.8)
8/15/2016	530	16-90-ER-SPK-CF-051	1													Lead (DW 200.8)
8/15/2016	530	16-90-ER-SPK-CFF-052	1													Lead (DW 200.8)
8/15/2016	534	16-90-ER-SPK-CF-053	1													Lead (DW 200.8)
8/15/2016	533	16-90-ER-SPK-CFF-054	1													Lead (DW 200.8)
8/15/2016	532	16-90-ER-SPK-CF-055	1													Lead (DW 200.8)
8/15/2016	531	16-90-ER-SPK-CFF-056	1													Lead (DW 200.8)
8/15/2016	530	16-90-ER-SPK-DW-057	1													Lead (DW 200.8)
8/15/2016	529	16-90-ER-SPK-CF-058	1													Lead (DW 200.8)
8/15/2016	528	16-90-ER-SPK-CFF-059	1													Lead (DW 200.8)
8/15/2016	526	16-90-ER-SPK-CF-060	1													Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME
<i>[Signature]</i>	COMPANY	8/15/16	8:45 AM
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME
<i>[Signature]</i>	COMPANY	8-15-16	8:00 AM
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME
<i>[Signature]</i>	COMPANY		

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT
<i>[Signature]</i>	8/15/16	8:45	YES
LABORATORY REMARKS: ICE (Y/N) PH CL2	Revised by		

km815116
108866
5 of 5



CHAIN OF CUSTODY

Lab Name **EnviroTest Laboratories**
Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)
108866

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 5
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER Specify	40ml Vials HCl	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	D (Drinking Water) or W (Waste Water) (Indicate)	250ml Plastic Nitric Acid	NORMAL <input checked="" type="checkbox"/> X
CLIENT NAME Rockland BOCES	igulino@rboces.org/ samstrong@rboces.org/ klewando@rboces.org		AQUEOUS (WATER)	250ml Plastic Sulfuric Acid	QUICK
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994			COMPOSITE (C) OR GRAB (G) INDICATE	Liter Amber HCl	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)					
SAMPLE DATE		SAMPLE IDENTIFICATION		NUMBER OF CONTAINERS SUBMITTED	
8/15/2016	527	16-90-ER-SPK-CFF-061	S/D	1	Lead (DW 200.8)
8/15/2016	528	16-90-ER-SPK-CF-062	S/D	1	Lead (DW 200.8)
8/15/2016	525	16-90-ER-SPK-CFF-063	S/D	1	Lead (DW 200.8)
8/15/2016	523	16-90-ER-SPK-CF-064	S/D	1	Lead (DW 200.8)
8/15/2016	524	16-90-ER-SPK-CFF-065	S/D	1	Lead (DW 200.8)
8/15/2016		16-90-ER-SPK-CF-066 NOT SAMPLED	S/D	1	Lead (DW 200.8)
8/15/2016		16-90-ER-SPK-CFF-067 NOT SAMPLED	S/D	1	Lead (DW 200.8)
8/15/2016	520	16-90-ER-SPK-CF-068	S/D	1	Lead (DW 200.8)
8/15/2016	519	16-90-ER-SPK-CFF-069	S/D	1	Lead (DW 200.8)
8/15/2016	518	16-90-ER-SPK-CF-070	S/D	1	Lead (DW 200.8)
8/15/2016	517	16-90-ER-SPK-CFF-071	S/D	1	Lead (DW 200.8)
8/15/2016	515	16-90-ER-SPK-CF-072	S/D	1	Lead (DW 200.8)
8/15/2016	516	16-90-ER-SPK-CFF-073	S/D	1	Lead (DW 200.8)
8/15/2016	517	16-90-ER-SPK-CF-074	S/D	1	Lead (DW 200.8)
8/15/2016	517	16-90-ER-SPK-CFF-075	S/D	1	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)	DATE	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/15/16	8-15-16	0945	<i>[Signature]</i>	
SAMPLED BY: (SIGNATURE)	DATE	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/15/16	8-15-16	5:40-549	<i>[Signature]</i>	
RELINQUISHED BY: (SIGNATURE)	DATE	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>				<i>[Signature]</i>	
RECEIVED FOR LABORATORY BY: (SIGNATURE)					
<i>[Signature]</i>					
DATE	TIME	CUSTODY INTACT	LABORATORY REMARKS:	ICE (Y/N) <input checked="" type="checkbox"/> CL2	Revised by
8/15/16	0945	YES	75.8		
RECEIVED BY: (SIGNATURE)					
<i>[Signature]</i>					

From: [Gulino, John](mailto:Gulino,John)
To: dbayer@envirotestlaboratories.com
Subject: Re: Files from 420-108866-1 Rockland BOCES --- Chain -- School Location?
Date: Thursday, August 18, 2016 5:10:53 PM

Yes please add Summit Park for location on coc

Sent from my iPhone

> On Aug 18, 2016, at 5:07 PM, "dbayer@envirotestlaboratories.com" <dbayer@envirotestlaboratories.com> wrote:
>
>
>
> Good Afternoon
> Please let me know if you would like a school location reference for the attached chain of custody Lab # 420-108866.
> Thank you
> Debbie
>
>
> Debra Bayer
> EnviroTest Laboratories, Inc.
> [<mailto:dbayer@envirotestlaboratories.com>]
>
> Reference: [148792]
> <1088660001.pdf>

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you are not the named addressee you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake and delete this e-mail from your system. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Rockland BOCES

Job Number: 420-108866-1

SDG Number: East Rambo CSD 2016-090 Summit Park

Login Number: 108866

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	25.8 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	True	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	