

## **ANALYTICAL REPORT**

Job Number: 420-109125-1


SDG Number: East Ramapo CSD 2016-090 Transportation

Job Description: Rockland BOCES

For:

Rockland BOCES  
65 Parrott Road, B-4  
West Nyack, NY 10994

Attention: Seth Armstrong



---

Debra Bayer

Customer Service Manager

dbayer@envirotestlaboratories.com

08/25/2016

cc: John Gulino

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

**Envirotest Laboratories, Inc.**

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 [www.envirotestlaboratories.com](http://www.envirotestlaboratories.com)

## METHOD SUMMARY

Client: Rockland BOCES

Job Number: 420-109125-1

SDG Number: East Ramapo CSD 2016-090 Transportation

<b>Description</b>	<b>Lab Location</b>	<b>Method</b>	<b>Preparation Method</b>
<b>Matrix: Water</b>			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

### Lab References:

EnvTest = EnviroTest

### Method References:

EPA = US Environmental Protection Agency

**METHOD / ANALYST SUMMARY**

Client: Rockland BOCES

Job Number: 420-109125-1

SDG Number: East Ramapo CSD 2016-090 Transportation

<b>Method</b>	<b>Analyst</b>	<b>Analyst ID</b>
EPA 200.8 Rev.5.4	Sirico, Derek	DS

## SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-109125-1

SDG Number: East Ramapo CSD 2016-090 Transportation

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Client Matrix</b>	<b>Date/Time Sampled</b>	<b>Date/Time Received</b>
420-109125-1	16-90-ER-TRO-BF-001	Drinking Water	08/19/2016 0511	08/19/2016 1010
420-109125-2	16-90-ER-TRO-SC-002	Drinking Water	08/19/2016 0512	08/19/2016 1010
420-109125-3	16-90-ER-TRO-BF-003	Drinking Water	08/19/2016 0511	08/19/2016 1010

Seth Armstrong  
Rockland BOCES  
65 Parrott Road, B-4  
West Nyack, NY 10994

Job Number: 420-109125-1  
Sdg Number: East Ramapo CSD 2016-090 Transportation

**Client Sample ID:** 16-90-ER-TRO-BF-001  
**Lab Sample ID:** 420-109125-1

Date Sampled: 08/19/2016 0511  
Date Received: 08/19/2016 1010  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2334	
Prep Method: 200			Date Prepared:	08/21/2016 1700	
Lead	9.52	ug/L	1.00	1.00	1.0

Seth Armstrong  
Rockland BOCES  
65 Parrott Road, B-4  
West Nyack, NY 10994

Job Number: 420-109125-1  
Sdg Number: East Ramapo CSD 2016-090 Transportation

**Client Sample ID:** 16-90-ER-TRO-SC-002  
**Lab Sample ID:** 420-109125-2

Date Sampled: 08/19/2016 0512  
Date Received: 08/19/2016 1010  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2338	
Prep Method: 200			Date Prepared:	08/21/2016 1700	
Lead	4.86	ug/L	1.00	1.00	1.0

Seth Armstrong  
Rockland BOCES  
65 Parrott Road, B-4  
West Nyack, NY 10994

Job Number: 420-109125-1  
Sdg Number: East Ramapo CSD 2016-090 Transportation

**Client Sample ID:** 16-90-ER-TRO-BF-003  
**Lab Sample ID:** 420-109125-3

Date Sampled: 08/19/2016 0511  
Date Received: 08/19/2016 1010  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 1942	
Prep Method: 200			Date Prepared:	08/22/2016 1230	
Lead	14.8	ug/L	1.00	1.00	1.0

## DATA REPORTING QUALIFIERS

<b>Lab Section</b>	<b>Qualifier</b>	<b>Description</b>
--------------------	------------------	--------------------

---



## Certification Information

---

### **The following analytes are Not Part of the ELAP scope of accreditation**

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalien Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

### **The following analytes are Not Part of ELAP Potable Water scope of accreditation**

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

### **The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation**

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

### **The following analytes are Not Part of ELAP Non Potable Water scope of accreditation**

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

## Definitions and Glossary

---

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points

109125

Lab Name: EnviroTest Laboratories  
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO	PROJECT LOCATION Transportation	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 1
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER SPECIFY	Other	TURNAROUND TIME
CLIENT(SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	ACQUOUS (WATER)	250ml Plastic	NORMAL <input checked="" type="checkbox"/> X
CLIENT NAME Rockland BOCES	igulino@rboces.org/ sarmsstrong@rboces.org klewando@rboces.org	COMPOSITE (C) OR GRAB (G) INDICATE	SOLID OR SEMISOLID	Liter Plastic	QUICK
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994	COMPANY CONTRACTING THIS WORK (if applicable)	OTHER SPECIFY	OTHER SPECIFY	250ml Plastic Sulfuric Acid	VERBAL

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	ACQUOUS (WATER)	SOLID OR SEMISOLID	OTHER SPECIFY	NUMBER OF CONTAINERS SUBMITTED										REMARKS	
							Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other		
8/19/2016	5:11	16-90-ER-TRO-BF-001	S	D			1	1										Lead (DW 200.8)
8/19/2016	5:12	16-90-ER-TRO-SC-002	S	D			1	1										Lead (DW 200.8)
8/19/2016	5:11	16-90-ER-TRO-BF-003	S	D			1	1										Lead (DW 200.8)
			S	D			1	1										Lead (DW 200.8)
			S	D			1	1										Lead (DW 200.8)
			S	D			1	1										Lead (DW 200.8)
			S	D			1	1										Lead (DW 200.8)
			S	D			1	1										Lead (DW 200.8)
			S	D			1	1										Lead (DW 200.8)
			S	D			1	1										Lead (DW 200.8)
			S	D			1	1										Lead (DW 200.8)
			S	D			1	1										Lead (DW 200.8)

RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>	COMPANY ETR	DATE 8/19/16	TIME 2:53	RECEIVED BY (SIGNATURE) <i>[Signature]</i>	COMPANY ETR	DATE 8/19	TIME 2:53
RELINQUISHED BY (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY (SIGNATURE)	COMPANY	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]*

DATE: 8/19/16 TIME: 1010

CUSTOMER INTACT COOLER TEMP (C): 250

LABORATORY REMARKS: ICE (Y/N) V<sub>PH</sub> CL<sub>2</sub> Reviewed by: \_\_\_\_\_

## LOGIN SAMPLE RECEIPT CHECK LIST

Client: Rockland BOCES

Job Number: 420-109125-1

SDG Number: East Ramapo CSD 2016-090 Transportation

**Login Number: 109125**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is recorded.	True	25.0 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	True	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	