

ANALYTICAL REPORT

Job Number: 420-109229-1


SDG Number: East Ramapo 2016-090 Spring Valley HS

Job Description: Rockland BOCES

For:

Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Attention: Seth Armstrong



Debra Bayer

Customer Service Manager

dbayer@envirotestlaboratories.com

08/27/2016

cc: John Gulino

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

Envirotest Laboratories, Inc.

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Rockland BOCES

Job Number: 420-109229-1
SDG Number: East Ramapo 2016-090 Spring Valley HS

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Rockland BOCES

Job Number: 420-109229-1

SDG Number: East Ramapo 2016-090 Spring Valley HS

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-109229-1

SDG Number: East Ramapo 2016-090 Spring Valley HS

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-109229-1	16-90-ER-SVHS-SC-001	Drinking Water	08/22/2016 0454	08/22/2016 1218
420-109229-2	16-90-ER-SVHS-BF(A)-002	Drinking Water	08/22/2016 0603	08/22/2016 1218
420-109229-3	16-90-ER-SVHS-BF(B)-003	Drinking Water	08/22/2016 0603	08/22/2016 1218
420-109229-4	16-90-ER-SVHS-DW-004	Drinking Water	08/22/2016 0601	08/22/2016 1218
420-109229-5	16-90-ER-SVHS-BF(A)-005	Drinking Water	08/22/2016 0606	08/22/2016 1218
420-109229-6	16-90-ER-SVHS-BF(B)-006	Drinking Water	08/22/2016 0605	08/22/2016 1218
420-109229-7	16-90-ER-SVHS-BF(C) -007	Drinking Water	08/22/2016 0607	08/22/2016 1218
420-109229-8	16-90-ER-SVHS-WC-008	Drinking Water	08/22/2016 0555	08/22/2016 1218
420-109229-9	16-90-ER-SVHS-WC-009	Drinking Water	08/22/2016 0555	08/22/2016 1218
420-109229-10	16-90-ER-SVHS-KF(A)-010	Drinking Water	08/22/2016 0540	08/22/2016 1218
420-109229-11	16-90-ER-SVHS-KF(B)-011	Drinking Water	08/22/2016 0542	08/22/2016 1218
420-109229-12	16-90-ER-SVHS-KF(C) -012	Drinking Water	08/22/2016 0542	08/22/2016 1218
420-109229-13	16-90-ER-SVHS-KF(D) -013	Drinking Water	08/22/2016 0544	08/22/2016 1218
420-109229-14	16-90-ER-SVHS-KF -014	Drinking Water	08/22/2016 0539	08/22/2016 1218
420-109229-15	16-90-ER-SVHS-IM -014 A	Drinking Water	08/22/2016 0530	08/22/2016 1218
420-109229-17	16-90-ER-SVHS-BF -016	Drinking Water	08/22/2016 0556	08/22/2016 1218
420-109229-18	16-90-ER-SVHS-WC -017	Drinking Water	08/22/2016 0534	08/22/2016 1218
420-109229-19	16-90-ER-SVHS-BF(A)-018	Drinking Water	08/22/2016 0621	08/22/2016 1218
420-109229-20	16-90-ER-SVHS-BF(B)-019	Drinking Water	08/22/2016 0621	08/22/2016 1218
420-109229-21	16-90-ER-SVHS-BF(C) -020	Drinking Water	08/22/2016 0622	08/22/2016 1218
420-109229-22	16-90-ER-SVHS-BF(A)-021	Drinking Water	08/22/2016 0622	08/22/2016 1218
420-109229-23	16-90-ER-SVHS-BF(B)-022	Drinking Water	08/22/2016 0622	08/22/2016 1218
420-109229-24	16-90-ER-SVHS-BF(C) -023	Drinking Water	08/22/2016 0623	08/22/2016 1218
420-109229-25	16-90-ER-SVHS-BF(D) -024	Drinking Water	08/22/2016 0623	08/22/2016 1218
420-109229-26	16-90-ER-SVHS-DW-025	Drinking Water	08/22/2016 0620	08/22/2016 1218
420-109229-28	16-90-ER-SVHS-BF-027	Drinking Water	08/22/2016 0632	08/22/2016 1218
420-109229-29	16-90-ER-SVHS-BF-028	Drinking Water	08/22/2016 0614	08/22/2016 1218
420-109229-30	16-90-ER-SVHS-BF-029	Drinking Water	08/22/2016 0617	08/22/2016 1218
420-109229-31	16-90-ER-SVHS-BF-030	Drinking Water	08/22/2016 0612	08/22/2016 1218
420-109229-32	16-90-ER-SVHS-KF-031	Drinking Water	08/22/2016 0608	08/22/2016 1218
420-109229-33	16-90-ER-SVHS-BF-032	Drinking Water	08/22/2016 0609	08/22/2016 1218
420-109229-34	16-90-ER-SVHS-DW-033	Drinking Water	08/22/2016 0611	08/22/2016 1218
420-109229-35	16-90-ER-SVHS-BF(A)-034	Drinking Water	08/22/2016 0453	08/22/2016 1218
420-109229-36	16-90-ER-SVHS-BF(B)-035	Drinking Water	08/22/2016 0512	08/22/2016 1218
420-109229-37	16-90-ER-SVHS-BF(A)-036	Drinking Water	08/22/2016 0519	08/22/2016 1218
420-109229-38	16-90-ER-SVHS-BF(B)-037	Drinking Water	08/22/2016 0519	08/22/2016 1218
420-109229-39	16-90-ER-SVHS-WC-038	Drinking Water	08/22/2016 0517	08/22/2016 1218
420-109229-40	16-90-ER-SVHS-WC-039	Drinking Water	08/22/2016 0514	08/22/2016 1218
420-109229-42	16-90-ER-SVHS-BF-041	Drinking Water	08/22/2016 0530	08/22/2016 1218
420-109229-43	16-90-ER-SVHS-DW-042	Drinking Water	08/22/2016 0525	08/22/2016 1218
420-109229-44	16-90-ER-SVHS-BF-043	Drinking Water	08/22/2016 0523	08/22/2016 1218
420-109229-46	16-90-ER-SVHS-BF(A)-045	Drinking Water	08/22/2016 0512	08/22/2016 1218

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-109229-1
SDG Number: East Ramapo 2016-090 Spring Valley HS

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-109229-47	16-90-ER-SVHS-BF(B)-046	Drinking Water	08/22/2016 0512	08/22/2016 1218
420-109229-48	16-90-ER-SVHS-BF(C) -047	Drinking Water	08/22/2016 0513	08/22/2016 1218
420-109229-49	16-90-ER-SVHS-BF(D) -048	Drinking Water	08/22/2016 0513	08/22/2016 1218
420-109229-50	16-90-ER-SVHS-BF(A)-049	Drinking Water	08/22/2016 0515	08/22/2016 1218
420-109229-51	16-90-ER-SVHS-BF(B)-050	Drinking Water	08/22/2016 0515	08/22/2016 1218
420-109229-52	16-90-ER-SVHS-BF(C) -051	Drinking Water	08/22/2016 0516	08/22/2016 1218
420-109229-53	16-90-ER-SVHS-BF(D) -052	Drinking Water	08/22/2016 0516	08/22/2016 1218
420-109229-54	16-90-ER-SVHS-HEF(A) -053	Drinking Water	08/22/2016 0521	08/22/2016 1218
420-109229-55	16-90-ER-SVHS-HEF(B) -054	Drinking Water	08/22/2016 0521	08/22/2016 1218
420-109229-56	16-90-ER-SVHS-HEF(C) -055	Drinking Water	08/22/2016 0520	08/22/2016 1218
420-109229-57	16-90-ER-SVHS-HEF(D) -056	Drinking Water	08/22/2016 0520	08/22/2016 1218
420-109229-58	16-90-ER-SVHS-HEF(E) -057	Drinking Water	08/22/2016 0519	08/22/2016 1218
420-109229-59	16-90-ER-SVHS-HEF(F) -058	Drinking Water	08/22/2016 0519	08/22/2016 1218
420-109229-60	16-90-ER-SVHS-HEF(G) -059	Drinking Water	08/22/2016 0519	08/22/2016 1218
420-109229-61	16-90-ER-SVHS-CF-060	Drinking Water	08/22/2016 0522	08/22/2016 1218
420-109229-63	16-90-ER-SVHS-CF(A) -062	Drinking Water	08/22/2016 0530	08/22/2016 1218
420-109229-64	16-90-ER-SVHS-CF(B) -063	Drinking Water	08/22/2016 0528	08/22/2016 1218
420-109229-65	16-90-ER-SVHS-CF(C) -064	Drinking Water	08/22/2016 0528	08/22/2016 1218
420-109229-66	16-90-ER-SVHS-CF(D) -065	Drinking Water	08/22/2016 0529	08/22/2016 1218
420-109229-67	16-90-ER-SVHS-CF(E) -066	Drinking Water	08/22/2016 0529	08/22/2016 1218
420-109229-68	16-90-ER-SVHS-CF(F)-067	Drinking Water	08/22/2016 0525	08/22/2016 1218
420-109229-69	16-90-ER-SVHS-CF(G) -068	Drinking Water	08/22/2016 0525	08/22/2016 1218
420-109229-70	16-90-ER-SVHS-CF(H) -069	Drinking Water	08/22/2016 0527	08/22/2016 1218
420-109229-71	16-90-ER-SVHS-CF(I)-070	Drinking Water	08/22/2016 0527	08/22/2016 1218
420-109229-72	16-90-ER-SVHS-CF(J)-071	Drinking Water	08/22/2016 0527	08/22/2016 1218
420-109229-73	16-90-ER-SVHS-CF(K) -072	Drinking Water	08/22/2016 0526	08/22/2016 1218
420-109229-74	16-90-ER-SVHS-CF(L)-073	Drinking Water	08/22/2016 0526	08/22/2016 1218
420-109229-75	16-90-ER-SVHS-CF(M) -074	Drinking Water	08/22/2016 0526	08/22/2016 1218
420-109229-76	16-90-ER-SVHS-CF(N) -075	Drinking Water	08/22/2016 0525	08/22/2016 1218
420-109229-78	16-90-ER-SVHS-CF-077	Drinking Water	08/22/2016 0534	08/22/2016 1218

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-109229-1
SDG Number: East Ramapo 2016-090 Spring Valley HS

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-109229-79	16-90-ER-SVHS-CF(A) -078	Drinking Water	08/22/2016 0535	08/22/2016 1218
420-109229-80	16-90-ER-SVHS-CF(B) -079	Drinking Water	08/22/2016 0535	08/22/2016 1218
420-109229-81	16-90-ER-SVHS-CF(C) -080	Drinking Water	08/22/2016 0536	08/22/2016 1218
420-109229-82	16-90-ER-SVHS-CF(D) -081	Drinking Water	08/22/2016 0536	08/22/2016 1218
420-109229-83	16-90-ER-SVHS-CF(E) -082	Drinking Water	08/22/2016 0537	08/22/2016 1218
420-109229-84	16-90-ER-SVHS-CF(F)-083	Drinking Water	08/22/2016 0537	08/22/2016 1218
420-109229-85	16-90-ER-SVHS-CF(G) -084	Drinking Water	08/22/2016 0538	08/22/2016 1218
420-109229-86	16-90-ER-SVHS-CF(H) -085	Drinking Water	08/22/2016 0538	08/22/2016 1218
420-109229-87	16-90-ER-SVHS-CF(I)-086	Drinking Water	08/22/2016 0539	08/22/2016 1218
420-109229-88	16-90-ER-SVHS-CF(J)-087	Drinking Water	08/22/2016 0540	08/22/2016 1218
420-109229-89	16-90-ER-SVHS-CF(K) -088	Drinking Water	08/22/2016 0540	08/22/2016 1218
420-109229-90	16-90-ER-SVHS-CF(L)-089	Drinking Water	08/22/2016 0540	08/22/2016 1218
420-109229-91	16-90-ER-SVHS-DW-090	Drinking Water	08/22/2016 0550	08/22/2016 1218
420-109229-92	16-90-ER-SVHS-BF-091	Drinking Water	08/22/2016 0548	08/22/2016 1218
420-109229-93	16-90-ER-SVHS-BF-092	Drinking Water	08/22/2016 0547	08/22/2016 1218
420-109229-94	16-90-ER-SVHS-BF-093	Drinking Water	08/22/2016 0549	08/22/2016 1218
420-109229-95	16-90-ER-SVHS-CF(A) -094	Drinking Water	08/22/2016 0523	08/22/2016 1218
420-109229-96	16-90-ER-SVHS-CF(B) -095	Drinking Water	08/22/2016 0524	08/22/2016 1218
420-109229-97	16-90-ER-SVHS-CF(C) -096	Drinking Water	08/22/2016 0525	08/22/2016 1218
420-109229-98	16-90-ER-SVHS-CF(D) -097	Drinking Water	08/22/2016 0526	08/22/2016 1218
420-109229-99	16-90-ER-SVHS-CF(E) -098	Drinking Water	08/22/2016 0526	08/22/2016 1218
420-109229-100	16-90-ER-SVHS-CF(F)-099	Drinking Water	08/22/2016 0527	08/22/2016 1218
420-109229-101	16-90-ER-SVHS-CF(G) -100	Drinking Water	08/22/2016 0528	08/22/2016 1218
420-109229-102	16-90-ER-SVHS-CF(H) -101	Drinking Water	08/22/2016 0528	08/22/2016 1218
420-109229-103	16-90-ER-SVHS-CF(I)-102	Drinking Water	08/22/2016 0529	08/22/2016 1218
420-109229-104	16-90-ER-SVHS-CF(J)-103	Drinking Water	08/22/2016 0529	08/22/2016 1218
420-109229-106	16-90-ER-SVHS-CF(L)-105	Drinking Water	08/22/2016 0531	08/22/2016 1218
420-109229-108	16-90-ER-SVHS-CF-107	Drinking Water	08/22/2016 0538	08/22/2016 1218
420-109229-109	16-90-ER-SVHS-CF(A) -108	Drinking Water	08/22/2016 0545	08/22/2016 1218
420-109229-110	16-90-ER-SVHS-CF(B) -109	Drinking Water	08/22/2016 0545	08/22/2016 1218
420-109229-111	16-90-ER-SVHS-CF(C) -110	Drinking Water	08/22/2016 0544	08/22/2016 1218
420-109229-112	16-90-ER-SVHS-CF(D) -111	Drinking Water	08/22/2016 0543	08/22/2016 1218

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-109229-1

SDG Number: East Ramapo 2016-090 Spring Valley HS

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-109229-113	16-90-ER-SVHS-CF(E) -112	Drinking Water	08/22/2016 0542	08/22/2016 1218
420-109229-114	16-90-ER-SVHS-CF(F)-113	Drinking Water	08/22/2016 0542	08/22/2016 1218
420-109229-115	16-90-ER-SVHS-CF(G) -114	Drinking Water	08/22/2016 0540	08/22/2016 1218
420-109229-116	16-90-ER-SVHS-CF(H) -115	Drinking Water	08/22/2016 0540	08/22/2016 1218
420-109229-117	16-90-ER-SVHS-CF(I)-116	Drinking Water	08/22/2016 0537	08/22/2016 1218
420-109229-118	16-90-ER-SVHS-CF(J)-117	Drinking Water	08/22/2016 0537	08/22/2016 1218
420-109229-119	16-90-ER-SVHS-CF(K) -118	Drinking Water	08/22/2016 0547	08/22/2016 1218
420-109229-120	16-90-ER-SVHS-CF(L)-119	Drinking Water	08/22/2016 0547	08/22/2016 1218
420-109229-121	16-90-ER-SVHS-CF(M) -120	Drinking Water	08/22/2016 0547	08/22/2016 1218
420-109229-122	16-90-ER-SVHS-CF-121	Drinking Water	08/22/2016 0516	08/22/2016 1218
420-109229-123	16-90-ER-SVHS-CF-122	Drinking Water	08/22/2016 0541	08/22/2016 1218
420-109229-124	16-90-ER-SVHS-CF-123	Drinking Water	08/22/2016 0543	08/22/2016 1218
420-109229-125	16-90-ER-SVHS-CF-124	Drinking Water	08/22/2016 0517	08/22/2016 1218
420-109229-126	16-90-ER-SVHS-CF-125	Drinking Water	08/22/2016 0518	08/22/2016 1218
420-109229-127	16-90-ER-SVHS-BF-126	Drinking Water	08/22/2016 0515	08/22/2016 1218
420-109229-128	16-90-ER-SVHS-BF-127	Drinking Water	08/22/2016 0514	08/22/2016 1218
420-109229-129	16-90-ER-SVHS-DW-128	Drinking Water	08/22/2016 0513	08/22/2016 1218
420-109229-130	16-90-ER-SVHS-CF-129	Drinking Water	08/22/2016 0512	08/22/2016 1218
420-109229-131	16-90-ER-SVHS-BF-130	Drinking Water	08/22/2016 0512	08/22/2016 1218
420-109229-132	16-90-ER-SVHS-OT-131	Drinking Water	08/22/2016 0512	08/22/2016 1218
420-109229-133	16-90-ER-SVHS-IM-132	Drinking Water	08/22/2016 0515	08/22/2016 1218
420-109229-134	16-90-ER-SVHS-DW-133	Drinking Water	08/22/2016 0520	08/22/2016 1218
420-109229-135	16-90-ER-SVHS-BF(A)-134	Drinking Water	08/22/2016 0524	08/22/2016 1218
420-109229-136	16-90-ER-SVHS-BF(B)-135	Drinking Water	08/22/2016 0522	08/22/2016 1218
420-109229-137	16-90-ER-SVHS-BF(C) -136	Drinking Water	08/22/2016 0522	08/22/2016 1218
420-109229-138	16-90-ER-SVHS-BF(A)-137	Drinking Water	08/22/2016 0526	08/22/2016 1218
420-109229-139	16-90-ER-SVHS-BF(B)-138	Drinking Water	08/22/2016 0526	08/22/2016 1218
420-109229-140	16-90-ER-SVHS-BF(C) -139	Drinking Water	08/22/2016 0529	08/22/2016 1218
420-109229-142	16-90-ER-SVHS-BF-141	Drinking Water	08/22/2016 0610	08/22/2016 1218
420-109229-143	16-90-ER-SVHS-NF-142	Drinking Water	08/22/2016 0606	08/22/2016 1218
420-109229-144	16-90-ER-SVHS-BF-143	Drinking Water	08/22/2016 0607	08/22/2016 1218
420-109229-145	16-90-ER-SVHS-BF(A)-144	Drinking Water	08/22/2016 0602	08/22/2016 1218
420-109229-146	16-90-ER-SVHS-BF(B)-145	Drinking Water	08/22/2016 0603	08/22/2016 1218
420-109229-147	16-90-ER-SVHS-BF(C) -146	Drinking Water	08/22/2016 0603	08/22/2016 1218
420-109229-148	16-90-ER-SVHS-BF(D) -147	Drinking Water	08/22/2016 0604	08/22/2016 1218
420-109229-149	16-90-ER-SVHS-BF(E)-148	Drinking Water	08/22/2016 0605	08/22/2016 1218
420-109229-150	16-90-ER-SVHS-BF(A)-149	Drinking Water	08/22/2016 0558	08/22/2016 1218
420-109229-151	16-90-ER-SVHS-BF(B)-150	Drinking Water	08/22/2016 0559	08/22/2016 1218
420-109229-152	16-90-ER-SVHS-BF(C) -151	Drinking Water	08/22/2016 0559	08/22/2016 1218

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-109229-1

SDG Number: East Ramapo 2016-090 Spring Valley HS

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-109229-153	16-90-ER-SVHS-BF(D) -152	Drinking Water	08/22/2016 0600	08/22/2016 1218
420-109229-154	16-90-ER-SVHS-BF(E)-153	Drinking Water	08/22/2016 0604	08/22/2016 1218
420-109229-155	16-90-ER-SVHS-CF-154	Drinking Water	08/22/2016 0557	08/22/2016 1218
420-109229-156	16-90-ER-SVHS-CF-155	Drinking Water	08/22/2016 0600	08/22/2016 1218
420-109229-157	16-90-ER-SVHS-CF(A) -156	Drinking Water	08/22/2016 0603	08/22/2016 1218
420-109229-158	16-90-ER-SVHS-CF(B) -157	Drinking Water	08/22/2016 0603	08/22/2016 1218
420-109229-159	16-90-ER-SVHS-CF-158	Drinking Water	08/22/2016 0604	08/22/2016 1218
420-109229-160	16-90-ER-SVHS-CF(A) -159	Drinking Water	08/22/2016 0605	08/22/2016 1218
420-109229-162	16-90-ER-SVHS-BF(A)-161	Drinking Water	08/22/2016 0609	08/22/2016 1218
420-109229-163	16-90-ER-SVHS-BF(B)-162	Drinking Water	08/22/2016 0609	08/22/2016 1218
420-109229-164	16-90-ER-SVHS-BF(C) -163	Drinking Water	08/22/2016 0610	08/22/2016 1218
420-109229-165	16-90-ER-SVHS-BF(D) -164	Drinking Water	08/22/2016 0610	08/22/2016 1218
420-109229-166	16-90-ER-SVHS-DW-165	Drinking Water	08/22/2016 0612	08/22/2016 1218
420-109229-167	16-90-ER-SVHS-BF(A)-166	Drinking Water	08/22/2016 0613	08/22/2016 1218
420-109229-168	16-90-ER-SVHS-BF(B)-167	Drinking Water	08/22/2016 0613	08/22/2016 1218
420-109229-169	16-90-ER-SVHS-BF(C) -168	Drinking Water	08/22/2016 0612	08/22/2016 1218
420-109229-170	16-90-ER-SVHS-BF(D) -169	Drinking Water	08/22/2016 0612	08/22/2016 1218
420-109229-171	16-90-ER-SVHS-CF(M) -170	Drinking Water	08/22/2016 0516	08/22/2016 1218
420-109229-172	16-90-ER-SVHS-CF(M) -171	Drinking Water	08/22/2016 0519	08/22/2016 1218
420-109229-173	16-90-ER-SVHS-DW-172	Drinking Water	08/22/2016 0525	08/22/2016 1218
420-109229-174	16-90-ER-SVHS-BF(A)-173	Drinking Water	08/22/2016 0527	08/22/2016 1218
420-109229-175	16-90-ER-SVHS-BF(B)-174	Drinking Water	08/22/2016 0527	08/22/2016 1218
420-109229-176	16-90-ER-SVHS-BF(C)-175	Drinking Water	08/22/2016 0528	08/22/2016 1218
420-109229-177	16-90-ER-SVHS-BF(D) -176	Drinking Water	08/22/2016 0528	08/22/2016 1218
420-109229-178	16-90-ER-SVHS-BF(A)-177	Drinking Water	08/22/2016 0526	08/22/2016 1218
420-109229-179	16-90-ER-SVHS-BF(B)-178	Drinking Water	08/22/2016 0527	08/22/2016 1218
420-109229-180	16-90-ER-SVHS-BF(C) -179	Drinking Water	08/22/2016 0528	08/22/2016 1218
420-109229-181	16-90-ER-SVHS-BF(D) -180	Drinking Water	08/22/2016 0530	08/22/2016 1218
420-109229-183	16-90-ER-SVHS-DW-182	Drinking Water	08/22/2016 0626	08/22/2016 1218
420-109229-184	16-90-ER-SVHS-OT-183	Drinking Water	08/22/2016 0548	08/22/2016 1218
420-109229-185	16-90-ER-SVHS-BF-184	Drinking Water	08/22/2016 0542	08/22/2016 1218
420-109229-186	16-90-ER-SVHS-BF-185	Drinking Water	08/22/2016 0543	08/22/2016 1218
420-109229-187	16-90-ER-SVHS-OT-186	Drinking Water	08/22/2016 0542	08/22/2016 1218
420-109229-188	16-90-ER-SVHS-BE-187	Drinking Water	08/22/2016 0550	08/22/2016 1218
420-109229-189	16-90-ER-SVHS-CF(A) -188	Drinking Water	08/22/2016 0607	08/22/2016 1218

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-109229-1
SDG Number: East Ramapo 2016-090 Spring Valley HS

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-109229-190	16-90-ER-SVHS-CF(B) -189	Drinking Water	08/22/2016 0607	08/22/2016 1218
420-109229-191	16-90-ER-SVHS-CF(C) -190	Drinking Water	08/22/2016 0611	08/22/2016 1218
420-109229-192	16-90-ER-SVHS-CF(D) -191	Drinking Water	08/22/2016 0611	08/22/2016 1218
420-109229-193	16-90-ER-SVHS-CF(E) -192	Drinking Water	08/22/2016 0617	08/22/2016 1218
420-109229-194	16-90-ER-SVHS-CF(F)-193	Drinking Water	08/22/2016 0617	08/22/2016 1218
420-109229-195	16-90-ER-SVHS-CF(G) -194	Drinking Water	08/22/2016 0618	08/22/2016 1218
420-109229-196	16-90-ER-SVHS-CF(H) -195	Drinking Water	08/22/2016 0620	08/22/2016 1218
420-109229-197	16-90-ER-SVHS-CF(I)-196	Drinking Water	08/22/2016 0613	08/22/2016 1218
420-109229-198	16-90-ER-SVHS-CF(J)-197	Drinking Water	08/22/2016 0615	08/22/2016 1218
420-109229-199	16-90-ER-SVHS-CF(K) -198	Drinking Water	08/22/2016 0609	08/22/2016 1218
420-109229-200	16-90-ER-SVHS-CF(L)-199	Drinking Water	08/22/2016 0610	08/22/2016 1218
420-109229-201	16-90-ER-SVHS-CF(M) -200	Drinking Water	08/22/2016 0607	08/22/2016 1218
420-109229-203	16-90-ER-SVHS-CF-202	Drinking Water	08/22/2016 0605	08/22/2016 1218
420-109229-205	16-90-ER-SVHS-CF(B) -204	Drinking Water	08/22/2016 0555	08/22/2016 1218
420-109229-206	16-90-ER-SVHS-CF(C) -205	Drinking Water	08/22/2016 0555	08/22/2016 1218
420-109229-207	16-90-ER-SVHS-CF(D) -206	Drinking Water	08/22/2016 0558	08/22/2016 1218
420-109229-208	16-90-ER-SVHS-CF(E) -207	Drinking Water	08/22/2016 0558	08/22/2016 1218
420-109229-209	16-90-ER-SVHS-CF(F)-208	Drinking Water	08/22/2016 0602	08/22/2016 1218
420-109229-210	16-90-ER-SVHS-CF(G) -209	Drinking Water	08/22/2016 0602	08/22/2016 1218
420-109229-211	16-90-ER-SVHS-CF(H) -210	Drinking Water	08/22/2016 0602	08/22/2016 1218
420-109229-212	16-90-ER-SVHS-CF(I)-211	Drinking Water	08/22/2016 0601	08/22/2016 1218
420-109229-213	16-90-ER-SVHS-CF(J)-212	Drinking Water	08/22/2016 0559	08/22/2016 1218
420-109229-214	16-90-ER-SVHS-CF(K) -213	Drinking Water	08/22/2016 0558	08/22/2016 1218
420-109229-215	16-90-ER-SVHS-CF(L)-214	Drinking Water	08/22/2016 0556	08/22/2016 1218
420-109229-216	16-90-ER-SVHS-CF(M) -215	Drinking Water	08/22/2016 0555	08/22/2016 1218
420-109229-217	16-90-ER-SVHS-DW-216	Drinking Water	08/22/2016 0620	08/22/2016 1218
420-109229-218	16-90-ER-SVHS-TL-217	Drinking Water	08/22/2016 0626	08/22/2016 1218

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-SC-001
Lab Sample ID: 420-109229-1

Date Sampled: 08/22/2016 0454
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1218	
Prep Method: 200			Date Prepared:	08/23/2016 0907	
Lead	2.55	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-002
Lab Sample ID: 420-109229-2

Date Sampled: 08/22/2016 0603
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1222	
Prep Method: 200			Date Prepared:	08/23/2016 0907	
Lead	3.44	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-003
Lab Sample ID: 420-109229-3

Date Sampled: 08/22/2016 0603
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1225	
Prep Method: 200			Date Prepared:	08/23/2016 0907	
Lead	3.83	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-004
Lab Sample ID: 420-109229-4

Date Sampled: 08/22/2016 0601
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1229	
Prep Method: 200			Date Prepared:	08/23/2016 0907	
Lead	6.63	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-005
Lab Sample ID: 420-109229-5

Date Sampled: 08/22/2016 0606
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1606	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	11.3	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-006
Lab Sample ID: 420-109229-6

Date Sampled: 08/22/2016 0605
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1620	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	9.44	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-007
Lab Sample ID: 420-109229-7

Date Sampled: 08/22/2016 0607
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1624		
Prep Method: 200			Date Prepared: 08/23/2016 0945		
Lead	10.3	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-WC-008
Lab Sample ID: 420-109229-8

Date Sampled: 08/22/2016 0555
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1627		
Prep Method: 200			Date Prepared: 08/23/2016 0945		
Lead	3.05	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-WC-009
Lab Sample ID: 420-109229-9

Date Sampled: 08/22/2016 0555
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1631	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	3.93	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-KF(A)-010
Lab Sample ID: 420-109229-10

Date Sampled: 08/22/2016 0540
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1634		
Prep Method: 200			Date Prepared: 08/23/2016 0945		
Lead	28.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-KF(B)-011
Lab Sample ID: 420-109229-11

Date Sampled: 08/22/2016 0542
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1645	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	6.26	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-KF(C)-012
Lab Sample ID: 420-109229-12

Date Sampled: 08/22/2016 0542
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1648	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	12.9	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-KF(D)-013
Lab Sample ID: 420-109229-13

Date Sampled: 08/22/2016 0544
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1652		
Prep Method: 200			Date Prepared: 08/23/2016 0945		
Lead	8.46	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-KF -014
Lab Sample ID: 420-109229-14

Date Sampled: 08/22/2016 0539
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1655		
Prep Method: 200			Date Prepared: 08/23/2016 0945		
Lead	241 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-IM -014 A
Lab Sample ID: 420-109229-15

Date Sampled: 08/22/2016 0530
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1659	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	<1.00	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF -016
Lab Sample ID: 420-109229-17

Date Sampled: 08/22/2016 0556
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1702	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	6.40	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-WC -017
Lab Sample ID: 420-109229-18

Date Sampled: 08/22/2016 0534
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1706		
Prep Method: 200			Date Prepared: 08/23/2016 0945		
Lead	6.18	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-018
Lab Sample ID: 420-109229-19

Date Sampled: 08/22/2016 0621
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1709	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	7.39	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-019
Lab Sample ID: 420-109229-20

Date Sampled: 08/22/2016 0621
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1713	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	9.22	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-020
Lab Sample ID: 420-109229-21

Date Sampled: 08/22/2016 0622
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1716	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	3.96	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-021
Lab Sample ID: 420-109229-22

Date Sampled: 08/22/2016 0622
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1727	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	5.14	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-022
Lab Sample ID: 420-109229-23

Date Sampled: 08/22/2016 0622
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1730	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	4.25	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-023
Lab Sample ID: 420-109229-24

Date Sampled: 08/22/2016 0623
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1734	
Prep Method: 200			Date Prepared:	08/23/2016 0945	
Lead	5.01	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(D)-024
Lab Sample ID: 420-109229-25

Date Sampled: 08/22/2016 0623
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1737		
Prep Method: 200			Date Prepared: 08/23/2016 0945		
Lead	7.42	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-025
Lab Sample ID: 420-109229-26

Date Sampled: 08/22/2016 0620
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1741		
Prep Method: 200			Date Prepared: 08/23/2016 1030		
Lead	4.15	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-027
Lab Sample ID: 420-109229-28

Date Sampled: 08/22/2016 0632
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1755	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	9.50	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-028
Lab Sample ID: 420-109229-29

Date Sampled: 08/22/2016 0614
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1758	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	4.90	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-029
Lab Sample ID: 420-109229-30

Date Sampled: 08/22/2016 0617
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1809		
Prep Method: 200			Date Prepared: 08/23/2016 1030		
Lead	40.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-030
Lab Sample ID: 420-109229-31

Date Sampled: 08/22/2016 0612
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1813	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	6.89	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-KF-031
Lab Sample ID: 420-109229-32

Date Sampled: 08/22/2016 0608
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1816	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	3.78	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-032
Lab Sample ID: 420-109229-33

Date Sampled: 08/22/2016 0609
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1820	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	11.2	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-033
Lab Sample ID: 420-109229-34

Date Sampled: 08/22/2016 0611
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1823		
Prep Method: 200			Date Prepared: 08/23/2016 1030		
Lead	5.71	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-034
Lab Sample ID: 420-109229-35

Date Sampled: 08/22/2016 0453
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1827	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	12.1	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-035
Lab Sample ID: 420-109229-36

Date Sampled: 08/22/2016 0512
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1830	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	10.0	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-036
Lab Sample ID: 420-109229-37

Date Sampled: 08/22/2016 0519
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1834	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	4.36	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-037
Lab Sample ID: 420-109229-38

Date Sampled: 08/22/2016 0519
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1837	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	4.10	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-WC-038
Lab Sample ID: 420-109229-39

Date Sampled: 08/22/2016 0517
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1841	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	2.12	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-WC-039
Lab Sample ID: 420-109229-40

Date Sampled: 08/22/2016 0514
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1851	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	<1.00	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-041
Lab Sample ID: 420-109229-42

Date Sampled: 08/22/2016 0530
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1855	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	5.66	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-042
Lab Sample ID: 420-109229-43

Date Sampled: 08/22/2016 0525
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1858	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	18.7 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-043
Lab Sample ID: 420-109229-44

Date Sampled: 08/22/2016 0523
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1902	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	43.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-045
Lab Sample ID: 420-109229-46

Date Sampled: 08/22/2016 0512
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1905		
Prep Method: 200			Date Prepared: 08/23/2016 1030		
Lead	129 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-046
Lab Sample ID: 420-109229-47

Date Sampled: 08/22/2016 0512
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1909	
Prep Method: 200			Date Prepared:	08/23/2016 1030	
Lead	12.0	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-047
Lab Sample ID: 420-109229-48

Date Sampled: 08/22/2016 0513
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1912		
Prep Method: 200			Date Prepared: 08/23/2016 1030		
Lead	15.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(D)-048
Lab Sample ID: 420-109229-49

Date Sampled: 08/22/2016 0513
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1916		
Prep Method: 200			Date Prepared: 08/23/2016 1249		
Lead	17.3 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-049
Lab Sample ID: 420-109229-50

Date Sampled: 08/22/2016 0515
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1937		
Prep Method: 200			Date Prepared: 08/23/2016 1249		
Lead	16.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-050
Lab Sample ID: 420-109229-51

Date Sampled: 08/22/2016 0515
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1941	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	21.3 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-051
Lab Sample ID: 420-109229-52

Date Sampled: 08/22/2016 0516
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1944	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	14.3	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(D)-052
Lab Sample ID: 420-109229-53

Date Sampled: 08/22/2016 0516
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1948	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	14.4	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-HEF(A)-053
Lab Sample ID: 420-109229-54

Date Sampled: 08/22/2016 0521
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1951		
Prep Method: 200			Date Prepared: 08/23/2016 1249		
Lead	33.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-HEF(B)-054
Lab Sample ID: 420-109229-55

Date Sampled: 08/22/2016 0521
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 1955	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	32.0 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-HEF(C)-055
Lab Sample ID: 420-109229-56

Date Sampled: 08/22/2016 0520
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 1958		
Prep Method: 200			Date Prepared: 08/23/2016 1249		
Lead	24.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-HEF(D)-056
Lab Sample ID: 420-109229-57

Date Sampled: 08/22/2016 0520
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016	2002	
Prep Method: 200			Date Prepared: 08/23/2016	1249	
Lead	102 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-HEF(E)-057
Lab Sample ID: 420-109229-58

Date Sampled: 08/22/2016 0519
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2005	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	45.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-HEF(F)-058
Lab Sample ID: 420-109229-59

Date Sampled: 08/22/2016 0519
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016	2016
Prep Method: 200			Date Prepared:	08/23/2016	1249
Lead	97.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-HEF(G)-059
Lab Sample ID: 420-109229-60

Date Sampled: 08/22/2016 0519
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2019	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	70.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-060
Lab Sample ID: 420-109229-61

Date Sampled: 08/22/2016 0522
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2023	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	8.59	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(A)-062
Lab Sample ID: 420-109229-63

Date Sampled: 08/22/2016 0530
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2027		
Prep Method: 200			Date Prepared: 08/23/2016 1249		
Lead	89.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(B)-063
Lab Sample ID: 420-109229-64

Date Sampled: 08/22/2016 0528
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2030	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	4.23	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(C)-064
Lab Sample ID: 420-109229-65

Date Sampled: 08/22/2016 0528
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2034	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	2.62	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(D)-065
Lab Sample ID: 420-109229-66

Date Sampled: 08/22/2016 0529
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2037	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	4.71	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(E)-066
Lab Sample ID: 420-109229-67

Date Sampled: 08/22/2016 0529
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2041	
Prep Method: 200			Date Prepared:	08/23/2016 1249	
Lead	11.2	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(F)-067
Lab Sample ID: 420-109229-68

Date Sampled: 08/22/2016 0525
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016	2044	
Prep Method: 200			Date Prepared: 08/23/2016	1249	
Lead	15.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(G)-068
Lab Sample ID: 420-109229-69

Date Sampled: 08/22/2016 0525
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2048		
Prep Method: 200			Date Prepared: 08/23/2016 1249		
Lead	7.29	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(H)-069
Lab Sample ID: 420-109229-70

Date Sampled: 08/22/2016 0527
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2058	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	7.30	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(I)-070
Lab Sample ID: 420-109229-71

Date Sampled: 08/22/2016 0527
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2112	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	12.8	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(J)-071
Lab Sample ID: 420-109229-72

Date Sampled: 08/22/2016 0527
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2116		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	13.4	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(K)-072
Lab Sample ID: 420-109229-73

Date Sampled: 08/22/2016 0526
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2120	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	8.59	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(L)-073
Lab Sample ID: 420-109229-74

Date Sampled: 08/22/2016 0526
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2123		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	17.3 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(M)-074
Lab Sample ID: 420-109229-75

Date Sampled: 08/22/2016 0526
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2127	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	8.05	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(N)-075
Lab Sample ID: 420-109229-76

Date Sampled: 08/22/2016 0525
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2130		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	64.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-077
Lab Sample ID: 420-109229-78

Date Sampled: 08/22/2016 0534
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2141		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	51.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(A)-078
Lab Sample ID: 420-109229-79

Date Sampled: 08/22/2016 0535
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2144		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	14.0	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(B)-079
Lab Sample ID: 420-109229-80

Date Sampled: 08/22/2016 0535
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2148	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	3.79	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(C)-080
Lab Sample ID: 420-109229-81

Date Sampled: 08/22/2016 0536
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2151	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	17.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(D)-081
Lab Sample ID: 420-109229-82

Date Sampled: 08/22/2016 0536
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2155	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	14.2	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(E)-082
Lab Sample ID: 420-109229-83

Date Sampled: 08/22/2016 0537
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2159		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	34.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(F)-083
Lab Sample ID: 420-109229-84

Date Sampled: 08/22/2016 0537
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2202	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	71.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(G)-084
Lab Sample ID: 420-109229-85

Date Sampled: 08/22/2016 0538
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2206		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	65.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(H)-085
Lab Sample ID: 420-109229-86

Date Sampled: 08/22/2016 0538
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2209		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	133 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(I)-086
Lab Sample ID: 420-109229-87

Date Sampled: 08/22/2016 0539
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2213		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	55.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(J)-087
Lab Sample ID: 420-109229-88

Date Sampled: 08/22/2016 0540
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2239	
Prep Method: 200			Date Prepared:	08/23/2016 1502	
Lead	99.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(K)-088
Lab Sample ID: 420-109229-89

Date Sampled: 08/22/2016 0540
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2223	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	27.7 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(L)-089
Lab Sample ID: 420-109229-90

Date Sampled: 08/22/2016 0540
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/23/2016 2227	
Prep Method: 200			Date Prepared:	08/23/2016 1344	
Lead	61.7 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-090
Lab Sample ID: 420-109229-91

Date Sampled: 08/22/2016 0550
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/23/2016 2231		
Prep Method: 200			Date Prepared: 08/23/2016 1344		
Lead	81.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-091
Lab Sample ID: 420-109229-92

Date Sampled: 08/22/2016 0548
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2121		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	5.74	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-092
Lab Sample ID: 420-109229-93

Date Sampled: 08/22/2016 0547
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2142	
Prep Method: 200			Date Prepared:	08/23/2016 1502	
Lead	13.9	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-093
Lab Sample ID: 420-109229-94

Date Sampled: 08/22/2016 0549
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2146		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	8.44	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(A)-094
Lab Sample ID: 420-109229-95

Date Sampled: 08/22/2016 0523
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2149		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	58.0 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(B)-095
Lab Sample ID: 420-109229-96

Date Sampled: 08/22/2016 0524
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2153		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	65.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(C)-096
Lab Sample ID: 420-109229-97

Date Sampled: 08/22/2016 0525
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 1748	
Prep Method: 200			Date Prepared:	08/24/2016 1500	
Lead	121 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(D)-097
Lab Sample ID: 420-109229-98

Date Sampled: 08/22/2016 0526
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 1752		
Prep Method: 200			Date Prepared: 08/24/2016 1500		
Lead	174 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(E)-098
Lab Sample ID: 420-109229-99

Date Sampled: 08/22/2016 0526
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2156		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	65.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(F)-099
Lab Sample ID: 420-109229-100

Date Sampled: 08/22/2016 0527
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2200		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	220 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(G)-100
Lab Sample ID: 420-109229-101

Date Sampled: 08/22/2016 0528
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 1756	
Prep Method: 200			Date Prepared:	08/24/2016 1500	
Lead	728 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(H)-101
Lab Sample ID: 420-109229-102

Date Sampled: 08/22/2016 0528
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2203		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	444 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(I)-102
Lab Sample ID: 420-109229-103

Date Sampled: 08/22/2016 0529
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 1759	
Prep Method: 200			Date Prepared:	08/24/2016 1500	
Lead	221 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(J)-103
Lab Sample ID: 420-109229-104

Date Sampled: 08/22/2016 0529
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 1803		
Prep Method: 200			Date Prepared: 08/24/2016 1500		
Lead	503 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(L)-105
Lab Sample ID: 420-109229-106

Date Sampled: 08/22/2016 0531
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2214	
Prep Method: 200			Date Prepared:	08/23/2016 1502	
Lead	79.3 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-107
Lab Sample ID: 420-109229-108

Date Sampled: 08/22/2016 0538
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2218		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	26.7 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(A)-108
Lab Sample ID: 420-109229-109

Date Sampled: 08/22/2016 0545
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2221	
Prep Method: 200			Date Prepared:	08/23/2016 1502	
Lead	28.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(B)-109
Lab Sample ID: 420-109229-110

Date Sampled: 08/22/2016 0545
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 1813		
Prep Method: 200			Date Prepared: 08/24/2016 1500		
Lead	96.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(C)-110
Lab Sample ID: 420-109229-111

Date Sampled: 08/22/2016 0544
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2225	
Prep Method: 200			Date Prepared:	08/23/2016 1502	
Lead	46.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(D)-111
Lab Sample ID: 420-109229-112

Date Sampled: 08/22/2016 0543
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2228		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	34.3 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(E)-112
Lab Sample ID: 420-109229-113

Date Sampled: 08/22/2016 0542
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2232		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	65.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(F)-113
Lab Sample ID: 420-109229-114

Date Sampled: 08/22/2016 0542
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 1817		
Prep Method: 200			Date Prepared: 08/24/2016 1500		
Lead	152 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(G)-114
Lab Sample ID: 420-109229-115

Date Sampled: 08/22/2016 0540
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2235		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	39.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(H)-115
Lab Sample ID: 420-109229-116

Date Sampled: 08/22/2016 0540
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2242		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	21.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(I)-116
Lab Sample ID: 420-109229-117

Date Sampled: 08/22/2016 0537
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2246		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	27.0 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(J)-117
Lab Sample ID: 420-109229-118

Date Sampled: 08/22/2016 0537
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2257		
Prep Method: 200			Date Prepared: 08/23/2016 1502		
Lead	20.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(K)-118
Lab Sample ID: 420-109229-119

Date Sampled: 08/22/2016 0547
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2300	
Prep Method: 200			Date Prepared:	08/23/2016 1502	
Lead	70.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(L)-119
Lab Sample ID: 420-109229-120

Date Sampled: 08/22/2016 0547
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2304	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	81.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(M)-120
Lab Sample ID: 420-109229-121

Date Sampled: 08/22/2016 0547
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2318		
Prep Method: 200			Date Prepared: 08/23/2016 1615		
Lead	127 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-121
Lab Sample ID: 420-109229-122

Date Sampled: 08/22/2016 0516
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2321	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	14.0	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-122
Lab Sample ID: 420-109229-123

Date Sampled: 08/22/2016 0541
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2325		
Prep Method: 200			Date Prepared: 08/23/2016 1615		
Lead	29.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-123
Lab Sample ID: 420-109229-124

Date Sampled: 08/22/2016 0543
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution	
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2329			
Prep Method: 200			Date Prepared: 08/23/2016 1615			
Lead	130	g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-124
Lab Sample ID: 420-109229-125

Date Sampled: 08/22/2016 0517
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2339		
Prep Method: 200			Date Prepared: 08/23/2016 1615		
Lead	64.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-125
Lab Sample ID: 420-109229-126

Date Sampled: 08/22/2016 0518
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2343		
Prep Method: 200			Date Prepared: 08/23/2016 1615		
Lead	86.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-126
Lab Sample ID: 420-109229-127

Date Sampled: 08/22/2016 0515
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2346	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	6.76	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-127
Lab Sample ID: 420-109229-128

Date Sampled: 08/22/2016 0514
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2350	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	5.92	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-128
Lab Sample ID: 420-109229-129

Date Sampled: 08/22/2016 0513
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/24/2016 2353		
Prep Method: 200			Date Prepared: 08/23/2016 1615		
Lead	11.8	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-129
Lab Sample ID: 420-109229-130

Date Sampled: 08/22/2016 0512
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/24/2016 2357	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	19.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-130
Lab Sample ID: 420-109229-131

Date Sampled: 08/22/2016 0512
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0000	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	12.4	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-OT-131
Lab Sample ID: 420-109229-132

Date Sampled: 08/22/2016 0512
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0004	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	<1.00	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-IM-132
Lab Sample ID: 420-109229-133

Date Sampled: 08/22/2016 0515
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0008	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	<1.00	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-133
Lab Sample ID: 420-109229-134

Date Sampled: 08/22/2016 0520
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0011	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	8.80	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-134
Lab Sample ID: 420-109229-135

Date Sampled: 08/22/2016 0524
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0022	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	13.9	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-135
Lab Sample ID: 420-109229-136

Date Sampled: 08/22/2016 0522
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0025	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	24.7 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-136
Lab Sample ID: 420-109229-137

Date Sampled: 08/22/2016 0522
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0029	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	21.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-137
Lab Sample ID: 420-109229-138

Date Sampled: 08/22/2016 0526
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0033		
Prep Method: 200			Date Prepared: 08/23/2016 1615		
Lead	171 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-138
Lab Sample ID: 420-109229-139

Date Sampled: 08/22/2016 0526
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0036	
Prep Method: 200			Date Prepared:	08/23/2016 1615	
Lead	14.1	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-139
Lab Sample ID: 420-109229-140

Date Sampled: 08/22/2016 0529
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0040		
Prep Method: 200			Date Prepared: 08/24/2016 0848		
Lead	35.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-141
Lab Sample ID: 420-109229-142

Date Sampled: 08/22/2016 0610
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0054		
Prep Method: 200			Date Prepared: 08/24/2016 0848		
Lead	29.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-NF-142
Lab Sample ID: 420-109229-143

Date Sampled: 08/22/2016 0606
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0105	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	31.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-143
Lab Sample ID: 420-109229-144

Date Sampled: 08/22/2016 0607
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0108	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	13.8	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-144
Lab Sample ID: 420-109229-145

Date Sampled: 08/22/2016 0602
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0112	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	20.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-145
Lab Sample ID: 420-109229-146

Date Sampled: 08/22/2016 0603
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0115	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	13.2	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-146
Lab Sample ID: 420-109229-147

Date Sampled: 08/22/2016 0603
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0119		
Prep Method: 200			Date Prepared: 08/24/2016 0848		
Lead	21.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(D)-147
Lab Sample ID: 420-109229-148

Date Sampled: 08/22/2016 0604
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0122	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	164 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(E)-148
Lab Sample ID: 420-109229-149

Date Sampled: 08/22/2016 0605
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0126		
Prep Method: 200			Date Prepared: 08/24/2016 0848		
Lead	777 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-149
Lab Sample ID: 420-109229-150

Date Sampled: 08/22/2016 0558
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0130	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	27.0 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-150
Lab Sample ID: 420-109229-151

Date Sampled: 08/22/2016 0559
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0133	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	18.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-151
Lab Sample ID: 420-109229-152

Date Sampled: 08/22/2016 0559
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0137		
Prep Method: 200			Date Prepared: 08/24/2016 0848		
Lead	36.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(D)-152
Lab Sample ID: 420-109229-153

Date Sampled: 08/22/2016 0600
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0148		
Prep Method: 200			Date Prepared: 08/24/2016 0848		
Lead	59.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(E)-153
Lab Sample ID: 420-109229-154

Date Sampled: 08/22/2016 0604
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0151	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	26.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-154
Lab Sample ID: 420-109229-155

Date Sampled: 08/22/2016 0557
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0155	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	30.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-155
Lab Sample ID: 420-109229-156

Date Sampled: 08/22/2016 0600
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0158	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	8.58	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(A)-156
Lab Sample ID: 420-109229-157

Date Sampled: 08/22/2016 0603
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0202	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	18.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(B)-157
Lab Sample ID: 420-109229-158

Date Sampled: 08/22/2016 0603
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0205	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	12.3	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-158
Lab Sample ID: 420-109229-159

Date Sampled: 08/22/2016 0604
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0209	
Prep Method: 200			Date Prepared:	08/24/2016 0848	
Lead	9.69	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(A)-159
Lab Sample ID: 420-109229-160

Date Sampled: 08/22/2016 0605
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0212		
Prep Method: 200			Date Prepared: 08/24/2016 0848		
Lead	7.22	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-161
Lab Sample ID: 420-109229-162

Date Sampled: 08/22/2016 0609
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0216		
Prep Method: 200			Date Prepared: 08/24/2016 0920		
Lead	3.16	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-162
Lab Sample ID: 420-109229-163

Date Sampled: 08/22/2016 0609
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0238	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	1.54	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-163
Lab Sample ID: 420-109229-164

Date Sampled: 08/22/2016 0610
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0241	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	2.77	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(D)-164
Lab Sample ID: 420-109229-165

Date Sampled: 08/22/2016 0610
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0245		
Prep Method: 200			Date Prepared: 08/24/2016 0920		
Lead	3.37	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-165
Lab Sample ID: 420-109229-166

Date Sampled: 08/22/2016 0612
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0248	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	3.61	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-166
Lab Sample ID: 420-109229-167

Date Sampled: 08/22/2016 0613
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0252	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	4.65	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-167
Lab Sample ID: 420-109229-168

Date Sampled: 08/22/2016 0613
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0255	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	3.45	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-168
Lab Sample ID: 420-109229-169

Date Sampled: 08/22/2016 0612
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0259		
Prep Method: 200			Date Prepared: 08/24/2016 0920		
Lead	3.34	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(D)-169
Lab Sample ID: 420-109229-170

Date Sampled: 08/22/2016 0612
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0303	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	3.55	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(M)-170
Lab Sample ID: 420-109229-171

Date Sampled: 08/22/2016 0516
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0313	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	2.23	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(M)-171
Lab Sample ID: 420-109229-172

Date Sampled: 08/22/2016 0519
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0317	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	73.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-172
Lab Sample ID: 420-109229-173

Date Sampled: 08/22/2016 0525
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0321		
Prep Method: 200			Date Prepared: 08/24/2016 0920		
Lead	3.00	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-173
Lab Sample ID: 420-109229-174

Date Sampled: 08/22/2016 0527
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0324		
Prep Method: 200			Date Prepared: 08/24/2016 0920		
Lead	38.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-174
Lab Sample ID: 420-109229-175

Date Sampled: 08/22/2016 0527
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0328	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	35.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C-175)
Lab Sample ID: 420-109229-176

Date Sampled: 08/22/2016 0528
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0331	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	13.6	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(D)-176
Lab Sample ID: 420-109229-177

Date Sampled: 08/22/2016 0528
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0335		
Prep Method: 200			Date Prepared: 08/24/2016 0920		
Lead	18.5 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(A)-177
Lab Sample ID: 420-109229-178

Date Sampled: 08/22/2016 0526
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0338		
Prep Method: 200			Date Prepared: 08/24/2016 0920		
Lead	24.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(B)-178
Lab Sample ID: 420-109229-179

Date Sampled: 08/22/2016 0527
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0342	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	12.5	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(C)-179
Lab Sample ID: 420-109229-180

Date Sampled: 08/22/2016 0528
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0346	
Prep Method: 200			Date Prepared:	08/24/2016 0920	
Lead	7.28	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF(D)-180
Lab Sample ID: 420-109229-181

Date Sampled: 08/22/2016 0530
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 1820	
Prep Method: 200			Date Prepared:	08/24/2016 1500	
Lead	18.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-182
Lab Sample ID: 420-109229-183

Date Sampled: 08/22/2016 0626
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0356		
Prep Method: 200			Date Prepared: 08/24/2016 0920		
Lead	2.66	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-OT-183
Lab Sample ID: 420-109229-184

Date Sampled: 08/22/2016 0548
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0400		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	3.92	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-184
Lab Sample ID: 420-109229-185

Date Sampled: 08/22/2016 0542
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0414	
Prep Method: 200			Date Prepared:	08/24/2016 1025	
Lead	5.85	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BF-185
Lab Sample ID: 420-109229-186

Date Sampled: 08/22/2016 0543
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0418		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	12.4	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-OT-186
Lab Sample ID: 420-109229-187

Date Sampled: 08/22/2016 0542
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0422		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	72.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-BE-187
Lab Sample ID: 420-109229-188

Date Sampled: 08/22/2016 0550
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0425		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	3.96	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(A)-188
Lab Sample ID: 420-109229-189

Date Sampled: 08/22/2016 0607
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0429		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	27.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(B)-189
Lab Sample ID: 420-109229-190

Date Sampled: 08/22/2016 0607
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0440		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	26.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(C)-190
Lab Sample ID: 420-109229-191

Date Sampled: 08/22/2016 0611
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0443		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	204 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(D)-191
Lab Sample ID: 420-109229-192

Date Sampled: 08/22/2016 0611
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0447		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	56.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(E)-192
Lab Sample ID: 420-109229-193

Date Sampled: 08/22/2016 0617
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0450	
Prep Method: 200			Date Prepared:	08/24/2016 1025	
Lead	19.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(F)-193
Lab Sample ID: 420-109229-194

Date Sampled: 08/22/2016 0617
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0454	
Prep Method: 200			Date Prepared:	08/24/2016 1025	
Lead	23.8 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(G)-194
Lab Sample ID: 420-109229-195

Date Sampled: 08/22/2016 0618
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0458		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	18.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(H)-195
Lab Sample ID: 420-109229-196

Date Sampled: 08/22/2016 0620
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0501	
Prep Method: 200			Date Prepared:	08/24/2016 1025	
Lead	5.28	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(I)-196
Lab Sample ID: 420-109229-197

Date Sampled: 08/22/2016 0613
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0505	
Prep Method: 200			Date Prepared:	08/24/2016 1025	
Lead	7.84	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(J)-197
Lab Sample ID: 420-109229-198

Date Sampled: 08/22/2016 0615
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0508	
Prep Method: 200			Date Prepared:	08/24/2016 1025	
Lead	4.55	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(K)-198
Lab Sample ID: 420-109229-199

Date Sampled: 08/22/2016 0609
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0512		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	8.79	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(L)-199
Lab Sample ID: 420-109229-200

Date Sampled: 08/22/2016 0610
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0523		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	10.6	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(M)-200
Lab Sample ID: 420-109229-201

Date Sampled: 08/22/2016 0607
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0526	
Prep Method: 200			Date Prepared:	08/24/2016 1025	
Lead	47.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF-202
Lab Sample ID: 420-109229-203

Date Sampled: 08/22/2016 0605
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0530		
Prep Method: 200			Date Prepared: 08/24/2016 1025		
Lead	16.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(B)-204
Lab Sample ID: 420-109229-205

Date Sampled: 08/22/2016 0555
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0534	
Prep Method: 200			Date Prepared:	08/24/2016 1025	
Lead	2.90	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(C)-205
Lab Sample ID: 420-109229-206

Date Sampled: 08/22/2016 0555
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0537	
Prep Method: 200			Date Prepared:	08/24/2016 1112	
Lead	10.0	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(D)-206
Lab Sample ID: 420-109229-207

Date Sampled: 08/22/2016 0558
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0552	
Prep Method: 200			Date Prepared:	08/24/2016 1112	
Lead	5.46	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(E)-207
Lab Sample ID: 420-109229-208

Date Sampled: 08/22/2016 0558
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0555		
Prep Method: 200			Date Prepared: 08/24/2016 1112		
Lead	6.06	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(F)-208
Lab Sample ID: 420-109229-209

Date Sampled: 08/22/2016 0602
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0606	
Prep Method: 200			Date Prepared:	08/24/2016 1112	
Lead	5.70	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(G)-209
Lab Sample ID: 420-109229-210

Date Sampled: 08/22/2016 0602
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0610	
Prep Method: 200			Date Prepared:	08/24/2016 1112	
Lead	10.6	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(H)-210
Lab Sample ID: 420-109229-211

Date Sampled: 08/22/2016 0602
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0613		
Prep Method: 200			Date Prepared: 08/24/2016 1112		
Lead	2.67	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(I)-211
Lab Sample ID: 420-109229-212

Date Sampled: 08/22/2016 0601
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0617	
Prep Method: 200			Date Prepared:	08/24/2016 1112	
Lead	3.06	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(J)-212
Lab Sample ID: 420-109229-213

Date Sampled: 08/22/2016 0559
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0620		
Prep Method: 200			Date Prepared: 08/24/2016 1112		
Lead	15.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(K)-213
Lab Sample ID: 420-109229-214

Date Sampled: 08/22/2016 0558
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0624	
Prep Method: 200			Date Prepared:	08/24/2016 1112	
Lead	24.4 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(L)-214
Lab Sample ID: 420-109229-215

Date Sampled: 08/22/2016 0556
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 1824		
Prep Method: 200			Date Prepared: 08/24/2016 1500		
Lead	20.1 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-CF(M)-215
Lab Sample ID: 420-109229-216

Date Sampled: 08/22/2016 0555
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0628		
Prep Method: 200			Date Prepared: 08/24/2016 1112		
Lead	7.72	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-DW-216
Lab Sample ID: 420-109229-217

Date Sampled: 08/22/2016 0620
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/25/2016 0631		
Prep Method: 200			Date Prepared: 08/24/2016 1112		
Lead	3.65	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-109229-1
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Client Sample ID: 16-90-ER-SVHS-TL-217
Lab Sample ID: 420-109229-218

Date Sampled: 08/22/2016 0626
Date Received: 08/22/2016 1218
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/25/2016 0635	
Prep Method: 200			Date Prepared:	08/24/2016 1112	
Lead	3.85	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Rockland BOCES

Job Number:
Sdg Number: East Ramapo 2016-090 Spring Valley HS

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards

Certification Information

Client: Rockland BOCES

Job Number:

Sdg Number: East Ramapo 2016-090 Spring Valley HS

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalien Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Rockland BOCES

Job Number:

Sdg Number: East Ramapo 2016-090 Spring Valley HS

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.



CHAIN OF CUSTODY

Lab Name: **EnviroTest Laboratories**
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)
109229

PROJECT REFERENCE East Ramapo CSD 2016-090		PROJECT NO.	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES				PAGE 1 of 15					
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky		CLIENT PHONE 845-627-4775	CLIENT FAX		NUMBER OF CONTAINERS SUBMITTED								NORMAL <u> X </u>	
CLIENT NAME Rockland BOCES		iagulino@rboces.org/ sarnstrong@rboces.org klewando@rboces.org			Total # of Containers								QUICK <u> </u>	
CLIENT ADDRESS 65 Patriot Road, B-4, West Nyack, NY 10994		SAMPLE IDENTIFICATION			# OF COOLERS								VERBAL <u> </u>	
COMPANY CONTRACTING THIS WORK (if applicable)		DATE	TIME		OTHER Specify									
8/22/2016	0454	16-90-ER-SVHS-SC-001		S	D	1								Lead (DW 200.8)
8/22/2016	0603	16-90-ER-SVHS-BF-002(A)	8/23/16 DS	S	D	1								Lead (DW 200.8)
8/22/2016	0603	16-90-ER-SVHS-BF-003(B)	8/23/16 DS	S	D	1								Lead (DW 200.8)
8/22/2016	0606	16-90-ER-SVHS-DW-004	8/23/16 DS	S	D	1								Lead (DW 200.8)
8/22/2016	0606	16-90-ER-SVHS-BF(A)-005		S	D	1								Lead (DW 200.8)
8/22/2016	0605	16-90-ER-SVHS-BF(B)-006		S	D	1								Lead (DW 200.8)
8/22/2016	0607	16-90-ER-SVHS-BF(C)-007		S	D	1								Lead (DW 200.8)
8/22/2016	0555	16-90-ER-SVHS-WC-008		S	D	1								Lead (DW 200.8)
8/22/2016	0555	16-90-ER-SVHS-WC-009		S	D	1								Lead (DW 200.8)
8/22/2016	0540	16-90-ER-SVHS-KF(A)-010		S	D	1								Lead (DW 200.8)
8/22/2016	0542	16-90-ER-SVHS-KF(B)-011		S	D	1								Lead (DW 200.8)
8/22/2016	0542	16-90-ER-SVHS-KF(C)-012		S	D	1								Lead (DW 200.8)
8/22/2016	0544	16-90-ER-SVHS-KF(D)-013		S	D	1								Lead (DW 200.8)
8/22/2016	0539	16-90-ER-SVHS-KF-014		S	D	1								Lead (DW 200.8)
8/22/2016	0530	16-90-ER-SVHS-IM-014 A		S	D	1								Lead (DW 200.8)
RELINQUISHED BY (SIGNATURE)		DATE	TIME	RECEIVED BY (SIGNATURE)		DATE	TIME	COMP. DATE		COMP. DATE		COMP. DATE		TIME
<i>[Signature]</i>		8/22	10:42	<i>[Signature]</i>		8/22/16	10:42	8/22/16		8/22/16		8/22/16		10:42
SAMPLED BY (SIGNATURE)		DATE	TIME	RECEIVED BY (SIGNATURE)		DATE	TIME	COMP. DATE		COMP. DATE		COMP. DATE		TIME
<i>[Signature]</i>		8/22	10:42	<i>[Signature]</i>		8/22/16	10:42	8/22/16		8/22/16		8/22/16		10:42
RELINQUISHED BY (SIGNATURE)		DATE	TIME	RECEIVED BY (SIGNATURE)		DATE	TIME	COMP. DATE		COMP. DATE		COMP. DATE		TIME
<i>[Signature]</i>		8/22/16	12:18	<i>[Signature]</i>		8/22/16	12:18	8/22/16		8/22/16		8/22/16		12:18

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE 8/22/16 TIME 12:18
 CUSTODY INTACT YES NO
 COOLER TEMP (C): 25.0°C
 LABORATORY REMARKS: ICE (Y/N) pH 7 CL2
 Reviewed by: _____

Change as per John Gulino of Rockland BOCES
 8/23/16 DS 11:18
 IR Gun # 2

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

109229

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE East Ramapo CSD 2016-090		PROJECT NO.	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES				PAGE 2 of 15
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		Other	Other	Terra Core	TURNAROUND TIME	
CLIENT (SITE) PM John Gulino/Keith Lewandosky		CLIENT PHONE 845-627-4775	CLIENT FAX		250ml Plastic	250ml Plastic	250ml Plastic	NORMAL <input checked="" type="checkbox"/>	
CLIENT NAME Rockland BOCES		jgolino@rboces.org/ sarmstrong@rboces.org/ klewando@rboces.org			250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	40ml Vials HCl	QUICK <input type="checkbox"/>	
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994					1Lter Amber HCl			VERBAL <input type="checkbox"/>	
COMPANY CONTRACTING THIS WORK (if applicable)					NUMBER OF CONTAINERS SUBMITTED			#OF COOLERS	
SAMPLE IDENTIFICATION		SAMPLE IDENTIFICATION		OTHER Specify				REMARKS	
DATE	TIME	DATE	TIME	COMPOSITE (C) OR GRAB (G) ANALYZE					
8/22/2016		16-90-ER-SVHS-KF -015 - NO SAMPLE		SOLID OR SEMISOLID				Lead (DW 200.8)	
8/22/2016	0556	16-90-ER-SVHS-BF -016		D (Drinking Water) or W (Waste Water) Indicate				Lead (DW 200.8)	
8/22/2016	0534	16-90-ER-SVHS-WC -017		AQUEOUS (WATER)				Lead (DW 200.8)	
8/22/2016	0621	16-90-ER-SVHS-BF(A) -018						Lead (DW 200.8)	
8/22/2016	0621	16-90-ER-SVHS-BF(B) -019						Lead (DW 200.8)	
8/22/2016	0622	16-90-ER-SVHS-BF(C) -020						Lead (DW 200.8)	
8/22/2016	0622	16-90-ER-SVHS-BF(A) -021						Lead (DW 200.8)	
8/22/2016	0622	16-90-ER-SVHS-BF(B) -022						Lead (DW 200.8)	
8/22/2016	0623	16-90-ER-SVHS-BF(C) -023						Lead (DW 200.8)	
8/22/2016	0623	16-90-ER-SVHS-BF(D) -024						Lead (DW 200.8)	
8/22/2016	0620	16-90-ER-SVHS-DW -025						Lead (DW 200.8)	
8/22/2016		16-90-ER-SVHS-BF -026 - NO SAMPLE						Lead (DW 200.8)	
8/22/2016	0632	16-90-ER-SVHS-BF -027						Lead (DW 200.8)	
8/22/2016	0614	16-90-ER-SVHS-BF -028						Lead (DW 200.8)	
8/22/2016	0617	16-90-ER-SVHS-BF -029						Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE	COMP. DATE	TIME	
<i>[Signature]</i>		ETL	8/22	10:42	<i>[Signature]</i>	8/22/16	8/22/16	1042	
SAMPLED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE	COMP. DATE	TIME	
<i>[Signature]</i>		ETL	8/22	0632	<i>[Signature]</i>	8/22/16	8/22/16		
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE	COMP. DATE	TIME	
<i>[Signature]</i>			8/22/16	12:18	<i>[Signature]</i>				

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE 8/22/16 TIME 12:18 CUSTODY INTACT YES NO COOLER TEMP(C): 25.0°C

LABORATORY REMARKS: ICE (Y - N) CL2 Reviewed by _____

IR Gun #2

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO. P.O. NUMBER	PROJECT LOCATION Spring Valley HS	MATRIX TYPE OTHER SPECIFY _____	REQUIRED ANALYSES 40ml Vials HCl _____ Liter Amber HCl _____ 250ml Plastic Nitric Acid _____ Liter Plastic _____ 250ml Plastic Sulfuric Acid _____ Terra Core _____ Other _____ Other _____	PAGE 3 of 15
ENVIROTEST PROJECT MANAGER Debra Bayer	CLIENT PHONE 845-627-4775	TOWN	NUMBER OF CONTAINERS SUBMITTED	TURNAROUND TIME	NORMAL <input checked="" type="checkbox"/> QUICK _____ VERBAL _____
CLIENT (SITE) PM John Guilino/Keith Lewandosky	CLIENT FAX	COMPOSITE (C) OR GRAB (G) INDICATE	OTHER SPECIFY	#OF COOLERS	
CLIENT NAME Rockland BOCES	igulino@rboces.org/ sairmstirong@rboces.org klewando@rboces.org	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPACT DATE
CLIENT ADDRESS 65 Patriot Road, B-4, West Nyack, NY 10994	COMPOSITE CONTRACTING THIS WORK (if applicable)	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPACT DATE
DATE	TIME	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPACT DATE
8/22/2016	0517	16-90-ER-SVHS-BF-030	10:42	8/22/16	
8/22/2016	0508	16-90-ER-SVHS-KF-031	08:12	8/22/16	
8/22/2016	0609	16-90-ER-SVHS-BF-032 not sampled 8/25/16	08:32	8/22/16	
8/22/2016	0611	16-90-ER-SVHS-DW-033	08:32	8/22/16	
8/22/2016	0453	16-90-ER-SVHS-BF(A)-034	12:18		
8/22/2016	0512	16-90-ER-SVHS-BF(B)-035			
8/22/2016	0519	16-90-ER-SVHS-BF(A)-036			
8/22/2016	0519	16-90-ER-SVHS-BF(B)-037			
8/22/2016	0517	16-90-ER-SVHS-WC-038			
8/22/2016	0514	16-90-ER-SVHS-WC-039			
8/22/2016		16-90-ER-SVHS-OT-040 Not Sampled			
8/22/2016	0530	16-90-ER-SVHS-BF-041			
8/22/2016	0525	16-90-ER-SVHS-DW-042			
8/22/2016	0523	16-90-ER-SVHS-BF-043			
8/22/2016		16-90-ER-SVHS-DW-044 - NO SAMPLE			
RECEIVED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPACT DATE
<i>[Signature]</i>	ETL	8/22	10:42	<i>[Signature]</i>	
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPACT DATE
<i>[Signature]</i>	ETL	8/22	08:32	<i>[Signature]</i>	
REMOVED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPACT DATE
<i>[Signature]</i>		8/22/16	12:18	<i>[Signature]</i>	
RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>[Signature]</i>			DATE 8/22/16	TIME 12:18	CUSTODY INTACT YES NO
LABORATORY REMARKS:			ICE <input checked="" type="checkbox"/> N <input checked="" type="checkbox"/> PH _____ CL2 _____	Revised by _____	Cooler Temp(C): 25.0°C

spc ID -032 was rec'd. As per
 John Guilino of Rockland BOCES pr
 analyze. 8/23/16 11:15 DS
 IR Gun #2



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

109229

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

Lab Name
Address & Phone

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO. P.O. NUMBER	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 4 of 15
ENVIROTEST PROJECT MANAGER Debra Bayer	CLIENT PHONE 845-627-4775	TOWN	OTHER SPECIFY	Other	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT FAX	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER) D (Drinking Water) or W (Waste Water) Indicate	250ml Plastic Sulfuric Acid	NORMAL <u> </u> X <u> </u>
CLIENT NAME Rockland BOCES	iaulino@rboces.org/ sarmstrong@rboces.org klewando@rboces.org	SOLID OR SEMISOLID	OTHER SPECIFY	250ml Plastic Nitric Acid	QUICK <u> </u>
CLIENT ADDRESS 65 Patriot Road, B-4, West Nyack, NY 10994	COMPOSITE (C) OR GRAB (G) INDICATE	OTHER SPECIFY	OTHER SPECIFY	Liter Amber HCl	VERBAL <u> </u>
COMPANY CONTRACTING THIS WORK (If applicable):					
SAMPLE IDENTIFICATION		NUMBER OF CONTAINERS SUBMITTED			
DATE	TIME	DATE	TIME	RECEIVED BY: (SIGNATURE)	REMARKS
8/22/2016	0512	16-90-ER-SVHS-BF(A) -045		1	Lead (DW 200.8)
8/22/2016	0512	16-90-ER-SVHS-BF(B) -046		1	Lead (DW 200.8)
8/22/2016	0513	16-90-ER-SVHS-BF(C) -047		1	Lead (DW 200.8)
8/22/2016	0513	16-90-ER-SVHS-BF(D) -048		1	Lead (DW 200.8)
8/22/2016	0515	16-90-ER-SVHS-BF(A) -049		1	Lead (DW 200.8)
8/22/2016	0515	16-90-ER-SVHS-BF(B) -050		1	Lead (DW 200.8)
8/22/2016	0516	16-90-ER-SVHS-BF(C) -051		1	Lead (DW 200.8)
8/22/2016	0516	16-90-ER-SVHS-BF(D) -052		1	Lead (DW 200.8)
8/22/2016	0521	16-90-ER-SVHS-HEF(A) -053		1	Lead (DW 200.8)
8/22/2016	0521	16-90-ER-SVHS-HEF(B) -054		1	Lead (DW 200.8)
8/22/2016	0520	16-90-ER-SVHS-HEF(C) -055		1	Lead (DW 200.8)
8/22/2016	0520	16-90-ER-SVHS-HEF(D) -056		1	Lead (DW 200.8)
8/22/2016	0519	16-90-ER-SVHS-HEF(E) -057		1	Lead (DW 200.8)
8/22/2016	0519	16-90-ER-SVHS-HEF(F) -058		1	Lead (DW 200.8)
8/22/2016	0519	16-90-ER-SVHS-HEF(G) -059		1	Lead (DW 200.8)
RECEIVED BY: (SIGNATURE)	DATE	COMPANY	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/22	ETL	10:42	<i>[Signature]</i>	8/24/16
SAMPLE BY: (SIGNATURE)	DATE	COMPANY	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/22	ETL	10:42	<i>[Signature]</i>	8/24/16
RELINQUISHED BY: (SIGNATURE)	DATE	COMPANY	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/22/16	ETL	1218	<i>[Signature]</i>	8/24/16

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP(C):	LABORATORY REMARKS:	ICE (Y/N)	CL-1	CL-2	REVIEWED BY:
<i>[Signature]</i>	8/22/16	1218	YES	25.0°C					

IR Gun # 2

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

109229

Lab Name: **EnviroTest Laboratories**
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO.	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 5 of 15
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER SPECIFY	Other	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	AQUEOUS (WATER) D (Drinking Water) or W (Waste Water) Indicate	250ml Plastic Nitric Acid	NORMAL <u>X</u>
CLIENT NAME Rockland BOCES	iqulino@rboces.org/ sarmstrong@rboces.org/ klewando@rboces.org		SOIL OR SEMISOLID	250ml Plastic Sulfuric Acid	QUICK
CLIENT ADDRESS 60 Parrott Road, B-4, West Nyack, NY 10994			OTHER	40ml Vials HCl	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)				Liter Amber HCl	
				Liter Plastic	
				250ml Plastic Nitric Acid	
				250ml Plastic Sulfuric Acid	
				Terra Core	
				Other	
				Other	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	NUMBER OF CONTAINERS SUBMITTED	REMARKS
8/22/2016	0527	16-90-ER-SVHS-CF-060	S	1	Lead (DW 200.8)
8/22/2016		16-90-ER-SVHS-CFF-061	S	1	Lead (DW 200.8)
8/22/2016	0530	16-90-ER-SVHS-CF(A)-062	S	1	Lead (DW 200.8)
8/22/2016	0528	16-90-ER-SVHS-CF(B)-063	S	1	Lead (DW 200.8)
8/22/2016	0528	16-90-ER-SVHS-CF(C)-064	S	1	Lead (DW 200.8)
8/22/2016	0529	16-90-ER-SVHS-CF(D)-065	S	1	Lead (DW 200.8)
8/22/2016	0529	16-90-ER-SVHS-CF(E)-066	S	1	Lead (DW 200.8)
8/22/2016	0525	16-90-ER-SVHS-CF(F)-067	S	1	Lead (DW 200.8)
8/22/2016	0525	16-90-ER-SVHS-CF(G)-068	S	1	Lead (DW 200.8)
8/22/2016	0527	16-90-ER-SVHS-CF(H)-069	S	1	Lead (DW 200.8)
8/22/2016	0527	16-90-ER-SVHS-CF(I)-070	S	1	Lead (DW 200.8)
8/22/2016	0527	16-90-ER-SVHS-CF(J)-071	S	1	Lead (DW 200.8)
8/22/2016	0526	16-90-ER-SVHS-CF(K)-072	S	1	Lead (DW 200.8)
8/22/2016	0526	16-90-ER-SVHS-CF(L)-073	S	1	Lead (DW 200.8)
8/22/2016	0526	16-90-ER-SVHS-CF(M)-074	S	1	Lead (DW 200.8)

RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY
<i>[Signature]</i>	8/22	10:40	ETL	<i>[Signature]</i>	8/22/16	1047	
SAMPLED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY
<i>[Signature]</i>	8/22	0632	ETL	<i>[Signature]</i>	8/22/16		
REINVESTIGATED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY
<i>[Signature]</i>	8/22/16	1218		<i>[Signature]</i>			

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP(C)	LABORATORY REMARKS
<i>[Signature]</i>	8/22/16	1218	YES	25.0°C	ICE (Y/N) PH CL2 Revisited by

IR Gun # 2



CHAIN OF CUSTODY

Lab Name **EnviroTest Laboratories**
 Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)
109229

PROJECT REFERENCE	PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES	PAGE 6 of 15
East Ramapo CSD 2016-090		Spring Valley HS			
ENVIROTEST PROJECT MANAGER	P.O. NUMBER	TOWN	OTHER SPECIFY	Other	
Debra Bayer			SOLID OR SEMISOLID	Other	
CLIENT (SITE) PM	CLIENT PHONE	CLIENT FAX	AQUEOUS (WATER)	250ml Plastic	TURNAROUND TIME
John Gulino/Keith Lewandosky	845-627-4775		COMPOSITE (C) OR GRAB (G) INDICATE	Liter Plastic	NORMAL X
CLIENT NAME				250ml Plastic Sulfuric Acid	QUICK
Rockland BOCES				Liter Amber HCl	VERBAL
CLIENT ADDRESS				40ml Vials HCl	
65 Parrott Road, B-4, West Nyack, NY 10994				250ml Plastic Nitric Acid	
COMPANY CONTRACTING THIS WORK (If applicable)				Other	
SAMPLE IDENTIFICATION					
DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	NUMBER OF CONTAINERS SUBMITTED	REMARKS
8/22/2016	0535	16-90-ER-SVHS-CF(N) -075	S	1	Lead (DW 200.8)
8/22/2016		16-90-ER-SVHS-OT -076 - NO SAMPLE	S	1	Lead (DW 200.8)
8/22/2016	0534	16-90-ER-SVHS-CF-077	S	1	Lead (DW 200.8)
8/22/2016	0535	16-90-ER-SVHS-CF(A) -078	S	1	Lead (DW 200.8)
8/22/2016	0535	16-90-ER-SVHS-CF(B) -079	S	1	Lead (DW 200.8)
8/22/2016	0536	16-90-ER-SVHS-CF(C) -080	S	1	Lead (DW 200.8)
8/22/2016	0536	16-90-ER-SVHS-CF(D) -081	S	1	Lead (DW 200.8)
8/22/2016	0537	16-90-ER-SVHS-CF(E) -082	S	1	Lead (DW 200.8)
8/22/2016	0537	16-90-ER-SVHS-CF(F) -083	S	1	Lead (DW 200.8)
8/22/2016	0538	16-90-ER-SVHS-CF(G) -084	S	1	Lead (DW 200.8)
8/22/2016	0538	16-90-ER-SVHS-CF(H) -085	S	1	Lead (DW 200.8)
8/22/2016	0539	16-90-ER-SVHS-CF(I) -086	S	1	Lead (DW 200.8)
8/22/2016	0540	16-90-ER-SVHS-CF(J) -087	S	1	Lead (DW 200.8)
8/22/2016	0540	16-90-ER-SVHS-CF(K) -088	S	1	Lead (DW 200.8)
8/22/2016	0540	16-90-ER-SVHS-CF(L) -089	S	1	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)	DATE	COMPANY	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/22	FR	10:42	<i>[Signature]</i>	8/22/16
SAMPLED BY: (SIGNATURE)	DATE	COMPANY	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/22	FR	15:43	<i>[Signature]</i>	8/22/16
RELINQUISHED BY: (SIGNATURE)	DATE	COMPANY	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/22/16		12:18	<i>[Signature]</i>	8/22/16
RECEIVED FOR LABORATORY BY: (SIGNATURE)					
<i>[Signature]</i>	DATE	TIME	CUSTODY INTACT	LABORATORY REMARKS: ICE Y. N. J. CL2	
	8/22/16	12:18	YES		
			NO		
Cooler Temp(C): 25.0°C					

FR Gun # 2



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

109229

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE East Ramapo CSD 2016-090		PROJECT NO.	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 7 of 15
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER SPECIFY	Other	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky		CLIENT PHONE 845-627-4775	CLIENT FAX	LIQUID OR SEMISOLID	Other	NORMAL <input checked="" type="checkbox"/> X
CLIENT NAME Rockland BOCES		igulino@rboces.org/ sarmstrong@rboces.org klewando@rboces.org		COMPOSITE (C) OR GRAB (G) INDICATE	40ml Vials HCl	QUICK
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994		SAMPLE IDENTIFICATION		OTHER (WATER) OR V (WASTE WATER) INDICATE	250ml Plastic Sulfuric Acid	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)		DATE	TIME	TIME	250ml Plastic Nitric Acid	# OF COOLERS
8/22/2016	0530	16-90-ER-SVHS-DW-090	8:22	10:42	Liter Amber HCl	
8/22/2016	0548	16-90-ER-SVHS-BF-091	8:22	10:42	250ml Plastic Nitric Acid	Lead (DW 200.8)
8/22/2016	0547	16-90-ER-SVHS-BF-092	8:22	10:42	Liter Plastic	Lead (DW 200.8)
8/22/2016	0549	16-90-ER-SVHS-BF-093	8:22	10:42	250ml Plastic Sulfuric Acid	Lead (DW 200.8)
8/22/2016	0523	16-90-ER-SVHS-CF(A)-094	8:22	10:42	Liter Plastic	Lead (DW 200.8)
8/22/2016	0524	16-90-ER-SVHS-CF(B)-095	8:22	10:42	250ml Plastic Nitric Acid	Lead (DW 200.8)
8/22/2016	0525	16-90-ER-SVHS-CF(C)-096	8:22	10:42	Liter Amber HCl	Lead (DW 200.8)
8/22/2016	0526	16-90-ER-SVHS-CF(D)-097	8:22	10:42	40ml Vials HCl	Lead (DW 200.8)
8/22/2016	0526	16-90-ER-SVHS-CF(E)-098	8:22	10:42	Other	Lead (DW 200.8)
8/22/2016	0527	16-90-ER-SVHS-CF(F)-099	8:22	10:42	Other	Lead (DW 200.8)
8/22/2016	0528	16-90-ER-SVHS-CF(G)-100	8:22	10:42	Other	Lead (DW 200.8)
8/22/2016	0528	16-90-ER-SVHS-CF(H)-101	8:22	10:42	Other	Lead (DW 200.8)
8/22/2016	0529	16-90-ER-SVHS-CF(I)-102	8:22	10:42	Other	Lead (DW 200.8)
8/22/2016	0529	16-90-ER-SVHS-CF(J)-103	8:22	10:42	Other	Lead (DW 200.8)
8/22/2016		16-90-ER-SVHS-CF(K)-104 - NO SAMPLE	8:22	10:42	Other	Lead (DW 200.8)
RECEIVED BY (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY (SIGNATURE)	COMP. DATE
<i>[Signature]</i>		ETR	8/22	10:42	<i>[Signature]</i>	8/24/16
SAMPLE BY (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY (SIGNATURE)	COMP. DATE
<i>[Signature]</i>		ETR	8/22	10:42	<i>[Signature]</i>	8/24/16
RELINQUISHED BY (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY (SIGNATURE)	COMP. DATE
<i>[Signature]</i>		ETR	8/22/16	12:18	<i>[Signature]</i>	8/22/16
RECEIVED FOR LABORATORY BY (SIGNATURE)		DATE	TIME	CUSTODY INTACT	COOLER TEMP(C)	LABORATORY REMARKS
<i>[Signature]</i>		8/22/16	12:18	YES	25.0°C	ICE (Y/N) <input checked="" type="checkbox"/> CL2 <input checked="" type="checkbox"/> Revisited by

IR Gun #2

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

REPORT# (Lab Use Only) **109229**

Lab Name: **EnviroTest Laboratories**
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO. P.O. NUMBER	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 8 of 15
ENVIROTEST PROJECT MANAGER Debra Bayer	CLIENT PHONE 845-627-4775	TOWN	OTHER SPECIFY	40ml Vials HCl	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT FAX	COMPOSITE (C) OR GRAB (G) INDICATE	OTHER SPECIFY	Liter Amber HCl	NORMAL <input checked="" type="checkbox"/> X
CLIENT NAME Rockland BOCES	igulino@rboces.org/ sarmstrong@rboces.org klewando@rboces.org	ACQUEOUS (WATER)	OTHER SPECIFY	250ml Plastic Sulfuric Acid	QUICK
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994	COMPOSITE (C) OR GRAB (G) INDICATE	SOLID OR SEMISOLID	OTHER SPECIFY	250ml Plastic Nitric Acid	VERBAL
COMPANY CONTRACTING THIS WORK (IF APPLICABLE):					

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	MATRIX TYPE	REQUIRED ANALYSES	NUMBER OF CONTAINERS SUBMITTED	REMARKS
8/22/2016	0531	16-90-ER-SVHS-CF(L)-105	S	D	40ml Vials HCl	1	Lead (DW 200.8)
8/22/2016		16-90-ER-SVHS-CF-106 - NO SAMPLE	S	D	Liter Amber HCl	1	Lead (DW 200.8)
8/22/2016	0538	16-90-ER-SVHS-CF-107	S	D	250ml Plastic Sulfuric Acid	1	Lead (DW 200.8)
8/22/2016	0545	16-90-ER-SVHS-CF(A)-108	S	D	250ml Plastic Nitric Acid	1	Lead (DW 200.8)
8/22/2016	0545	16-90-ER-SVHS-CF(B)-109	S	D	Liter Amber HCl	1	Lead (DW 200.8)
8/22/2016	0544	16-90-ER-SVHS-CF(C)-110	S	D	40ml Vials HCl	1	Lead (DW 200.8)
8/22/2016	0543	16-90-ER-SVHS-CF(D)-111	S	D	250ml Plastic Sulfuric Acid	1	Lead (DW 200.8)
8/22/2016	0542	16-90-ER-SVHS-CF(E)-112	S	D	250ml Plastic Nitric Acid	1	Lead (DW 200.8)
8/22/2016	0542	16-90-ER-SVHS-CF(F)-113	S	D	Liter Amber HCl	1	Lead (DW 200.8)
8/22/2016	0540	16-90-ER-SVHS-CF(G)-114	S	D	40ml Vials HCl	1	Lead (DW 200.8)
8/22/2016	0540	16-90-ER-SVHS-CF(H)-115	S	D	250ml Plastic Sulfuric Acid	1	Lead (DW 200.8)
8/22/2016	0537	16-90-ER-SVHS-CF(I)-116	S	D	250ml Plastic Nitric Acid	1	Lead (DW 200.8)
8/22/2016	0537	16-90-ER-SVHS-CF(J)-117	S	D	Liter Amber HCl	1	Lead (DW 200.8)
8/22/2016	0547	16-90-ER-SVHS-CF(K)-118	S	D	40ml Vials HCl	1	Lead (DW 200.8)
8/22/2016	0547	16-90-ER-SVHS-CF(L)-119	S	D	250ml Plastic Sulfuric Acid	1	Lead (DW 200.8)

RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY
<i>[Signature]</i>	8/22	12:42	FIR	<i>[Signature]</i>	8/22/16	1042	FIR
SAMPLED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY
<i>[Signature]</i>	8/22	12:42	FIR	<i>[Signature]</i>	8/22/16		FIR
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY
<i>[Signature]</i>	8/22/16	12:18	FIR	<i>[Signature]</i>	8/22/16		FIR

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE **8/22/16** TIME **12:18** YES NO

COOLER TEMP (C): **25.0°C**

LABORATORY REMARKS: ICE (Y) NO CL2

RECEIVED BY: _____

IR Gun #2



CHAIN OF CUSTODY

EnviroTest Laboratories, Inc.
 Lab Name
 Address & Phone

Enviro Test Laboratories
 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

109229

PROJECT REFERENCE East Ramapo CSD 2016-090		PROJECT NO.	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES								PAGE 9 of 15			
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER SPECIFY	Other	Other	Terra Core	Liter Plastic	250ml Plastic	250ml Plastic Sulfuric Acid	Liter Plastic Nitric Acid	250ml Plastic Nitric Acid	Liter Amber HCl	40ml Vials HCl	Turnaround Time	
CLIENT (SITE) PM John Gulino/Keith Lewandosky		CLIENT PHONE 845-627-4775	CLIENT FAX	ACQUEOUS (WATER)	Other										NORMAL <input checked="" type="checkbox"/> X	
CLIENT NAME Rockland BOCES		iugulino@rboces.org/ sarnstrong@rboces.org klewando@rboces.org		SOLID OR SEMISOLID	# OF COOLERS											
CLIENT ADDRESS 65 Parrot Road, B-4, West Nyack, NY 10994		COMPOSITE (C) OR GRAB (G) INDICATE		D (Drinking Water) or W (Waste Water) Indicate	NUMBER OF CONTAINERS SUBMITTED											
COMPANY CONTRACTING THIS WORK (if applicable)		SAMPLE IDENTIFICATION		OTHER SPECIFY	REMARKS											
DATE	TIME															
8/22/2016	0547		16-90-ER-SVHS-CF(M)-120	S	D							1				Lead (DW 200.8)
8/22/2016	0516		16-90-ER-SVHS-CF-121	S	D							1				Lead (DW 200.8)
8/22/2016	0541		16-90-ER-SVHS-CF-122	S	D							1				Lead (DW 200.8)
8/22/2016	0543		16-90-ER-SVHS-CF-123	S	D							1				Lead (DW 200.8)
8/22/2016	0517		16-90-ER-SVHS-CF-124	S	D							1				Lead (DW 200.8)
8/22/2016	0518		16-90-ER-SVHS-CF-125	S	D							1				Lead (DW 200.8)
8/22/2016	0515		16-90-ER-SVHS-BF-126	S	D							1				Lead (DW 200.8)
8/22/2016	0514		16-90-ER-SVHS-BF-127	S	D							1				Lead (DW 200.8)
8/22/2016	0513		16-90-ER-SVHS-DW-128	S	D							1				Lead (DW 200.8)
8/22/2016	0512		16-90-ER-SVHS-CF-129	S	D							1				Lead (DW 200.8)
8/22/2016	0512		16-90-ER-SVHS-BF-130	S	D							1				Lead (DW 200.8)
8/22/2016	0512		16-90-ER-SVHS-OT-131	S	D							1				Lead (DW 200.8)
8/22/2016	0515		16-90-ER-SVHS-IM-132	S	D							1				Lead (DW 200.8)
8/22/2016	0520		16-90-ER-SVHS-DW-133	S	D							1				Lead (DW 200.8)
8/22/2016	0524		16-90-ER-SVHS-BF(A)-134	S	D							1				Lead (DW 200.8)
REMOVED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	
[Signature]		ETR	8/12/22	10:42	[Signature]		ETR	8/22/16	8:46	[Signature]		ETR	8/22/16	10:47		
SAVED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	
[Signature]		ETR	8/12/22	06:37	[Signature]		ETR	8/22/16	9:22	[Signature]		ETR	8/22/16			
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	
[Signature]			8/22/16	12:18	[Signature]					[Signature]						

RECEIVED FOR LABORATORY BY: (SIGNATURE) [Signature] DATE 8/22/16 TIME 12:18
 CUSTODY INTACT YES NO
 LABORATORY REMARKS: ICE Y N N pH CL2 Revisited by _____
 Cooler Temp(C): 25.0°C

IR Gun #2

CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

109229

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO.	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 10 of 15
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER SPACE	Other	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	OTHER SPACE	Other	NORMAL <input checked="" type="checkbox"/>
CLIENT NAME Rockland BOCES	iquilino@rboces.org/ sarmstrong@rboces.org/ klewando@rboces.org		OTHER SPACE	Other	QUICK <input type="checkbox"/>
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994			OTHER SPACE	Other	VERBAL <input type="checkbox"/>
COMPANY CONTRACTING THIS WORK (if applicable)					

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	NUMBER OF CONTAINERS SUBMITTED										# OF COOLERS	REMARKS		
				40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other					
8/22/2016	0522	16-90-ER-SVHS-BF(B)-135	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0522	16-90-ER-SVHS-BF(C)-136	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0526	16-90-ER-SVHS-BF(A)-137	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0526	16-90-ER-SVHS-BF(B)-138	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0529	16-90-ER-SVHS-BF(C)-139	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016		16-90-ER-SVHS-WC-140 NOT Sampled	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0610	16-90-ER-SVHS-BF-141	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0606	16-90-ER-SVHS-NF-142	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0607	16-90-ER-SVHS-BF-143	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0607	16-90-ER-SVHS-BF(A)-144	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0605	16-90-ER-SVHS-BF(B)-145	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0603	16-90-ER-SVHS-BF(C)-146	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0604	16-90-ER-SVHS-BF(D)-147	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0605	16-90-ER-SVHS-BF(E)-148	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/22/2016	0558	16-90-ER-SVHS-BF(A)-149	S	1	1	1	1	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP (C)	LABORATORY REMARKS
<i>[Signature]</i>	8/22	12:22	YES	25.0°C	ICE (Y) <input checked="" type="checkbox"/> PH <input checked="" type="checkbox"/> CL2 <input type="checkbox"/> Reviewed by: _____
SAMPLED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	RECEIVED BY: (SIGNATURE)
<i>[Signature]</i>	8/22	12:22	<i>[Signature]</i>	ETR	<i>[Signature]</i>
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	RECEIVED BY: (SIGNATURE)
<i>[Signature]</i>	8/22/16	12:18	<i>[Signature]</i>	ETR	<i>[Signature]</i>

IR Gun #2

EnviroTest Laboratories, Inc.



CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

10922

PROJECT REFERENCE: East Ramapo CSD 2016-090
 ENVIROTEST PROJECT MANAGER: Debra Bayer
 CLIENT (SITE) PM: John Gulino/Keith Lewandosky
 CLIENT NAME: Rockland BOCES
 CLIENT ADDRESS: 65 Patriot Road, B-4, West Nyack, NY 10994
 COMPANY CONTRACTING THIS WORK (if applicable):

PROJECT LOCATION: Spring Valley HS
 TOWN: _____
 CLIENT PHONE: 845-627-4775
 CLIENT FAX: _____
 CLIENT EMAIL: igulino@boces.org, saamstrong@boces.org, kiewando@boces.org

PROJECT NO.: _____
 P.O. NUMBER: _____

MATRIX TYPE: _____
 OTHER SPECIFY: _____

REQUIRED ANALYSES:

40ml Vials HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other
----------------	---------------------------	-----------------------------	---------------	---------------	------------	-------	-------

TURNAROUND TIME: 15

NORMAL: X
 QUICK: _____
 VERBAL: _____

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED								# OF COOLERS	REMARKS
			1	1	1	1	1	1	1	1		
8/22/2016	0551	16-90-ER-SVHS-BF(B)-150	1									Lead (DW 200.8)
8/22/2016	0554	16-90-ER-SVHS-BF(C)-151	1									Lead (DW 200.8)
8/22/2016	0600	16-90-ER-SVHS-BF(D)-152	1									Lead (DW 200.8)
8/22/2016	0601	16-90-ER-SVHS-BF(E)-153	1									Lead (DW 200.8)
8/22/2016	0607	16-90-ER-SVHS-CF-154	1									Lead (DW 200.8)
8/22/2016	0608	16-90-ER-SVHS-CF-155	1									Lead (DW 200.8)
8/22/2016	0603	16-90-ER-SVHS-CF(A)-156	1									Lead (DW 200.8)
8/22/2016	0603	16-90-ER-SVHS-CF(B)-157	1									Lead (DW 200.8)
8/22/2016	0604	16-90-ER-SVHS-CF-158	1									Lead (DW 200.8)
8/22/2016	0605	16-90-ER-SVHS-CF(A)-159	1									Lead (DW 200.8)
8/22/2016		16-90-ER-SVHS-CF(B)-160 not sampled	1									Lead (DW 200.8)
8/22/2016	0609	16-90-ER-SVHS-BF(A)-161	1									Lead (DW 200.8)
8/22/2016	0609	16-90-ER-SVHS-BF(B)-162	1									Lead (DW 200.8)
8/22/2016	0610	16-90-ER-SVHS-BF(C)-163	1									Lead (DW 200.8)
8/22/2016	0610	16-90-ER-SVHS-BF(D)-164	1									Lead (DW 200.8)

RECEIVED BY: (SIGNATURE) _____ DATE: 8/22/16 TIME: 10:42
 RECEIVED BY: (SIGNATURE) _____ DATE: 8/22/16 TIME: 10:42
 RECEIVED BY: (SIGNATURE) _____ DATE: 8/22/16 TIME: 12:18

RECEIVED BY: (SIGNATURE) _____ DATE: 8/22/16 TIME: 12:18

RECEIVED BY: (SIGNATURE) _____ DATE: 8/22/16 TIME: 12:18

LABORATORY REMARKS: ICE (Y) _____ CL2 _____ Received by: _____
 CUSTODY INTACT: YES _____ NO _____
 DATE: 8/22/16 TIME: 12:18
 DATE: 8/22/16 TIME: 12:18
 DATE: 8/22/16 TIME: 12:18

COOLER TEMP (C): 25.0°C
 IR Gun #2



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

109229

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

Lab Name
Address & Phone

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO.	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 12 of 15
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER SPECIFY	Other	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	AQUEOUS (WATER)	250ml Plastic Nitric Acid	NORMAL <input checked="" type="checkbox"/> X
CLIENT NAME Rockland BOCES	iqulino@rboces.org/ sarmstrong@rboces.org klewando@rboces.org		SOLID OR SEMISOLID	Liter Plastic	QUICK
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994			OTHER SPECIFY	250ml Plastic Sulfuric Acid	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable):					
SAMPLE	DATE	TIME	COMPOSITE (C) OR GRAB (G) INDICATE	40ml Vials HCl	#OF COOLERS
				Liter Amber HCl	
				250ml Plastic Nitric Acid	
				Liter Plastic	
				250ml Plastic Sulfuric Acid	
				Terra Core	
				Other	
				Other	
				NUMBER OF CONTAINERS SUBMITTED	REMARKS
8/22/216	0612		S	1	Lead (DW 200.8)
8/22/216	0613		S	1	Lead (DW 200.8)
8/22/216	0613		S	1	Lead (DW 200.8)
8/22/216	0612		S	1	Lead (DW 200.8)
8/22/216	0612		S	1	Lead (DW 200.8)
8/22/216	0516		S	1	Lead (DW 200.8)
8/22/216	0519		S	1	Lead (DW 200.8)
8/22/216	0525		S	1	Lead (DW 200.8)
8/22/216	0527		S	1	Lead (DW 200.8)
8/22/216	0527		S	1	Lead (DW 200.8)
8/22/216	0528		S	1	Lead (DW 200.8)
8/22/216	0528		S	1	Lead (DW 200.8)
8/22/216	0526		S	1	Lead (DW 200.8)
8/22/216	0527		S	1	Lead (DW 200.8)
8/22/216	0528		S	1	Lead (DW 200.8)
REQUISITED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	COMPACT DATE
<i>[Signature]</i>	8/22	10:42	<i>[Signature]</i>	ETL	8/22/16
SAMPLE BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	COMPACT DATE
<i>[Signature]</i>	8/22	10:52	<i>[Signature]</i>	ETL	8/22/16
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	COMPACT DATE
<i>[Signature]</i>	8/22/16	12:18	<i>[Signature]</i>	ETL	8/22/16

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE 8/22/16 TIME 12:18

COOLER TEMP (C): 25.0°C

ICE (Y/N) PH CL2

LABORATORY REMARKS: IR Gun #2



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

109229

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO.	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 13 of 15	
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER SPECIALTY	Terra Core	TURNAROUND TIME	
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	AQUEOUS (WATER) D (Drinking Water) or W (Waste Water) Indicate	Liter Plastic	NORMAL <input checked="" type="checkbox"/> X	
CLIENT NAME Rockland BOCES	igulino@rboces.org/ sarmstrong@rboces.org kliewando@rboces.org		SOIL OR SEMISOLID	250ml Plastic Sulfuric Acid	QUICK	
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994			OTHER	Liter Plastic Nitric Acid	VERBAL	
COMPOSITE (C) OR GRAB (G) INDICATE						
SAMPLE IDENTIFICATION						
DATE	TIME	SAMPLE IDENTIFICATION		NUMBER OF CONTAINERS SUBMITTED	REMARKS	
8/22/2016	0530	16-90-ER-SVHS-BF(D)-180	S	1	Lead (DW 200.8)	
8/22/2016		16-90-ER-SVHS-BF-181 - NO SAMPLE	S	1	Lead (DW 200.8)	
8/22/2016	0626	16-90-ER-SVHS-DW-182	S	1	Lead (DW 200.8)	
8/22/2016	0548	16-90-ER-SVHS-OT-183	S	1	Lead (DW 200.8)	
8/22/2016	0547	16-90-ER-SVHS-BF-184	S	1	Lead (DW 200.8)	
8/22/2016	0543	16-90-ER-SVHS-BF-185	S	1	Lead (DW 200.8)	
8/22/2016	0542	16-90-ER-SVHS-OT-186	S	1	Lead (DW 200.8)	
8/22/2016	0550	16-90-ER-SVHS-BF-187	S	1	Lead (DW 200.8)	
8/22/2016	0607	16-90-ER-SVHS-CF(A)-188	S	1	Lead (DW 200.8)	
8/22/2016	0607	16-90-ER-SVHS-CF(B)-189	S	1	Lead (DW 200.8)	
8/22/2016	0611	16-90-ER-SVHS-CF(C)-190	S	1	Lead (DW 200.8)	
8/22/2016	0611	16-90-ER-SVHS-CF(D)-191	S	1	Lead (DW 200.8)	
8/22/2016	0617	16-90-ER-SVHS-CF(E)-192	S	1	Lead (DW 200.8)	
8/22/2016	0617	16-90-ER-SVHS-CF(F)-193	S	1	Lead (DW 200.8)	
8/22/2016	0618	16-90-ER-SVHS-CF(G)-194	S	1	Lead (DW 200.8)	
REQUISITIONED BY: (SIGNATURE) <i>[Signature]</i>	DATE 8/22/16	COMPANY ETR	TIME 10:42	RECEIVED BY: (SIGNATURE) <i>[Signature]</i>	COMP. DATE 8/24/16	TIME 1047
SAMPLED BY: (SIGNATURE) <i>[Signature]</i>	DATE 8/22/16	COMPANY ETR	TIME 0635	RECEIVED BY: (SIGNATURE) <i>[Signature]</i>	COMP. DATE	TIME
RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>	DATE 8/22/16	COMPANY	TIME 1218	RECEIVED BY: (SIGNATURE)	COMP. DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)
[Signature]

DATE 8/22/16 TIME 1218

CUSTODY INTACT
YES NO

Cooler Temp (C): 25.0°C

LABORATORY REMARKS: ICE N P CL2

Reviewed by: _____

IR Gun #2



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

109229

EnviroTest Laboratories
 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO.	PROJECT LOCATION Spring Valley HS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 14 of 15
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	SOLID OR SEMISOLID	Other	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	D (Drinking Water) or W (Waste Water) Indicate	250ml Plastic	NORMAL <input checked="" type="checkbox"/> X
CLIENT NAME Rockland BOCES	igulino@rboces.org/ sarmstrong@rboces.org/ klewanda@rboces.org		AGUEOUS (WATER)	Liter Plastic	QUICK
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994			COMPOSITE (C) OR GRAB (G) INDICATE	250ml Plastic Sulfuric Acid	VERBAL
COMPANY CONTRACTING THIS WORK (If applicable):					
SAMPLE IDENTIFICATION		NUMBER OF CONTAINERS SUBMITTED		REMARKS	
DATE	TIME	DATE	TIME		
8/22/2016	0620	16-90-ER-SVHS-CF(H)-195		1	Lead (DW 200.8)
8/22/2016	0613	16-90-ER-SVHS-CF(I)-196		1	Lead (DW 200.8)
8/22/2016	0615	16-90-ER-SVHS-CF(J)-197		1	Lead (DW 200.8)
8/22/2016	0609	16-90-ER-SVHS-CF(K)-198		1	Lead (DW 200.8)
8/22/2016	0610	16-90-ER-SVHS-CF(L)-199		1	Lead (DW 200.8)
8/22/2016	0607	16-90-ER-SVHS-CF(M)-200		1	Lead (DW 200.8)
8/22/2016		16-90-ER-SVHS-CF(N)-201 Not Sampled		1	Lead (DW 200.8)
8/22/2016	0605	16-90-ER-SVHS-CF-202		1	Lead (DW 200.8)
8/22/2016		16-90-ER-SVHS-CF(A)-203 Not Sampled		1	Lead (DW 200.8)
8/22/2016	0555	16-90-ER-SVHS-CF(B)-204		1	Lead (DW 200.8)
8/22/2016	0555	16-90-ER-SVHS-CF(G)-205		1	Lead (DW 200.8)
8/22/2016	0558	16-90-ER-SVHS-CF(D)-206		1	Lead (DW 200.8)
8/22/2016	0558	16-90-ER-SVHS-CF(E)-207		1	Lead (DW 200.8)
8/22/2016	0607	16-90-ER-SVHS-CF(F)-208		1	Lead (DW 200.8)
8/22/2016	0602	16-90-ER-SVHS-CF(G)-209		1	Lead (DW 200.8)
RECEIVED BY: (SIGNATURE)	DATE	COMPANY	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/22/16	ETR	0620	<i>[Signature]</i>	8/22/16
RECEIVED BY: (SIGNATURE)	DATE	COMPANY	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/22/16	ETR	0620	<i>[Signature]</i>	8/22/16
RECEIVED BY: (SIGNATURE)	DATE	COMPANY	TIME	RECEIVED BY: (SIGNATURE)	COMP. DATE
<i>[Signature]</i>	8/22/16	ETR	1218	<i>[Signature]</i>	8/22/16

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE 8/22/16 TIME 12:18

LABORATORY REMARKS: ICE Y No CL2 _____ Reviewed by _____

Cooler Temp(C): 25.0°C

CUSTODY INTACT YES NO

IR Gun #2

Lab Name
Address & Phone

Envirotest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: East Ramapo CSD 2016-090
 ENVIROTEST PROJECT MANAGER: Debra Bayer
 CLIENT (SITES) PM: John Gulino/Keith Lewandosky
 CLIENT NAME: Rockland BOCES
 CLIENT ADDRESS: 65 Parrott Road, B-4, West Nyack, NY 10994
 COMPANY CONTRACTING THIS WORK (if applicable):

PROJECT LOCATION: Spring Valley HS
 TOWN:
 CLIENT PHONE: 845-627-4775
 CLIENT FAX:
 CLIENT EMAIL: igulino@rboces.org/
 sarmstrong@rboces.org/
 klewand@rboces.org

PROJECT NO.:
 P.O. NUMBER:
 CLIENT PHONE:
 CLIENT FAX:

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	REQUIRED ANALYSES										# OF COOLERS	REMARKS	
			Total # of Containers	4ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other			
8/22/216	0602	16-90-ER-SVHS-CF(H)-210	1												Lead (DW 200.8)
8/22/216	0601	16-90-ER-SVHS-CF(I)-211	1												Lead (DW 200.8)
8/22/216	0559	16-90-ER-SVHS-CF(J)-212	1												Lead (DW 200.8)
8/22/216	0558	16-90-ER-SVHS-CF(K)-213	1												Lead (DW 200.8)
8/22/216	0556	16-90-ER-SVHS-CF(L)-214	1												Lead (DW 200.8)
8/22/216	0555	16-90-ER-SVHS-CF(M)-215	1												Lead (DW 200.8)
8/22/216	0620	16-90-ER-SVHS-DW-216	1												Lead (DW 200.8)
8/22/216	0626	16-90-ER-SVHS-TL-217	1												Lead (DW 200.8)
8/22/216		16-90-ER-SVHS-DF-218	1												Lead (DW 200.8)

MATRIX TYPE: D (Drinking Water) or W (Waste Water) indicate OTHER Specify _____

NUMBER OF CONTAINERS SUBMITTED: SOLID OR SEMISOLID

COMPOSITE (C) OR GRAB (G) INDICATE AQUEOUS (WATER)

RECEIVED BY (SIGNATURE): [Signature] DATE: 8/22/16 TIME: 10:42

RECEIVED BY (SIGNATURE): [Signature] DATE: 8/22/16 TIME: 10:42

RECEIVED BY (SIGNATURE): [Signature] DATE: 8/22/16 TIME: 12:18

RECEIVED FOR LABORATORY BY: (SIGNATURE) [Signature] DATE: 8/22/16 TIME: 12:18

LABORATORY REMARKS: ICE (Y/N) PH CL2 Revisited by _____

IR Gun # 2

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Rockland BOCES

Job Number: 420-109229-1

SDG Number: East Ramapo 2016-090 Spring Valley HS

Login Number: 109229

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	25.0 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	True	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	