

ANALYTICAL REPORT

Job Number: 420-108932-1


SDG Number: East Ramapo CSD 2016-090 - Elmwood ES

Job Description: Rockland BOCES

For:

Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Attention: Seth Armstrong



Debra Bayer

Customer Service Manager

dbayer@envirotestlaboratories.com

08/24/2016

cc: John Gulino

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

Envirotest Laboratories, Inc.

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Rockland BOCES

Job Number: 420-108932-1
SDG Number: East Ramapo CSD 2016-090 - Elmwood ES

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Rockland BOCES

Job Number: 420-108932-1

SDG Number: East Ramapo CSD 2016-090 - Elmwood ES

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-108932-1

SDG Number: East Ramapo CSD 2016-090 - Elmwood ES

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-108932-1	16-90-ER-Elm-SC-001	Drinking Water	08/16/2016 0050	08/16/2016 1110
420-108932-2	16-90-ER-Elm-OT-002	Drinking Water	08/16/2016 0509	08/16/2016 1110
420-108932-3	16-90-ER-Elm-KF-003	Drinking Water	08/16/2016 0509	08/16/2016 1110
420-108932-4	16-90-ER-Elm-KF-004	Drinking Water	08/16/2016 0508	08/16/2016 1110
420-108932-5	16-90-ER-Elm-BF-005	Drinking Water	08/16/2016 0508	08/16/2016 1110
420-108932-6	16-90-ER-Elm-BF-006	Drinking Water	08/16/2016 0510	08/16/2016 1110
420-108932-7	16-90-ER-Elm-CF-007	Drinking Water	08/16/2016 0515	08/16/2016 1110
420-108932-8	16-90-ER-Elm-CFF-008	Drinking Water	08/16/2016 0516	08/16/2016 1110
420-108932-9	16-90-ER-Elm-CF-009	Drinking Water	08/16/2016 0515	08/16/2016 1110
420-108932-10	16-90-ER-Elm-CFF-010	Drinking Water	08/16/2016 0516	08/16/2016 1110
420-108932-11	16-90-ER-Elm-CF-011	Drinking Water	08/16/2016 0519	08/16/2016 1110
420-108932-13	16-90-ER-Elm-CF-013	Drinking Water	08/16/2016 0519	08/16/2016 1110
420-108932-14	16-90-ER-Elm-CFF-014	Drinking Water	08/16/2016 0520	08/16/2016 1110
420-108932-15	16-90-ER-Elm-CF-015	Drinking Water	08/16/2016 0522	08/16/2016 1110
420-108932-16	16-90-ER-Elm-BF-016	Drinking Water	08/16/2016 0522	08/16/2016 1110
420-108932-17	16-90-ER-Elm-BF-017	Drinking Water	08/16/2016 0523	08/16/2016 1110
420-108932-18	16-90-ER-Elm-BF-018	Drinking Water	08/16/2016 0523	08/16/2016 1110
420-108932-19	16-90-ER-Elm-BF-019	Drinking Water	08/16/2016 0524	08/16/2016 1110
420-108932-20	16-90-ER-Elm-OT-020	Drinking Water	08/16/2016 0526	08/16/2016 1110
420-108932-21	16-90-ER-Elm-OT-021	Drinking Water	08/16/2016 0527	08/16/2016 1110
420-108932-22	16-90-ER-Elm-OT-022	Drinking Water	08/16/2016 0529	08/16/2016 1110
420-108932-23	16-90-ER-Elm-DW-023	Drinking Water	08/16/2016 0530	08/16/2016 1110
420-108932-24	16-90-ER-Elm-BF-024	Drinking Water	08/16/2016 0531	08/16/2016 1110
420-108932-25	16-90-ER-Elm-BF-025	Drinking Water	08/16/2016 0532	08/16/2016 1110
420-108932-26	16-90-ER-Elm-WF-026	Drinking Water	08/16/2016 0532	08/16/2016 1110
420-108932-27	16-90-ER-Elm-CF-027	Drinking Water	08/16/2016 0536	08/16/2016 1110
420-108932-28	16-90-ER-Elm-CF-028	Drinking Water	08/16/2016 0535	08/16/2016 1110
420-108932-29	16-90-ER-Elm-CFF-088	Drinking Water	08/16/2016 0534	08/16/2016 1110
420-108932-30	16-90-ER-Elm-CF-089	Drinking Water	08/16/2016 0534	08/16/2016 1110
420-108932-31	16-90-ER-Elm-CFF-090	Drinking Water	08/16/2016 0535	08/16/2016 1110
420-108932-32	16-90-ER-Elm-CF-091	Drinking Water	08/16/2016 0539	08/16/2016 1110
420-108932-33	16-90-ER-Elm-CFF-092	Drinking Water	08/16/2016 0540	08/16/2016 1110
420-108932-34	16-90-ER-Elm-CF-093	Drinking Water	08/16/2016 0541	08/16/2016 1110
420-108932-35	16-90-ER-Elm-CFF-094	Drinking Water	08/16/2016 0542	08/16/2016 1110
420-108932-36	16-90-ER-Elm-CF-095	Drinking Water	08/16/2016 0540	08/16/2016 1110
420-108932-37	16-90-ER-Elm-CFF-096	Drinking Water	08/16/2016 0541	08/16/2016 1110
420-108932-38	16-90-ER-Elm-CF-097	Drinking Water	08/16/2016 0539	08/16/2016 1110
420-108932-39	16-90-ER-Elm-CFF-098	Drinking Water	08/16/2016 0540	08/16/2016 1110
420-108932-40	16-90-ER-Elm-CF-038	Drinking Water	08/16/2016 0623	08/16/2016 1110
420-108932-41	16-90-ER-Elm-CFF-039	Drinking Water	08/16/2016 0622	08/16/2016 1110
420-108932-42	16-90-ER-Elm-CF-040	Drinking Water	08/16/2016 0622	08/16/2016 1110
420-108932-43	16-90-ER-Elm-CFF-041	Drinking Water	08/16/2016 0623	08/16/2016 1110
420-108932-44	16-90-ER-Elm-CF-042	Drinking Water	08/16/2016 0619	08/16/2016 1110
420-108932-45	16-90-ER-Elm-CFF-043	Drinking Water	08/16/2016 0620	08/16/2016 1110
420-108932-46	16-90-ER-Elm-CF-044	Drinking Water	08/16/2016 0619	08/16/2016 1110
420-108932-47	16-90-ER-Elm-CFF-045	Drinking Water	08/16/2016 0620	08/16/2016 1110

SAMPLE SUMMARY

Client: Rockland BOCES

Job Number: 420-108932-1

SDG Number: East Ramapo CSD 2016-090 - Elmwood ES

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-108932-48	16-90-ER-Elm-CF-046	Drinking Water	08/16/2016 0617	08/16/2016 1110
420-108932-49	16-90-ER-Elm-CFF-047	Drinking Water	08/16/2016 0617	08/16/2016 1110
420-108932-50	16-90-ER-Elm-CF-048	Drinking Water	08/16/2016 0616	08/16/2016 1110
420-108932-51	16-90-ER-Elm-CFF-049	Drinking Water	08/16/2016 0617	08/16/2016 1110
420-108932-52	16-90-ER-Elm-BF-050	Drinking Water	08/16/2016 0614	08/16/2016 1110
420-108932-53	16-90-ER-Elm-BF-051	Drinking Water	08/16/2016 0615	08/16/2016 1110
420-108932-54	16-90-ER-Elm-BF-052	Drinking Water	08/16/2016 0614	08/16/2016 1110
420-108932-55	16-90-ER-Elm-BF-053	Drinking Water	08/16/2016 0615	08/16/2016 1110
420-108932-56	16-90-ER-Elm-DW-054	Drinking Water	08/16/2016 0612	08/16/2016 1110
420-108932-57	16-90-ER-Elm-CF-055	Drinking Water	08/16/2016 0610	08/16/2016 1110
420-108932-58	16-90-ER-Elm-CFF-056	Drinking Water	08/16/2016 0611	08/16/2016 1110
420-108932-59	16-90-ER-Elm-CF-057	Drinking Water	08/16/2016 0610	08/16/2016 1110
420-108932-60	16-90-ER-Elm-CFF-058	Drinking Water	08/16/2016 0611	08/16/2016 1110
420-108932-61	16-90-ER-Elm-CF-059	Drinking Water	08/16/2016 0607	08/16/2016 1110
420-108932-62	16-90-ER-Elm-CFF-060	Drinking Water	08/16/2016 0608	08/16/2016 1110
420-108932-63	16-90-ER-Elm-CF-061	Drinking Water	08/16/2016 0606	08/16/2016 1110
420-108932-64	16-90-ER-Elm-CFF-062	Drinking Water	08/16/2016 0607	08/16/2016 1110
420-108932-65	16-90-ER-Elm-OT-063	Drinking Water	08/16/2016 0613	08/16/2016 1110
420-108932-66	16-90-ER-Elm-CF-064	Drinking Water	08/16/2016 0604	08/16/2016 1110
420-108932-67	16-90-ER-Elm-CFF-065	Drinking Water	08/16/2016 0605	08/16/2016 1110
420-108932-68	16-90-ER-Elm-CF-066	Drinking Water	08/16/2016 0604	08/16/2016 1110
420-108932-69	16-90-ER-Elm-CFF-067	Drinking Water	08/16/2016 0605	08/16/2016 1110
420-108932-70	16-90-ER-Elm-CF-068	Drinking Water	08/16/2016 0601	08/16/2016 1110
420-108932-71	16-90-ER-Elm-CFF-069	Drinking Water	08/16/2016 0602	08/16/2016 1110
420-108932-72	16-90-ER-Elm-CF-070	Drinking Water	08/16/2016 0601	08/16/2016 1110
420-108932-73	16-90-ER-Elm-CFF-071	Drinking Water	08/16/2016 0602	08/16/2016 1110
420-108932-74	16-90-ER-Elm-TL-072	Drinking Water	08/16/2016 0558	08/16/2016 1110
420-108932-75	16-90-ER-Elm-BF-073	Drinking Water	08/16/2016 0600	08/16/2016 1110
420-108932-76	16-90-ER-Elm-BF-074	Drinking Water	08/16/2016 0559	08/16/2016 1110
420-108932-77	16-90-ER-Elm-DW-075	Drinking Water	08/16/2016 0558	08/16/2016 1110
420-108932-78	16-90-ER-Elm-CF-076	Drinking Water	08/16/2016 0555	08/16/2016 1110
420-108932-79	16-90-ER-Elm-CFF-077	Drinking Water	08/16/2016 0555	08/16/2016 1110
420-108932-80	16-90-ER-Elm-CF-078	Drinking Water	08/16/2016 0555	08/16/2016 1110
420-108932-81	16-90-ER-Elm-CFF-079	Drinking Water	08/16/2016 0556	08/16/2016 1110
420-108932-82	16-90-ER-Elm-CF-080	Drinking Water	08/16/2016 0551	08/16/2016 1110
420-108932-83	16-90-ER-Elm-CFF-081	Drinking Water	08/16/2016 0552	08/16/2016 1110
420-108932-84	16-90-ER-Elm-CF-082	Drinking Water	08/16/2016 0551	08/16/2016 1110
420-108932-86	16-90-ER-Elm-CF-084	Drinking Water	08/16/2016 0548	08/16/2016 1110
420-108932-87	16-90-ER-Elm-CFF-085	Drinking Water	08/16/2016 0549	08/16/2016 1110
420-108932-88	16-90-ER-Elm-CF-086	Drinking Water	08/16/2016 0549	08/16/2016 1110
420-108932-89	16-90-ER-Elm-CFF-087	Drinking Water	08/16/2016 0549	08/16/2016 1110

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-SC-001
Lab Sample ID: 420-108932-1

Date Sampled: 08/16/2016 0050
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/22/2016 1951	
Prep Method: 200			Date Prepared:	08/18/2016 1545	
Lead	533 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-OT-002
Lab Sample ID: 420-108932-2

Date Sampled: 08/16/2016 0509
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/17/2016 2358	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	2.89	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-KF-003
Lab Sample ID: 420-108932-3

Date Sampled: 08/16/2016 0509
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0001	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	7.04	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-KF-004
Lab Sample ID: 420-108932-4

Date Sampled: 08/16/2016 0508
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/22/2016 1955		
Prep Method: 200			Date Prepared: 08/18/2016 1545		
Lead	6.34	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-005
Lab Sample ID: 420-108932-5

Date Sampled: 08/16/2016 0508
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0005	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	2.94	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-006
Lab Sample ID: 420-108932-6

Date Sampled: 08/16/2016 0510
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0015	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	11.3	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-007
Lab Sample ID: 420-108932-7

Date Sampled: 08/16/2016 0515
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0019	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	14.3	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-008
Lab Sample ID: 420-108932-8

Date Sampled: 08/16/2016 0516
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0023	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	9.28	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-009
Lab Sample ID: 420-108932-9

Date Sampled: 08/16/2016 0515
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 0026		
Prep Method: 200			Date Prepared: 08/17/2016 1315		
Lead	22.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-010
Lab Sample ID: 420-108932-10

Date Sampled: 08/16/2016 0516
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0030	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	1.69	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-011
Lab Sample ID: 420-108932-11

Date Sampled: 08/16/2016 0519
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0033	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	4.82	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-013
Lab Sample ID: 420-108932-13

Date Sampled: 08/16/2016 0519
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0037	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	13.0	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-014
Lab Sample ID: 420-108932-14

Date Sampled: 08/16/2016 0520
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0040	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	4.80	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-015
Lab Sample ID: 420-108932-15

Date Sampled: 08/16/2016 0522
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 0044		
Prep Method: 200			Date Prepared: 08/17/2016 1315		
Lead	12.8	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-016
Lab Sample ID: 420-108932-16

Date Sampled: 08/16/2016 0522
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0047	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	3.98	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-017
Lab Sample ID: 420-108932-17

Date Sampled: 08/16/2016 0523
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/22/2016 1958	
Prep Method: 200			Date Prepared:	08/18/2016 1545	
Lead	2450 g	ug/L	100	100	100

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-018
Lab Sample ID: 420-108932-18

Date Sampled: 08/16/2016 0523
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0058	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	4.07	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-019
Lab Sample ID: 420-108932-19

Date Sampled: 08/16/2016 0524
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0102	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	2.35	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-OT-020
Lab Sample ID: 420-108932-20

Date Sampled: 08/16/2016 0526
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0105	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	7.17	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-OT-021
Lab Sample ID: 420-108932-21

Date Sampled: 08/16/2016 0527
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0109	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	4.08	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-OT-022
Lab Sample ID: 420-108932-22

Date Sampled: 08/16/2016 0529
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0112	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	3.11	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-DW-023
Lab Sample ID: 420-108932-23

Date Sampled: 08/16/2016 0530
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0116	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	3.02	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-024
Lab Sample ID: 420-108932-24

Date Sampled: 08/16/2016 0531
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 0119	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	9.22	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-025
Lab Sample ID: 420-108932-25

Date Sampled: 08/16/2016 0532
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1055	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	4.22	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-WF-026
Lab Sample ID: 420-108932-26

Date Sampled: 08/16/2016 0532
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1059	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	7.76	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-027
Lab Sample ID: 420-108932-27

Date Sampled: 08/16/2016 0536
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1102	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	9.71	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-028
Lab Sample ID: 420-108932-28

Date Sampled: 08/16/2016 0535
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 1106		
Prep Method: 200			Date Prepared: 08/17/2016 1315		
Lead	8.81	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-088
Lab Sample ID: 420-108932-29

Date Sampled: 08/16/2016 0534
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 1109		
Prep Method: 200			Date Prepared: 08/17/2016 1315		
Lead	16.7 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-089
Lab Sample ID: 420-108932-30

Date Sampled: 08/16/2016 0534
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1113	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	1.52	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-090
Lab Sample ID: 420-108932-31

Date Sampled: 08/16/2016 0535
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1116	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	1.84	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-091
Lab Sample ID: 420-108932-32

Date Sampled: 08/16/2016 0539
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1120	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	21.3 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-092
Lab Sample ID: 420-108932-33

Date Sampled: 08/16/2016 0540
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1123	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	3.59	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-093
Lab Sample ID: 420-108932-34

Date Sampled: 08/16/2016 0541
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1134	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	10.4	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-094
Lab Sample ID: 420-108932-35

Date Sampled: 08/16/2016 0542
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1137	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	3.08	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-095
Lab Sample ID: 420-108932-36

Date Sampled: 08/16/2016 0540
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 1141		
Prep Method: 200			Date Prepared: 08/17/2016 1315		
Lead	8.30	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-096
Lab Sample ID: 420-108932-37

Date Sampled: 08/16/2016 0541
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1144	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	3.69	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-097
Lab Sample ID: 420-108932-38

Date Sampled: 08/16/2016 0539
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1148	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	5.21	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-098
Lab Sample ID: 420-108932-39

Date Sampled: 08/16/2016 0540
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 1151		
Prep Method: 200			Date Prepared: 08/17/2016 1315		
Lead	6.80	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-038
Lab Sample ID: 420-108932-40

Date Sampled: 08/16/2016 0623
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1155	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	4.60	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-039
Lab Sample ID: 420-108932-41

Date Sampled: 08/16/2016 0622
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1158	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	9.60	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-040
Lab Sample ID: 420-108932-42

Date Sampled: 08/16/2016 0622
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1202	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	8.70	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-041
Lab Sample ID: 420-108932-43

Date Sampled: 08/16/2016 0623
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 1205		
Prep Method: 200			Date Prepared: 08/17/2016 1315		
Lead	5.61	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-042
Lab Sample ID: 420-108932-44

Date Sampled: 08/16/2016 0619
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/22/2016	2002	
Prep Method: 200			Date Prepared: 08/18/2016	1545	
Lead	9.94	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-043
Lab Sample ID: 420-108932-45

Date Sampled: 08/16/2016 0620
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 1216		
Prep Method: 200			Date Prepared: 08/17/2016 1315		
Lead	8.89	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-044
Lab Sample ID: 420-108932-46

Date Sampled: 08/16/2016 0619
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1230	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	12.0	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-045
Lab Sample ID: 420-108932-47

Date Sampled: 08/16/2016 0620
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1233	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	5.65	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-046
Lab Sample ID: 420-108932-48

Date Sampled: 08/16/2016 0617
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1237	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	13.4	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-047
Lab Sample ID: 420-108932-49

Date Sampled: 08/16/2016 0617
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1240	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	10.2	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-048
Lab Sample ID: 420-108932-50

Date Sampled: 08/16/2016 0616
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1244	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	8.69	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-049
Lab Sample ID: 420-108932-51

Date Sampled: 08/16/2016 0617
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1247	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	4.32	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-050
Lab Sample ID: 420-108932-52

Date Sampled: 08/16/2016 0614
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1258	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	7.08	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-051
Lab Sample ID: 420-108932-53

Date Sampled: 08/16/2016 0615
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1301	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	4.65	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-052
Lab Sample ID: 420-108932-54

Date Sampled: 08/16/2016 0614
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1305	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	8.48	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-053
Lab Sample ID: 420-108932-55

Date Sampled: 08/16/2016 0615
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1308	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	15.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-DW-054
Lab Sample ID: 420-108932-56

Date Sampled: 08/16/2016 0612
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1312	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	6.71	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-055
Lab Sample ID: 420-108932-57

Date Sampled: 08/16/2016 0610
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1315	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	23.0 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-056
Lab Sample ID: 420-108932-58

Date Sampled: 08/16/2016 0611
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1319	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	7.66	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-057
Lab Sample ID: 420-108932-59

Date Sampled: 08/16/2016 0610
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1322	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	8.84	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-058
Lab Sample ID: 420-108932-60

Date Sampled: 08/16/2016 0611
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1326	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	8.06	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-059
Lab Sample ID: 420-108932-61

Date Sampled: 08/16/2016 0607
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1330	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	6.32	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-060
Lab Sample ID: 420-108932-62

Date Sampled: 08/16/2016 0608
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1340	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	2.16	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-061
Lab Sample ID: 420-108932-63

Date Sampled: 08/16/2016 0606
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1344	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	7.16	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-062
Lab Sample ID: 420-108932-64

Date Sampled: 08/16/2016 0607
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 1347		
Prep Method: 200			Date Prepared: 08/17/2016 1315		
Lead	5.70	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-OT-063
Lab Sample ID: 420-108932-65

Date Sampled: 08/16/2016 0613
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1351	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	28.2 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-064
Lab Sample ID: 420-108932-66

Date Sampled: 08/16/2016 0604
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1405	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	7.25	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-065
Lab Sample ID: 420-108932-67

Date Sampled: 08/16/2016 0605
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1408	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	5.38	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-066
Lab Sample ID: 420-108932-68

Date Sampled: 08/16/2016 0604
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1412	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	5.30	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-067
Lab Sample ID: 420-108932-69

Date Sampled: 08/16/2016 0605
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1422	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	3.65	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-068
Lab Sample ID: 420-108932-70

Date Sampled: 08/16/2016 0601
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1426	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	8.86	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-069
Lab Sample ID: 420-108932-71

Date Sampled: 08/16/2016 0602
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1429	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	7.22	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-070
Lab Sample ID: 420-108932-72

Date Sampled: 08/16/2016 0601
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1433	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	7.53	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-071
Lab Sample ID: 420-108932-73

Date Sampled: 08/16/2016 0602
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1436	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	5.11	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-TL-072
Lab Sample ID: 420-108932-74

Date Sampled: 08/16/2016 0558
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1440	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	5.18	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-073
Lab Sample ID: 420-108932-75

Date Sampled: 08/16/2016 0600
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1443	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	8.11	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-BF-074
Lab Sample ID: 420-108932-76

Date Sampled: 08/16/2016 0559
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1447	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	4.37	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-DW-075
Lab Sample ID: 420-108932-77

Date Sampled: 08/16/2016 0558
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1451	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	3.21	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-076
Lab Sample ID: 420-108932-78

Date Sampled: 08/16/2016 0555
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1454	
Prep Method: 200			Date Prepared:	08/17/2016 1315	
Lead	9.17	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-077
Lab Sample ID: 420-108932-79

Date Sampled: 08/16/2016 0555
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1815	
Prep Method: 200			Date Prepared:	08/18/2016 1005	
Lead	3.40	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-078
Lab Sample ID: 420-108932-80

Date Sampled: 08/16/2016 0555
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1829	
Prep Method: 200			Date Prepared:	08/18/2016 1005	
Lead	8.29	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-079
Lab Sample ID: 420-108932-81

Date Sampled: 08/16/2016 0556
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1832	
Prep Method: 200			Date Prepared:	08/18/2016 1005	
Lead	4.68	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-080
Lab Sample ID: 420-108932-82

Date Sampled: 08/16/2016 0551
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1836	
Prep Method: 200			Date Prepared:	08/18/2016 1005	
Lead	21.9 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-081
Lab Sample ID: 420-108932-83

Date Sampled: 08/16/2016 0552
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1839	
Prep Method: 200			Date Prepared:	08/18/2016 1005	
Lead	8.92	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-082
Lab Sample ID: 420-108932-84

Date Sampled: 08/16/2016 0551
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 08/18/2016 1843		
Prep Method: 200			Date Prepared: 08/18/2016 1005		
Lead	21.6 g	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-084
Lab Sample ID: 420-108932-86

Date Sampled: 08/16/2016 0548
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1854	
Prep Method: 200			Date Prepared:	08/18/2016 1005	
Lead	8.96	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-085
Lab Sample ID: 420-108932-87

Date Sampled: 08/16/2016 0549
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1857	
Prep Method: 200			Date Prepared:	08/18/2016 1005	
Lead	8.45	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CF-086
Lab Sample ID: 420-108932-88

Date Sampled: 08/16/2016 0549
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1900	
Prep Method: 200			Date Prepared:	08/18/2016 1005	
Lead	7.52	ug/L	1.00	1.00	1.0

Seth Armstrong
Rockland BOCES
65 Parrott Road, B-4
West Nyack, NY 10994

Job Number: 420-108932-1
Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Client Sample ID: 16-90-ER-Elm-CFF-087
Lab Sample ID: 420-108932-89

Date Sampled: 08/16/2016 0549
Date Received: 08/16/2016 1110
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	08/18/2016 1904	
Prep Method: 200			Date Prepared:	08/18/2016 1005	
Lead	1.99	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Rockland BOCES

Job Number:

Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards

Certification Information

Client: Rockland BOCES

Job Number:

Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalien Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Rockland BOCES

Job Number:

Sdg Number: East Ramapo CSD 2016-090 - Elmwood ES

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.



CHAIN OF CUSTODY

Lab Name **EnviroTest Laboratories**
Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)

108132

PROJECT REFERENCE East Ramapo CSD 2016-090		PROJECT NO.	PROJECT LOCATION Elmwood ES	MATRIX TYPE	REQUIRED ANALYSES						PAGE 1 of 6			
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER SPECIFY	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
CLIENT (SITE) PM John Gulino/Keith Lewandosky		CLIENT PHONE 845-627-4775	CLIENT FAX	COMPOSITE (C) OR GRAB (G) INDICATE	1	1	1	1	1	1	1	1	1	
CLIENT NAME Rockland BOCES		i.gulino@boces.org/ s.lewandosky@boces.org/ k.lewand@boces.org		AQUEOUS (WATER)	1	1	1	1	1	1	1	1	1	
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994		SAMPLE IDENTIFICATION		SOLID OR SEMISOLID	1	1	1	1	1	1	1	1	1	
COMPANY CONTRACTING THIS WORK (if applicable)		DATE	TIME	D (Drinking Water) or W (Waste Water) Indicate	NUMBER OF CONTAINERS SUBMITTED								REMARKS	
8/16/2016	5:04	16-90-ER-Elm-SC-001		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:09	16-90-ER-Elm-OT-002		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:09	16-90-ER-Elm-KF-003		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:08	16-90-ER-Elm-KF-004		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:08	16-90-ER-Elm-BF-005		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:10	16-90-ER-Elm-BF-006		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:15	16-90-ER-Elm-CF-007		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:16	16-90-ER-Elm-CFF-008		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:15	16-90-ER-Elm-CF-009		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:16	16-90-ER-Elm-CFF-010		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:14	16-90-ER-Elm-CF-011		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:19	16-90-ER-Elm-CFF-012 - Not Sampled		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:19	16-90-ER-Elm-CF-013		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:20	16-90-ER-Elm-CFF-014		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
8/16/2016	5:22	16-90-ER-Elm-CF-015		S	1	1	1	1	1	1	1	1	1	Lead (DW 200.8)
RELINQUISHED BY (SIGNATURE)		DATE	TIME	COMPDATE	RECEIVED BY (SIGNATURE)								TIME	
[Signature]		8/16/16	1030		[Signature]								8:10	
SAMPLED BY (SIGNATURE)		DATE	TIME	COMPDATE	RECEIVED BY (SIGNATURE)								TIME	
[Signature]		8/16	8:10		[Signature]								8:10	
RELINQUISHED BY (SIGNATURE)		DATE	TIME	COMPDATE	RECEIVED BY (SIGNATURE)								TIME	
[Signature]		8/16	8:10		[Signature]								8:10	
RECEIVED FOR LABORATORY BY (SIGNATURE)				DATE	TIME	CUSTOMER INTACT	Cooler Temp(C)	LABORATORY REMARKS: ICE (Y, N) PH CL2						Revised by
[Signature]				8/16/16	1030	YES	25.6	[Signature]						



CHAIN OF CUSTODY

Lab Name **EnviroTest Laboratories**
 Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)
105932

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO. Elmwood ES	MATRIX TYPE OTHER SPECIFY	REQUIRED ANALYSES 40ml Vials HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid Liter Plastic 250ml Plastic Terra Core Other Other	PAGE 2 of 6
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	PROJECT LOCATION TOWN	TURNAROUND TIME	
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX	NORMAL <input checked="" type="checkbox"/>	QUICK <input type="checkbox"/>
CLIENT NAME Rockland BOCES	igulino@rboces.org/ sarmstrong@rboces.org/ klewand@rboces.org		VERBAL <input type="checkbox"/>	
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994			# OF COOLERS	REMARKS
COMPANY CONTRACTING THIS WORK (IF APPLICABLE)				

SAMPLE	SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G) INDICATE	ACQUEOUS (WATER)	SOLID OR SEMISOLID	OTHER SPECIFY	Total # of Containers	REQUIRED ANALYSES							# OF COOLERS	REMARKS
	DATE	TIME						40ml Vials HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other		
8/16/2016	5:22	16-90-ER-Elm-BF-016		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:23	16-90-ER-Elm-BF-017		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:23	16-90-ER-Elm-BF-018		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:24	16-90-ER-Elm-BF-019		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:26	16-90-ER-Elm-OT-020		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:27	16-90-ER-Elm-OT-021		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:29	16-90-ER-Elm-OT-022		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:30	16-90-ER-Elm-DW-023		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:31	16-90-ER-Elm-BF-024		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:32	16-90-ER-Elm-BF-025		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:32	16-90-ER-Elm-WF-026		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:36	16-90-ER-Elm-CF-027		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:35	16-90-ER-Elm-CF-028		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:34	16-90-ER-Elm-CFF-088		S	D		1		1						Lead (DW 200.8)	
8/16/2016	5:34	16-90-ER-Elm-CF-089		S	D		1		1						Lead (DW 200.8)	

RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>	DATE 8/16/16	TIME 1030	RECEIVED BY (SIGNATURE)	COMP DATE	TIME
SAMPLED BY (SIGNATURE) <i>[Signature]</i>	DATE 8/16	TIME 8:10	RECEIVED BY (SIGNATURE)	COMP DATE	TIME
RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>	DATE 8/16	TIME 8:10	RECEIVED BY (SIGNATURE) <i>[Signature]</i>	COMP DATE 8/16/16	TIME 8:10

RECEIVED FOR LABORATORY BY (SIGNATURE) <i>[Signature]</i>	DATE 8/16/16	TIME 1030	CUSTOMER INTACT YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	Cooler Temp (C) 25.6	LABORATORY REMARKS: ICE (Y) <input checked="" type="checkbox"/> PH <input checked="" type="checkbox"/> CL2 <input type="checkbox"/>	Revised by
--	------------------------	---------------------	--	--------------------------------	---	------------



CHAIN OF CUSTODY

Lab Name **EnviroTest Laboratories**
 Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)
108932

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO. Eimwood ES	PROJECT LOCATION TOWN	MATRIX TYPE OTHER SPECIFY	REQUIRED ANALYSES	PAGE 3 of 6
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER			250ml Plastic Nitric Acid	TURNAROUND TIME
CLIENT (SITE) PM John Gullino/Keith Lewandosky	CLIENT PHONE 845-627-4775			250ml Plastic Sulfuric Acid	NORMAL <input checked="" type="checkbox"/>
CLIENT NAME Rockland BOCES	iqulino@rboces.org/ sarmstrong@rboces.org kiewando@rboces.org			Liter Amber HCl	QUICK <input type="checkbox"/>
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994				40ml Vials HCl	VERBAL <input type="checkbox"/>
COMPANY CONTRACTING THIS WORK (if applicable)				Total # of Containers	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED								REMARKS				
			Lead (DW 200.8)	Lead (DW 200.8)	Lead (DW 200.8)	Lead (DW 200.8)	Lead (DW 200.8)	Lead (DW 200.8)	Lead (DW 200.8)	Lead (DW 200.8)					
8/16/2016	5:35	16-90-ER-Eim-CFF-090	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	5:39	16-90-ER-Eim-CF-091	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	5:40	16-90-ER-Eim-CFF-092	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	5:41	16-90-ER-Eim-CF-093	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	5:42	16-90-ER-Eim-CFF-094	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	5:40	16-90-ER-Eim-CF-095	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	5:41	16-90-ER-Eim-CFF-096	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	5:39	16-90-ER-Eim-CF-097	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	5:40	16-90-ER-Eim-CFF-098	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	6:23	16-90-ER-Eim-CF-038	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	6:22	16-90-ER-Eim-CFF-039	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	6:22	16-90-ER-Eim-CF-040	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	6:23	16-90-ER-Eim-CFF-041	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	6:19	16-90-ER-Eim-CF-042	1	1	1	1	1	1	1	1	1	1	1	1	
8/16/2016	6:20	16-90-ER-Eim-CFF-043	1	1	1	1	1	1	1	1	1	1	1	1	

RELINQUISHED BY: SIGNATURE <i>[Signature]</i>	DATE 8/16/16	TIME 1030	COMPANY Eimwood ES	RECEIVED BY: SIGNATURE <i>[Signature]</i>	DATE 8/16	TIME 8:10
RELINQUISHED BY: SIGNATURE <i>[Signature]</i>	DATE 8/16/16	TIME 1030	COMPANY Eimwood ES	RECEIVED BY: SIGNATURE <i>[Signature]</i>	DATE 8/16	TIME 8:10
RELINQUISHED BY: SIGNATURE <i>[Signature]</i>	DATE 8/16/16	TIME 1030	COMPANY Eimwood ES	RECEIVED BY: SIGNATURE <i>[Signature]</i>	DATE 8-16-16	TIME 8:10

RECEIVED FOR LABORATORY BY: SIGNATURE *[Signature]* DATE 8/16/16 TIME 1030

LABORATORY REMARKS: ICE (Y/N) PH CL2 Cooler Temp(C): 25.6

Reviewed by _____



CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

105902

PROJECT REFERENCE East Ramapo CSD 2016-090		PROJECT NO. Elmwood ES	PROJECT LOCATION		MATRIX TYPE	REQUIRED ANALYSES		PAGE 1 of 6
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER SPECIFY	OTHER SPECIFY	Other	Other	TURNAROUND TIME
CLIENT (SITE) PM John Gulino/Keith Lewandosky		CLIENT PHONE 845-627-4775	CLIENT FAX	OTHER SPECIFY	OTHER SPECIFY	250ml Plastic	250ml Plastic	NORMAL X
CLIENT NAME Rockland BOCES		igulino@rboces.org/ sarmstrong@rboces.org klewandos@rboces.org		COMPOSITE (C) OR GRAB (G) INDICATE	COMPOSITE (C) OR GRAB (G) INDICATE	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	QUICK
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994		SAMPLE IDENTIFICATION		AOUCOUS (WATER)	AOUCOUS (WATER)	Liter Amber HCl	Liter Amber HCl	VERBAL
COMPANY CONTRACTING THIS WORK (If applicable)		DATE	TIME	DATE	TIME	40ml Vials HCl	Total # of Containers	# OF COOLERS
8/16/2016	6:19	16-90-ER-Elm-CF-044		S	D		1	Lead (DW 200.8)
8/16/2016	6:20	16-90-ER-Elm-CFF-045		S	D		1	Lead (DW 200.8)
8/16/2016	6:17	16-90-ER-Elm-CF-046		S	D		1	Lead (DW 200.8)
8/16/2016	6:17	16-90-ER-Elm-CFF-047		S	D		1	Lead (DW 200.8)
8/16/2016	6:16	16-90-ER-Elm-CF-048		S	D		1	Lead (DW 200.8)
8/16/2016	6:17	16-90-ER-Elm-CFF-049		S	D		1	Lead (DW 200.8)
8/16/2016	6:14	16-90-ER-Elm-BF-050		S	D		1	Lead (DW 200.8)
8/16/2016	6:15	16-90-ER-Elm-BF-051		S	D		1	Lead (DW 200.8)
8/16/2016	6:14	16-90-ER-Elm-BF-052		S	D		1	Lead (DW 200.8)
8/16/2016	6:15	16-90-ER-Elm-BF-053		S	D		1	Lead (DW 200.8)
8/16/2016	6:12	16-90-ER-Elm-DW-054		S	D		1	Lead (DW 200.8)
8/16/2016	6:10	16-90-ER-Elm-CF-055		S	D		1	Lead (DW 200.8)
8/16/2016	6:11	16-90-ER-Elm-CFF-056		S	D		1	Lead (DW 200.8)
8/16/2016	6:10	16-90-ER-Elm-CF-057		S	D		1	Lead (DW 200.8)
8/16/2016	6:11	16-90-ER-Elm-CFF-058		S	D		1	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY	REMARKS
<i>[Signature]</i>	8/16/16	10:30		<i>[Signature]</i>	8/16/16	8:10		
SAMPLE BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY	
<i>[Signature]</i>	8/16	8:10	E+R	<i>[Signature]</i>	8/16/16	8:10		
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	COMPANY	RECEIVED BY: (SIGNATURE)	DATE	TIME	COMPANY	
<i>[Signature]</i>	8/16	8:10	E+R	<i>[Signature]</i>	8/16/16	8:10		
RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER TEMP(C)	LABORATORY REMARKS:	ICE (Y/N) PH (Y/N)	RECEIVED BY:	
<i>[Signature]</i>	8/16/16	10:30	NO	25.6				



CHAIN OF CUSTODY

Lab Name **Enviro Test Laboratories**
 Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)
108932

PROJECT REFERENCE East Ramapo CSD 2016-090	PROJECT NO. Elimwood ES	PROJECT LOCATION Elimwood ES	MATRIX TYPE SOLID OR SEMISOLID	REQUIRED ANALYSES 40ml Vials HCl Liter Amber HCl 250ml Plastic Nitric Acid 250ml Plastic Sulfuric Acid Liter Plastic 250ml Plastic Terra Core Other Other	PAGES of 6
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER 845-627-4775	TOWN Rockland BOCES	OTHER SPECIFY	TURNAROUND TIME NORMAL X	
CLIENT (SITE) PM John Gulino/Keith Lewandosky	CLIENT PHONE 845-627-4775	CLIENT FAX 845-627-4775		QUICK	
CLIENT NAME Rockland BOCES	CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994	CLIENT EMAIL kgulino@rboces.org/ sarmstrong@rboces.org/ klewando@rboces.org		VERBAL	
COMPANY CONTRACTING THIS WORK (IF APPLICABLE)				#OF COOLERS	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	NUMBER OF CONTAINERS SUBMITTED								REMARKS	
				40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other		Other
8/16/2016	6:07	16-90-ER-Eim-CF-059	S	1	1								Lead (DW 200.8)
8/16/2016	6:08	16-90-ER-Eim-CFF-060	S	1	1								Lead (DW 200.8)
8/16/2016	6:06	16-90-ER-Eim-CF-061	S	1	1								Lead (DW 200.8)
8/16/2016	6:07	16-90-ER-Eim-CFF-062	S	1	1								Lead (DW 200.8)
8/16/2016	6:13	16-90-ER-Eim-OT-063	S	1	1								Lead (DW 200.8)
8/16/2016	6:04	16-90-ER-Eim-CF-064	S	1	1								Lead (DW 200.8)
8/16/2016	6:05	16-90-ER-Eim-CFF-065	S	1	1								Lead (DW 200.8)
8/16/2016	6:04	16-90-ER-Eim-CF-066	S	1	1								Lead (DW 200.8)
8/16/2016	6:05	16-90-ER-Eim-CFF-067	S	1	1								Lead (DW 200.8)
8/16/2016	6:01	16-90-ER-Eim-CF-068	S	1	1								Lead (DW 200.8)
8/16/2016	6:07	16-90-ER-Eim-CFF-069	S	1	1								Lead (DW 200.8)
8/16/2016	6:01	16-90-ER-Eim-CF-070	S	1	1								Lead (DW 200.8)
8/16/2016	6:02	16-90-ER-Eim-CFF-071	S	1	1								Lead (DW 200.8)
8/16/2016	5:58	16-90-ER-Eim-TL-072	S	1	1								Lead (DW 200.8)
8/16/2016	6:00	16-90-ER-Eim-BF-073	S	1	1								Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>	DATE 8/16/16	TIME 10:30	RECEIVED BY: (SIGNATURE) <i>[Signature]</i>	DATE 8/16/16	TIME 8:10
COMPANY EIR			RECEIVED BY: (SIGNATURE) <i>[Signature]</i>	DATE 8-16-16	TIME 8:10

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE **8/16/16** TIME **10:30**

LABORATORY REMARKS: ICE Y N PH **25.6** Revisited by _____



CHAIN OF CUSTODY

Lab Name: **EnviroTest Laboratories**
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

REPORT# (Lab Use Only)

108932

PROJECT REFERENCE East Ramapo CSD 2016-090		PROJECT NO.	PROJECT LOCATION Elmwood ES	MATRIX TYPE	REQUIRED ANALYSES		PAGE 6 of 6
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER SPECIFY	40ml Vials HCl	250ml Plastic Nitric Acid	TURNAROUND TIME
CLIENT (SITE) PW John Gulino/Keith Lewandosky		CLIENT PHONE 845-627-4775	CLIENT FAX	ACQUEOUS (WATER)	Liter Amber HCl	250ml Plastic Sulfuric Acid	NORMAL <input checked="" type="checkbox"/> X
CLIENT NAME Rockland BOCES		jgulino@rboces.org/ sarmstrong@rboces.org klewando@rboces.org		SOLID OR SEMISOLID	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	QUICK
CLIENT ADDRESS 65 Parrott Road, B-4, West Nyack, NY 10994		COMPOSITE (C) OR GRAB (G) INDICATE		D (Drinking Water) or W (Waste Water) Indicate	Liter Amber HCl	250ml Plastic Sulfuric Acid	VERBAL
COMPANY CONTRACTING THIS WORK (IF APPLICABLE)		SAMPLE IDENTIFICATION		OTHER SPECIFY	40ml Vials HCl	250ml Plastic Sulfuric Acid	# OF COOLERS
DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME
8/16/2016	5:54	16-90-ER-Elm-BF-074		1		1	Lead (DW 200.8)
8/16/2016	5:58	16-90-ER-Elm-DW-075		1		1	Lead (DW 200.8)
8/16/2016	5:55	16-90-ER-Elm-CF-076		1		1	Lead (DW 200.8)
8/16/2016	5:55	16-90-ER-Elm-CFF-077		1		1	Lead (DW 200.8)
8/16/2016	5:55	16-90-ER-Elm-CF-078		1		1	Lead (DW 200.8)
8/16/2016	5:56	16-90-ER-Elm-CFF-079		1		1	Lead (DW 200.8)
8/16/2016	5:51	16-90-ER-Elm-CF-080		1		1	Lead (DW 200.8)
8/16/2016	5:52	16-90-ER-Elm-CFF-081		1		1	Lead (DW 200.8)
8/16/2016	5:51	16-90-ER-Elm-CF-082		1		1	Lead (DW 200.8)
8/16/2016	5:48	16-90-ER-Elm-CFF-083	Not Sampled	1		1	Lead (DW 200.8)
8/16/2016	5:48	16-90-ER-Elm-CF-084		1		1	Lead (DW 200.8)
8/16/2016	5:49	16-90-ER-Elm-CFF-085		1		1	Lead (DW 200.8)
8/16/2016	5:49	16-90-ER-Elm-CF-086		1		1	Lead (DW 200.8)
8/16/2016	5:49	16-90-ER-Elm-CFF-087		1		1	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE) <i>Debra Bayer</i>		COMPANY EIR	DATE 8/16/16	TIME 10:39	RECEIVED BY: (SIGNATURE)	COMPDATE	TIME
SAMPLED BY: (SIGNATURE) <i>John Gulino</i>		COMPANY EIR	DATE 8/16	TIME 8:10	RECEIVED BY: (SIGNATURE)	COMPDATE	TIME
RELINQUISHED BY: (SIGNATURE) <i>John Gulino</i>		COMPANY EIR	DATE 8/16	TIME 8:10	RECEIVED BY: (SIGNATURE) <i>John Gulino</i>	COMPDATE	TIME 8-16-16 8:10
RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>John Gulino</i>		DATE 8/16/16	TIME 10:30	CUSTOMER INTACT YES <input checked="" type="checkbox"/> NO	COOLER TEMP (C) 25.6	LABORATORY REMARKS: ICE (Y/N) <input checked="" type="checkbox"/> PH <input checked="" type="checkbox"/> CL2	

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Rockland BOCES

Job Number: 420-108932-1

SDG Number: East Ramapo CSD 2016-090 - Elmwood ES

Login Number: 108932

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	25.6 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling. AE 8/16/16
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	