

# St Leonard Elementary School

## 2023-2024 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date and time Water Last Used	Date and Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 5.5 ppb AL?
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	1	DF	fountain in cafeteria	FD	4/23/24 8:00pm	4/24/24 6:33am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	2	DF	bottle filler outside gym	FD	4/23/24 8:00pm	4/24/24 6:34am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	2B	DF	bottle filler fountain outside of gym	FD	4/24/24 8:00pm	4/25/24 6:27am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	3	DF	fountain in gym	FD	4/23/24 8:00pm	4/24/24 6:35am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	4	DF	left fountain by 112	FD	4/23/24 8:00pm	4/24/24 6:38am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	5	DF	right fountain by 112	FD	4/23/24 8:00pm	4/24/24 6:38am	5/2/24	<1.0	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	6	DF	Bottle filler outside B 05	FD	4/23/24 8:00pm	4/24/24 6:35am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	6B	DF	Bottle filler fountain outside B 05	FD	4/24/24 8:00pm	4/25/24 6:32am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	7	DF	fountain by B 06	FD	4/23/24 8:00pm	4/24/24 6:33am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	8	NO	faucet in nurse room	FD	4/23/24 8:00pm	4/24/24 6:21am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	9	CR	faucet in office work room	FD	4/23/24 8:00pm	4/24/24 6:20am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	10	CR	closest faucet in 130	FD	4/23/24 8:00pm	4/24/24 6:25am	5/2/24	1.7	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	11	CR	far faucet in 130	FD	4/24/24 8:00pm	4/25/24 6:22am	5/2/24	1.9	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b12	CF	bubbler in 128	FD	4/24/24 8:00pm	4/25/24 6:23am	5/2/24	<1.0	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	13	CS	faucet in 128	FD	4/23/24 8:00pm	4/24/24 6:26am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	14	TL	faucet in staff lounge	FD	4/23/24 8:00pm	4/24/24 6:27am	5/2/24	1.3	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	15	KS	left faucet in kitchen	FD	4/23/24 8:00pm	4/24/24 6:29am	5/2/24	5.1	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	16	KS	right faucet in kitchen	FD	4/24/24 8:00pm	4/25/24 6:25am	5/2/24	9.7	Yes
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	16	KS	right faucet in kitchen	Flush	6/12/24	6/12/24	6/14/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	17	KS	solo faucet, 2 compartment sink	FD	4/23/24 8:00pm	4/24/24 6:30am	5/2/24	3.9	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b18	CF	bubbler room 127	FD	4/24/24 8:00pm	4/25/24 6:28am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	19	CS	faucet in 127	FD	4/23/24 8:00pm	4/24/24 6:36am	5/2/24	<1.0	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b20	CF	bubbler in 126	FD	4/24/24 8:00pm	4/25/24 6:29am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	21	cs	faucet in 126	FD	4/23/24 8:00pm	4/24/24 6:37am	5/2/24	1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b22	CF	bubbler in 125	FD	4/24/24 8:00pm	4/25/24 6:30am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	23	CS	faucet in 125	FD	4/23/24 8:00pm	4/24/24 6:37am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	24	CR	faucet outside 125	FD	4/23/24 8:00pm	4/24/24 6:38am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b25	CF	bubbler in 124	FD	4/24/24 8:00pm	4/25/24 6:31am	5/2/24	1.7	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	26	CS	faucet in 124	FD	4/23/24 8:00pm	4/24/24 6:39am	5/2/24	2.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b27	CF	bubbler in 123	FD	4/24/24 8:00pm	4/25/24 6:32am	5/2/24	1.1	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	28	CS	faucet in 123	FD	4/23/24 8:00pm	4/24/24 6:40am	5/2/24	1.9	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	29	TL	faucet in media workroom	FD	4/23/24 8:00pm	4/24/24 6:50am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b30	CF	bubbler in 122	FD	4/24/24 8:00pm	4/25/24 6:34am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	31	CS	faucet in 122	FD	4/23/24 8:00pm	4/24/24 6:42am	5/2/24	20.5	Yes
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b32	CF	bubbler in 121	FD	4/24/24 8:00pm	4/25/24 6:35am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	33	CS	faucet in 121	FD	4/23/24 8:00pm	4/24/24 6:43am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b34	CF	bubbler in 120	FD	4/24/24 8:00pm	4/25/24 6:36am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	35	CS	faucet in 120	FD	4/23/24 8:00pm	4/24/24 6:44am	5/2/24	<1.0	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b36	CF	bubbler in 119	FD	4/24/24 8:00pm	4/25/24 6:37am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	37	CS	faucet in 119	FD	4/23/24 8:00pm	4/24/24 6:45am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b38	CF	bubbler in 118	FD	4/24/24 8:00pm	4/25/24 6:39am	5/2/24	1.1	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	39	CS	faucet in 118	FD	4/23/24 8:00pm	4/24/24 6:46am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	40	CR	faucet between 120	FD	4/23/24 8:00pm	4/24/24 6:42am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b41	CF	bubbler in 117	FD	4/24/24 8:00pm	4/25/24 6:31am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	42	CS	faucet in 117	FD	4/23/24 8:00pm	4/24/24 6:42am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b43	CF	bubbler in 116	FD	4/24/24 8:00pm	4/25/24 6:31am	5/2/24	<1.0	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	44	CS	faucet in 116	FD	4/23/24 8:00pm	4/24/24 6:27am	5/2/24	1.4	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b45	CF	bubbler in 115	FD	4/24/24 8:00pm	4/25/24 6:31am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	46	CS	faucet in 115	FD	4/23/24 8:00pm	4/24/24 6:26am	5/2/24	2.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b47	CF	bubbler in 114	FD	4/24/24 8:00pm	4/25/24 6:30am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	48	CS	faucet in 114	FD	4/23/24 8:00pm	4/24/24 6:24am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b49	CF	bubbler in 113	FD	4/24/24 8:00pm	4/25/24 6:30am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	50	CS	faucet in 113	FD	4/23/24 8:00pm	4/24/24 6:24am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	51	CR	faucet between 115	FD	4/23/24 8:00pm	4/24/24 6:26am	5/2/24	1.4	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b52	CF	bubbler in 108	FD	4/24/24 8:00pm	4/25/24 6:28am	5/2/24	1.2	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	53	CS	faucet in 108	FD	4/23/24 8:00pm	4/24/24 6:22am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b54	CF	bubbler in 107	FD	4/24/24 8:00pm	4/25/24 6:27am	5/2/24	1.2	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	55	CS	faucet in 107	FD	4/23/24 8:00pm	4/24/24 6:22am	5/2/24	1.9	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b56	CF	bubbler in 101	FD	4/24/24 8:00pm	4/25/24 6:32am	5/2/24	1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	57	CS	faucet in 101	FD	4/23/24 8:00pm	4/24/24 6:18am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b58	CF	bubbler in 102	FD	4/24/24 8:00pm	4/25/24 6:34am	5/2/24	1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	59	CS	faucet in 102	FD	4/23/24 8:00pm	4/24/24 6:20am	5/2/24	1.3	No



Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b60	CF	bubbler in 133	FD	4/24/24 8:00pm	4/25/24 6:25am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	61	CS	faucet in 133	FD	4/23/24 8:00pm	4/24/24 6:21am	5/2/24	1.1	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	b62	CF	bubbler in 134	FD	4/24/24 8:00pm	4/25/24 6:26am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	63	CS	faucet in 134	FD	4/23/24 8:00pm	4/24/24 6:21am	5/2/24	2.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	b64	CF	bubbler in B10	FD	4/24/24 8:00pm	4/25/24 6:40am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	65	CS	faucet in B10	FD	4/23/24 8:00pm	4/24/24 6:36am	5/2/24	1.4	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	b66	CF	bubbler in B09	FD	4/24/24 8:00pm	4/25/24 6:39am	5/2/24	1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower		CS	faucet in B09	FD	4/23/24 8:00pm	4/24/24 6:35am	5/2/24	1.4	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower		CF	bubbler in B08	FD	4/24/24 8:00pm	4/25/24 6:39am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower		CS	faucet in B08	FD	4/23/24 8:00pm	4/24/24 6:35am	5/2/24	1.9	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower		CF	bubbler in B07	FD	4/24/24 8:00pm	4/25/24 6:38am	5/2/24	1.2	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	71	CS	faucet in B07	FD	4/23/24 8:00pm	4/24/24 6:34am	5/2/24	2.4	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	b72	CF	bubbler in B06	FD	4/24/24 8:00pm	4/25/24 6:38am	5/2/24	1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	73	CS	faucet in B06	FD	4/23/24 8:00pm	4/24/24 6:34am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	74	CR	faucet between B08	FD	4/23/24 8:00pm	4/24/24 6:36am	5/2/24	1.3	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	b75	CF	bubbler in B05	FD	4/24/24 8:00pm	4/25/24 6:35am	5/2/24	<1.0	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	76	CS	faucet in B05	FD	4/23/24 8:00pm	4/24/24 6:31am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	b77	CF	bubbler in B04	FD	4/24/24 8:00pm	4/25/24 6:34am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	78	CS	faucet in B04	FD	4/23/24 8:00pm	4/24/24 6:31am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	b79	CF	bubbler in B03	FD	4/24/24 8:00pm	4/25/24 6:34am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	80	CS	faucet in B03	FD	4/23/24 8:00pm	4/24/24 6:30am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	b81	CF	bubbler in B02	FD	4/24/24 8:00pm	4/25/24 6:33am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	82	CS	faucet in B02	FD	4/23/24 8:00pm	4/24/24 6:30am	5/2/24	5.5	Yes
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	b83	CF	bubbler in B01	FD	4/24/24 8:00pm	4/25/24 6:35am	5/2/24	1.2	No

Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	84	CS	Faucet in B01	FD	4/23/24 8:00pm	4/24/24 6:29am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Lower	85	CR	faucet between B03	FD	4/23/24 8:00pm	4/24/24 6:29am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	86	DF	fountain outside by black top	FD	4/23/24 8:00pm	4/24/24 6:32am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	87	IM	ice machine in health room	FD	4/23/24 8:00pm	4/24/24 6:32am	5/2/24	<1.0	No
Water Testing Laboratory of MD	St Leonard Elementary School	6/11/24	Main	89	DF	Water fountain in 102	FD	4/23/24 8:00pm	4/24/24 6:30am	5/2/24	2.5	No