

Windy Hill Elementary School

2023-2024 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date and Time Water Last Used	Date and Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 5.5 ppb AL?
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	1a	DF	bottle filler fountain past main office	FD	5/15/24 8:00pm	5/16/24 6:23am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	1b	DF	bottle filler past main office	FD	5/14/24 8:00pm	5/15/24 6:15am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	2	DF	fountain between 27 and 46	FD	5/14/24 8:00pm	5/15/24 6:16am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	3a	DF	Bottle Filler outside gym	FD	5/15/24 8:00pm	5/16/24 6:24am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	3b	DF	Bottle Filler Bubbler outside gym	FD	5/14/24 8:00pm	5/15/24 6:17am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	4	DF	fountain across from 47	FD	5/14/24 8:00pm	5/15/24 6:18am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	5	DF	fountain across from 69	FD	5/14/24 8:00pm	5/15/24 6:15am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	6	DF	fountain in gym	FD	5/14/24 8:00pm	5/15/24 6:16am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	7	DF	fountain in cafeteria	FD	5/14/24 8:00pm	5/15/24 6:17am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	B8	CF	bubbler in 24	FD	5/15/24 8:00pm	5/16/24 6:25am	05/24/2024	1.8	No

Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	9	CS	faucet in 24	FD	5/14/24 8:00pm	5/15/24 6:19am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	B10	CF	bubbler in 25	FD	5/15/24 8:00pm	5/16/24 6:26am	05/24/2024	3.6	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	11	CS	faucet in 25	FD	5/14/24 8:00pm	5/15/24 6:20am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	B12	CF	bubbler in 26	FD	5/15/24 8:00pm	5/16/24 6:27am	05/24/2024	1.5	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	13	CS	faucet in 26	FD	5/14/24 8:00pm	5/15/24 6:21am	05/24/2024	1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	B14	CF	bubbler in 27	FD	5/15/24 8:00pm	5/16/24 6:28am	05/24/2024	2.3	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	15	CS	faucet in 27	FD	5/14/24 8:00pm	5/15/24 6:22am	05/24/2024	1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	B16	CF	bubbler in 42	FD	5/15/24 8:00pm	5/16/24 6:29am	05/24/2024	2.2	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	17	CS	faucet in 42	FD	5/14/24 8:00pm	5/15/24 6:23am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	B18	CF	bubbler in 43	FD	5/15/24 8:00pm	5/16/24 6:30am	05/24/2024	1.4	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	19	CS	faucet in 43	FD	5/14/24 8:00pm	5/15/24 6:24am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	20	CF	bubbler in 44	FD	5/15/24 8:00pm	5/16/24 6:31am	05/24/2024	1.5	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	21	CS	faucet in 44	FD	5/14/24 8:00pm	5/15/24 6:25am	05/24/2024	<1.0	No

Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	22	CF	bubbler in 45	FD	5/15/24 8:00pm	5/16/24 6:32am	05/24/2024	1.2	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	23	CS	faucet in 45	FD	5/14/24 8:00pm	5/15/24 6:26am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	24	CF	bubbler in 46	FD	5/15/24 8:00pm	5/16/24 6:33am	05/24/2024	1.4	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	25	CS	faucet in 46	FD	5/14/24 8:00pm	5/15/24 6:27am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	26	CR	faucet in 29	FD	5/14/24 8:00pm	5/15/24 6:28am	05/24/2024	2.6	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	27	CF	bubbler in 47	FD	5/15/24 8:00pm	5/16/24 6:34am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	28	CS	faucet in 47	FD	5/14/24 8:00pm	5/15/24 6:29am	05/24/2024	1.2	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	29	CF	bubbler in 48	FD	5/15/24 8:00pm	5/16/24 6:35am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	30	CS	faucet in 48	FD	5/14/24 8:00pm	5/15/24 6:30am	05/24/2024	1.2	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	31	CF	bubbler in 49	FD	5/15/24 8:00pm	5/16/24 6:36am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	32	CS	faucet in 49	FD	5/14/24 8:00pm	5/15/24 6:31am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	33	CF	bubbler in 50	FD	5/15/24 8:00pm	5/16/24 6:37am	05/24/2024	1.9	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	34	CS	faucet in 50	FD	5/14/24 8:00pm	5/15/24 6:32am	05/24/2024	<1.0	No

Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	35	CF	bubbler in 51	FD	5/15/24 8:00pm	5/16/24 6:38am	05/24/2024	1.2	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	36	CS	faucet in 51	FD	5/14/24 8:00pm	5/15/24 6:33am	05/24/2024	1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	37	CF	bubbler in 201	FD	5/15/24 8:00pm	5/16/24 6:39am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	38	CS	faucet in 201	FD	5/14/24 8:00pm	5/15/24 6:34am	05/24/2024	1.2	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	39	CF	bubbler in 202	FD	5/15/24 8:00pm	5/16/24 6:40am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	40	CS	faucet in 202	FD	5/14/24 8:00pm	5/15/24 6:35am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	41	CF	bubbler in 60	FD	5/15/24 8:00pm	5/16/24 6:24am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	42	CS	faucet in 60	FD	5/14/24 8:00pm	5/15/24 6:18am	05/24/2024	1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	43	CF	bubbler in 70	FD	5/15/24 8:00pm	5/16/24 6:25am	05/24/2024	2.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	44	CS	faucet in 70	FD	5/14/24 8:00pm	5/15/24 6:19am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	45	CF	bubbler in 69	FD	5/15/24 8:00pm	5/16/24 6:26am	05/24/2024	2.3	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	46	CS	faucet in 69	FD	5/14/24 8:00pm	5/15/24 6:20am	05/24/2024	1.8	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	47	CF	bubbler in 72	FD	5/15/24 8:00pm	5/16/24 6:27am	05/24/2024	1.4	No

Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	48	CS	faucet in 72	FD	5/14/24 8:00pm	5/15/24 6:21am	05/24/2024	1.7	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	49	CF	bubbler in 71	FD	5/15/24 8:00pm	5/16/24 6:28am	05/24/2024	1.4	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	50	CS	faucet in 71	FD	5/14/24 8:00pm	5/15/24 6:22am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	51	CF	bubbler in 76	FD	5/15/24 8:00pm	5/16/24 6:29am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	52	CS	faucet in 76	FD	5/14/24 8:00pm	5/15/24 6:23am	05/24/2024	1.4	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	53	CF	bubbler in 77	FD	5/15/24 8:00pm	5/16/24 6:30am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	54	CS	faucet in 77	FD	5/14/24 8:00pm	5/15/24 6:24am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	55	CF	bubbler in 78	FD	5/15/24 8:00pm	5/16/24 6:31am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	56	CS	faucet in 78	FD	5/14/24 8:00pm	5/15/24 6:25am	05/24/2024	1.4	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	57	CF	bubbler in 79	FD	5/15/24 8:00pm	5/16/24 6:32am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	58	CS	faucet in 79	FD	5/14/24 8:00pm	5/15/24 6:26am	05/24/2024	3.2	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	59	CF	bubbler in 81	FD	5/15/24 8:00pm	5/16/24 6:33am	05/24/2024	1.5	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	60	CS	faucet in 81	FD	5/14/24 8:00pm	5/15/24 6:27am	05/24/2024	1.5	No

Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	61	CF	bubbler in 89	FD	5/15/24 8:00pm	5/16/24 6:34am	05/24/2024	1.9	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	62	CS	faucet in 89	FD	5/14/24 8:00pm	5/15/24 6:28am	05/24/2024	2.3	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	63	CF	bubbler in 90	FD	5/15/24 8:00pm	5/16/24 6:35am	05/24/2024	2.6	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	64	CS	faucet in 90	FD	5/14/24 8:00pm	5/15/24 6:29am	05/24/2024	2.1	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	65	CF	bubbler in 91	FD	5/15/24 8:00pm	5/16/24 6:36am	05/24/2024	1.8	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	66	CS	faucet in 91	FD	5/15/24 8:00pm	5/16/24 6:30am	05/24/2024	1.7	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	67	CF	bubbler in 92	FD	5/15/24 8:00pm	5/16/24 6:37am	05/24/2024	4.4	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	68	CS	faucet in 92	FD	5/14/24 8:00pm	5/15/24 6:31am	05/24/2024	4.4	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	69	CF	bubbler in 97	FD	5/15/24 8:00pm	5/16/24 6:38am	05/27/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	70	CS	faucet in 97	FD	5/14/24 8:00pm	5/15/24 6:32am	05/27/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	71	CF	bubbler in 100	FD	5/15/24 8:00pm	5/16/24 6:39am	05/27/2024	1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	72	CS	faucet in 100	FD	5/14/24 8:00pm	5/15/24 6:33am	05/27/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	73	CF	bubbler in 105	FD	5/15/24 8:00pm	5/16/24 6:40am	05/27/2024	2.1	No

Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	74	CS	faucet in 105	FD	5/14/24 8:00pm	5/15/24 6:34am	05/27/2024	2.4	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	75	TL	faucet in lounge	FD	5/14/24 8:00pm	5/15/24 6:35am	05/27/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	76	CR	left faucet in 115	FD	5/14/24 8:00pm	5/15/24 6:36am	05/27/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	77	CR	right faucet in 115	FD	5/15/24 8:00pm	5/16/24 6:41am	05/27/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	78	CF	bubbler in 123	FD	5/15/24 8:00pm	5/16/24 6:42am	05/27/2024	3.5	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	79	CS	faucet in 123	FD	5/14/24 8:00pm	5/15/24 6:37am	05/27/2024	1.4	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	80	CF	bubbler in 124	FD	5/15/24 8:00pm	5/16/24 6:43am	05/27/2024	1.1	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	81	CS	faucet in 124	FD	5/14/24 8:00pm	5/15/24 6:38am	05/27/2024	2.5	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	82	KS	left solo faucet in kitchen	FD	5/14/24 8:00pm	5/15/24 6:39am	05/27/2024	2.3	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	83	KS	left faucet 3 compartment sink in kitchen	FD	5/14/24 8:00pm	5/15/24 6:40am	05/27/2024	1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	84	KS	right faucet 3 compartment sink in kitchen	FD	5/15/24 8:00pm	5/16/24 6:44am	05/27/2024	1.6	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	85	NO	faucet in health room	FD	5/14/24 8:00pm	5/15/24 6:36am	05/27/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	86	CR	faucet in 5	FD	5/14/24 8:00pm	5/15/24 6:37am	05/27/2024	1.6	No

Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	87	DF	Quench cold in 5(use to be fountain outside building by 39, that was removed)	FD	5/14/24 8:00pm	5/15/24 6:38am	05/24/2024	<1.0	No
Water Testing Laboratory of MD	Windy Hill Elementary School	6/12/24	1	88	CR	Quench Hot in 5	FD	5/15/24 8:00pm	5/16/24 6:41am	05/24/2024	<1.0	No