

# Barstow Elementary School

## 2023-2024 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date and Time Water Last Used	Date and Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 5.5 ppb AL?
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	1	DF	bottle filler fountain outside of cafeteria	FD	4/30/24 10:00pm	5/1/24 6:48am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	1b	DF	bottle filler outside of cafeteria	FD	5/1/24 10:00pm	5/2/24 6:16am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	4	DF	bottle filler fountain outside of grade 2 storage	FD	4/30/24 10:00pm	5/1/24 6:33am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	4b	DF	bottle filler outside of grade 2 storage	FD	5/2/24 10:00pm	2/3/24 6:25am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	7	DF	bottle filler fountain outside of grade 5 storage	FD	4/30/24 10:00pm	5/1/24 6:30am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	7b	DF	bottle filler outside of grade 5 storage	FD	5/1/24 10:00pm	5/2/24 6:27am	05/08/2024	<1.0	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	8	NO	faucet in health suite	FD	4/30/24 10:00pm	5/1/24 6:15am	05/08/2024	1.5	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	9	NO	faucet in health suite exam room	FD	4/30/24 10:00pm	5/1/24 6:16am	05/08/2024	2.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	10	TL	faucet in main office work room	FD	4/30/24 10:00pm	5/1/24 6:19am	05/08/2024	2.4	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	11	TL	faucet in lounge	FD	4/30/24 10:00pm	5/1/24 6:21am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	12	KS	left faucet in kitchen	FD	4/30/24 10:00pm	5/1/24 6:25am	05/08/2024	2.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	13	KS	right faucet in kitchen	FD	5/1/24 10:00pm	5/2/24 6:18am	05/08/2024	2.5	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	14	DF	fountain in cafeteria	FD	4/30/24 10:00pm	5/1/24 6:26am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	15	CR	faucet in music room	FD	4/30/24 10:00pm	5/1/24 6:27am	05/08/2024	2.6	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	16	CR	faucet in art room	FD	4/30/24 10:00pm	5/1/24 6:28am	05/08/2024	1.3	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	17	CR	faucet in media center work room	FD	4/30/24 10:00pm	5/1/24 6:29am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b18	CF	bubbler in 125	FD	5/1/24 10:00pm	5/2/24 6:19am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	19	CS	faucet in 125	FD	4/30/24 10:00pm	5/1/24 6:30am	05/08/2024	2.2	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b20	CF	bubbler in 124	FD	5/1/24 10:00pm	5/2/24 6:20am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	21	CS	faucet in 124	FD	4/30/24 10:00pm	5/1/24 6:31am	05/08/2024	2.6	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b22	CF	bubbler in 123	FD	5/1/24 10:00pm	5/2/24 6:21am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	23	CS	faucet in 123	FD	4/30/24 10:00pm	5/1/24 6:32am	05/08/2024	3.0	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b24	CF	bubbler in 122	FD	5/1/24 10:00pm	5/2/24 6:22am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	25	CS	faucet in 122	FD	4/30/24 10:00pm	5/1/24 6:33am	05/08/2024	1.8	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b26	CF	bubbler in 121	FD	5/1/24 10:00pm	5/2/24 6:23am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	27	CS	faucet in 121	FD	4/30/24 10:00pm	5/1/24 6:34am	05/08/2024	2.6	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b28	CF	bubbler in 120	FD	5/1/24 10:00pm	5/2/24 6:24am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	29	CS	faucet in 120	FD	4/30/24 10:00pm	5/1/24 6:35am	05/08/2024	2.1	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b30	CF	bubbler in 115	FD	5/1/24 10:00pm	5/2/24 6:25am	05/08/2024	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	31	CS	faucet in 115	FD	4/30/24 10:00pm	5/1/24 6:36am	05/08/2024	3.0	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b32	CF	bubbler in 114	FD	5/1/24 10:00pm	5/2/24 6:26am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	33	CS	faucet in 114	FD	4/30/24 10:00pm	5/1/24 6:37am	05/08/2024	2.2	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b34	CF	bubbler in 113	FD	5/1/24 10:00pm	5/2/24 6:27am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	35	CS	faucet in 113	FD	4/30/24 10:00pm	5/1/24 6:38am	05/08/2024	4.1	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b36	CF	bubbler in 112	FD	5/1/24 10:00pm	5/2/24 6:28am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	37	CS	faucet in 112	FD	4/30/24 10:00pm	5/1/24 6:39am	05/08/2024	3.5	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b38	CF	bubbler in 111	FD	5/1/24 10:00pm	5/2/24 6:29am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	39	CS	faucet in 111	FD	4/30/24 10:00pm	5/1/24 6:40am	05/08/2024	1.9	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b40	CF	bubbler in 110	FD	5/1/24 10:00pm	5/2/24 6:30am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	41	CS	faucet in 110	FD	4/30/24 10:00pm	5/1/24 6:41am	05/08/2024	2.1	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	42	CR	faucet in grade 1 work room	FD	4/30/24 10:00pm	5/1/24 6:42am	05/08/2024	3.4	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b43	CF	bubbler in 106	FD	5/1/24 10:00pm	5/2/24 6:18am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	44	CS	faucet in 106	FD	4/30/24 10:00pm	5/1/24 6:16am	05/08/2024	4.9	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b45	CF	bubbler in 105	FD	5/1/24 10:00pm	5/2/24 6:19am	05/08/2024	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	46	CS	faucet in 105	FD	4/30/24 10:00pm	5/1/24 6:17am	05/08/2024	3.4	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b47	CF	bubbler in 104	FD	5/1/24 10:00pm	5/2/24 6:20am	05/08/2024	<1.0	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	48	CS	faucet in 104	FD	4/30/24 10:00pm	5/1/24 6:18am	05/08/2024	1.2	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b49	CF	bubbler in 103	FD	5/1/24 10:00pm	5/2/24 6:21am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	50	CS	faucet in 103	FD	4/30/24 10:00pm	5/1/24 6:19am	05/08/2024	2.6	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b51	CF	bubbler in 102	FD	5/1/24 10:00pm	5/2/24 6:22am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	52	CS	faucet in 102	FD	4/30/24 10:00pm	5/1/24 6:20am	05/08/2024	2.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	b53	CF	bubbler in 101	FD	5/1/24 10:00pm	5/2/24 6:23am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	54	CS	faucet in 101	FD	4/30/24 10:00pm	5/1/24 6:21am	05/08/2024	2.4	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	55	CR	faucet in 130	FD	4/30/24 10:00pm	5/1/24 6:22am	05/08/2024	2.4	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b56	CF	bubbler in 225	FD	5/1/24 10:00pm	5/2/24 6:24am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	57	CS	faucet in 225	FD	4/30/24 10:00pm	5/1/24 6:23am	05/08/2024	1.9	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b58	CF	bubbler in 224	FD	5/1/24 10:00pm	5/2/24 6:25am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	59	CS	faucet 224	FD	4/30/24 10:00pm	5/1/24 6:24am	05/08/2024	1.2	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b60	CF	bubbler in 223	FD	5/1/24 10:00pm	5/2/24 6:26am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	61	CS	faucet in 223	FD	4/30/24 10:00pm	5/1/24 6:25am	05/08/2024	1.4	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b62	CF	bubbler in 222	FD	5/1/24 10:00pm	5/2/24 6:27am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	63	CS	faucet in 222	FD	4/30/24 10:00pm	5/1/24 6:26am	05/08/2024	1.2	No



Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b64	CF	bubbler in 221	FD	5/1/24 10:00pm	5/2/24 6:28am	05/08/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	65	CS	faucet in 221	FD	4/30/24 10:00pm	5/1/24 6:27am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b66	CF	bubbler in 220	FD	5/1/24 10:00pm	5/2/24 6:29am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	67	CS	faucet in 220	FD	4/30/24 10:00pm	5/1/24 6:28am	05/09/2024	1.6	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b68	CF	bubbler in 215	FD	5/1/24 10:00pm	5/2/24 6:31am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	69	CS	faucet in 215	FD	4/30/24 10:00pm	5/1/24 6:29am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b70	CF	bubbler in 214	FD	5/1/24 10:00pm	5/2/24 6:32am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	71	CS	faucet in 214	FD	4/30/24 10:00pm	5/1/24 6:30am	05/09/2024	1.1	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b72	CF	bubbler in 213	FD	5/1/24 10:00pm	5/2/24 6:33am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	73	CS	faucet in 213	FD	4/30/24 10:00pm	5/1/24 6:31am	05/09/2024	2.6	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b74	CF	bubbler in 212	FD	5/1/24 10:00pm	5/2/24 6:34am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	75	CS	faucet in 212	FD	4/30/24 10:00pm	5/1/24 6:32am	05/09/2024	4.2	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b76	CF	bubbler in 211	FD	5/1/24 10:00pm	5/2/24 6:35am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	77	CS	faucet in 211	FD	4/30/24 10:00pm	5/1/24 6:33am	05/09/2024	2.1	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b78	CF	bubbler in 210	FD	5/1/24 10:00pm	5/2/24 6:36am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	79	CS	faucet in 210	FD	4/30/24 10:00pm	5/1/24 6:34am	05/09/2024	2.2	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	80	CR	faucet in grade 4 work room	FD	4/30/24 10:00pm	5/1/24 6:35am	05/09/2024	4.4	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b81	CF	bubbler in 205	FD	5/1/24 10:00pm	5/2/24 6:37am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	82	CS	faucet in 205	FD	4/30/24 10:00pm	5/1/24 6:36am	05/09/2024	2.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b83	CF	bubbler in 204	FD	5/1/24 10:00pm	5/2/24 6:38am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	84	CS	faucet in 204	FD	4/30/24 10:00pm	5/1/24 6:37am	05/09/2024	1.6	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b85	CF	bubbler in 203	FD	5/1/24 10:00pm	5/2/24 6:39am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	86	CS	faucet in 203	FD	4/30/24 10:00pm	5/1/24 6:38am	05/09/2024	1.8	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b87	CF	bubbler in 202	FD	5/1/24 10:00pm	5/2/24 6:40am	05/09/2024	<1.0	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	88	CS	faucet in 202	FD	4/30/24 10:00pm	5/1/24 6:39am	05/09/2024	2.6	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	b89	CF	bubbler in 201	FD	5/1/24 10:00pm	5/2/24 6:41am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	2	90	CS	faucet in 201	FD	4/30/24 10:00pm	5/1/24 6:40am	05/09/2024	1.9	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	91	DF	fountain on play ground	FD	4/30/24 10:00pm	5/1/24 6:45am	05/09/2024	1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	92	DF	fountain outside of gym	FD	5/1/24 10:00pm	5/2/24 6:35am	05/09/2024	6.2	Yes
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	92	DF	fountain outside of gym	Flush	5/31/24 7:46am	5/31/24 7:46am	6/6/24	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	93	IM	Ice Machine in lounge	FD	4/30/24 10:00pm	5/1/24 6:20am	05/09/2024	<1.0	No
Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	94	IM	Ice Machine in nurse room	FD	4/30/24 10:00pm	5/1/24 6:16am	05/09/2024	<1.0	No

Water Testing Laboratory of MD	Barstow Elementary School	5/30/24	1	95	CR	Faucet in Band room storage	FD	4/30/24 10:00pm	5/1/24 6:23am	05/09/2024	1.2	No
--------------------------------	---------------------------	---------	---	----	----	-----------------------------	----	-----------------	---------------	------------	-----	----