Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
COPPER:			
Elementary Wrestling Drinking Fountain	20810105-001DW	6/25/2024	ND
Elementary Library West Drinking Fountain	20810109-001DW	6/25/2024	ND
Elementary K-1 Commons Drinking Fountain	20810100-001DW	6/25/2024	ND
Elementary #17 Drinking Fountain	20810100-002DW	6/25/2024	ND
Elementary #14 Drinking Fountain	20810100-003DW	6/25/2024	ND
High School Canteen / Sink	20810201-001KF	6/25/2024	ND
High School Library South Sink	20810206-002SF	6/25/2024	ND
High School Office Staff LR / Sink	20810209-001KF	6/25/2024	ND
High School Band Room Sink	20810202-001CF	6/25/2024	ND
District Office Kitchen Sink	20810000-001KF	6/25/2024	ND
ND = Not Dectected at the Reporting Limit			