

Annual Fire Alarm and Signaling Inspection

CINTAS FIRE PROTECTION

1030 CONSHOHOCKEN RD
CONSHOHOCKEN, PA 19428
19428



Inspector: MARK MCGINN 00D4722

03/28/2024

Inspection date:

Inspection Location
STRING THEORY SCHOOLS
2407 S BROAD ST
PHILA , PA 191483508
2673344222
Customer
STRING THEORY SCHOOLS
2407 S BROAD ST
PHILA , PA 191483508
2673344222

*Inspection performed in accordance with
NFPA 72 National Fire Alarm and Signaling Code, 2019 edition*

Notification Prior to Testing	
Person at alarm-receiving facility notified before testing. (14.2.4)	Customer called
Time alarm-receiving facility notified	07:30
Person at Fire Department notified before testing. (14.2.4)	740
Time FD notified before testing	07:30
Time AHJ notified	07:30

Notifications After Testing	
Person at alarm-receiving facility notified after testing. (14.2.4)	Customer called
Time alarm-receiving facility notified after testing	15:00
Person at Fire Department notified after testing. (14.2.4)	740
Time FD notified after testing	15:00
Time AHJ notified after testing	15:00
Date and Time system restored to normal operation.	3/28/2024 3:00pm

Monitoring Entity	
Agency name	Fidelity
Contact	Operator
Telephone	1-888-ALARM00
Monitoring account number	165498
Type transmission	Cellular

Type of System	
Control Unit Manufacturer	SILENT KNIGHT
Control Unit Model	IFP 1000
Software Revision and date last updated	NA
Quantity of Signaling Line Circuits connected to system	1
Class(es) of Signaling Line Circuits connected to system	B
System Documentation on site	Yes

Fire Alarm Box Summary

Type	Total	Tested	Failed
Pull Station - Manual	17	17	0
Total	17	17	0

Fire Alarm Box Devices

Type	Area/Location	Address	Visual Inspection	Functional Test
Pull Station - Manual	1ST FL FRONT DOOR		Pass	Pass
Pull Station - Manual	1ST FL LIBRARY MAIN		Pass	Pass
Pull Station - Manual	1ST FL LIBRARY NORTH DOOR		Pass	Pass
Pull Station - Manual	1ST FL NE EXIT PULL		Pass	Pass
Pull Station - Manual	1ST FL NORTH EXIT PULL		Pass	Pass
Pull Station - Manual	1ST FL POOL PULL		Pass	Pass
Pull Station - Manual	1ST FL SOUTH EXIT STAIR		Pass	Pass
Pull Station - Manual	1ST FL SOUTH EXIT STAIR		Pass	Pass
Pull Station - Manual	1ST FL SOUTH GYM		Pass	Pass
Pull Station - Manual	1ST FL SOUTH GYM		Pass	Pass
Pull Station - Manual	1ST FL SOUTH HALL		Pass	Pass
Pull Station - Manual	1ST FL STAGE LEFT NORTH		Pass	Pass
Pull Station - Manual	1ST FL STAGE LEFT SOUTH		Pass	Pass
Pull Station - Manual	2ND FL STAIR 1		Pass	Pass
Pull Station - Manual	B1 STAIR 1		Pass	Pass
Pull Station - Manual	B2 CENTER STAIR		Pass	Pass
Pull Station - Manual	B2 STAIR 3		Pass	Pass

Duct Detector Summary

Type	Total	Tested	Failed
Duct Detector w/Sensitivity	7	7	0
Total	7	7	0

Duct Detectors - Sensitivity Test

Area/Location	Address	Sensitivity Range	Visual Inspection	Functional Test	Sensitivity Test
1ST FL MAIN LOBBY		0.5%-4.0%	Pass	Pass	Pass
2ND FL BOYS RESTROOM		0.5%-4.0%	Pass	Pass	Pass
2ND FL GYM DUCT		0.5%-4.0%	Pass	Pass	Pass
2ND FL GYM STORAGE		0.5%-4.0%	Pass	Pass	Pass
2ND FL LOBBY DUCT		0.5%-4.0%	Pass	Pass	Pass
2ND FL NORTH LAB		0.5%-4.0%	Pass	Pass	Pass
2ND FL NORTH LAB		0.5%-4.0%	Pass	Pass	Pass

Heat and Other Detectors Summary

Type	Total	Tested	Failed
Heat Detector	2	2	0
Total	2	2	0

Heat and Other Detectors

Type	Area/Location	Address	Visual Inspection	Functional Test
Heat Detector	B1 ELEV MACHINE ROOM		Pass	Pass
Heat Detector	B1 ELEV SHAFT		Pass	Pass

Smoke Detector Summary

Type	Total	Tested	Failed
Smoke Detector - Sens.	12	12	0
Total	12	12	0

Smoke Detectors - Sensitivity Test

Type	Area/Location	Address	Sensitivity Range	Visual Inspection	Functional Test	Sensitivity Test
Smoke Detector - Sens.	1ST FL ELEV SMOKE		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FL STAGE LEFT NORTH		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FL STAGE LEFT SOUTH		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FL ELEV SMOKE		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FL LOBBY		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FL STAIRS		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FL STAIRS		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	B1 ELEV MECH RM		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	B1 ELEV SMOKE		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	B1 SHAFT SMOKE		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	B2 ELEV SMOKE		0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	B2 FACP SMOKE		0.5%-4.0%	Pass	Pass	Pass 3.5%

Audio/Visual Device Summary

Type	Total	Tested	Failed
Horn/Strobe	39	39	0
Strobe	13	13	0
Total	52	52	0

Audio/Visual Devices

Type	Area/Location	Address	Visual Inspection	Functional Test
Horn/Strobe	1ST FLOOR CAFETERIA		Pass	Pass
Strobe	1ST FLOOR HALLWAY NEAR CAFETERIA		Pass	Pass
Horn/Strobe	1ST FLOOR HALLWAY NEAR CASHIER		Pass	Pass
Horn/Strobe	1ST FLOOR HALLWAY NEAR ROOM K3		Pass	Pass
Strobe	1ST FLOOR HALLWAY NEAR ROOM K7		Pass	Pass

Audio/Visual Devices				
Type	Area/Location	Address	Visual Inspection	Functional Test
Horn/Strobe	1ST FLOOR HALLWAY NEAR VICE PRINCIPAL'S OFFICE		Pass	Pass
Strobe	1ST FLOOR K1 RESTROOM		Pass	Pass
Horn/Strobe	1ST FLOOR MAIN ENTRANCE		Pass	Pass
Strobe	1ST FLOOR MEN'S RESTROOM		Pass	Pass
Horn/Strobe	1ST FLOOR ROOM 109		Pass	Pass
Horn/Strobe	1ST FLOOR ROOM K1		Pass	Pass
Horn/Strobe	1ST FLOOR ROOM K2		Pass	Pass
Horn/Strobe	1ST FLOOR ROOM K3		Pass	Pass
Horn/Strobe	1ST FLOOR ROOM K4		Pass	Pass
Horn/Strobe	1ST FLOOR ROOM K5		Pass	Pass
Horn/Strobe	1ST FLOOR ROOM K6		Pass	Pass
Horn/Strobe	1ST FLOOR ROOM K7		Pass	Pass
Horn/Strobe	1ST FLOOR ROOM K8		Pass	Pass
Strobe	1ST FLOOR WOMEN'S RESTROOM		Pass	Pass
Horn/Strobe	2ND FLOOR ART ROOM		Pass	Pass
Horn/Strobe	2ND FLOOR BALLET STUDIO		Pass	Pass
Horn/Strobe	2ND FLOOR GYM		Pass	Pass
Horn/Strobe	2ND FLOOR GYM		Pass	Pass
Strobe	2ND FLOOR HALLWAY NEAR BALLET STUDIO		Pass	Pass
Horn/Strobe	2ND FLOOR HALLWAY NEAR ROOM 201		Pass	Pass
Horn/Strobe	2ND FLOOR HALLWAY NEAR VOCAL MUSIC ROOM		Pass	Pass
Horn/Strobe	2ND FLOOR HALLWAY NEAR WOMEN'S RESTROOM		Pass	Pass
Horn/Strobe	2ND FLOOR INSTRUMENTAL STUDIO		Pass	Pass
Horn/Strobe	2ND FLOOR LIBRARY BACK WALL		Pass	Pass
Horn/Strobe	2ND FLOOR LIBRARY FRONT SIDE EXIT		Pass	Pass
Horn/Strobe	2ND FLOOR LIBRARY MAIN ENTRANCE		Pass	Pass
Strobe	2ND FLOOR MEN'S RESTROOM		Pass	Pass
Horn/Strobe	2ND FLOOR ROOM 201		Pass	Pass
Horn/Strobe	2ND FLOOR ROOM 203		Pass	Pass
Horn/Strobe	2ND FLOOR ROOM 205		Pass	Pass
Horn/Strobe	2ND FLOOR SCIENCE LAB		Pass	Pass
Horn/Strobe	2ND FLOOR VOCAL MUSIC ROOM		Pass	Pass
Strobe	2ND FLOOR WOMEN'S RESTROOM		Pass	Pass
Strobe	BASEMENT BOY'S RESTROOM		Pass	Pass
Horn/Strobe	BASEMENT CLASSROOM NEAR EXIT		Pass	Pass
Strobe	BASEMENT GIRL'S RESTROOM		Pass	Pass
Horn/Strobe	BASEMENT HALLWAY IN BETWEEN RESTROOMS		Pass	Pass
Horn/Strobe	BASEMENT HALLWAY NEAR GIRL'S RESTROOM		Pass	Pass
Horn/Strobe	BASEMENT HALLWAY NEAR POOL MECHANICAL ROOM		Pass	Pass
Strobe	BASEMENT HALLWAY NEAR ROOM B4		Pass	Pass
Horn/Strobe	BASEMENT POOL AREA		Pass	Pass
Strobe	BASEMENT RESTROOM NEAR POOL		Pass	Pass

Audio/Visual Devices

Type	Area/Location	Address	Visual Inspection	Functional Test
Strobe	BASEMENT RESTROOM NEAR POOL		Pass	Pass
Horn/Strobe	BASEMENT ROOM B1		Pass	Pass
Horn/Strobe	BASEMENT ROOM B2		Pass	Pass
Horn/Strobe	BASEMENT ROOM B3		Pass	Pass
Horn/Strobe	BASEMENT ROOM B4		Pass	Pass

Liability Release Statement:

The owner and/or designated representative acknowledges the responsibility of the operating condition of the component parts at the time of this inspection. It is agreed that the inspection service provided by the contractor as prescribed herein is limited to performing a visual inspection and/or routine testing, and any investigation or unscheduled testing, modification, maintenance, repair, etc., of the component parts is not included as part of the inspection work performed. It is further understood that all information contained herein is provided to the best of the knowledge of the party providing such information.



3/28/24

Customer: James Parker



3/28/24

Technician: MARK MCGINN 00D4722