

Annual Fire Alarm and Signaling Inspection

CINTAS FIRE PROTECTION

1030 CONSHOHOCKEN RD
CONSHOHOCKEN, PA 19428
19428



Inspector: MARK MCGINN 00D4722

03/27/2024

Inspection date:

Inspection Location
STRING THEORY 2600 S BROA
2600 S BROAD ST
PHILADELPHIA , PA 191454616
2673344223
Customer
STRING THEORY 2600 S BROA
2600 S BROAD ST
PHILADELPHIA , PA 191454616
2673344223

*Inspection performed in accordance with
NFPA 72 National Fire Alarm and Signaling Code, 2019 edition*

Notification Prior to Testing	
Person at alarm-receiving facility notified before testing. (14.2.4)	CUSTOMER CALLED
Time alarm-receiving facility notified	08:00
Person at Fire Department notified before testing. (14.2.4)	740
Time FD notified before testing	08:00
Time AHJ notified	08:00

Notifications After Testing	
Person at alarm-receiving facility notified after testing. (14.2.4)	CUSTOMER CALLED
Time alarm-receiving facility notified after testing	15:00
Person at Fire Department notified after testing. (14.2.4)	740
Time FD notified after testing	15:00
Time AHJ notified after testing	15:00
Date and Time system restored to normal operation.	3/26/2024 3:00PM

Monitoring Entity	
Agency name	FIDELITY ALARM
Contact	CUSTOMER CALLED
Telephone	1-888-252-7600
Monitoring account number	164150
Type transmission	Phone Line

<i>FACU and Power Supply Summary</i>			
Type	Total	Tested	Failed
Main Fire Alarm Control Unit	1	1	0
	1	1	0

FACU and Power Supply	
Main Fire Alarm Control Unit	
1ST FLOOR HALLWAY NEAR STUDENT ENTRANCE LOBBY SILENT KNIGHT IFP-300	
Correct fuses installed.	Pass
Disconnect switches, if applicable, operating properly.	Pass
Ground fault monitoring circuit, if applicable, operates properly.	Pass
Installation documents or location of documents stored in document cabinet.	Pass
Interfaced equipment signals verified.	Pass
Lamps/LEDs function properly.	Pass
Power supply supervision operating properly.	Pass
Secondary (standby) power supply.	Pass
Transmission of signals to off-premises location.	Pass

Fire Alarm Box Summary

Type	Total	Tested	Failed
Pull Station - Manual	18	18	0
Total	18	18	0

Fire Alarm Box Devices

Type	Area/Location	Address	Visual Inspection	Functional Test
Pull Station - Manual	1ST FLOOR ADMINISTRATION OFFICE ENTRANCE	M97-M003	Pass	Pass
Pull Station - Manual	1ST FLOOR BOTTOM OF STAIRS EXIT	M97-M005	Pass	Pass
Pull Station - Manual	1ST FLOOR CAFETERIA EXIT	M97-M006	Pass	Pass
Pull Station - Manual	1ST FLOOR ELEVATOR LOBBY	M97:M028	Pass	Pass
Pull Station - Manual	1ST FLOOR HALLWAY NEAR BACK STAIR	M97-M027	Pass	Pass
Pull Station - Manual	1ST FLOOR HALLWAY NEAR ELEVATOR LOBBY	M97:M030	Pass	Pass
Pull Station - Manual	1ST FLOOR HALLWAY NEAR ENTRANCE	M97-M029	Pass	Pass
Pull Station - Manual	1ST FLOOR ROOM 115 EXIT	M97-M004	Pass	Pass
Pull Station - Manual	1ST FLOOR STUDENT ENTRANCE	M97-M001	Pass	Pass
Pull Station - Manual	2ND FLOOR BOTTOM OF STAIR AT EXIT	M97-M002	Pass	Pass
Pull Station - Manual	2ND FLOOR HALLWAY NEAR ELEVATOR LOBBY	M97-M032	Pass	Pass
Pull Station - Manual	2ND FLOOR HALLWAY NEAR STAIRS	M97-M033	Pass	Pass
Pull Station - Manual	2ND FLOOR HALLWAY NEAR STAIRS	M97-M031	Pass	Pass
Pull Station - Manual	BASEMENT BOTTOM OF STAIRS	M97:M012	Pass	Pass
Pull Station - Manual	BASEMENT BOTTOM OF STAIRS	M97:M026	Pass	Pass
Pull Station - Manual	BASEMENT ELEVATOR LOBBY	M97:M025	Pass	Pass
Pull Station - Manual	BASEMENT HALLWAY NEAR STAIRS	M97:M009	Pass	Pass
Pull Station - Manual	BASEMENT REAR EXIT	M97:M008	Pass	Pass

Smoke Detector Summary

Type	Total	Tested	Failed
Smoke Detector - Sens.	70	70	0
Total	70	70	0

Smoke Detectors - Sensitivity Test

Type	Area/Location	Address	Sensitivity Range	Visual Inspection	Functional Test	Sensitivity Test
Smoke Detector - Sens.	1ST FLOOR ADMINISTRATION OFFICE ENTRANCE	M97:S006	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR CAFETERIA LEFT	M97:S026	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR CAFETERIA RIGHT	M97:S027	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR ELEVATOR LOBBY	M97:S103	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR ELEVATOR LOBBY	M97:S101	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR HALLWAY ABOVE FACP	M97:S002	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR HALLWAY NEAR ROOM 107	M97:S018	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR HALLWAY NEAR ROOM 108	M97:S019	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR HALLWAY NEAR ROOM 111	M97:S005	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR HALLWAY NEAR ROOM 113	M97:S007	0.5%-4.0%	Pass	Pass	Pass 3.5%

Smoke Detectors - Sensitivity Test						
Type	Area/Location	Address	Sensitivity Range	Visual Inspection	Functional Test	Sensitivity Test
Smoke Detector - Sens.	1ST FLOOR HALLWAY NEAR ROOM 114	M97:S008	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR HALLWAY NEAR ROOM 115	M97:S009	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR HALLWAY NEAR ROOM 124	M97:S050	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR HALLWAY NEAR TEACHER'S LOUNGE	M97:S004	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR PAPER STORAGE ROOM	M97:S015	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR ROOM 101	M97:S003	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR ROOM 102	M97:S062	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR ROOM 104	M97:S024	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR ROOM 106	M97:S017	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR ROOM 107	M97:S022	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR ROOM 108	M97:S020	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR ROOM 109	M97:S023	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR SCIENCE LAB	M97:S021	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR SCIENCE LAB	M97:S025	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR STUDENT ENTRANCE LOBBY	M97:S001	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	1ST FLOOR TEACHER'S LOUNGE	M97:S011	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR BALLET STUDIO	M97:S046	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR BALLET STUDIO	M97:S044	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR BALLET STUDIO LEFT	M97:S071	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR BALLET STUDIO RIGHT	M97:S072	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ELEVATOR LOBBY	M97:S087	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ELEVATOR LOBBY	M97:S081	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ELEVATOR LOBBY	M97:S047	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR HALLWAY NEAR ROOM 204	M97:S032	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR HALLWAY NEAR ROOM 205	M97:S042	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR HALLWAY NEAR ROOM 226	M97:S093	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR HALLWAY NEAR ROOM 228	M97:S092	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR HALLWAY NEAR ROOM 232A	M97:S091	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR HALLWAY NEAR ROOM 237	M97:S094	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR MUSIC HALL LEFT	M97:S057	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR MUSIC HALL RIGHT	M97:S067	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR MUSIC HALL TOP OF STAIR	M97:S064	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 200	M97:S051	0.5%-4.0%	Pass	Pass	Pass 3.5%

Smoke Detectors - Sensitivity Test						
Type	Area/Location	Address	Sensitivity Range	Visual Inspection	Functional Test	Sensitivity Test
Smoke Detector - Sens.	2ND FLOOR ROOM 201	M97:S059	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 202	M97:S031	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 203	M97:S030	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 204	M97:S069	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 205	M97:S052	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 206	M97:S053	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 207	M97:S054	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 208	M97:S055	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 209	M97:S045	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 213	M97:S065	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 233	M97:S099	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 235	M97:S098	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 236	M97:S097	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM 237	M97:S095	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR ROOM AS216	M97:S056	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR TOP OF STAIR 3	M97:S029	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR TOP OF STAIRS	M97:S088	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	2ND FLOOR TOP OF STAIRS NEAR ROOM 208	M97:S048	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	BASEMENT ART CLASSROOM	M97:S034	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	BASEMENT ART CLASSROOM	M97:S035	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	BASEMENT ELEVATOR LOBBY	M97:S104	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	BASEMENT ELEVATOR LOBBY	M97:S041	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	BASEMENT HALLWAY NEAR ELEVATOR MACHINE ROOM	M97:S039	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	BASEMENT HALLWAY NEAR RESTROOMS	M97:S033	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	BASEMENT SUPPLEMENTAL	M97:S036	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	BASEMENT TOP OF REAR STAIRS	M97:S028	0.5%-4.0%	Pass	Pass	Pass 3.5%
Smoke Detector - Sens.	BASEMENT VOCAL MUSIC ROOM	M97:S040	0.5%-4.0%	Pass	Pass	Pass 3.5%

Audio/Visual Device Summary

Type	Total	Tested	Failed
LoudSpeaker/Strobe	110	110	1
Strobe	14	14	0
Total	124	124	1

Audio/Visual Devices				
Type	Area/Location	Address	Visual Inspection	Functional Test
Strobe	1ST FLOOR BOY'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR CAFETERIA		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR CAFETERIA LEFT		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR CAFETERIA RIGHT		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ELEVATOR LOBBY		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR EMPLOYEE'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR EMPLOYEE'S RESTROOM		Pass	Pass
Strobe	1ST FLOOR GIRL'S RESROOM		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR BOY'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR CLASSROOM		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ELEVATOR LOBBY		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR EMPLOYEE'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ROOM 101		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ROOM 107		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ROOM 109		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ROOM 110		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ROOM 116		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ROOM 119		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ROOM 119		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ROOM 121		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR HALLWAY NEAR ROOM 126		Pass	Pass
Strobe	1ST FLOOR MEN'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR NURSE'S ROOM		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR REAR EXIT		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR REAR EXIT		Pass	Pass
Strobe	1ST FLOOR RESTROOM		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 101		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 102		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 104		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 106		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 107		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 108		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 109		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 110		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 111		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 112		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 113		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 114		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 115		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 116		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 117		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 118		Pass	Pass

Audio/Visual Devices				
Type	Area/Location	Address	Visual Inspection	Functional Test
LoudSpeaker/Strobe	1ST FLOOR ROOM 119		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 120		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 120		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 121		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 124		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR ROOM 126		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR SCIENCE LAB		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR STUDENT ENTRANCE		Pass	Pass
LoudSpeaker/Strobe	1ST FLOOR TEACHER'S LOUNGE		Pass	Pass
Strobe	1ST FLOOR WOMEN'S RESTROOM		Pass	Pass
Strobe	2ND FLOOR BOY'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ELEVATOR LOBBY		Pass	Pass
Strobe	2ND FLOOR EMPLOYEES MEN'S RESTROOM		Pass	Pass
Strobe	2ND FLOOR EMPLOYEES WOMEN'S RESTROOM		Pass	Pass
Strobe	2ND FLOOR GIRL'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR MEN'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 201		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 203		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 205		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 207		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 226		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 228		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 231		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 236		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 237		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 240		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 242		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 244		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR ROOM 245		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR HALLWAY NEAR STAIRS		Pass	Pass
Strobe	2ND FLOOR HANDICAP RESTROOM		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR LAB		Pass	Pass
Strobe	2ND FLOOR MEN'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR MUSIC HALL		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 200		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 201		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 202		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 203		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 204		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 205		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 206		Pass	Pass

Audio/Visual Devices				
Type	Area/Location	Address	Visual Inspection	Functional Test
LoudSpeaker/Strobe	2ND FLOOR ROOM 207		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 208		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 209		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 209		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 213		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 225		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 226		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 227		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 228		Pass	Fail
LoudSpeaker/Strobe	2ND FLOOR ROOM 229		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 230		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 231		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 232B		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 233		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 234		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 235		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 236		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 239		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 240		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 242		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 243		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 244		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM 245		Pass	Pass
LoudSpeaker/Strobe	2ND FLOOR ROOM AS216		Pass	Pass
Strobe	2ND FLOOR WOMEN'S RESTROOM		Pass	Pass
LoudSpeaker/Strobe	BASEMENT ART CLASSROOM		Pass	Pass
LoudSpeaker/Strobe	BASEMENT ART CLASSROOM		Pass	Pass
LoudSpeaker/Strobe	BASEMENT ELEVATOR LOBBY		Pass	Pass
LoudSpeaker/Strobe	BASEMENT ELEVATOR LOBBY		Pass	Pass
LoudSpeaker/Strobe	BASEMENT HALLWAY NEAR RESTROOMS		Pass	Pass
LoudSpeaker/Strobe	BASEMENT HALLWAY NEAR ROOM 6		Pass	Pass
LoudSpeaker/Strobe	BASEMENT HALLWAY NEAR ROOM 9		Pass	Pass
LoudSpeaker/Strobe	BASEMENT REAR CLASSROOM		Pass	Pass
Strobe	BASEMENT RESTROOM		Pass	Pass
Strobe	BASEMENT RESTROOM		Pass	Pass
LoudSpeaker/Strobe	BASEMENT ROOM 10		Pass	Pass
LoudSpeaker/Strobe	BASEMENT ROOM 4		Pass	Pass
LoudSpeaker/Strobe	BASEMENT ROOM 5		Pass	Pass
LoudSpeaker/Strobe	BASEMENT ROOM 6		Pass	Pass
LoudSpeaker/Strobe	BASEMENT ROOM 9		Pass	Pass
LoudSpeaker/Strobe	BASEMENT VOCAL MUSIC ROOM		Pass	Pass

Deficiencies

**PAR response indicated "Pass After Repair". Technician notes a deficiency of a device, and repairs the deficiency during inspection.*

LoudSpeaker/Strobe


2ND FLOOR ROOM 228 OTHER EATON M/N: ELSPSTC

Ques: Functional Test

Technician Response: STROBE DID NOT OPERATE

Liability Release Statement:

The owner and/or designated representative acknowledges the responsibility of the operating condition of the component parts at the time of this inspection. It is agreed that the inspection service provided by the contractor as prescribed herein is limited to performing a visual inspection and/or routine testing, and any investigation or unscheduled testing, modification, maintenance, repair, etc., of the component parts is not included as part of the inspection work performed. It is further understood that all information contained herein is provided to the best of the knowledge of the party providing such information.



3/26/24

Customer: Charlie Parker



3/26/24

Technician: MARK MCGINN 00D4722