

J 6# 5803 X1

CITY OF PHILADELPHIA  
DEPARTMENT OF LICENSES AND INSPECTIONS  
COMMERCIAL AND INDUSTRIAL FIRE UNIT  
CERTIFICATION OF  
STANDBY/EMERGENCY ELECTRICAL SYSTEM

PROPERTY NAME: Philadelphia Performing Arts Charter School

PROPERTY ADDRESS: 2600 South Broad Street  
Philadelphia, PA. 19107

TYPE OF TEST: Emergency

DATE OF TEST: June 10, 2024

TYPE OF SYSTEM: Generator

FIRE PUMP: X YES        NO

Maximum output of system was 42 amps. The generator ran for 136 minutes under full load operating conditions.

This system was tested in accordance with the operational inspection and testing procedures established in both the Philadelphia Fire Prevention Code F-501.4 (R) and Section 6-4 of NFPA 110.

The result of the test(s) indicate(s) that no elements of the system were found to be defective on this date and the system is certified.

The result of the test(s) indicate(s) that certain elements of the system were found to be defective on this date and the system could not be certified.

COMMENTS:

\_\_\_\_\_

Bruce D. Shelly  
CONTRACTOR'S SIGNATURE

Shelly Electric Co. Inc.  
Bruce D. Shelly  
CONTRACTOR'S NAME (PRINTED)

162312  
CONTRACTOR'S LICENSES NUMBER

Jcb# 5803

CITY OF PHILADELPHIA  
DEPARTMENT OF LICENSES AND INSPECTIONS  
COMMERCIAL AND INDUSTRIAL FIRE UNIT  
CERTIFICATION OF  
STANDBY/EMERGENCY ELECTRICAL SYSTEM

PROPERTY NAME: Philadelphia Performing Arts Charter School

PROPERTY ADDRESS: 2407 South Broad Street  
Philadelphia, PA. 19107

TYPE OF TEST: Emergency

DATE OF TEST: June 10, 2024

TYPE OF SYSTEM: Generator

FIRE PUMP:  YES  NO

Maximum output of system was 34.6 amps. The generator ran for 136 minutes under full load operating conditions.

This system was tested in accordance with the operational inspection and testing procedures established in both the Philadelphia Fire Prevention Code F-501.4 (R) and Section 6-4 of NFPA 110.

The result of the test(s) indicate(s) that no elements of the system were found to be defective on this date and the system is certified.

The result of the test(s) indicate(s) that certain elements of the system were found to be defective on this date and the system could not be certified.

COMMENTS:

\_\_\_\_\_

Bruce D Shelly  
CONTRACTOR'S SIGNATURE

Shelly Electric Co. Inc.  
Bruce D. Shelly pres.  
CONTRACTOR'S NAME (PRINTED)

162312

Bruce D. Shelly

CONTRACTOR'S LICENSES NUMBER