



CITY OF PHILADELPHIA
DEPARTMENT OF LICENSES AND INSPECTIONS
ANNUAL CERTIFICATION FOR EMERGENCY AND STANDBY POWER SYSTEMS

PROPERTY ADDRESS (BRT Address Required)	1197 Haworth Street, Phila. Pa. 19124
TESTING CONTRACTOR (Name and Address)	Shoreline Electric
	License No. 16024
ANNUAL CERTIFICATIONS MUST BE KEPT ON SITE FOR A PERIOD OF THREE YEARS	

TYPE OF OCCUPANCY:

☒ Commercial ☐ Residential or ☐ Mixed (commercial and residential)

TYPE OF TEST: Emergency Lighting

DATE OF TEST: 5/30/2024

TYPE OF SYSTEM: ☒ Generator ☐ Storage Battery System

☐ Dual Service (include testing criteria and results)

FIRE PUMP: ☐ NO ☐ Yes (Electric ☐ or Diesel

Maximum output of the system was _____ amps. The generator ran for _____ minutes under full load operating conditions.

This system was tested in accordance with the operational inspection and testing procedures established in both the Philadelphia Fire Code section F-604 and the applicable sections of NFPA 110 or 111.

COMMENTS:

5/30 Confirmed All EM Lighting was operational

Replaced 2 Exit fixtures
3 Exit fixtures needed Re-lamping

TEST CONDUCTED/WITNESSED BY (Print and sign name) Stephen Randazzo 

EMAIL ADDRESS Steve.r@shorelineelect.com

PHONE NUMBER 610-362-2491

ELECTRICAL CONTRACTORS LICENSE#: (3516) 16024 OR,

MANUFACTURER'S REP. LICENSE# (Commercial Activity License #) _____