

COMMENTS AND OBSERVATIONS FORM OF WATER BASED FIRE PROTECTION SYSTEMS

This form is to be completed by the system inspection and testing contractor at the time of a system test.
Insert N/A in all unused lines.

System Name: Philadelphia Charter School Building(s):
Equipment Group Name: 01 - Bsmt Fire Command

1. PROPERTY INFORMATION

Name of property: Philadelphia Charter School (4433-19124-00025)
Address: 1197 HAWORTH ST. Philadelphia, PA 19124
Description of property: School
Name of property representative: THE PHILADELPHIA CHARTER SCHOOL FOR (30454774), None
Address: 1197 HAWORTH ST, PHILADELPHIA, PA 19124
Phone: None Fax: None E-mail: None

2. TESTING INFORMATION

Testing Organization: SIEMENS Organization License No.: NA
Address: 1450 Union Meeting Road, Blue Bell, PA 19422
Phone: 215-654-8040 Fax: NA E-mail: NA
Start Date/Time: 2024-06-21 7:00am Completion Date/Time: 2024-06-21 3:00pm
Contract Info: BPA2 FIS Philadelphia Charter (2600124827) Notification Number: 5102615798

Items listed below are not part of an NFPA 25 Inspection. The identification of these items does not constitute a design review or engineering analysis of your system. These items were noticed during an inspection of your life protection system performed in accordance with NFPA 25 but are not part of the NFPA 25 inspections. Siemens makes no guarantee or assurance that any or all design or engineering defects or deficiencies have been detected.

3. COMMENTS AND OBSERVATIONS

Need to replace fire pump test header. valves are all bad

4. CERTIFICATION

This Testing Was Performed in Accordance with Applicable NFPA Standards.

Name of Inspector: Lance Corbett & Greg McGovern Inspector License #: P00597

Signature: Lance Corbett Date: 6/21/24

5. ACCEPTANCE BY OWNER OR OWNER'S REPRESENTATIVE

Name: Carl Pharo Organization: THE PHILADELPHIA CHARTER SCHOOL FOR (30454774) Phone: None

Signature: Carl Pharo Date: 6/21/24

The owner and/or designated representative acknowledges the responsibility of the operating condition of the component parts at the time of this inspection. Pursuant to the National Fire Protection Association Form 25, Chapter 4, the owner is responsible for proper maintenance and care of the sprinkler system. It is agreed that the inspection service provided by the contractor as prescribed herein is limited to performing a visual inspection and/or routine testing, and any investigation or unscheduled testing, modification, maintenance, repair, etc., of the component parts is not included as part of the inspection work performed. It is understood that this inspection pertains to the condition of the sprinkler system on the day of inspection only. This inspection meets or exceeds NFPA 25 requirements and or local AHJ requirements. AHJ requirements supersede all other code requirements. The inspector shall not be liable for future defaults or defects in the sprinkler system which are beyond the inspector's control, including, but not limited to, failure from malicious tampering, accidents, lack of proper inspection, material failure or inadequate heating. The inspector can give no assurance, nor will be held liable, with regard to work that may have been previously performed or work performed at a future date by other companies. It is further understood that all information contained herein is provided to the best of the knowledge of the party providing such information.
