



Emboss Design, PSC
906 Monmouth Street
Newport, KY 41071

ADDENDUM NO. 2

July 10, 2024

TO:

Request for Proposals
For Design-Build Services
Renovations to Covington ISD
Softball Field

FOR:

Covington Independent Schools
25 East 7th Street
Covington KY 41011

NOTE: This Addendum must be receipted in the Proposal. This Addendum is comprised of (1) page.

Appendix A – Criteria Information

1. See Appendix A – 4 (Page 4 of Appendix A), Item 7.
 - a. Revise the outfield polymer coated fence to be **10' in height**. This fence height shall extend from foul pole to foul pole, at 185' to all fields, to compensate for being less than 200' to center field.

Commentary: Assuming field orientation matches existing, it is understood the KHSAA preferred center field distance of 200' results in an appreciable retaining wall height increase. "Such linear distance can be compensated by fence height" shall be interpreted to apply to all fields.

Note to bidders: Addendum 1 re-issued the RFP in its entirety. The Addendum 1 version of the RFP is the only version available for download from the school district's website.

End of Addendum

