

AERO ENVIRONMENTAL SERVICES, INC.

ENGINEERING • CONSULTING • TESTING

275 Route 10 East, Suite 220-306 Succasunna, NJ 07876

Telephone (973) 920-9061

May 18, 2021

Mr. Evan Morley
Facilities
Chester Twp School District
50 North Road
Chester, NJ 07930

Re: Black River School, Asbestos AHERA Periodic Six Month Inspection – May 2021

Dear Mr. Morley,

Enclosed are results for a Six Month Periodic Inspection performed by AERO Environmental Services at the Black River School. The inspection should be kept with the School's Districts asbestos management plan at the Board of Education Office & a copy placed in the schools asbestos management plan.

This Inspection was based on previous inspections and data collected by prior consultants including AHERA accredited Building Inspectors.

Additional asbestos materials may be discovered within walls, ceiling plenums, floors, or any other building component that could not be accessed. Should any unknown materials be discovered during future renovations or demolition, they will need to be properly identified and addressed prior to continuing with the project.

If you have any questions or require further information regarding this Three (3) Year Inspection, please do not hesitate to contact me.

Sincerely,



Michael S. Berta
Health & Safety Project Manager

Building Inspected: Black River Middle School
Building Owner: Chester Twp School District

6 Month Periodic Surveillance Date: 5/13/2021
Performed By: Michael Berta

<u>HID#</u>	<u>Type</u> <u>of</u> <u>ACBM</u>	<u>Friability</u>	<u>Qty</u>	<u>Description</u>	<u>Prior</u> <u>Condition</u>	<u>Present</u> <u>Condition</u>	<u>Comment</u>
-------------	---	-------------------	------------	--------------------	----------------------------------	------------------------------------	----------------

Pump House

A37	T	F	260 SF	Tank Insulation	ND	ND	Continue O&M
-----	---	---	--------	-----------------	----	----	--------------

Material Type: S=Surface, M=Miscellaneous, T=Thermal System
Friability: F=Friable, NF=Non Friable, ---=Non Applicable
ND = No Damage D = Damage NQ = Not Quantified

RUTGERS

School of Public Health

Michael S. Berta

Certificate # RWJ 2932AA

has successfully completed the requisite training for
asbestos accreditation under TSCA Title II in the course entitled
Annual Refresher for AHERA Inspectors

Centers for Education and Training (CET)

Center for Public Health Workforce Development

300 Alton Drive

Somerset, NJ 08873

<http://mhgerstraining.sph.rutgers.edu>

The official record of successful training completion in the New York State is the
Department of Health Certificate of Asbestos Safety Training Completion (DOH 2832)

[Signature]

Mitchel A. Rosen, PhD

Center Director

August 13, 2020

Course Date

[Signature]
Margaret C. Neville, REHS

Course Instructor

August 13, 2020

Exam Date

August 13, 2021


Expiration Date

NIOSH-ERC

Continuing Education and Outreach Program
Universities Occupational Safety and Health Education and Research Center

US EPA SATELLITE

Mid-Atlantic Asbestos Training Center



School of Public Health

Michael S. Berta

Certificate # RWJ 2344BB

has successfully completed the requisite training for
asbestos accreditation under TSCA Title II in the course entitled

AHERA Management Planner Refresher

Centers for Education and Training (CET)

Center for Public Health Workforce Development

300 Atrium Drive, Suite 100

Somerset, NJ 08873

<https://rutgerstraining.sph.rutgers.edu>

The official record of successful training completion in New York State is the
Department of Health Certificate of Asbestos Safety Training Completion (DOH 2832)

This course is 4 hours and may be eligible for AHA/CMA points See ABEHL.org



Mitchel A. Rosen, PhD

Center Director

August 13, 2020

Course Date

August 13, 2020

Exam Date

August 13, 2021

Expiration Date



Margaret C. Neville, REHS

Course Instructor



US EPA SATELLITE

Mid-Atlantic Asbestos Training Center