

Addendum 1 to the Bottle filler project. 5/11/2023

Can the height of the fountain change if it makes it easier to install?

The height of the bubbler should not change more than one from its original height.

Can the fountain be moved left or right if it makes it easier to install?

Yes, fountains can be moved left or right as needed.

Is the contractor responsible for moving electrical outlets?

If the outlet is more than 6 inches edge to edge from the side of the fountain then the contractor will be responsible for moving it.

Without digging in depth adding the fountain in Hillsborough elementary cafeteria would be best if all bidders priced adding a chase wall.

I agree I think it's in the best interest of all parties involved to plan on adding a chase wall.

How will asbestos be handled?

Orange county schools will have all asbestos abated through our abatement monitoring contractor.

Who is responsible for repairing walls back if the fountain is moved and new holes are exposed?

Contractor is responsible for filling holes from old equipment. Contractor is not responsible for painting anything.

At Hillsborough E cafeteria some of the drain to tie into looks like it hasn't been used in a while. What if it's clogged?

Contractor should price for the augering 20 feet of line past the fountain.

Is a bid bond, performance bond, construction bond needed for this project?

No, this project is expected to be under the \$500,000 threshold so no bond requirements are being made.

Can partial payments be made for materials?

Orange county schools will provide a storage location for fillers at the maintenance shop. Orange county schools will pay for any materials stored on location after taking position on maintenance property.