

Inspection Certificate

For

Phila Charter School for Artsb &
Sciences
1197 Haworth Street
Philadelphisa, PA 19124

This Inspection was performed in accordance with applicable Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Date
Jul 16, 2024

Building: Phila Charter School for Artsb & Sciences
Contact: Matthew Wasco
Title: -

Company: Shapiro Fire Protection Company
Contact: Paul Johnson
Title: Technician

Safety Equipment Report

Executive Summary

Generated by: BuildingReports.com

Building Information								
Building: Phila Charter School for Artsb & Sciences			Contact: Matthew Wasco					
Address: 1197 Haworth Street			Phone: 215-537-2520					
Address:			Fax:					
City/State/ZIP Code: Philadelphis, PA 19124			Mobile:					
Country: United States of America			Email: mjwasco@stringtheoryschools.com					
Inspection Performed By								
Company: Shapiro Fire Protection Company			Inspector: Paul Johnson					
Address: 105 Camars Drive			Phone: 215-675-9847					
Address:			Fax: 215-675-4847					
City/State/ZIP Code: Warminster, Pennsylvania 18974			Mobile: 215-622-1017					
Country: United States of America			Email: paul@shapirofire.com					
Inspection Summary								
Category:	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Fire	47	100.00%	47	100.00%	45	95.74%	2	4.26%
Totals	47	100%	47	100.00%	45	95.74%	2	4.26%
Verification								
			Company: Shapiro Fire Protection Company			Building: Phila Charter School for Artsb & Sciences		
			Inspector: Paul Johnson			Contact: Matthew Wasco		

Discrepancy Report

Generated by: BuildingReports.com

Building: Phila Charter School for Artsb & Sciences				
<i>The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is subject to a recall or part of a manufacturer’s replacement/upgrade program is included.</i>				
Device Type	Manufacturer	Model Number	Date	Qty
<i>Items listed for Recall or Replacement/Upgrade</i>				
No items found during this inspection.				
ScanID	Location	Problem	Reference	
<i>Fire</i>				
Fire Extinguisher, A.B.C., 10 Lbs				
BE647641	Ground Maintenance Spare	Discharged	NFPA 10 7.3.2.5	
Fire Extinguisher, Class K, 6 Ltr				
AD64113	Ground Cafeteria Kitchen	Hydro Due	NFPA 10 8.3.1	

Proposed Solutions Report

Generated by: BuildingReports.com

Building: Phila Charter School for Artsb & Sciences					
<i>The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.</i>					
ScanID	Location	Solution	Model #	Cost	Fix
Fire					
Fire Extinguisher, A.B.C., 10 Lbs					
BE647641	Ground Maintenance Spare	Recharge	AB456-12	T/M	☐
Fire Extinguisher, Class K, 6 Ltr					
AD64113	Ground Cafeteria Kitchen	Hydro Test	AB260-12	T/M	☐
PO #: (none)				T/M	

Inspection & Testing

Generated by: BuildingReports.com

Building: Phila Charter School for Artsb & Sciences				
<p><i>The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed /Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.</i></p>				
Device Type	Location	ScanID : S/N	Service	Date Time
Passed				
Fire				
Fire Extinguisher, 5 Lbs, A.B.C.	Ground Ballet Studio G12	BV687004	Annual Service	07/16/24 9:21:33 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Boiler Front	H-96879285	Annual Service	07/16/24 9:26:45 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Boiler Rear	H-96879275	Annual Service	07/16/24 9:27:45 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Boiler room Office	BM998317	Annual Service	07/16/24 9:25:05 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Cafeteria Front	BN000457	Annual Service	07/16/24 10:28:10 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Cafeteria Rear	L680526	Annual Service	07/16/24 9:15:11 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Elevator Closet	BM998318	Annual Service	07/16/24 10:25:17 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Hallway Elevator	BM997773	Annual Service	07/16/24 9:12:05 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Hallway G11	B00814193	Annual Service	07/16/24 9:19:15 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Hallway G5	A27511866	Annual Service	07/16/24 9:08:44 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Hallway G6	BX946573	Annual Service	07/16/24 9:14:18 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Hallway G7	ZR-494106	Annual Service	07/16/24 9:13:17 AM
Fire Extinguisher, 5 Lbs, A.B.C.	Ground Haworth Electrical Room	BV685705	Annual Service	07/16/24 10:26:49 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Kitchen Loading Dock Entrance	BN855818	Annual Service	07/16/24 9:09:45 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Mechanical Back	I-01311176	Annual Service	07/16/24 11:42:53 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Mechanical Front	I-01311174	Annual Service	07/16/24 11:41:38 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Mechanical Middle	I-01317102	Annual Service	07/16/24 11:40:44 AM

Device Type	Location	ScanID : S/N	Service	Date Time
<i>Passed</i>				
Fire				
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Paint Room	BX184433	Annual Service	07/16/24 9:29:06 AM
Fire Extinguisher, 5 Lbs, A.B.C.	Ground Security	BV686375	Annual Service	07/16/24 10:24:24 AM
Fire Extinguisher, 5 Lbs, A.B.C.	1st Haworth Electrical Closet	AV186221	Annual Service	07/16/24 10:21:32 AM
Fire Extinguisher, 10 Lbs, A.B.C.	1st Art room Hallway	B00814186	Annual Service	07/16/24 9:44:39 AM
Fire Extinguisher, 5 Lbs, A.B.C.	1st Auditorium	F-52579638	Annual Service	07/16/24 9:36:13 AM
Fire Extinguisher, 5 Lbs, A.B.C.	1st Auditorium Stage	SU-589707	Annual Service	07/16/24 9:37:34 AM
Fire Extinguisher, 5 Lbs, FE-36	1st Elevator Closet	Y-613187	Annual Service	07/16/24 10:20:15 AM
Fire Extinguisher, 5 Lbs, A.B.C.	1st Gym	F-52579656	Annual Service	07/16/24 9:42:25 AM
Fire Extinguisher, 5 Lbs, A.B.C.	1st Gym	F-52579639	Annual Service	07/16/24 9:43:51 AM
Fire Extinguisher, 10 Lbs, A.B.C.	1st Hallway Haworth Side Gym	G-46661957	Annual Service	07/16/24 11:28:03 AM
Fire Extinguisher, 10 Lbs, A.B.C.	1st Hallway Haworth Stairwell	BN000455	Annual Service	07/16/24 9:47:07 AM
Fire Extinguisher, 10 Lbs, A.B.C.	1st Hallway Outside Main Office	BX184883	Annual Service	07/16/24 9:32:43 AM
Fire Extinguisher, 10 Lbs, A.B.C.	1st Hallway by Elevator	BN001086	Annual Service	07/16/24 9:40:52 AM
Fire Extinguisher, 10 Lbs, A.B.C.	1st Nurse's Office	B00814185	Annual Service	07/16/24 9:39:19 AM
Fire Extinguisher, 5 Lbs, A.B.C.	1st Office	BR619825	Annual Service	07/16/24 9:34:27 AM
Fire Extinguisher, 10 Lbs, A.B.C.	2nd Haworth Electric Closet	SA-440453	Annual Service	07/16/24 10:17:49 AM
Fire Extinguisher, 5 Lbs, A.B.C.	2nd 208	BP911776	Annual Service	07/16/24 9:49:27 AM
Fire Extinguisher, 10 Lbs, A.B.C.	2nd Art room Hallway	BM997255	Annual Service	07/16/24 9:56:41 AM
Fire Extinguisher, 10 Lbs, A.B.C.	2nd Elevator	BX184432	Annual Service	07/16/24 9:55:00 AM
Fire Extinguisher, 5 Lbs, FE-36	2nd Elevator Closet	Y-613200	Annual Service	07/16/24 10:15:11 AM
Fire Extinguisher, 5 Lbs, A.B.C.	2nd Employee Break Room	WS335721	Annual Service	07/16/24 10:00:18 AM
Fire Extinguisher, 10 Lbs, A.B.C.	2nd Hallway 207	BM995170	Annual Service	07/16/24 9:48:14 AM

Device Type	Location	ScanID : S/N	Service	Date Time
<i>Passed</i>				
Fire				
Fire Extinguisher, 10 Lbs, A.B.C.	2nd Hallway 208	BM997774	Annual Service	07/16/24 9:51:43 AM
Fire Extinguisher, 10 Lbs, A.B.C.	2nd Hallway Haworth	BN000459	Annual Service	07/16/24 9:53:31 AM
Fire Extinguisher, 5 Lbs, A.B.C.	3rd Elevator	YX610303	Annual Service	07/16/24 10:03:33 AM
Fire Extinguisher, 10 Lbs, A.B.C.	3rd Elevator Closet	L680518	Annual Service	07/16/24 10:13:30 AM
Fire Extinguisher, 5 Lbs, A.B.C.	3rd Hallway Rm 310	BX184429	Annual Service	07/16/24 10:06:03 AM
Fire Extinguisher, 5 Lbs, A.B.C.	3rd Pull Out Room	BX946572	Annual Service	07/16/24 10:08:01 AM
<i>Failed/Other</i>				
Fire				
Fire Extinguisher, 6 Ltr, Class K	Ground Cafeteria Kitchen	AD64113	Annual Service	07/16/24 9:11:00 AM
Fire Extinguisher, 10 Lbs, A.B.C.	Ground Maintenance Spare	BE647641	Annual Service	07/16/24 9:24:41 AM

Service Summary

Generated by: BuildingReports.com

Building: Phila Charter School for Artsb & Sciences		
The Service Summary section provides an overview of the services performed in this report.		
Device Type	Service	Quantity
<i>Failed/Other</i>		
Fire Extinguisher, 10 Lbs, A.B.C.	Annual Service	1
Fire Extinguisher, 6 Ltr, Class K	Annual Service	1
Total		2
<i>Passed</i>		
Fire Extinguisher, 10 Lbs, A.B.C.	Annual Service	29
Fire Extinguisher, 5 Lbs, A.B.C.	Annual Service	14
Fire Extinguisher, 5 Lbs, FE-36	Annual Service	2
Total		45
Grand Total		47

Fire Extinguisher Maintenance Report

Generated by: BuildingReports.com

Building: Phila Charter School for Artsb & Sciences					
This report provides details on the Hydrostatic Test and Maintenance/Breakdown dates for fire extinguishers. Items that will need either of these services at any time in the next two years are displayed. Items are grouped together by year for budgeting purposes.					
ScanID	Location	Serial #	Hydro	Breakdown	Mfr Date
Due in 2024					
Hydrostatic Test					
Fire Extinguisher, Class K, 6 Ltr					
AD64113	Ground Cafeteria Kitchen		07/01/19		01/01/12
Total Fire Extinguisher, Class K, 6 Ltr:					1
Due in 2025					
Breakdown/Maintenance					
Fire Extinguisher, A.B.C., 10 Lbs					
A27511866	Ground Hallway G5		01/01/14	07/01/19	01/01/14
SA-440453	2nd Haworth Electric Closet		01/01/19	07/01/13	01/01/00
Total Fire Extinguisher, A.B.C., 10 Lbs:					2
Fire Extinguisher, A.B.C., 5 Lbs					
F-52579638	1st Auditorium		01/01/19	01/01/19	01/01/19
SU-589707	1st Auditorium Stage		07/01/19	01/01/13	01/01/01
F-52579656	1st Gym		01/01/19	01/01/19	01/01/19
F-52579639	1st Gym		01/01/19	01/01/19	01/01/19
YX610303	3rd Elevator		07/01/19	01/01/13	01/01/07
AV186221	1st Haworth Electrical Closet		08/19/19	08/18/12	08/19/12
Total Fire Extinguisher, A.B.C., 5 Lbs:					6
Hydrostatic Test					
Fire Extinguisher, A.B.C., 10 Lbs					
BN855818	Ground Kitchen Loading Dock Entrance		01/01/13	07/01/19	01/01/13
BM997773	Ground Hallway Elevator		01/01/13	07/01/19	01/01/13
BX946573	Ground Hallway G6		01/01/13	07/01/19	01/01/13
BM998317	Ground Boiler room Office		01/01/13	07/01/19	01/01/13
BX184433	Ground Paint Room		01/01/13	07/01/19	01/01/13
BX184883	1st Hallway Outside Main Office		01/01/13	07/01/19	01/01/13
BN001086	1st Hallway by Elevator		01/01/13	07/01/19	01/01/13
BN000455	1st Hallway Haworth Stairwell		01/01/13	07/01/19	01/01/13
BM995170	2nd Hallway 207		01/01/13	07/01/19	01/01/13
BM997774	2nd Hallway 208		01/01/13	07/01/19	01/01/13
BN000459	2nd Hallway Haworth		01/01/13	07/01/19	01/01/13
BX184432	2nd Elevator		01/01/13	07/01/19	01/01/13

ScanID	Location	Serial #	Hydro	Breakdown	Mfr Date
Due in 2025					
Hydrostatic Test					
Fire Extinguisher, A.B.C., 10 Lbs					
BM997255	2nd Art room Hallway		01/01/13	07/01/19	01/01/13
BM998318	Ground Elevator Closet		01/01/13	07/01/19	01/01/13
BN000457	Ground Cafeteria Front		01/01/13	07/01/19	01/01/13
			Total Fire Extinguisher, A.B.C., 10 Lbs: 15		
Fire Extinguisher, A.B.C., 5 Lbs					
BV687004	Ground Ballet Studio G12		01/01/13	08/19/19	01/01/13
BR619825	1st Office		01/01/13	07/01/19	01/01/13
BP911776	2nd 208		01/01/13	07/01/19	01/01/13
BX184429	3rd Hallway Rm 310		01/01/13	07/01/19	01/01/13
BX946572	3rd Pull Out Room		01/01/13	07/01/19	01/01/13
BV686375	Ground Security		01/01/13	07/01/19	01/01/13
BV685705	Ground Haworth Electrical Room		01/01/13	07/01/19	01/01/13
			Total Fire Extinguisher, A.B.C., 5 Lbs: 7		
Fire Extinguisher, FE-36, 5 Lbs					
Y-613200	2nd Elevator Closet		01/01/13	07/01/19	01/01/13
Y-613187	1st Elevator Closet		01/01/13	07/01/19	01/01/13
			Total Fire Extinguisher, FE-36, 5 Lbs: 2		
Due in 2026					
Breakdown/Maintenance					
Fire Extinguisher, A.B.C., 10 Lbs					
ZR-494106	Ground Hallway G7		07/01/20	07/01/14	01/01/08
BE647641	Ground Maintenance Spare		07/01/20	07/01/15	01/01/12
			Total Fire Extinguisher, A.B.C., 10 Lbs: 2		
Hydrostatic Test					
Fire Extinguisher, A.B.C., 10 Lbs					
A27511866	Ground Hallway G5		01/01/14	07/01/19	01/01/14
			Total Fire Extinguisher, A.B.C., 10 Lbs: 1		

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Phila Charter School for Artsb & Sciences				
The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.				
Device or Type		Category		Quantity
Fire Extinguisher		Fire		47
Type	Qty	Model #	Description	Manufacture Date
<i>In Service - 90 Days - 1 Year</i>				
Ansul				
Fire Extinguisher	5	X-AA10S	A.B.C.	07/31/2023
<i>In Service - 2 Years to 3 Years</i>				
Ansul				
Fire Extinguisher	1	XAA10S	A.B.C.	08/19/2021
<i>In Service - 5 Years to 10 Years</i>				
Ansul				
Fire Extinguisher	3	X-AA05S-1	A.B.C.	01/01/2019
Badger				
Fire Extinguisher	3	ADV-10	A.B.C.	01/01/2015
<i>In Service - 10 Years to 15 Years</i>				
Amerex				
Fire Extinguisher	1	AB456-14	A.B.C.	01/01/2014
Fire Extinguisher	15	AB456-13	A.B.C.	01/01/2013
Fire Extinguisher	1	A402-13	A.B.C.	01/01/2013
Fire Extinguisher	3	AB402-13	A.B.C.	01/01/2013
Fire Extinguisher	2	AB456-13	A.B.C.	01/01/2013
Fire Extinguisher	1	AB500-13	A.B.C.	01/01/2013
Ansul				
Fire Extinguisher	2	XFE05	FE-36	01/01/2013
Amerex				
Fire Extinguisher	1	AB500-12	A.B.C.	08/19/2012
Fire Extinguisher	1	AB456-12	A.B.C.	01/01/2012
Fire Extinguisher	1	AB260-12	Class K	01/01/2012
Ansul				
Fire Extinguisher	1	XA10H	A.B.C.	01/01/2011
Fire Extinguisher	1	XAA10S	A.B.C.	01/01/2011
<i>In Service - 15 Years to 25 Years</i>				
Buckeye				

Fire Extinguisher	1	10HISA80ABC	A.B.C.	01/01/2008
Amerex				
Fire Extinguisher	1	AB500-07	A.B.C.	01/01/2007
Fire Extinguisher	1	AB402-05	A.B.C.	01/01/2005
Badger				
Fire Extinguisher	1	5MB-6H	A.B.C.	01/01/2001
Amerex				
Fire Extinguisher	1	A402-00	A.B.C.	01/01/2000