

Oriskany CSD
LEAD IN WATER TEST RESULTS

SCHOOL: Walbran Elementary								
LAB: PACE ANALYTICAL					METHOD OF ANALYSIS: EPA METHOD 200.8			
LAB ID#	SCHOOL SAMPLE ID	COLLECTION DATE	SAMPLE LOCATION	OUTLET DESCRIPTION	INITIAL/POST REMEDIATION	LEAD RESULT mcg/L (ppb)	LAB REPORT RECEIPT DATE	ACTION TAKEN FOR OUTLETS GREATER THAN 5mgc/L (ppb)
70299841001	E-001	5/31/2024	Rm 1	Classroom Sink	INITIAL	9.5	6/12/2024	Post
70299841005	E-005	5/31/2024	Rm 4	Classroom Sink	INITIAL	37.3	6/12/2024	Post
70299841012	E-012	5/31/2024	Rm 11	Classroom Sink	INITIAL	9.8	6/12/2024	Post
70299841021	E-021	5/31/2024	Rm 22	Library Sink	INITIAL	47.6	6/12/2024	Post
70299841022	E-022	5/31/2024	Rm 23	Classroom Sink	INITIAL	6.8	6/12/2024	Post
70299841023	E-023	5/31/2024	Rm 24	Classroom Sink	INITIAL	5.1	6/12/2024	Post
70299841027	E-027	5/31/2024	Rm 30	Classroom Sink	INITIAL	39.7	6/12/2024	Post
70299841028	E-028	5/31/2024	Rm 31	Classroom Sink	INITIAL	5.3	6/12/2024	Post
70299841029	E-029	5/31/2024	Rm 32	Classroom Sink	INITIAL	5.4	6/12/2024	Post
70299841030	E-030	5/31/2024	Rm 33	Classroom Sink	INITIAL	15.1	6/12/2024	Post
70299841035	E-035	5/31/2024	Kitchen	Sanit. Sink L side	INITIAL	5.8	6/12/2024	Post
70299841036	E-036	5/31/2024	Kitchen	Sanit. Sink R Side	INITIAL	25.9	6/12/2024	Post
70298841037	E-037	5/31/2024	Kitchen	Kettle Rinse	INITIAL	12.4	6/12/2024	Placard
70299841056	E-056	5/31/2024	Con. Stand	inside Hose Bibb	INITIAL	18.7	6/12/2024	Placard