

# **LEAD IN DRINKING WATER SAMPLING**

*Of*

**Pittsburgh Public Schools**

*Survey Dates: February 15 – 19 and March 26 – June 25, 2019*

*Prepared for:*

Pittsburgh Public Schools  
Facilities  
1305 Muriel Street  
Pittsburgh, Pennsylvania 15203

*Prepared By:*



207 Pine Creek Road  
Wexford, PA 15090

## TABLE OF CONTENTS

1. INTRODUCTION .....	1
2. SAMPLING METHODOLOGY .....	1
3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION .....	2
4. RECOMMENDATIONS .....	9
REPORT DISCLAIMER: .....	10
APPENDIX A DRINKING WATER RESULTS TABLES.....	11
APPENDIX B LABORATORY RESULTS .....	12
APPENDIX C FACILITY MAPS .....	13

## **1. INTRODUCTION**

AGX, Inc. was retained by Pittsburgh Public School District to test for the presence of lead in drinking water. Fixture verification and sampling was conducted at thirty-seven (37) facility buildings and field houses from February 15 – 19 and March 26 – June 25, 2019. The objective of the testing was to screen the drinking water and cooking use fixtures and faucets for lead concentrations.

## **2. SAMPLING METHODOLOGY**

Sample collection, delivery and analysis were conducted according to the EPA's "3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities: A Training, Testing, and Taking Action Approach, October 2018. As per 3Ts, the EPA encourages schools to "prioritize remediation efforts based on lead sample results and to use the steps in the toolkit to pinpoint potential lead sources to reduce lead levels to the lowest possible concentration".

In accordance with the Pennsylvania Public School Code of 1949, as amended June 22, 2018, Section 742, the lead level of drinking water in schools should not exceed the concentrations established by the United States Environmental Protection Agency's (EPA) National Primary Drinking Water Regulations, currently 15 parts per billion (ppb). The testing procedures and recommended lead concentration were designed to pinpoint specific drinking water sources that require remediation. The sampling protocol maximizes the likelihood that the highest concentration of lead is found in the first 250 mL sample.

The action level for lead is not a health based standard and is based upon EPA's evaluation of available data.

Cold water drinking and cooking use fixtures were tested for lead concentrations. Drinking water and cooking fixtures were defined as classroom faucets, home economic faucets, ice machines, kitchen faucets, cafeteria faucets, nurse's office sink faucets, office sink faucets, teacher's lounge sinks, water fountains and miscellaneous sinks found in classrooms and offices. All samples were collected in 250 mL plastic containers that were prepackaged by the analytical laboratory. At each sample location, a first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight (8) hours but less than eighteen (18) hours. A second draw sample was collected after the water in the system was discharged for thirty (30) seconds. All samples were analyzed by RJ Lee, Inc., 350 Hochberg Road, Monroeville, PA 15146, an independent PA certified laboratory.

### **3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION**

Drinking water was tested for lead in thirty-seven (37) schools, field houses, and facility buildings. A total of two thousand two hundred and eighty-seven (2,287) samples were collected from one thousand one hundred and thirteen (1,113) designated drinking water and cooking use fixtures and faucets, service lines, and water mains. Analytical results were received by AGX and reviewed in relation to the EPA “3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities: A Training, Testing, and Taking Action Approach, October 2018 and in accordance with the Pennsylvania Public School Code of 1949, as amended June 22, 2018, Section 742 (Act 39). Based on Act 39, which recognizes the United States Environmental Protection Agency’s (EPA) National Primary Drinking Water Regulations, any lead concentrations at or above 15 parts per billion (ppb) were considered to be elevated.

The results of the sampling showed lead concentrations below 15 parts per billion (ppb) in one thousand and sixty-eight (1,068) of the one thousand one hundred and thirteen (1,113) tested fixtures, or 4%. The low percentage and isolated fixtures with lead concentrations at or above 15 ppb indicated that there were no source water or facility wide lead concerns. Based on testing and observation it is presumed that sources of elevated lead concentrations could be attributed to lack of routine use, fixtures not routinely cleaned and/or older outdated fixtures. Corrective actions, which include shutting off the fixture, posting signage, removing or replacing the aerator, replacing with new sink assembly, and/or removing the sink at any location that exceeded the recommended action level of 15 parts per billion (ppb) has been recommended. Following remediation of fixtures that exceeded the recommended lead concentration, verification sampling was conducted to ensure the lead concentrations in drinking water was reduced below 15 parts per billion (ppb).

#### **Arlington (Phillip Murray):**

At Pittsburgh Arlington PreK-8 (Phillip Murray), a total of thirty-six (36) samples were collected from seventeen (17) drinking water and cooking use fixtures and faucets on June 19, 2019. No samples collected were above the recommended action level of 15 ppb.

#### **Banksville:**

At Pittsburgh Banksville K-5 a total of forty-six (46) samples were collected from twenty-two (22) drinking water and cooking use fixtures and faucets on May 7, 2019. No samples collected were above the recommended action level of 15 ppb.

#### **Brookline:**

At Pittsburgh Brookline PreK-8 a total of ninety (90) samples were collected from forty-three (43) drinking water and cooking use fixtures and faucets on May 9, 2019. One (1) sample (BRO-GF-CF-24) collected was above the recommended action level of 15 ppb.

**Carrick Field House:**

At Pittsburgh Carrick Field House a total of seven (7) samples were collected from three (3) drinking water and cooking use fixtures and faucets on June 6, 2019. No samples collected were above the recommended action level of 15 ppb.

**Carrick:**

At Pittsburgh Carrick High School a total of one hundred and fifty-eight (158) samples were collected from eighty (80) drinking water and cooking use fixtures and faucets on April 18, 2019. Two (2) samples (CAR-02-NF-171 and CAR-01-KF-390) collected were above the recommended action level of 15 ppb.

**Central Operations:**

At Pittsburgh Central Operations a total of fifty-one (51) samples were collected from twenty-five (25) drinking water and cooking use fixtures and faucets on June 26, 2019. No samples collected were above the recommended action level of 15 ppb.

**Chartiers:**

At Pittsburgh Chartiers ECC a total of forty-two (42) samples were collected from twenty (20) drinking water and cooking use fixtures and faucets on February 16, 2019. No samples collected were above the recommended action level of 15 ppb.

**Clayton:**

At Pittsburgh Clayton Academy a total of fifty (50) samples were collected from twenty-three (23) drinking water and cooking use fixtures and faucets on June 12, 2019. Two (2) samples (CLA-01-WC-74) collected were above the recommended action level of 15 ppb.

**Crescent:**

At Pittsburgh Crescent ECC a total of sixty-four (64) samples were collected from thirty-one (31) drinking water and cooking use fixtures and faucets on February 19, 2019. Two (2) samples (CRE-BS-WC-01) collected were above the recommended action level of 15 ppb.

**Cupples Stadium:**

At Pittsburgh Cupples Stadium, a total of thirty-six (36) samples were collected from eighteen (18) drinking water and cooking use fixtures and faucets on June 18, 2019. No samples collected were above the recommended action level of 15 ppb.

**Faison:**

At Pittsburgh Faison K-5 a total of eighty (80) samples were collected from thirty-nine (39) drinking water and cooking use fixtures and faucets on May 8, 2019. No samples collected were above the recommended action level of 15 ppb.

**Greenfield:**

At Pittsburgh Greenfield PreK-8 a total of fifty-two (52) samples were collected from twenty-five (25) drinking water and cooking use fixtures and faucets on April 9, 2019. One (1) sample (GRE-03-CF-67) collected was above the recommended action level of 15 ppb.

**King:**

At Pittsburgh King PreK-8 a total of one hundred and seventy (170) samples were collected from eighty-four (84) drinking water and cooking use fixtures and faucets on April 16, 2019. Five (5) samples (KIN-03-CF-96, KIN-03-CF-126, KIN-03-CF-144, KIN-03-CF-161, and KIN-01-WO-170) collected were above the recommended action level of 15 ppb.

**Langley:**

At Pittsburgh Langley K-8, a total of one hundred and fifty (150) samples were collected from seventy-five (75) drinking water and cooking use fixtures and faucets on May 18, 2019. Two (2) samples (LAN-02-CF-210 and LAN-02-CF-297) collected were above the recommended action level of 15 ppb.

**Lincoln:**

At Pittsburgh Lincoln PreK-5 a total of fifty-six (56) samples were collected from twenty-seven (27) drinking water and cooking use fixtures and faucets on May 2, 2019. Seven (7) samples (LIN-01-NF-16, LIN-02-CF-40, LIN-02-CF-41, LIN-01-MS-58, and LIN-03-MS-62) collected were above the recommended action level of 15 ppb.

**Linden:**

At Pittsburgh Linden K-5 a total of forty-six (46) samples were collected from twenty-two (22) drinking water and cooking use fixtures and faucets on May 14, 2019. Three (3) samples (LND-BS-MS-09 and LND-02-MS-67) collected were above the recommended action level of 15 ppb.

**Manchester:**

At Pittsburgh Manchester PreK-8 a total of seventy-six (76) samples were collected from thirty-seven (37) drinking water and cooking use fixtures and faucets on April 23, 2019. Four (4) samples (MAN-01-CF-05, MAN-02-MS-53, MAN-02-CF-67, and MAN-01-WO-80) collected were above the recommended action level of 15 ppb.

**Miller:**

At Pittsburgh Miller PreK-5 a total of sixty (60) samples were collected from twenty-nine (29) drinking water and cooking use fixtures and faucets on March 27, 2019. No samples collected were above the recommended action level of 15 ppb.

**Milliones:**

At Pittsburgh Milliones 6-12 a total of fifty-four (54) samples were collected from twenty-six (26) drinking water and cooking use fixtures and faucets on April 30, 2019. No samples collected were above the recommended action level of 15 ppb.

**Montessori:**

At Pittsburgh Montessori PreK-5 a total of sixty-four (64) samples were collected from thirty-one (31) drinking water and cooking use fixtures and faucets on February 19, 2019. One (1) sample (MON-02-CF-26) collected was above the recommended action level of 15 ppb.

**Morrow Intermediate:**

At Pittsburgh Morrow Intermediate 5-8 a total of fifty-nine (59) samples were collected from twenty-nine (29) drinking water and cooking use fixtures and faucets on June 13, 2019. No samples collected were above the recommended action level of 15 ppb.

**Morrow:**

At Pittsburgh Morrow PreK-8 a total of seventy-eight (78) samples were collected from thirty-eight (38) drinking water and cooking use fixtures and faucets on March 29, 2019. No samples collected were above the recommended action level of 15 ppb.

**Online Academy (South Annex):**

At Pittsburgh Online Academy (South Annex) a total of twenty-four (24) samples were collected from eleven (11) drinking water and cooking use fixtures and faucets on June 18, 2019. Six (6) samples (SOU-02-CF-20, SOU-02-WC-32, SOU-02-WC-46, SOU-02-CF-47, and SOU-02-CF-48) collected were above recommended action level of 15 ppb.

**Perry Field House:**

At Pittsburgh Perry Field House a total of eleven (11) samples were collected from five (5) drinking water and cooking use fixtures and faucets on June 1, 2019. No samples collected were above the recommended action level of 15 ppb.

**Perry:**

At Pittsburgh Perry High School a total of one hundred and three (103) samples were collected from fifty (50) drinking water and cooking use fixtures and faucets on June 1, 2019. One (1) sample (PER-03-CF-135) collected was above the recommended action level of 15 ppb.

**Pioneer:**

At Pittsburgh Pioneer a total of fourteen (14) samples were collected from six (6) drinking water and cooking use fixtures and faucets on February 16, 2019. No samples collected were above the recommended action level of 15 ppb.

**Roosevelt:**

At Pittsburgh Roosevelt 2-5 a total of thirty-two (32) samples were collected from fifteen (15) drinking water and cooking use fixtures and faucets on May 21, 2019. No samples collected were above the recommended action level of 15 ppb.

**Schenley Field House:**

At Pittsburgh Schenley Field House a total of sixteen (16) samples were collected from seven (7) drinking water and cooking use fixtures and faucets on April 30, 2019. One (1) sample (SFH-GF-FF-13) collected was above the recommended action level of 15 ppb.

**Science and Technology Academy:**

At Pittsburgh Science and Technology Academy 6-12 a total of sixty-one (61) samples were collected from thirty (30) drinking water and cooking use fixtures and faucets on April 25, 2019. No results collected were above the recommended action level of 15 ppb.

**Service Center:**

At Pittsburgh Service Center, a total of thirty (30) samples were collected from fifteen (15) drinking water and cooking use fixtures and faucets on June 27, 2019. No samples collected were above the recommended action level of 15 ppb.

**South Brook:**

At Pittsburgh South Brook 6-8 a total of forty-six (46) samples were collected from twenty-two (22) drinking water and cooking use fixtures and faucets on June 4, 2019. No samples collected were above the recommended action level of 15 ppb.

**Sterrett:**

At Pittsburgh Sterrett 6-8 a total of fifty-three (53) samples were collected from twenty-six (26) drinking water and cooking use fixtures and faucets on June 11, 2019. One (1) sample (STE-01-WC-63) collected was above the recommended action level of 15 ppb.

**Sunnyside:**

At Pittsburgh Sunnyside PreK-8 a total of eighty-four (84) samples were collected from forty-one (41) drinking water and cooking use fixtures and faucets on April 10, 2019. One (1) sample (SUN-01-CF-64) collected was above the recommended action level of 15 ppb.

**Weil:**

At Pittsburgh Weil PreK-5 a total of sixty-two (62) samples were collected from thirty (30) drinking water and cooking use fixtures and faucets on April 4, 2019. Four (4) samples (WEI-01-CF-26, WEI-01-CF-27, WEI-02-CF-44, WEI-02-MS-63) collected were above the recommended action level of 15 ppb.

**West Liberty:**

At Pittsburgh West Liberty PreK-5 a total of forty-two (42) samples were collected from twenty (20) drinking water and cooking use fixtures and faucets on May 22, 2019. No samples collected were above the recommended action level of 15 ppb.



**Westinghouse Academy:**

At Pittsburgh Westinghouse Academy 6-12 a total of one hundred and seventy-four (174) samples were collected from eighty-seven (87) drinking water and cooking use fixtures and faucets on April 6, 2019. Six (6) samples (WES-GF-NF-105, WES-GF-NF-117, WES-01-CF-207, WES-01-MS-212, WES-01-CF-333, and WES-02-CF-336) collected were above the recommended action level of 15 ppb.

**Westinghouse Field House:**

At Pittsburgh Westinghouse Field House a total of ten (10) samples were collected from four (4) drinking water and cooking use fixtures and faucets on April 10, 2019. One (1) sample (WFH-GF-MS-09) collected was above the recommended action level of 15 ppb.

Table 1: Facility drinking water and cooking use fixtures and faucets along with total number of drinking water samples obtained.

School/Building	Date Sampled	Total # of Fixtures	# Samples Collected
Pittsburgh Arlington PreK-8 (Phillip Murray)	6/19/2019	17	36
Pittsburgh Banksville K-5	5/7/2019	22	46
Pittsburgh Brookline PreK-8	5/9/2019	43	90
Pittsburgh Carrick Field House	6/6/2019	3	7
Pittsburgh Carrick High School	4/18/2019	80	158
Pittsburgh Central Operations	6/26/2019	25	51
Pittsburgh Chartiers ECC	2/16/2019	20	42
Pittsburgh Clayton Academy	6/12/2019	23	50
Pittsburgh Crescent ECC	2/19/2019	31	64
Pittsburgh Cupples Stadium	6/18/2019	18	36
Pittsburgh Faison K-5	5/8/2019	39	80
Pittsburgh Greenfield PreK-8	4/9/2019	25	52
Pittsburgh King PreK-8	4/16/2019	84	170
Pittsburgh Langley K-8	5/18/2019	75	150
Pittsburgh Lincoln PreK-5	5/2/2019	27	56
Pittsburgh Linden K-5	5/14/2019	22	46
Pittsburgh Manchester PreK-8	4/23/2019	37	76

School/Building	Date Sampled	Total # of Fixtures	# Samples Collected
Pittsburgh Miller PreK-5	3/27/2019	29	60
Pittsburgh Milliones 6-12	4/30/2019	26	54
Pittsburgh Montessori PreK-5	2/19/2019	31	64
Pittsburgh Morrow Intermediate 5-8	6/13/2019	29	59
Pittsburgh Morrow PreK-8	3/29/2019	38	78
Pittsburgh Online Academy (South Annex)	6/18/2019	11	24
Pittsburgh Perry Field House	6/1/2019	5	11
Pittsburgh Perry High School	6/1/2019	50	103
Pittsburgh Pioneer	2/16/2019	6	14
Pittsburgh Roosevelt 2-5	5/21/2019	15	32
Pittsburgh Schenley Field House	4/30/2019	7	16
Pittsburgh Science and Technology Academy 6-12	4/25/2019	30	61
Pittsburgh Service Center	6/27/2019	15	30
Pittsburgh South Brook 6-8	6/4/2019	22	46
Pittsburgh Sterrett 6-8	6/11/2019	26	53
Pittsburgh Sunnyside PreK-8	4/10/2019	41	84
Pittsburgh Weil PreK-5	4/4/2019	30	62
Pittsburgh West Liberty PreK-5	5/22/2019	20	42
Pittsburgh Westinghouse Academy 6-12	4/6/2019	87	174
Pittsburgh Westinghouse Field House	4/10/2019	4	10

## 4. RECOMMENDATIONS

1. In accordance with the Pennsylvania Public School Code of 1949, as amended June 22, 2018, Section 742, the lead level of drinking water in schools should not exceed the concentrations established by the United States Environmental Protection Agency's National Primary Drinking Water Regulations, currently 15 parts per billion (ppb) and the Pittsburgh Public School District's recommended action level for lead concentrations of 15 parts per billion (ppb); all drinking water sources that exceed 15 ppb or greater should be remediated to reduce lead concentrations. Remediation may include but not be limited to posting signs indicating "not for drinking", cleaning fixtures, replacing individual fixtures with lead free fixtures, replacing the system or plumbing (lead solder joints or brass) with lead free materials, point of source filters and/or disabling fixtures. The remediation action will depend on the fixture and circumstances involved. Following remediation efforts before any drinking water source is placed back into service the fixture should be re-tested to ensure the lead level was reduced below the recommended lead concentration of 15 parts per billion (ppb).
2. A procedure should be implemented to inform staff of best drinking water practices, which should include but not be limited to:
  - a. Staff and students should refrain from using classroom faucets for drinking water. Instead they should be encouraged to use designated water fountains, kitchen faucets and teachers' lounge sinks.
  - b. Prior to drinking, water should be run for one minute or until the water runs cold.
  - c. Only use cold water for drinking and cooking.
3. Following any break longer than five days the water in the facility should be run through drinking water sources to ensure stagnant water has been moved through the plumbing. It is recommended that flushing directions provided by EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002", April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities: A Training, Testing, and Taking Action Approach, October 2018 be followed.
4. A procedure should be implemented to routinely clean drinking water sources and distribution piping. Cleaning should include but not be limited to ensuring fixtures are free from debris, drain properly, aerators (screens) are clean and free from debris, and filters changed in accordance with the manufacture's guidelines.

5. Designate specific drinking water sources and differentiate “Hand Wash Only” or “Not for Drinking” using signs posted at designated non-drinking water sources (restrooms, science labs, utility sinks, wash sinks, etc.).

## **REPORT DISCLAIMER:**

This AGX, Inc. report is based on information supplied by the client, occupants and on conditions readily observable or measurable on the date or dates of this study. The results and recommendations presented herein should not be relied upon exclusively for the prevention of all possible illnesses, injuries, or losses. These services are a supplement to, and not a substitute for, the client’s responsibility for protecting the health and safety of the occupants of the facility, and others, and for complying with applicable laws and regulations.

This report and the associated attachments and appendices have been produced and developed for, and at the request of, Pittsburgh Public Schools. It conveys the findings of AGX as of the date(s) noted herein. This report is intended for the exclusive use of Pittsburgh Board of Public Education (including its management, officers, and the School Board).

## **APPENDIX A**

### **DRINKING WATER RESULTS TABLES**

**Pittsburgh Arlington PreK-8 (Phillip Murray)**

Lead in Drinking Water Sample Results

School: Pittsburgh Arlington PreK-8 (Phillip Murray)

Address: 800 Rehtanwald Street, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PMU-GF-SL-00	SL	Service Line	Pipe Space	6/19/2019	0604	P	<1.00	N/A	N/A	
PMU-GF-WM-00	WM	Water Main	Pipe Space	6/19/2019	0607	P	<1.00	N/A	N/A	
PMU-GF-WC-02	WC	Water fountain with cooler	Corridor GA	6/19/2019	0610	P	<1.00	P	<1.00	
PMU-GF-WC-03	WC	Water fountain with cooler	Corridor GA	6/19/2019	0612	P	<1.00	P	<1.00	
PMU-GF-WF-13	WF	Water fountain with filter & cooler	Corridor GA	6/19/2019	0616	P	<1.00	P	<1.00	
PMU-GF-WFC-14	WFC	Filtering water cooler w/ bottle filler	Corridor GA	6/19/2019	0617	P	<1.00	P	<1.00	
PMU-GF-WC-30	WC	Water fountain with cooler	Corridor GD	6/19/2019	0634	P	<1.00	P	<1.00	
PMU-GF-WC-31	WC	Water fountain with cooler	Corridor GD	6/19/2019	0636	P	<1.00	P	<1.00	
PMU-BS-WF-39	WF	Water fountain with filter & cooler	Lunch Room (B1)	6/19/2019	0640	P	<1.00	P	<1.00	
PMU-BS-WFC-40	WFC	Filtering water cooler w/ bottle filler	Lunch Room (B1)	6/19/2019	0642	P	<1.00	P	<1.00	
PMU-BS-KF-43	KF	Kitchen faucets	Kitchen (B2)	6/19/2019	0644	P	<1.00	P	<1.00	
PMU-01-WC-45	WC	Water fountain with cooler	Corridor 1A	6/19/2019	0651	P	<1.00	P	<1.00	
PMU-01-WC-46	WC	Water fountain with cooler	Corridor 1A	6/19/2019	0652	P	<1.00	P	<1.00	
PMU-01-CF-50	CF	Classroom faucets	203	6/19/2019						Posted Hand Wash Only
PMU-01-MS-51	MS	Miscellaneous sinks	203	6/19/2019						Posted Hand Wash Only
PMU-01-MS-53	MS	Miscellaneous sinks	202	6/19/2019						Posted Hand Wash Only
PMU-01-CF-55	CF	Classroom faucets	202	6/19/2019						Posted Hand Wash Only
PMU-01-WF-56	WF	Water fountain with filter & cooler	Corridor 1A	6/19/2019	0656	P	<1.00	P	<1.00	
PMU-01-WFC-57	WFC	Filtering water cooler w/ bottle filler	Corridor 1A	6/19/2019	0658	P	<1.00	P	<1.00	
PMU-01-WC-70	WC	Water fountain with cooler	Corridor 1D	6/19/2019	0705	P	<1.00	P	<1.00	
PMU-01-WC-71	WC	Water fountain with cooler	Corridor 1D	6/19/2019	0707	P	<1.00	P	2.52	
PMU-GF-TF-78	TF	Teacher's lounge sinks	102	6/19/2019						Posted Hand Wash Only
PMU-GF-HF-83	HF	Home economics faucets (with cooking)	118	6/19/2019	0630	P	<1.00	P	<1.00	
PMU-GF-CF-89	CF	Classroom faucets	104	6/19/2019						Posted Hand Wash Only
PMU-GF-CF-90	CF	Classroom faucets	104	6/19/2019						Posted Hand Wash Only
PMU-01-CF-104	CF	Classroom faucets	226	6/19/2019						Posted Hand Wash Only
PMU-01-WO-105	WO	Water fountain attached to sink	226	6/19/2019	0701	P	<1.00	P	1.16	

## **Pittsburgh Banksville K-5**

---



## Lead in Drinking Water Sample Results

School: Pittsburgh Banksville K-5

Address: 1001 Carnahan Road, Pittsburgh, PA 15216

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
BAN-BS-SL-00	SL	Service Line	B6	5/7/2019	0535	P	<1.00	N/A	N/A	
BAN-BS-WM-00	WM	Water Main	B6	5/7/2019	0537	P	<1.00	N/A	N/A	
BAN-BS-TF-01	TF	Teacher's lounge sinks	B5-B	5/7/2019	0534	P	1.75	P	<1.00	
BAN-GF-WF-05	WF	Water fountain with filter & cooler	Corridor 1	5/7/2019	0545	P	<1.00	P	<1.00	
BAN-GF-WFC-06	WFC	Filtering water cooler w/ bottle filler	Corridor 1	5/7/2019	0546	P	<1.00	P	<1.00	
BAN-GF-CF-07	CF	Classroom faucets	111	5/7/2019	0548	P	1.08	P	<1.00	
BAN-GF-CF-09	CF	Classroom faucets	113	5/7/2019	0553	P	2.32	P	<1.00	
BAN-GF-KF-12	KF	Kitchen faucets	12A	5/7/2019	0551	P	1.32	P	<1.00	
BAN-GF-WO-13	WO	Water fountain without cooler	12	5/7/2019	0550	P	1.07	P	<1.00	
BAN-GF-WF-17	WF	Water fountain with filter & cooler	Corridor 1	5/7/2019	0540	P	<1.00	P	<1.00	
BAN-GF-WFC-18	WFC	Filtering water cooler w/ bottle filler	Corridor 1	5/7/2019	0541	P	<1.00	P	<1.00	
BAN-GF-NF-19	NF	Nurse's office sink faucets	Nurse's Office	5/7/2019	0542	P	<1.00	P	<1.00	
BAN-GF-CF-21	CF	Classroom faucets	104	5/7/2019	0558	P	<1.00	P	<1.00	
BAN-GF-CF-22	CF	Classroom faucets	107	5/7/2019	0556	P	1.84	P	<1.00	
BAN-GF-CF-23	CF	Classroom faucets	105	5/7/2019	0600	P	1.25	P	<1.00	
BAN-01-CF-28	CF	Classroom faucets	208	5/7/2019	0608	P	12.5	P	2.00	
BAN-01-WF-29	WF	Water fountain with filter & cooler	Corridor 101	5/7/2019	0612	P	<1.00	P	<1.00	
BAN-01-WFC-30	WFC	Filtering water cooler w/ bottle filler	Corridor 101	5/7/2019	0613	P	<1.00	P	<1.00	
BAN-01-CF-31	CF	Classroom faucets	211	5/7/2019	0621	P	2.54	P	<1.00	
BAN-01-WC-35	WC	Water fountain with cooler	Corridor 101	5/7/2019	0604	P	<1.00	P	<1.00	
BAN-01-WC-36	WC	Water fountain with cooler	Corridor 101	5/7/2019	0605	P	<1.00	P	<1.00	
BAN-01-CF-40	CF	Classroom faucets	208	5/7/2019	0610	P	1.84	P	<1.00	
BAN-01-CF-41	CF	Classroom faucets	210	5/7/2019	0618	P	1.20	P	<1.00	
BAN-01-MS-42	MS	Miscellaneous sinks	209-Library	5/7/2019	0615	P	3.77	P	<1.00	

## **Pittsburgh Brookline PreK-8**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Brookline PreK-8

Address: 500 Woodbourne Avenue, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
BRO-GF-SL-00	SL	Service Line	15	5/9/2019	0535	P	<1.00	N/A	N/A	
BRO-GF-WM-00	WM	Water Main	15	5/9/2019	0537	P	<1.00	N/A	N/A	
BRO-GF-KF-06	KF	Kitchen faucets	Kitchen (3D)	5/9/2019	0549	P	<1.00	P	<1.00	
BRO-GF-CF-24	CF	Classroom faucets	Demountable Classroom (321)	5/9/2019	0713	F	15.0	P	<1.00	
BRO-GF-CF-27	CF	Classroom faucets	Annex Building (323)	5/9/2019	0720	P	5.64	P	1.19	
BRO-01-WF-32	WF	Water fountain with filter & cooler	Corridor 100A	5/9/2019	0612	P	<1.00	P	<1.00	
BRO-01-WFC-33	WFC	Filtering water cooler w/ bottle filler	Corridor 100A	5/9/2019	0614	P	<1.00	P	<1.00	
BRO-01-WC-43	WC	Water fountain with cooler	Corridor 100B	5/9/2019	0631	P	<1.00	P	<1.00	
BRO-01-WC-44	WC	Water fountain with cooler	Corridor 100B	5/9/2019	0632	P	<1.00	P	<1.00	
BRO-02-TF-48	TF	Teacher's lounge sinks	216	5/9/2019	0637	P	<1.00	P	<1.00	
BRO-02-WF-49	WF	Water fountain with filter & cooler	Corridor 200A	5/9/2019	0641	P	<1.00	P	<1.00	
BRO-02-WFC-50	WFC	Filtering water cooler w/ bottle filler	Corridor 200A	5/9/2019	0642	P	<1.00	P	<1.00	
BRO-02-CF-55	CF	Classroom faucets	202A	5/9/2019	0644	P	<1.00	P	<1.00	
BRO-02-NF-57	NF	Nurse's office sink faucets	200A	5/9/2019	0639	P	1.64	P	<1.00	
BRO-02-WC-64	WC	Water fountain with cooler	Corridor 200B	5/9/2019	0657	P	<1.00	P	<1.00	
BRO-02-WC-65	WC	Water fountain with cooler	Corridor 200B	5/9/2019	0658	P	<1.00	P	<1.00	
BRO-02-CF-66	CF	Classroom faucets	213	5/9/2019	0700	P	<1.00	P	<1.00	
BRO-GF-CF-71	CF	Classroom faucets	11F	5/9/2019	0558	P	6.93	P	<1.00	
BRO-GF-CF-72	CF	Classroom faucets	11	5/9/2019	0602	P	<1.00	P	<1.00	
BRO-01-CF-73	CF	Classroom faucets	103A	5/9/2019	0616	P	<1.00	P	<1.00	
BRO-01-WC-74	WC	Water fountain with cooler	Corridor 100A	5/9/2019	0620	P	<1.00	P	<1.00	
BRO-01-WC-75	WC	Water fountain with cooler	Corridor 100A	5/9/2019	0621	P	<1.00	P	<1.00	
BRO-01-CF-76	CF	Classroom faucets	104A	5/9/2019	0624	P	8.00	P	3.62	
BRO-01-CF-77	CF	Classroom faucets	107A	5/9/2019	0623	P	7.69	P	1.25	
BRO-01-CF-78	CF	Classroom faucets	105A	5/9/2019	0627	P	8.80	P	4.77	
BRO-01-CF-79	CF	Classroom faucets	106A	5/9/2019	0629	P	6.62	P	<1.00	
BRO-01-MS-80	MS	Miscellaneous sinks	Library - 115	5/9/2019	0634	P	1.11	P	<1.00	
BRO-02-WC-81	WC	Water fountain with cooler	Corridor 200A	5/9/2019	0652	P	<1.00	P	<1.00	
BRO-02-WC-82	WC	Water fountain with cooler	Corridor 200A	5/9/2019	0653	P	<1.00	P	<1.00	
BRO-02-CF-83	CF	Classroom faucets	206A	5/9/2019	0647	P	1.73	P	<1.00	
BRO-02-CF-84	CF	Classroom faucets	205A	5/9/2019	0654	P	<1.00	P	<1.00	
BRO-GF-WO-85	WO	Water Fountain attached to sink	Demountable Classroom (321)	5/9/2019	0714	P	<1.00	P	<1.00	
BRO-GF-CF-86	CF	Classroom faucets	Demountable Classroom (320)	5/9/2019	0716	P	1.00	P	<1.00	
BRO-GF-WO-87	WO	Water Fountain attached to sink	Demountable Classroom (320)	5/9/2019	0717	P	1.13	P	<1.00	
BRO-GF-WO-88	WO	Water Fountain attached to sink	Annex Building (323)	5/9/2019	0721	P	1.28	P	<1.00	
BRO-GF-CF-89	CF	Classroom faucets	Annex Building (322)	5/9/2019	0723	P	5.80	P	<1.00	
BRO-GF-WO-90	WO	Water Fountain attached to sink	Annex Building (322)	5/9/2019	0724	P	1.29	P	<1.00	
BRO-GF-WF-91	WF	Water fountain with filter & cooler	Corridor 1	5/9/2019	0544	P	<1.00	P	<1.00	
BRO-GF-WFC-92	WFC	Filtering water cooler w/ bottle filler	Corridor 1	5/9/2019	0546	P	<1.00	P	<1.00	
BRO-GF-CF-93	CF	Classroom faucets	13	5/9/2019	0554	P	2.77	P	<1.00	
BRO-GF-MS-94	MS	Miscellaneous sinks	11B	5/9/2019	0607	P	<1.00	P	<1.00	
BRO-GF-CF-95	CF	Classroom faucets	11F	5/9/2019	0559	P	<1.00	P	<1.00	
BRO-GF-KF-97	KF	Kitchen faucets	Kitchen (3D)	5/9/2019	0550	P	<1.00	P	<1.00	
BRO-GF-SL-98	SL	Service Line	Street	5/9/2019	0709	P	<1.00	N/A	N/A	
BRO-GF-WM-98	WM	Water Main	Street	5/9/2019	0712	P	<1.00	N/A	N/A	
BRO-02-CF-102	CF	Classroom faucets	203A	5/9/2019	0650	P	1.87	P	1.04	
BRO-GF-CF-104	CF	Classroom faucets	11	5/9/2019	0604	P	<1.00	P	<1.00	

**Pittsburgh Carrick Field House**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Carrick Field House

Address: Park Boulevard, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing (B)	Second Draw Lead Concentration (ppb)	Comments
CFH-01-SL-00	SL	Service Line	Utility Room	6/6/2019	0656	P	<1.00	N/A	N/A	
CFH-01-WM-00	WM	Water Main	Utility Room	6/6/2019	0658	P	<1.00	N/A	N/A	
CFH-01-US-03	US	Utility sinks	Utility Room	6/6/2019	0655	P	1.15	P	<1.00	
CFH-01-WO-16	WO	Water fountain without cooler	Outside Field House	6/6/2019	0700	P	<1.00	P	<1.00	
CFH-01-IM-19	IM	Ice machines	Training Room	6/6/2019	0703	P	<1.00	N/A	N/A	

**Pittsburgh Carrick High School**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Carrick High School

Address: 125 Parkfield Street, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CAR-SB-SL-00	SL	Service Line	Boiler Room	4/18/2019	0554	P	<1.00	N/A	N/A	
CAR-SB-WM-00	WM	Water Main	Boiler Room	4/18/2019	0556	P	<1.00	N/A	N/A	
CAR-BS-WC-03	WC	Water fountain with cooler	B9	4/18/2019	0600	P	<1.00	P	<1.00	
CAR-BS-WFC-05	WFC	Filtering water cooler w/ bottle filler	Basement Corridor	4/18/2019	0602	P	<1.00	P	<1.00	
CAR-BS-CF-07	CF	Classroom faucets	B-1	4/18/2019	0603	P	<1.00	P	<1.00	
CAR-BS-WC-08	WC	Water fountain with cooler	B-1	4/18/2019	0604	P	<1.00	P	<1.00	
CAR-01-CF-09	CF	Classroom faucets	703	4/18/2019	0625	P	<1.00	P	<1.00	
CAR-01-CF-10	CF	Classroom faucets	703	4/18/2019	0626	P	<1.00	P	<1.00	
CAR-01-CF-11	CF	Classroom faucets	701	4/18/2019						Not in Operation - Water Turned Off Due to Construction
CAR-01-WF-13	WF	Water fountain with filter & cooler	Corridor 700	4/18/2019	0630	P	<1.00	P	<1.00	
CAR-01-WFC-14	WFC	Filtering water cooler w/ bottle filler	Corridor 700	4/18/2019	0631	P	<1.00	P	<1.00	
CAR-01-WC-21	WC	Water fountain with cooler	Corridor 700	4/18/2019	0656	P	<1.00	P	<1.00	
CAR-01-WC-22	WC	Water fountain with cooler	Corridor 700	4/18/2019	0657	P	<1.00	P	<1.00	
CAR-01-WC-48	WC	Water fountain with cooler	715	4/18/2019	0636	P	<1.00	P	<1.00	
CAR-01-MS-56	MS	Miscellaneous sinks	704	4/18/2019	0639	P	<1.00	P	<1.00	
CAR-01-IM-57	IM	Ice machines	704	4/18/2019	0640	P	<1.00	N/A	N/A	
CAR-01-WC-67	WC	Water fountain with cooler	728	4/18/2019	0644	P	<1.00	P	<1.00	
CAR-01-WC-68	WC	Water fountain with cooler	736	4/18/2019	0649	P	<1.00	P	<1.00	
CAR-01-WC-69	WC	Water fountain with cooler	736	4/18/2019	0650	P	<1.00	P	<1.00	
CAR-01-WC-84	WC	Water fountain with cooler	726	4/18/2019	0652	P	1.08	P	<1.00	
CAR-01-WFC-100	WFC	Filtering water cooler w/ bottle filler	Corridor 100	4/18/2019	0621	P	<1.00	P	<1.00	
CAR-01-MS-105	MS	Miscellaneous sinks	116	4/18/2019						Not in Operation - Water Turned Off Due to Construction
CAR-01-KF-107	KF	Kitchen faucets	Kitchen	4/18/2019	0615	P	1.34	P	<1.00	
CAR-01-KF-109	KF	Kitchen faucets	Kitchen	4/18/2019	0616	P	<1.00	P	<1.00	
CAR-01-KF-110	KF	Kitchen faucets	Kitchen	4/18/2019	0617	P	1.26	P	<1.00	
CAR-01-KF-112	KF	Kitchen faucets	Kitchen	4/18/2019	0618	P	2.08	P	<1.00	
CAR-01-MS-116	MS	Miscellaneous sinks	200	4/18/2019	0702	P	<1.00	P	<1.00	
CAR-01-TF-117	TF	Teacher's lounge sinks	201	4/18/2019	0704	P	1.04	P	<1.00	
CAR-01-CF-120	CF	Classroom faucets	205	4/18/2019	0706	P	<1.00	P	<1.00	
CAR-01-CF-121	CF	Classroom faucets	205	4/18/2019	0707	P	<1.00	P	<1.00	
CAR-01-WF-122	WF	Water fountain with filter & cooler	Corridor 200	4/18/2019	0709	P	<1.00	P	<1.00	
CAR-01-WFC-123	WFC	Filtering water cooler w/ bottle filler	Corridor 200	4/18/2019	0710	P	<1.00	P	<1.00	
CAR-01-CF-127	CF	Classroom faucets	227	4/18/2019	0716	P	<1.00	P	<1.00	
CAR-01-CF-129	CF	Classroom faucets	230	4/18/2019						Not in Operation
CAR-01-KF-130	KF	Home EC. Kitchen Faucet	226	4/18/2019	0720	P	3.10	P	<1.00	
CAR-01-IM-131	IM	Ice machines	226	4/18/2019	0722	P	<1.00	N/A	N/A	
CAR-01-CF-136	CF	Classroom faucets	228	4/18/2019	0734	P	1.57	P	<1.00	
CAR-01-CF-137	CF	Classroom faucets	228	4/18/2019	0735	P	<1.00	P	<1.00	
CAR-01-CF-138	CF	Classroom faucets	228	4/18/2019	0736	P	3.76	P	<1.00	
CAR-01-CF-139	CF	Classroom faucets	228	4/18/2019	0738	P	<1.00	P	<1.00	
CAR-01-CF-140	CF	Classroom faucets	228	4/18/2019	0739	P	1.41	P	<1.00	
CAR-01-CF-141	CF	Classroom faucets	228	4/18/2019	0740	P	<1.00	P	<1.00	
CAR-01-KF-142	KF	Home EC. Kitchen Faucet	226	4/18/2019	0723	P	1.62	P	<1.00	
CAR-01-KF-143	KF	Home EC. Kitchen Faucet	226	4/18/2019	0724	P	1.33	P	<1.00	
CAR-01-KF-145	KF	Home EC. Kitchen Faucet	226	4/18/2019	0727	P	2.75	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Carrick High School

Address: 125 Parkfield Street, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CAR-01-CF-149	CF	Classroom faucets	206	4/18/2019	0713	P	<1.00	P	<1.00	
CAR-02-CF-150	CF	Classroom faucets	338	4/18/2019	0748	P	<1.00	P	<1.00	
CAR-02-CF-151	CF	Classroom faucets	338	4/18/2019	0749	P	<1.00	P	<1.00	
CAR-02-CF-152	CF	Classroom faucets	338	4/18/2019	0750	P	<1.00	P	<1.00	
CAR-02-WC-153	WC	Water fountain with cooler	Corridor 300	4/18/2019	0800	P	<1.00	P	<1.00	
CAR-02-CF-154	CF	Classroom faucets	337	4/18/2019	0756	P	<1.00	P	<1.00	
CAR-02-CF-155	CF	Classroom faucets	337	4/18/2019	0758	P	<1.00	P	<1.00	
CAR-02-CF-156	CF	Classroom faucets	335	4/18/2019	0802	P	<1.00	P	<1.00	
CAR-02-WF-162	WF	Water fountain with filter & cooler	Corridor 300	4/18/2019	0809	P	<1.00	P	<1.00	
CAR-02-WFC-163	WFC	Filtering water cooler w/ bottle filler	Corridor 300	4/18/2019	0810	P	<1.00	P	<1.00	
CAR-02-MS-169	MS	Miscellaneous sinks	305	4/18/2019	0815	P	<1.00	P	<1.00	
CAR-02-NF-171	NF	Nurse's office sink faucets	301C	4/18/2019	0817	F	36.1	P	1.98	
CAR-02-NF-172	NF	Nurse's office sink faucets	301B	4/18/2019	0818	P	6.51	P	<1.00	
CAR-02-NF-173	NF	Nurse's office sink faucets	301	4/18/2019	0819	P	1.60	P	<1.00	
CAR-02-TF-174	TF	Teacher's lounge sinks	401	4/18/2019	0823	P	<1.00	P	<1.00	
CAR-02-WF-176	WF	Water fountain with filter & cooler	Corridor 400	4/18/2019	0826	P	<1.00	P	<1.00	
CAR-02-WFC-177	WFC	Filtering water cooler w/ bottle filler	Corridor 400	4/18/2019	0827	P	<1.00	P	<1.00	
CAR-03-WC-228	WC	Water fountain with cooler	Corridor 500	4/18/2019	0838	P	<1.00	P	<1.00	
CAR-03-WF-339	WF	Water fountain with filter & cooler	Corridor 500	4/18/2019	0841	P	<1.00	P	<1.00	
CAR-03-WFC-340	WFC	Filtering water cooler w/ bottle filler	Corridor 500	4/18/2019	0842	P	<1.00	P	<1.00	
CAR-03-TF-354	TF	Teacher's lounge sinks	502	4/18/2019	0843	P	3.26	P	<1.00	
CAR-03-TF-355	TF	Teacher's lounge sinks	601	4/18/2019	0847	P	5.56	P	<1.00	
CAR-03-WF-357	WF	Water fountain with filter & cooler	Corridor 600	4/18/2019	0852	P	<1.00	P	<1.00	
CAR-03-WFC-358	WFC	Filtering water cooler w/ bottle filler	Corridor 600	4/18/2019	0853	P	<1.00	P	<1.00	
CAR-03-MS-362	MS	Miscellaneous sinks	611	4/18/2019	0855	P	<1.00	P	<1.00	
CAR-04-TF-366	TF	Teacher's lounge sinks	801	4/18/2019	0903	P	<1.00	P	<1.00	
CAR-04-WF-368	WF	Water fountain with filter & cooler	Corridor 800	4/18/2019	0905	P	<1.00	P	<1.00	
CAR-04-WFC-369	WFC	Filtering water cooler w/ bottle filler	Corridor 800	4/18/2019	0907	P	<1.00	P	<1.00	
CAR-BS-MS-375	MS	Miscellaneous sinks	B-6	4/18/2019	0607	P	3.27	P	<1.00	
CAR-01-WQ-376	WO	Water Fountain Attached to Sink	701	4/18/2019						Not in Operation - Water Turned Off Due to Construction
CAR-01-WQ-377	WO	Water Fountain Attached to Sink	703	4/18/2019	0627	P	<1.00	P	<1.00	
CAR-01-IM-385	IM	Ice machines	Kitchen	4/18/2019						Not in Operation
CAR-03-WC-388	WC	Water fountain with cooler	Outside 328	4/18/2019	0806	P	1.25	P	<1.00	
CAR-01-KF-390	KF	Home EC. Kitchen Faucet	226	4/18/2019	0729	F	32.3	P	<1.00	
CAR-02-TF-392	TF	Teacher's lounge sinks	302	4/18/2019	0813	P	<1.00	P	<1.00	
CAR-02-CF-393	CF	Classroom faucets	335	4/18/2019	0803	P	<1.00	P	<1.00	
CAR-02-CF-394	CF	Classroom faucets	338	4/18/2019	0752	P	<1.00	P	<1.00	
CAR-02-CF-395	CF	Classroom faucets	338	4/18/2019	0753	P	1.11	P	<1.00	
CAR-02-WC-396	WC	Water fountain with cooler	418	4/18/2019	0831	P	<1.00	P	<1.00	
CAR-02-CF-397	CF	Classroom faucets	418	4/18/2019	0832	P	<1.00	P	<1.00	
CAR-01-WC-399	WC	Water fountain with cooler	711	4/18/2019	0634	P	<1.00	P	<1.00	
CAR-01-IM-402	IM	Ice machines	728B	4/18/2019						Not in Operation



## **Pittsburgh Central Operations**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Central Operations

Address: 8 S. 13th Street, Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
COP-01-SL-00	SL	Service Line	Storage (131)	6/26/2019	0559	P	<1.00	N/A	N/A	
COP-01-WM-00	WM	Water Main	Storage (131)	6/26/2019	0602	P	<1.00	N/A	N/A	
COP-01-KF-04	KF	Kitchen faucets	Lunch Room (106)	6/26/2019	0603	P	<1.00	P	<1.00	
COP-01-WF-06	WF	Water fountain with filter & cooler	Corridor 117	6/26/2019	0607	P	<1.00	P	<1.00	
COP-01-WFC-07	WFC	Filtering water cooler w/ bottle filler	Corridor 117	6/26/2019	0608	P	<1.00	P	<1.00	
COP-01-KF-14	KF	Kitchen faucets	Kitchen	6/26/2019	0614	P	1.44	P	<1.00	
COP-01-KF-15	KF	Kitchen faucets	Kitchen	6/26/2019	0615	P	<1.00	P	<1.00	
COP-01-WC-18	WC	Water fountain with cooler	Kitchen	6/26/2019	0617	P	4.84	P	4.12	
COP-01-WC-21	WC	Water fountain with cooler	Kitchen	6/26/2019	0619	P	1.86	P	1.72	
COP-01-KF-24	KF	Kitchen faucets	Kitchen	6/26/2019	0620	P	<1.00	P	<1.00	
COP-01-KF-25	KF	Kitchen faucets	Kitchen	6/26/2019	0622	P	<1.00	P	<1.00	
COP-01-WC-26	WC	Water fountain with cooler	Kitchen	6/26/2019	0624	P	1.63	P	1.36	
COP-01-KF-28	KF	Kitchen faucets	Kitchen	6/26/2019	0625	P	1.33	P	<1.00	
COP-01-KF-29	KF	Kitchen faucets	Kitchen	6/26/2019	0626	P	<1.00	P	<1.00	
COP-02-MS-30	MS	Miscellaneous sinks	Conference Room	6/26/2019	0631	P	<1.00	P	<1.00	
COP-02-WC-31	WC	Water fountain with cooler	Elevator Lobby	6/26/2019	0632	P	1.14	P	<1.00	
COP-02-WC-32	WC	Water fountain with cooler	Elevator Lobby	6/26/2019	0633	P	2.36	P	<1.00	
COP-03-MS-38	MS	Miscellaneous sinks	Coffee (204)	6/26/2019	0642	P	1.43	P	<1.00	
COP-03-WC-39	WC	Water fountain with cooler	Office Area	6/26/2019	0637	P	<1.00	P	<1.00	
COP-03-WC-40	WC	Water fountain with cooler	Office Area	6/26/2019	0639	P	<1.00	P	<1.00	
COP-03-MS-55	MS	Miscellaneous sinks	Plant Operations	6/26/2019	0646	P	<1.00	P	<1.00	
COP-03-WC-58	WC	Water fountain with cooler	Corridor 233	6/26/2019	0647	P	<1.00	P	<1.00	
COP-03-WC-59	WC	Water fountain with cooler	Corridor 233	6/26/2019	0648	P	<1.00	P	<1.00	
COP-01-IM-62	IM	Ice machines	Lunch Room (106)	6/26/2019	0604	P	<1.00	N/A	N/A	
COP-01-MS-63	MS	Miscellaneous sinks	Lunch Room (106)	6/26/2019	0605	P	<1.00	P	<1.00	
COP-03-MS-73	MS	Miscellaneous sinks	Coffee (204)	6/26/2019	0643	P	<1.00	P	<1.00	
COP-01-MS-75	MS	Miscellaneous sinks	Kitchen	6/26/2019	0621	P	<1.00	P	<1.00	

## **Pittsburgh Chartiers Early Childhood Center**

Lead in Drinking Water Sample Results

School: Pittsburgh Chartiers Early Childhood Center

Address: 3799 Chartiers Avenue, Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CHA-01-SL-00	SL	Service Line	113	2/16/2019	0553	P	<1.00	N/A	N/A	
CHA-01-WM-00	WM	Water Main	113	2/16/2019	0555	P	<1.00	N/A	N/A	
CHA-01-WF-01	WF	Filtering water cooler w/ bottle filler	Corridor 100	2/16/2019	0557	P	<1.00	P	<1.00	CHA-01-WF-13
CHA-01-WFC-02	WFC	Filtering water cooler w/ bottle filler	Corridor 100	2/16/2019	0558	P	<1.00	P	<1.00	CHA-01-WFC-35
CHA-01-OF-03	OF	Office sink faucets	102	2/16/2019	0600	P	9.70	P	4.50	CHA-01-OF-11
CHA-01-CF-04	CF	Classroom faucets	105	2/16/2019	0602	P	<1.00	P	<1.00	CHA-01-CF-01
CHA-01-MS-05	MS	Miscellaneous sinks	105	2/16/2019	0603	P	1.10	P	<1.00	CHA-01-MS-36
CHA-01-CF-06	CF	Classroom faucets	101	2/16/2019	0605	P	<1.00	P	<1.00	CHA-01-CF-04
CHA-01-MS-07	MS	Miscellaneous sinks	101	2/16/2019	0606	P	<1.00	P	<1.00	CHA-01-MS-37
CHA-01-KF-08	KF	Kitchen faucets	121-B	2/16/2019	0608	P	<1.00	P	<1.00	CHA-01-KF-15
CHA-01-WC-09	WC	Water fountain with cooler	121	2/16/2019	0610	P	<1.00	P	<1.00	CHA-01-WC-16
CHA-01-WC-10	WC	Water fountain with cooler	121	2/16/2019	0613	P	<1.00	P	<1.00	CHA-01-WC-17
CHA-02-WFC-11	WFC	Filtering water cooler w/ bottle filler	101-A	2/16/2019	0617	P	<1.00	P	<1.00	CHA-02-WFC-24
CHA-02-WF-12	WF	Water fountain with filter & cooler	101-A	2/16/2019	0616	P	<1.00	P	<1.00	CHA-02-WF-25
CHA-02-CF-13	CF	Classroom faucets	202	2/16/2019	0626	P	4.59	P	1.30	CHA-02-CF-31
CHA-02-CF-14	CF	Classroom faucets	201	2/16/2019	0623	P	8.04	P	1.15	CHA-02-CF-32
CHA-02-MS-15	MS	Miscellaneous sinks	201	2/16/2019	0624	P	<1.00	P	<1.00	CHA-02-MS-38
CHA-02-CF-16	CF	Classroom faucets	204	2/16/2019	0628	P	2.78	P	1.03	CHA-02-CF-33

## **Pittsburgh Clayton Academy**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Clayton Academy

Address: 1901 Clayton Avenue, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CLA-BS-SL-00	SL	Service Line	Boiler Room	6/12/2019	0530	P	<1.00	N/A	N/A	
CLA-BS-WM-00	WM	Water Main	Boiler Room	6/12/2019	0533	P	<1.00	N/A	N/A	
CLA-BS-MS-02	MS	Miscellaneous sinks	SB02	6/12/2019	0534	P	1.38	P	<1.00	
CLA-GF-WF-03	WF	Water fountain with filter & cooler	Gym Corridor	6/12/2019	0537	P	<1.00	P	<1.00	
CLA-GF-KF-06	KF	Kitchen faucets	Kitchen	6/12/2019	0539	P	1.76	P	<1.00	
CLA-GF-KF-09	KF	Kitchen faucets	Kitchen	6/12/2019	0540	P	2.35	P	<1.00	
CLA-01-NF-13	NF	Nurse's office sink faucets	Nurse (104B)	6/12/2019	0545	P	6.86	P	<1.00	
CLA-01-WF-16	WF	Water fountain with filter & cooler	Across from 105	6/12/2019	0546	P	<1.00	P	<1.00	
CLA-01-WFC-17	WFC	Filtering water cooler w/ bottle filler	Across from 105	6/12/2019	0547	P	<1.00	P	<1.00	
CLA-01-MS-20	MS	Miscellaneous sinks	Art Room (116)	6/12/2019	0549	P	<1.00	P	<1.00	
CLA-01-WC-21	WC	Water fountain with cooler	Art Room (116)	6/12/2019	0550	P	<1.00	P	<1.00	
CLA-01-WC-23	WC	Water fountain with cooler	Outside 108	6/12/2019	0552	P	1.70	P	1.58	
CLA-01-WC-24	WC	Water fountain with cooler	Outside 108	6/12/2019	0553	P	1.08	P	1.24	
CLA-GF-MS-28	MS	Miscellaneous sinks	Computer Lab (110)	6/12/2019	0555	P	<1.00	P	<1.00	
CLA-01-WC-29	WC	Water fountain with cooler	Computer Lab (110)	6/12/2019	0556	P	<1.00	P	<1.00	
CLA-02-WC-33	WC	Water fountain with cooler	Library (201)	6/12/2019	0604	P	2.25	P	1.57	
CLA-02-MS-34	MS	Miscellaneous sinks	Library (201)	6/12/2019	0603	P	<1.00	P	<1.00	
CLA-02-WC-39	WC	Water fountain with cooler	Across from 203	6/12/2019	0606	P	1.66	P	1.40	
CLA-02-WC-40	WC	Water fountain with cooler	Across from 203	6/12/2019	0607	P	2.38	P	3.19	
CLA-02-WF-42	WF	Water fountain with filter & cooler	Outside 205	6/12/2019	0609	P	<1.00	P	<1.00	
CLA-02-WFC-43	WFC	Filtering water cooler w/ bottle filler	Outside 205	6/12/2019	0610	P	<1.00	P	<1.00	
CLA-02-WC-47	WC	Water fountain with cooler	Comuter Lab (206)	6/12/2019	0612	P	<1.00	P	<1.00	
CLA-02-MS-48	MS	Miscellaneous sinks	Comuter Lab (206)	6/12/2019	0611	P	<1.00	P	<1.00	
CLA-01-TF-53	TF	Teacher's lounge sinks	Teacher's Lab (103A)	6/12/2019	0543	P	<1.00	P	<1.00	
CLA-01-SL-71	SL	Service Line	Demountable (AC3)	6/12/2019	0618	P	14.1	N/A	N/A	
CLA-01-WM-71	WM	Water Main	Demountable (AC3)	6/12/2019	0621	P	6.36	N/A	N/A	
CLA-01-WC-74	WC	Water fountain with cooler	Demountable Entry	6/12/2019	0622	F	15.8	F	15.2	

**Pittsburgh Crescent Early Childhood Center**

Lead in Drinking Water Sample Results

School: Pittsburgh Crescent Early Childhood Center

Address: 8080 Bennett Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CRE-BS-SL-00	SL	Service Line	Boiler Room	2/16/2019	0506	P	<1.00	N/A	N/A	
CRE-BS-WM-00	WM	Water Main	Boiler Room	2/16/2019	0509	P	<1.00	N/A	N/A	
CRE-BS-WC-01	WC	Water fountain with cooler	Corridor 9	2/16/2019	0510	F	82.8	F	39.7	Fixture inaccessible to Students
CRE-01-CF-02	CF	Classroom faucets	105	2/16/2019	0513	P	2.72	P	<1.00	CRE-01-CF-20
CRE-01-WC-03	WC	Water fountain with cooler	Corridor 100	2/16/2019	0515	P	<1.00	P	<1.00	CRE-01-WC-08
CRE-01-WC-04	WC	Water fountain with cooler	Corridor 100	2/16/2019	0515	P	<1.00	P	<1.00	CRE-01-WC-09
CRE-01-WF-05	WF	Water fountain with filter & cooler	Corridor 100	2/16/2019	0517	P	<1.00	P	<1.00	CRE-01-WF-10
CRE-01-WFC-06	WFC	Filtering water cooler w/ bottle filler	Corridor 100	2/16/2019	0519	P	<1.00	P	<1.00	CRE-01-WFC-11
CRE-01-MS-07	MS	Miscellaneous sinks	101	2/16/2019	0521	P	1.16	P	<1.00	CRE-01-RF-25
CRE-01-MS-08	MS	Miscellaneous sinks	101	2/16/2019	0522	P	<1.00	P	<1.00	CRE-01-MS-61
CRE-01-CF-09	CF	Classroom faucets	101	2/16/2019	0524	P	<1.00	P	<1.00	CRE-01-CF-24
CRE-01-CF-10	CF	Classroom faucets	101	2/16/2019	0525	P	2.06	P	<1.00	CRE-01-CF-23
CRE-01-CF-11	CF	Classroom faucets	115	2/16/2019	0528	P	<1.00	P	<1.00	CRE-01-CF-15
CRE-01-CF-12	CF	Classroom faucets	115	2/16/2019	0535	P	<1.00	P	<1.00	CRE-01-CF-16
CRE-01-MS-13	MS	Miscellaneous sinks	115	2/16/2019	0536	P	<1.00	P	<1.00	CRE-01-MS-62
CRE-01-MS-14	MS	Miscellaneous sinks	115	2/16/2019	0538	P	<1.00	P	<1.00	CRE-01-RF-17
CRE-01-MS-15	MS	Miscellaneous sinks	115	2/16/2019	0539	P	<1.00	P	<1.00	CRE-01-MS-63
CRE-01-MS-16	MS	Miscellaneous sinks	115	2/16/2019	0540	P	<1.00	P	<1.00	CRE-01-MS-64
CRE-01-KF-17	KF	Kitchen faucets	Lobby 119A	2/16/2019	0545	P	1.49	P	2.20	CRE-01-KF-28
CRE-02-WC-18	WC	Water fountain with cooler	Corridor 200	2/16/2019	0550	P	<1.00	P	<1.00	CRE-02-WC-34
CRE-02-WC-19	WC	Water fountain with cooler	Corridor 200	2/16/2019	0551	P	<1.00	P	<1.00	CRE-02-WC-35
CRE-02-WF-20	WF	Water fountain with filter & cooler	Corridor 200	2/16/2019	0553	P	<1.00	P	<1.00	CRE-02-WF-37
CRE-02-WFC-21	WFC	Filtering water cooler w/ bottle filler	Corridor 200	2/16/2019	0554	P	<1.00	P	<1.00	CRE-02-WFC-38
CRE-02-MS-22	MS	Miscellaneous sinks	203	2/16/2019	0557	P	1.13	P	2.17	CRE-02-MS-36
CRE-02-CF-23	CF	Classroom faucets	207	2/16/2019	0600	P	2.66	P	1.31	CRE-02-CF-42
CRE-02-CF-24	CF	Classroom faucets	207	2/16/2019	0601	P	5.03	P	<1.00	CRE-02-CF-56
CRE-03-CF-25	CF	Classroom faucets	304	2/16/2019	0620	P	4.54	P	1.73	CRE-03-CF-49
CRE-03-WC-26	WC	Water fountain with cooler	Corridor 300	2/16/2019	0622	P	<1.00	P	<1.00	CRE-03-WC-47
CRE-03-WC-27	WC	Water fountain with cooler	Corridor 300	2/16/2019	0623	P	<1.00	P	<1.00	CRE-03-WC-48
CRE-03-WF-28	WF	Water fountain with filter & cooler	Corridor 300	2/16/2019	0625	P	<1.00	P	<1.00	CRE-03-WF-51
CRE-03-WFC-29	WFC	Filtering water cooler w/ bottle filler	Corridor 300	2/16/2019	0627	P	<1.00	P	<1.00	CRE-03-WFC-52
CRE-03-CF-30	CF	Classroom faucets	303	2/16/2019	0630	P	10.5	P	1.84	CRE-03-CF-50
CRE-03-CF-31	CF	Classroom faucets	303	2/16/2019	0631	P	8.27	P	2.72	CRE-03-CF-58



## Pittsburgh Cupples Stadium

---

Lead in Drinking Water Sample Results

School: Pittsburgh Cupples Stadium

Address: 800 E. Carson Street, Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CUP-GF-SL-00	SL	Service Line	Storage 102	6/18/2019	0655	P	<1.00	N/A	N/A	
CUP-GF-WM-00	WM	Water Main	Storage 102	6/18/2019	0657	P	<1.00	N/A	N/A	
CUP-GF-WF-01	WF	Water fountain with filter & cooler	Men's Restroom	6/18/2019	0654	P	<1.00	P	<1.00	
CUP-GF-WF-04	WF	Water fountain with filter & cooler	Women's Restroom	6/18/2019	0707	P	<1.00	P	<1.00	
CUP-GF-WF-20	WF	Water fountain with filter & cooler	Dressing Room (105)	6/18/2019	0713	P	<1.00	P	<1.00	
CUP-GF-IM-21	IM	Ice machines	Dressing Room (105)	6/18/2019	0712	P	<1.00	N/A	N/A	
CUP-GF-WFC-25	WFC	Filtering water cooler w/ bottle filler	Corridor 109	6/18/2019	0716	P	7.52	P	<1.00	
CUP-GF-IM-31	IM	Ice machines	Dressing Room (115)	6/18/2019	0720	P	<1.00	N/A	N/A	
CUP-GF-IM-32	IM	Ice machines	Dressing Room (115)	6/18/2019						Not in Operation
CUP-GF-WF-34	WF	Water fountain with filter & cooler	Dressing Room (115)	6/18/2019	0722	P	<1.00	P	<1.00	
CUP-01-MS-53	MS	Miscellaneous sinks	Press Box	6/18/2019	0727	P	<1.00	P	<1.00	
CUP-GF-IM-58	IM	Ice machines	Concession Stand	6/18/2019						Not in Operation
CUP-GF-KF-59	KF	Kitchen faucets	Concession Stand	6/18/2019	0703	P	1.32	P	<1.00	
CUP-GF-KF-60	KF	Kitchen faucets	Concession Stand	6/18/2019	0704	P	3.01	P	<1.00	
CUP-GF-WF-65	WF	Water fountain with filter & cooler	Public Restroom (201)	6/18/2019	0740	P	<1.00	P	<1.00	
CUP-GF-WF-66	WF	Water fountain with filter & cooler	Public Restroom (203)	6/18/2019	0735	P	<1.00	P	<1.00	
CUP-GF-KF-71	KF	Kitchen faucets	Grounds Keeper (110)	6/18/2019	0718	P	<1.00	P	<1.00	
CUP-GF-SL-72	SL	Service Line	Public Restroom (202)	6/18/2019	0736	P	<1.00	N/A	N/A	
CUP-GF-WM-73	WM	Water Main	Public Restroom (202)	6/18/2019	0738	P	<1.00	N/A	N/A	
CUP-GF-MS-74	MS	Miscellaneous sinks	Outside Stadium	6/18/2019						Not Testable - Knob Removed
CUP-GF-WFC-76	WFC	Filtering water cooler w/ bottle filler	Dressing Room (105)	6/18/2019	0714	P	<1.00	P	<1.00	
CUP-GF-WFC-78	WFC	Filtering water cooler w/ bottle filler	Dressing Room (115)	6/18/2019	0723	P	<1.00	P	<1.00	
CUP-GF-WF-80	WF	Water fountain with filter & cooler	Men's Restroom	6/18/2019	0658	P	<1.00	P	<1.00	
CUP-GF-WFC-81	WFC	Filtering water cooler w/ bottle filler	Women's Restroom	6/18/2019	0708	P	<1.00	P	<1.00	



## Lead in Drinking Water Sample Results

School: Pittsburgh Faison K-5

Address: 7430 Tioga Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
FAI-01-SL-00	SL	Service Line	133	5/8/2019	0600	P	<1.00	N/A	N/A	
FAI-01-WM-00	WM	Water Main	133	5/8/2019	0603	P	<1.00	N/A	N/A	
FAI-01-KF-03	KF	Kitchen faucets	125A	5/8/2019	0605	P	<1.00	P	<1.00	
FAI-01-WF-04	WF	Water fountain with filter & cooler	Café Lobby	5/8/2019	0609	P	<1.00	P	<1.00	
FAI-01-WFC-05	WFC	Filtering water cooler w/ bottle filler	Café Lobby	5/8/2019	0610	P	<1.00	P	<1.00	
FAI-01-MS-16	MS	Miscellaneous sinks	139	5/8/2019	0612	P	<1.00	P	<1.00	
FAI-01-WF-17	WF	Water fountain with filter & cooler	Gallery 100	5/8/2019	0614	P	<1.00	P	<1.00	
FAI-01-WFC-18	WFC	Filtering water cooler w/ bottle filler	Gallery 100	5/8/2019	0615	P	<1.00	P	<1.00	
FAI-01-CF-22	CF	Classroom faucets	101	5/8/2019	0621	P	<1.00	P	<1.00	
FAI-01-WC-23	WC	Water fountain with cooler	Outside 105A	5/8/2019	0623	P	<1.00	P	<1.00	
FAI-01-WC-24	WC	Water fountain with cooler	Outside 105A	5/8/2019	0624	P	<1.00	P	<1.00	
FAI-01-MS-27	MS	Miscellaneous sinks	105	5/8/2019	0626	P	1.09	P	<1.00	
FAI-01-MS-30	MS	Miscellaneous sinks	122A	5/8/2019	0619	P	1.35	P	<1.00	
FAI-01-NF-32	NF	Nurse's office sink faucets	121B	5/8/2019	0629	P	<1.00	P	<1.00	
FAI-01-CF-33	CF	Classroom faucets	119	5/8/2019	0631	P	<1.00	P	<1.00	
FAI-01-CF-34	CF	Classroom faucets	119	5/8/2019	0632	P	<1.00	P	<1.00	
FAI-01-CF-35	CF	Classroom faucets	119	5/8/2019	0633	P	<1.00	P	<1.00	
FAI-01-WC-36	WC	Water fountain with cooler	Outside 110A	5/8/2019	0636	P	<1.00	P	<1.00	
FAI-01-WC-37	WC	Water fountain with cooler	Outside 110A	5/8/2019	0637	P	<1.00	P	<1.00	
FAI-01-MS-40	MS	Miscellaneous sinks	110	5/8/2019	0639	P	<1.00	P	<1.00	
FAI-01-MS-44	MS	Miscellaneous sinks	117A	5/8/2019	0641	P	<1.00	P	<1.00	
FAI-01-CF-45	CF	Classroom faucets	109	5/8/2019	0643	P	<1.00	P	<1.00	
FAI-01-CF-46	CF	Classroom faucets	111	5/8/2019	0647	P	<1.00	P	<1.00	
FAI-01-WC-48	WC	Water fountain with cooler	Outside 115A	5/8/2019	0649	P	<1.00	P	<1.00	
FAI-01-WC-49	WC	Water fountain with cooler	Outside 115A	5/8/2019	0650	P	<1.00	P	<1.00	
FAI-01-MS-52	MS	Miscellaneous sinks	115	5/8/2019	0652	P	<1.00	P	<1.00	
FAI-01-CF-57	CF	Classroom faucets	114	5/8/2019	0653	P	<1.00	P	<1.00	
FAI-02-WC-59	WC	Water fountain with cooler	Outside 205A	5/8/2019	0658	P	<1.00	P	<1.00	
FAI-02-WC-60	WC	Water fountain with cooler	Outside 205A	5/8/2019	0659	P	<1.00	P	<1.00	
FAI-02-MS-63	MS	Miscellaneous sinks	205	5/8/2019	0701	P	<1.00	P	<1.00	
FAI-02-CF-66	CF	Classroom faucets	204	5/8/2019	0703	P	1.07	P	<1.00	
FAI-02-MS-67	MS	Miscellaneous sinks	204A	5/8/2019	0705	P	<1.00	P	<1.00	
FAI-02-CF-68	CF	Classroom faucets	206	5/8/2019	0708	P	<1.00	P	<1.00	
FAI-02-WC-69	WC	Water fountain with cooler	Outside 210A	5/8/2019	0710	P	<1.00	P	<1.00	
FAI-02-WC-70	WC	Water fountain with cooler	Outside 210A	5/8/2019	0711	P	<1.00	P	<1.00	
FAI-02-MS-73	MS	Miscellaneous sinks	210	5/8/2019	0713	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Faison K-5

Address: 7430 Tioga Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
FAI-02-TF-76	TF	Teacher's lounge sinks	221	5/8/2019	0715	P	<1.00	P	<1.00	
FAI-02-WF-82	WF	Water fountain with filter & cooler	Outside 215A	5/8/2019	0719	P	<1.00	P	<1.00	
FAI-02-WFC-83	WFC	Filtering water cooler w/ bottle filler	Outside 215A	5/8/2019	0720	P	<1.00	P	<1.00	
FAI-02-MS-86	MS	Miscellaneous sinks	215	5/8/2019	0721	P	<1.00	P	<1.00	
FAI-01-KF-90	KF	Kitchen faucets	125A	5/8/2019	0606	P	<1.00	P	<1.00	

## **Pittsburgh Greenfield PreK-8**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Greenfield PreK-8

Address: 1 Alger Street, Pittsburgh, PA 15207

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
GRE-BS-SL-00	SL	Service Line	Duct Space	4/9/2019	0543	P	<1.00	N/A	N/A	
GRE-BS-WM-00	WM	Water Main	Duct Space	4/9/2019	0545	P	<1.00	N/A	N/A	
GRE-BS-MS-02	MS	Miscellaneous sinks	7	4/9/2019	0650	P	2.23	P	<1.00	
GRE-BS-MS-03	MS	Miscellaneous sinks	6	4/9/2019	0648	P	3.33	P	<1.00	
GRE-BS-WF-04	WF	Water fountain with filter and cooler	Pool Deck	4/9/2019	0542	P	<1.00	P	<1.00	
GRE-BS-WF-05	WF	Water fountain with filter and cooler	Pool Deck	4/9/2019	0546	P	<1.00	P	<1.00	
GRE-01-WC-10	WC	Water fountain with cooler	108	4/9/2019	0611	P	<1.00	P	<1.00	
GRE-01-WC-12	WC	Water fountain with cooler	Corridor 100	4/9/2019	0606	P	2.34	P	3.23	
GRE-01-WFC-32	WFC	Filtering water cooler with bottle filler	Corridor 100	4/9/2019	0551	P	<1.00	P	<1.00	
GRE-01-MS-37	MS	Miscellaneous sinks	109A	4/9/2019	0608	P	11.4	P	1.62	
GRE-01-CF-39	CF	Classroom faucets	112	4/9/2019	0554	P	<1.00	P	<1.00	
GRE-01-CF-40	CF	Classroom faucets	102	4/9/2019	0557	P	1.26	P	<1.00	
GRE-01-KF-41	KF	Kitchen faucets	101	4/9/2019	0559	P	<1.00	P	2.04	
GRE-01-KF-42	KF	Kitchen faucets	101	4/9/2019	0600	P	<1.00	P	<1.00	
GRE-02-WC-47	WC	Water fountain with cooler	Corridor 200	4/9/2019	0626	P	<1.00	P	<1.00	
GRE-02-MS-48	MS	Miscellaneous sinks	207C	4/9/2019	0627	P	<1.00	P	2.17	
GRE-02-NF-49	NF	Nurse's office sink faucets	210B	4/9/2019	0624	P	1.19	P	1.91	
GRE-02-WFC-51	WFC	Filtering water cooler with bottle filler	Corridor 200	4/9/2019	0617	P	<1.00	P	<1.00	
GRE-02-TF-58	TF	Teacher's lounge sinks	215A	4/9/2019	0615	P	<1.00	P	<1.00	
GRE-02-CF-59	CF	Classroom faucets	201D	4/9/2019	0620	P	4.50	P	<1.00	
GRE-02-WC-60	WC	Water fountain with cooler	201D	4/9/2019	0619	P	3.03	P	1.02	
GRE-03-WC-66	WC	Water fountain with cooler	Corridor 300	4/9/2019	0643	P	<1.00	P	<1.00	
GRE-03-CF-67	CF	Classroom faucets	310	4/9/2019	0641	F	29.4	P	3.70	
GRE-03-CF-69	CF	Classroom faucets	312	4/9/2019	0638	P	7.97	P	3.16	
GRE-03-WFC-70	WFC	Filtering water cooler with bottle filler	Corridor 300	4/9/2019	0636	P	<1.00	P	<1.00	
GRE-BS-WC-76	WC	Water fountain with cooler	2	4/9/2019	0602	P	4.09	P	1.83	
GRE-03-CF-79	CF	Classroom faucets	303	4/9/2019	0634	P	<1.00	P	1.01	





Lead in Drinking Water Sample Results

School: Pittsburgh King PreK-8

Address: 50 Montgomery Place, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
KIN-01-SL-00	SL	Service Line	141	4/16/2019	0705	P	1.33	N/A	N/A	
KIN-01-WM-00	WM	Water Main	141	4/16/2019	0708	P	<1.00	N/A	N/A	
KIN-01-MS-05	MS	Miscellaneous sinks	111 (G4)	4/16/2019	0719	P	1.66	P	<1.00	
KIN-01-CF-06	CF	Classroom faucets	123 (G2)	4/16/2019	0716	P	11.9	P	<1.00	
KIN-01-CF-07	CF	Classroom faucets	119 (G3)	4/16/2019	0723	P	7.73	P	<1.00	
KIN-01-CF-10	CF	Classroom faucets	111 (G4)	4/16/2019	0720	P	3.56	P	1.06	
KIN-01-MS-11	MS	Miscellaneous sinks	138	4/16/2019	0710	P	<1.00	P	<1.00	
KIN-01-WC-13	WC	Water fountain with cooler	Gym Lobby	4/16/2019	0728	P	<1.00	P	<1.00	
KIN-01-WC-14	WC	Water fountain with cooler	Gym Lobby	4/16/2019	0729	P	<1.00	P	<1.00	
KIN-01-WF-15	WF	Water fountain with filter & cooler	Gym Lobby	4/16/2019	0731	P	<1.00	P	<1.00	
KIN-01-WFC-16	WFC	Filtering water cooler w/ bottle filler	Gym Lobby	4/16/2019	0732	P	<1.00	P	<1.00	
KIN-01-WC-28	WC	Water fountain with cooler	176A (G5)	4/16/2019	0751	P	<1.00	P	<1.00	
KIN-01-MS-29	MS	Miscellaneous sinks	180 (G6A)	4/16/2019	0746	P	10.9	P	2.10	
KIN-01-CF-30	CF	Classroom faucets	184 (G8)	4/16/2019	0738	P	9.36	P	1.98	
KIN-01-WC-31	WC	Water fountain with cooler	Corridor 183	4/16/2019	0742	P	<1.00	P	<1.00	
KIN-01-WC-32	WC	Water fountain with cooler	Corridor 183	4/16/2019	0743	P	<1.00	P	<1.00	
KIN-01-MS-33	MS	Miscellaneous sinks	186 (G9)	4/16/2019	0736	P	7.03	P	2.30	
KIN-02-WF-44	WF	Water fountain with filter & cooler	223	4/16/2019	0806	P	<1.00	P	1.07	
KIN-02-WF-45	WF	Water fountain with filter & cooler	223	4/16/2019	0807	P	<1.00	P	<1.00	
KIN-02-WC-48	WC	Water fountain with cooler	221 (P2)	4/16/2019						Not Testable - Low Flow
KIN-02-CF-49	CF	Classroom faucets	219 (P3)	4/16/2019						Not in Operation
KIN-02-CF-50	CF	Classroom faucets	219 (P3)	4/16/2019	0831	P	6.39	P	<1.00	
KIN-02-CF-51	CF	Classroom faucets	217 (P1)	4/16/2019	0826	P	5.64	P	2.39	
KIN-02-CF-52	CF	Classroom faucets	217 (P1)	4/16/2019	0827	P	8.14	P	1.84	
KIN-02-KF-55	KF	Kitchen faucets	224	4/16/2019	0802	P	1.73	P	<1.00	
KIN-02-KF-57	KF	Kitchen faucets	224	4/16/2019	0803	P	1.39	P	<1.00	
KIN-02-WF-58	WF	Water fountain with filter & cooler	223	4/16/2019	0757	P	<1.00	P	<1.00	
KIN-02-WF-59	WF	Water fountain with filter & cooler	223	4/16/2019	0758	P	<1.00	P	<1.00	
KIN-02-MS-60	MS	Miscellaneous sinks	245A (P18A)	4/16/2019	0810	P	4.27	P	1.74	
KIN-02-TF-64	TF	Teacher's lounge sinks	252	4/16/2019						Posted Hand Wash Only
KIN-02-WC-66	WC	Water fountain with cooler	Corridor 209	4/16/2019	0815	P	<1.00	P	<1.00	
KIN-02-WC-67	WC	Water fountain with cooler	Corridor 209	4/16/2019	0813	P	<1.00	P	<1.00	
KIN-02-WO-69	WO	Water fountain without cooler	Outside Multi-Purpose Room 3	4/16/2019	0836	P	1.08	P	<1.00	
KIN-02-WO-75	WO	Water fountain without cooler	Outside Multi-Purpose Room 3	4/16/2019						Not in Operation
KIN-02-WC-76	WC	Water fountain with cooler	233	4/16/2019						Not in Operation
KIN-02-WF-77	WF	Water fountain with filter & cooler	Corridor 209	4/16/2019	0845	P	<1.00	P	<1.00	
KIN-02-WFC-78	WFC	Filtering water cooler w/ bottle filler	Corridor 209	4/16/2019	0846	P	<1.00	P	<1.00	
KIN-02-CF-80	CF	Classroom faucets	259	4/16/2019						Not in Operation
KIN-02-CF-81	CF	Classroom faucets	259	4/16/2019						Not in Operation
KIN-02-CF-83	CF	Classroom faucets	261 (P8)	4/16/2019	0841	P	3.95	P	3.48	
KIN-02-CF-84	CF	Classroom faucets	261 (P8)	4/16/2019	0842	P	11.0	P	2.95	
KIN-02-WC-87	WC	Water fountain with cooler	263 (P11)	4/16/2019	0848	P	<1.00	P	<1.00	
KIN-02-WC-88	WC	Water fountain with cooler	266 (P12)	4/16/2019	0850	P	<1.00	P	<1.00	
KIN-02-CF-91	CF	Classroom faucets	268	4/16/2019						Not in Operation

## Lead in Drinking Water Sample Results

School: Pittsburgh King PreK-8

Address: 50 Montgomery Place, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
KIN-02-CF-92	CF	Classroom faucets	270 (P13)	4/16/2019	0818	P	3.63	P	1.72	
KIN-03-CF-96	CF	Classroom faucets	A1	4/16/2019	0921	P	2.70	F	42.5	
KIN-03-CF-97	CF	Classroom faucets	A2	4/16/2019	0918	P	3.52	P	2.67	
KIN-03-CF-98	CF	Classroom faucets	A3	4/16/2019	0917	P	3.32	P	<1.00	
KIN-03-CF-99	CF	Classroom faucets	A5	4/16/2019	0915	P	2.26	P	1.73	
KIN-03-CF-100	CF	Classroom faucets	A6	4/16/2019	0913	P	6.02	P	1.64	
KIN-03-CF-101	CF	Classroom faucets	A7	4/16/2019	0911	P	7.32	P	2.77	
KIN-03-CF-102	CF	Classroom faucets	B1	4/16/2019	0905	P	2.74	P	<1.00	
KIN-03-CF-103	CF	Classroom faucets	B2	4/16/2019	0904	P	5.26	P	1.69	
KIN-03-CF-104	CF	Classroom faucets	B3	4/16/2019	0901	P	6.55	P	5.12	
KIN-03-CF-105	CF	Classroom faucets	B5	4/16/2019	0900	P	4.89	P	2.55	
KIN-03-CF-106	CF	Classroom faucets	B6	4/16/2019	0858	P	5.64	P	2.35	
KIN-03-CF-107	CF	Classroom faucets	B7	4/16/2019	0857	P	4.48	P	<1.00	
KIN-03-WC-113	WC	Water fountain with cooler	Corridor 335	4/16/2019						Not Testable - Low Flow
KIN-03-WC-114	WC	Water fountain with cooler	Corridor 335	4/16/2019						Not Testable - Low Flow
KIN-03-CF-126	CF	Classroom faucets	F3	4/16/2019	0927	F	16.1	P	2.87	
KIN-03-CF-127	CF	Classroom faucets	F2	4/16/2019	0930	P	4.04	P	<1.00	
KIN-03-CF-128	CF	Classroom faucets	F1	4/16/2019	0932	P	6.34	P	<1.00	
KIN-03-WF-129	WF	Water fountain with filter & cooler	Corridor 335	4/16/2019	0946	P	<1.00	P	<1.00	
KIN-03-WFC-130	WFC	Filtering water cooler w/ bottle filler	Corridor 335	4/16/2019	0947	P	<1.00	P	<1.00	
KIN-03-CF-134	CF	Classroom faucets	E1	4/16/2019	1000	P	6.54	P	2.18	
KIN-03-CF-135	CF	Classroom faucets	E2	4/16/2019	0958	P	6.96	P	1.19	
KIN-03-CF-136	CF	Classroom faucets	E3	4/16/2019	0956	P	5.10	P	2.14	
KIN-03-CF-137	CF	Classroom faucets	E5	4/16/2019	0954	P	8.68	P	9.28	
KIN-03-CF-138	CF	Classroom faucets	E6	4/16/2019	0952	P	9.79	P	6.72	
KIN-03-CF-139	CF	Classroom faucets	E7	4/16/2019	0950	P	7.55	P	5.95	
KIN-03-CF-140	CF	Classroom faucets	D1	4/16/2019	1019	P	4.59	P	1.44	
KIN-03-CF-141	CF	Classroom faucets	D2	4/16/2019	1015	P	2.69	P	1.28	
KIN-03-CF-142	CF	Classroom faucets	D3	4/16/2019	1013	P	1.91	P	1.14	
KIN-03-CF-143	CF	Classroom faucets	D5	4/16/2019	1009	P	4.76	P	1.77	
KIN-03-CF-144	CF	Classroom faucets	D6	4/16/2019	1007	F	34.3	P	3.80	
KIN-03-CF-145	CF	Classroom faucets	D7	4/16/2019	1005	P	12.3	P	9.63	
KIN-03-WF-146	WF	Water fountain with filter & cooler	Corridor 358	4/16/2019	0907	P	<1.00	P	<1.00	
KIN-03-WF-147	WF	Water fountain with filter & cooler	Corridor 358	4/16/2019	0908	P	<1.00	P	<1.00	
KIN-03-CF-159	CF	Classroom faucets	C1	4/16/2019	0937	P	2.79	P	2.40	
KIN-03-CF-160	CF	Classroom faucets	C2	4/16/2019	0940	P	3.29	P	<1.00	
KIN-03-CF-161	CF	Classroom faucets	C3	4/16/2019	0942	F	46.0	P	1.13	
KIN-03-WC-166	WC	Water fountain with cooler	Corridor 358	4/16/2019						Not Testable - Low Flow
KIN-03-WC-167	WC	Water fountain with cooler	Corridor 358	4/16/2019						Not Testable - Low Flow
KIN-01-WO-168	WO	Water Fountain Attached to Sink	111 (G4)	4/16/2019						Not Testable - Low Flow
KIN-01-WO-169	WO	Water Fountain Attached to Sink	119 (G3)	4/16/2019	0724	P	<1.00	P	<1.00	
KIN-01-WO-170	WO	Water Fountain Attached to Sink	184 (G8)	4/16/2019	0739	F	22.0	P	7.15	
KIN-01-MS-171	MS	Miscellaneous sinks	181(G6B)	4/16/2019	0748	P	11.9	P	2.51	
KIN-02-WO-173	WO	Water Fountain Attached to Sink	219 (P3)	4/16/2019	0832	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh King PreK-8

Address: 50 Montgomery Place, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
KIN-02-WO-174	WO	Water Fountain Attached to Sink	217	4/16/2019						Not Testable - Low Flow
KIN-02-CF-175	CF	Classroom faucets	268	4/16/2019						Not in Operation
KIN-02-WO-176	WO	Water Fountain Attached to Sink	268	4/16/2019						Not in Operation
KIN-02-CF-177	CF	Classroom faucets	270 (P13)	4/16/2019	0820	P	6.11	P	1.27	
KIN-02-WO-178	WO	Water Fountain Attached to Sink	270 (P13)	4/16/2019	0821	P	9.59	P	1.75	
KIN-03-WO-179	WO	Water Fountain Attached to Sink	B3	4/16/2019						Not Testable - Low Flow
KIN-03-WO-180	WO	Water Fountain Attached to Sink	B5	4/16/2019						Not in Operation
KIN-03-WO-181	WO	Water Fountain Attached to Sink	B6	4/16/2019						Not in Operation
KIN-03-WO-182	WO	Water Fountain Attached to Sink	B7	4/16/2019						Not Testable - Low Flow
KIN-03-WO-183	WO	Water Fountain Attached to Sink	B1	4/16/2019						Not Testable - Low Flow
KIN-03-WO-184	WO	Water Fountain Attached to Sink	B2	4/16/2019						Not in Operation
KIN-03-WO-185	WO	Water Fountain Attached to Sink	A1	4/16/2019						Removed
KIN-03-WO-186	WO	Water Fountain Attached to Sink	A2	4/16/2019						Not in Operation
KIN-03-WO-187	WO	Water Fountain Attached to Sink	A3	4/16/2019						Not in Operation
KIN-03-WO-188	WO	Water Fountain Attached to Sink	A5	4/16/2019						Not Testable - Low Flow
KIN-03-WO-189	WO	Water Fountain Attached to Sink	A6	4/16/2019	0914	P	1.71	P	1.38	
KIN-03-WO-190	WO	Water Fountain Attached to Sink	A7	4/16/2019						Not Testable - Low Flow
KIN-03-WO-191	WO	Water Fountain Attached to Sink	F3	4/16/2019	0926	P	9.97	P	3.59	Removed
KIN-03-WO-192	WO	Water Fountain Attached to Sink	F2	4/16/2019						Not Testable - Low Flow
KIN-03-WO-193	WO	Water Fountain Attached to Sink	F1	4/16/2019	0933	P	5.11	P	2.83	
KIN-03-WO-194	WO	Water Fountain Attached to Sink	C1	4/16/2019						Not in Operation
KIN-03-WO-195	WO	Water Fountain Attached to Sink	C2	4/16/2019						Not Testable - Low Flow
KIN-03-WO-196	WO	Water Fountain Attached to Sink	C3	4/16/2019						Removed
KIN-03-WO-197	WO	Water Fountain Attached to Sink	D1	4/16/2019						Not in Operation
KIN-03-WO-198	WO	Water Fountain Attached to Sink	D2	4/16/2019	1016	P	1.73	P	1.49	
KIN-03-WO-199	WO	Water Fountain Attached to Sink	D3	4/16/2019						Not in Operation
KIN-03-WO-200	WO	Water Fountain Attached to Sink	D5	4/16/2019	1010	P	1.85	P	1.32	
KIN-03-WO-201	WO	Water Fountain Attached to Sink	D6	4/16/2019						Removed
KIN-03-WO-202	WO	Water Fountain Attached to Sink	D7	4/16/2019						Not in Operation
KIN-03-WO-203	WO	Water Fountain Attached to Sink	E1	4/16/2019	1001	P	2.20	P	1.64	
KIN-03-WO-204	WO	Water Fountain Attached to Sink	E2	4/16/2019						Not in Operation
KIN-03-WO-205	WO	Water Fountain Attached to Sink	E3	4/16/2019	0957	P	1.91	P	1.76	
KIN-03-WO-206	WO	Water Fountain Attached to Sink	E5	4/16/2019						Not in Operation
KIN-03-WO-207	WO	Water Fountain Attached to Sink	E6	4/16/2019						Not in Operation
KIN-03-WO-208	WO	Water Fountain Attached to Sink	E7	4/16/2019	0951	P	4.96	P	3.52	



Lead in Drinking Water Sample Results

School: Pittsburgh Langley K-8

Address: 2940 Sheraden Boulevard, Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LAN-GF-SL-00	SL	Service Line	4	5/18/2019	0700	P	<1.00	N/A	N/A	
LAN-GF-WM-00	WM	Water Main	4	5/18/2019	0703	P	<1.00	N/A	N/A	
LAN-GF-MS-03	MS	Miscellaneous sinks	5	5/18/2019	0705	P	1.12	P	<1.00	
LAN-GF-CF-04	CF	Classroom faucets	7							Posted Hand Wash Only
LAN-GF-CF-14	CF	Classroom faucets	11							Not in Operation
LAN-GF-WC-16	WC	Water fountain with cooler	Corridor 01	5/18/2019	0707	P	<1.00	P	<1.00	
LAN-GF-WC-17	WC	Water fountain with cooler	Corridor 01	5/18/2019	0708	P	<1.00	P	<1.00	
LAN-GF-CF-18	CF	Classroom faucets	15	5/18/2019	0711	P	<1.00	P	<1.00	
LAN-GF-CF-19	CF	Classroom faucets	15	5/18/2019	0712	P	<1.00	P	<1.00	
LAN-GF-WO-46	WO	Water fountain without cooler	23							Not in Operation
LAN-GF-WO-47	WO	Water fountain without cooler	21	5/18/2019	0720	P	1.86	P	1.23	
LAN-GF-WC-55	WC	Water fountain with cooler	Corridor 25C							Not Testable - Low Flow
LAN-GF-WC-56	WC	Water fountain with cooler	Corridor 25C							Not in Operation
LAN-GF-WF-57	WF	Water fountain with filter & cooler	25	5/18/2019	0722	P	<1.00	P	<1.00	
LAN-GF-WFC-58	WFC	Filtering water cooler w/ bottle filler	25	5/18/2019	0723	P	<1.00	P	<1.00	
LAN-GF-WO-67	WO	Water fountain without cooler	33	5/18/2019	0725	P	<1.00	P	<1.00	
LAN-GF-WO-68	WO	Water fountain without cooler	38	5/18/2019	0727	P	<1.00	P	<1.00	
LAN-01-MS-136	MS	Miscellaneous sinks	106							Posted Hand Wash Only
LAN-01-WC-138	WC	Water fountain with cooler	145A	5/18/2019	0746	P	<1.00	P	<1.00	
LAN-01-WF-139	WF	Water fountain with filter & cooler	Corridor 101	5/18/2019	0747	P	<1.00	P	<1.00	
LAN-01-WFC-140	WFC	Filtering water cooler w/ bottle filler	Corridor 101	5/18/2019	0748	P	<1.00	P	<1.00	
LAN-01-MS-141	MS	Miscellaneous sinks	104D	5/18/2019	0750	P	2.80	P	<1.00	
LAN-01-MS-142	MS	Miscellaneous sinks	105	5/18/2019	0752	P	<1.00	P	<1.00	
LAN-01-WC-149	WC	Water fountain with cooler	Corridor 101	5/18/2019	0755	P	<1.00	P	<1.00	
LAN-01-WC-150	WC	Water fountain with cooler	Corridor 101	5/18/2019	0756	P	<1.00	P	<1.00	
LAN-01-CF-151	CF	Classroom faucets	119	5/18/2019	0800	P	1.51	P	<1.00	
LAN-01-CF-152	CF	Classroom faucets	120	5/18/2019	0802	P	3.91	P	<1.00	
LAN-01-CF-156	CF	Classroom faucets	122							Not in Operation
LAN-01-CF-157	CF	Classroom faucets	122	5/18/2019	0805	P	11.6	P	<1.00	
LAN-01-CF-158	CF	Classroom faucets	122	5/18/2019	0806	P	1.78	P	<1.00	
LAN-01-WC-162	WC	Water fountain with cooler	Corridor 101C	5/18/2019	0816	P	<1.00	P	<1.00	
LAN-01-WC-163	WC	Water fountain with cooler	Corridor 101C	5/18/2019	0817	P	<1.00	P	<1.00	
LAN-01-WC-169	WC	Water fountain with cooler	131	5/18/2019	0822	P	<1.00	P	<1.00	
LAN-01-CF-170	CF	Classroom faucets	131	5/18/2019	0823	P	2.17	P	<1.00	
LAN-01-CF-171	CF	Classroom faucets	134	5/18/2019	0758	P	<1.00	P	<1.00	
LAN-01-WC-173	WC	Water fountain with cooler	Crridor 101B	5/18/2019	0744	P	<1.00	P	<1.00	
LAN-01-WC-174	WC	Water fountain with cooler	Crridor 101B	5/18/2019	0745	P	<1.00	P	<1.00	
LAN-01-NF-177	NF	Nurse's office sink faucets	143	5/18/2019	0743	P	1.36	P	<1.00	
LAN-01-MS-182	MS	Miscellaneous sinks	Library - 137B	5/18/2019	0757	P	6.36	P	<1.00	
LAN-01-IM-192	IM	Ice machines	152A	5/18/2019	0851	P	<1.00	N/A	N/A	
LAN-01-WF-196	WF	Water fountain with filter & cooler	Corridor 146	5/18/2019	0835	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Langley K-8

Address: 2940 Sheraden Boulevard, Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LAN-01-WFC-197	WFC	Filtering water cooler w/ bottle filler	Corridor 146	5/18/2019	0836	P	<1.00	P	<1.00	
LAN-01-KF-198	KF	Kitchen faucets	Kitchen - 151A	5/18/2019	0844	P	1.98	P	<1.00	
LAN-01-KF-199	KF	Kitchen faucets	Kitchen - 151A	5/18/2019	0842	P	1.13	P	<1.00	
LAN-01-KF-200	KF	Kitchen faucets	Kitchen - 151A	5/18/2019	0841	P	<1.00	P	<1.00	
LAN-02-CF-202	CF	Classroom faucets	201	5/18/2019	0905	P	7.03	P	1.40	
LAN-02-CF-203	CF	Classroom faucets	204	5/18/2019	0907	P	12.1	P	2.48	
LAN-02-CF-204	CF	Classroom faucets	204	5/18/2019	0908	P	3.99	P	1.03	
LAN-02-CF-210	CF	Classroom faucets	207	5/18/2019	0916	F	525	P	3.24	
LAN-02-HF-215	HF	Home economics faucets (with cooking)	210	5/18/2019	0925	P	<1.00	P	<1.00	
LAN-02-HF-216	HF	Home economics faucets (with cooking)	210	5/18/2019	0926	P	1.34	P	<1.00	
LAN-02-HF-217	HF	Home economics faucets (with cooking)	210	5/18/2019	0927	P	1.76	P	<1.00	
LAN-02-HF-218	HF	Home economics faucets (with cooking)	210	5/18/2019	0928	P	2.70	P	<1.00	
LAN-02-HF-219	HF	Home economics faucets (with cooking)	210	5/18/2019	0930	P	4.34	P	<1.00	
LAN-02-WF-220	WF	Water fountain with filter & cooler	Corridor 200	5/18/2019	0919	P	<1.00	P	<1.00	
LAN-02-WFC-221	WFC	Filtering water cooler w/ bottle filler	Corridor 200	5/18/2019	0920	P	<1.00	P	<1.00	
LAN-02-CF-228	CF	Classroom faucets	216							Not in Operation
LAN-02-MS-232	MS	Miscellaneous sinks	218	5/18/2019	0930	P	2.10	P	<1.00	
LAN-02-CF-233	CF	Classroom faucets	219	5/18/2019	0933	P	1.76	P	<1.00	
LAN-02-CF-234	CF	Classroom faucets	219	5/18/2019	0934	P	2.91	P	<1.00	
LAN-02-WC-239	WC	Water fountain with cooler	Corridor 200C	5/18/2019	0931	P	<1.00	P	<1.00	
LAN-02-WC-240	WC	Water fountain with cooler	Corridor 200C	5/18/2019	0932	P	<1.00	P	<1.00	
LAN-02-WC-245	WC	Water fountain with cooler	Corridor 200B	5/18/2019	0900	P	<1.00	P	<1.00	
LAN-02-WC-246	WC	Water fountain with cooler	Corridor 200B	5/18/2019	0901	P	<1.00	P	<1.00	
LAN-02-TF-248	TF	Teacher's lounge sinks	234							Posted Hand Wash Only
LAN-02-WF-250	WF	Water fountain with filter & cooler	Corridor 236A	5/18/2019	0946	P	<1.00	P	<1.00	
LAN-02-WFC-251	WFC	Filtering water cooler w/ bottle filler	Corridor 236A	5/18/2019	0947	P	<1.00	P	<1.00	
LAN-02-WC-259	WC	Water fountain with cooler	Corridor 236E	5/18/2019	0955	P	<1.00	P	<1.00	
LAN-02-WC-260	WC	Water fountain with cooler	Corridor 236E	5/18/2019	0956	P	<1.00	P	<1.00	
LAN-02-CF-261	CF	Classroom faucets	242	5/18/2019	1000	P	1.64	P	<1.00	
LAN-02-CF-262	CF	Classroom faucets	242	5/18/2019	1001	P	3.15	P	<1.00	
LAN-02-CF-263	CF	Classroom faucets	244	5/18/2019	1003	P	3.92	P	<1.00	
LAN-02-CF-264	CF	Classroom faucets	244	5/18/2019	1004	P	<1.00	P	<1.00	
LAN-02-CF-265	CF	Classroom faucets	248	5/18/2019	1007	P	1.00	P	<1.00	
LAN-02-CF-266	CF	Classroom faucets	248	5/18/2019	1008	P	1.25	P	5.84	
LAN-03-MS-267	MS	Miscellaneous sinks	301	5/18/2019	1015	P	1.66	P	<1.00	
LAN-02-CF-268	CF	Classroom faucets	217	5/18/2019	0936	P	4.30	P	<1.00	
LAN-02-CF-270	CF	Classroom faucets	207	5/18/2019	0915	P	1.18	P	1.10	
LAN-02-WC-271	WF	Water fountain with filter & cooler	Corridor 200	5/18/2019	0910	P	<1.00	P	<1.00	
LAN-02-WC-272	WF	Water fountain with filter & cooler	Corridor 200	5/18/2019	0911	P	<1.00	P	<1.00	
LAN-01-CF-274	CF	Classroom faucets	131	5/18/2019	0825	P	1.04	P	<1.00	
LAN-01-CF-275	CF	Classroom faucets	131	5/18/2019	0826	P	1.30	P	<1.00	

## Lead in Drinking Water Sample Results

School: Pittsburgh Langley K-8

Address: 2940 Sheraden Boulevard, Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LAN-GF-WC-277	WC	Water fountain with cooler	Outside 41	5/18/2019	0750	P	<1.00	P	<1.00	
LAN-GF-WC-278	WC	Water fountain with cooler	Outside 41	5/18/2019	0731	P	<1.00	P	<1.00	
LAN-GF-CF-282	CF	Classroom faucets	11							Not in Operation
LAN-GF-CF-283	CF	Classroom faucets	11							Not in Operation
LAN-GF-CF-284	CF	Classroom faucets	7							Posted Hand Wash Only
LAN-GF-IM-293	IM	Ice machines	34B	5/18/2019	0740	P	<1.00	N/A	N/A	
LAN-02-CF-297	CF	Classroom faucets	256	5/18/2019	0950	F	36.6	P	14.2	





## Lead in Drinking Water Sample Results

School: Pittsburgh Lincoln PreK-5

Address: 328 Lincoln Avenue, Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LIN-BS-SL-00	SL	Service Line	Boiler Room	5/2/2019	0525	P	<1.00	N/A	N/A	
LIN-BS-WM-00	WM	Water Main	Boiler Room	5/2/2019	0528	P	<1.00	N/A	N/A	
LIN-01-TF-03	TF	Miscellaneous sinks	110	5/2/2019	0530	P	<1.00	P	<1.00	
LIN-01-WF-05	WF	Water fountain with filter & cooler	Corridor 100	5/2/2019	0534	P	<1.00	P	<1.00	
LIN-01-WFC-06	WFC	Filtering water cooler w/ bottle filler	Corridor 100	5/2/2019	0535	P	<1.00	P	<1.00	
LIN-01-CF-11	CF	Classroom faucets	115	5/2/2019	0537	P	<1.00	P	<1.00	
LIN-01-CF-13	CF	Classroom faucets	117	5/2/2019	0542	P	1.08	P	<1.00	
LIN-01-NF-16	NF	Nurse's office sink faucets	136	5/2/2019	0540	F	18.8	P	2.44	
LIN-01-WC-19	WC	Water fountain with cooler	Corridor 100	5/2/2019	0545	P	<1.00	P	<1.00	
LIN-01-CF-20	CF	Classroom faucets	132	5/2/2019	0547	P	1.20	P	<1.00	
LIN-01-CF-21	CF	Classroom faucets	132	5/2/2019	0549	P	<1.00	P	<1.00	
LIN-01-KF-22	KF	Kitchen faucets	Kitchen (129)	5/2/2019	0556	P	3.63	P	<1.00	
LIN-01-WF-23	WF	Water fountain with filter & cooler	Corridor 100G	5/2/2019	0553	P	<1.00	P	<1.00	
LIN-01-WFC-24	WFC	Filtering water cooler w/ bottle filler	Corridor 100G	5/2/2019	0554	P	<1.00	P	<1.00	
LIN-01-KF-25	KF	Kitchen faucets	Kitchen (129)	5/2/2019	0558	P	<1.00	P	<1.00	
LIN-02-WF-33	WF	Water fountain with filter & cooler	Corridor 200	5/2/2019	0602	P	<1.00	P	<1.00	
LIN-02-WFC-34	WFC	Filtering Water Cooler w/Bottle Filler	Corridor 200	5/2/2019	0603	P	<1.00	P	<1.00	
LIN-02-CF-37	CF	Classroom faucets	216	5/2/2019	0605	P	<1.00	P	<1.00	
LIN-02-CF-40	CF	Classroom faucets	205	5/2/2019	0608	F	69.3	F	24.0	
LIN-02-CF-41	CF	Classroom faucets	205	5/2/2019	0609	F	27.7	P	3.99	
LIN-02-WC-44	WC	Water fountain with cooler	Corridor 200	5/2/2019	0612	P	<1.00	P	<1.00	
LIN-03-WF-46	WF	Water fountain with filter & cooler	Corridor 300	5/2/2019	0616	P	<1.00	P	<1.00	
LIN-03-WFC-47	WFC	Filtering water cooler w/ bottle filler	Corridor 300	5/2/2019	0617	P	<1.00	P	<1.00	
LIN-03-CF-50	CF	Classroom faucets	306	5/2/2019	0623	P	<1.00	P	<1.00	
LIN-03-CF-51	CF	Classroom faucets	306	5/2/2019	0624	P	<1.00	P	<1.00	
LIN-03-WC-54	WC	Water fountain with cooler	Corridor 300	5/2/2019	0627	P	<1.00	P	<1.00	
LIN-03-CF-57	CF	Classroom faucets	306	5/2/2019	0622	P	<1.00	P	<1.00	
LIN-01-MS-58	MS	Miscellaneous sinks	107A	5/2/2019	0532	F	50.2	P	8.48	
LIN-03-MS-62	MS	Miscellaneous sinks	305	5/2/2019	0621	F	188	F	20.9	



Lead in Drinking Water Sample Results

School: Pittsburgh Linden K-5

Address: 725 S. Linden Avenue, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LND-SB-SL-00	SL	Service Line	4	5/14/2019	0559	P	1.54	N/A	N/A	
LND-SB-WM-00	WM	Water Main	4	5/14/2019	0601	P	<1.00	N/A	N/A	
LND-BS-CF-08	CF	Classroom faucets	1A	5/14/2019	0607	P	12.0	P	1.41	
LND-BS-MS-09	MS	Miscellaneous sinks	1C	5/14/2019	0602	F	21.1	P	1.96	
LND-BS-WO-10	WO	Water fountain without cooler	Corridor C	5/14/2019	0604	P	5.97	P	1.83	
LND-BS-WFC-18	WFC	Filtering water cooler w/ bottle filler	Corridor A	5/14/2019						Not in Operation
LND-BS-NF-19	NF	Nurse's office sink faucets	3A	5/14/2019	0611	P	3.19	P	1.02	
LND-BS-CF-20	CF	Classroom faucets	11	5/14/2019	0614	P	6.35	P	<1.00	
LND-BS-CF-21	CF	Classroom faucets	9	5/14/2019	0618	P	4.49	P	1.10	
LND-BS-CF-22	CF	Classroom faucets	10	5/14/2019	0620	P	6.39	P	1.05	
LND-01-CF-27	CF	Classroom faucets	102A	5/14/2019						Not in Operation
LND-01-CF-30	CF	Classroom faucets	101	5/14/2019						Cold Water Not in Operation
LND-01-WF-34	WF	Water fountain with filter & cooler	Corridor 100	5/14/2019	0631	P	<1.00	P	<1.00	
LND-01-WF-40	WF	Water fountain with filter & cooler	Corridor 100	5/14/2019	0635	P	<1.00	P	<1.00	
LND-01-WF-41	WF	Water fountain with filter & cooler	Corridor 100	5/14/2019	0636	P	<1.00	P	<1.00	
LND-02-TF-42	TF	Teacher's lounge sinks	202B	5/14/2019	0643	P	8.22	P	1.41	
LND-02-CF-44	CF	Classroom faucets	202	5/14/2019	0651	P	6.10	P	<1.00	
LND-02-WF-47	WF	Water fountain with filter & cooler	Corridor 200	5/14/2019	0645	P	<1.00	P	<1.00	
LND-02-WFC-48	WFC	Filtering water cooler w/ bottle filler	Corridor 200	5/14/2019	0646	P	<1.00	P	<1.00	
LND-02-WFC-49	WFC	Filtering water cooler w/ bottle filler	Corridor 200	5/14/2019	0654	P	<1.00	P	<1.00	
LND-BS-WO-54	WO	Water fountain attached to sink	B-13	5/14/2019	0623	P	1.10	P	1.23	
LND-BS-WO-55	WO	Water fountain attached to sink	B-12	5/14/2019	0625	P	<1.00	P	<1.00	
LND-BS-CF-56	CF	Classroom faucets	1A	5/14/2019	0608	P	6.47	P	2.36	
LND-02-WO-57	WO	Water fountain without cooler	Corridor 200	5/14/2019	0648	P	6.16	P	1.50	
LND-02-WO-58	WO	Water fountain without cooler	Corridor 200	5/14/2019						Not in Operation
LND-BS-CF-63	CF	Classroom faucets	12	5/14/2019	0616	P	6.83	P	<1.00	
LND-01-WFC-65	WFC	Filtering water cooler w/ bottle filler	Corridor 100	5/14/2019	0632	P	<1.00	P	<1.00	
LND-02-MS-67	MS	Miscellaneous sinks	202A	5/14/2019	0650	F	64.2	F	32.5	

**Pittsburgh Manchester PreK-8**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Manchester PreK-8

Address: 1612 Manhattan Street, Pittsburgh, PA 15233

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MAN-01-SL-00	SL	Service Line	Boiler Room	4/23/2019	0534	P	<1.00	N/A	N/A	
MAN-01-WM-00	WM	Water Main	Boiler Room	4/23/2019	0536	P	<1.00	N/A	N/A	
MAN-01-NF-03	NF	Nurse's office sink faucets	115	4/23/2019	0547	P	<1.00	P	<1.00	
MAN-01-WF-04	WF	Water fountain with filter & cooler	Corridor 120	4/23/2019	0548	P	<1.00	P	<1.00	
MAN-01-CF-05	CF	Classroom faucets	114	4/23/2019	0550	F	38.0	P	3.49	
MAN-01-CF-06	CF	Classroom faucets	113	4/23/2019	0552	P	3.04	P	<1.00	
MAN-01-KF-08	KF	Kitchen faucets	111	4/23/2019	0613	P	7.30	P	<1.00	
MAN-01-CF-10	CF	Classroom faucets	112	4/23/2019	0557	P	11.7	P	<1.00	
MAN-01-CF-12	CF	Classroom faucets	106	4/23/2019	0615	P	2.99	P	<1.00	
MAN-01-WF-22	WF	Water fountain with filter & cooler	Corridor 148	4/23/2019	0540	P	<1.00	P	<1.00	
MAN-01-CF-28	CF	Classroom faucets	128	4/23/2019						Posted Hand Wash Only
MAN-01-CF-31	CF	Classroom faucets	128	4/23/2019	0539	P	1.22	P	<1.00	
MAN-01-CF-32	CF	Classroom faucets	127	4/23/2019	0544	P	7.94	P	<1.00	
MAN-01-CF-33	CF	Classroom faucets	127	4/23/2019						Posted Hand Wash Only
MAN-01-CF-34	CF	Classroom faucets	149	4/23/2019	0600	P	10.8	P	<1.00	
MAN-01-CF-35	CF	Classroom faucets	150	4/23/2019	0603	P	4.20	P	<1.00	
MAN-01-WF-36	WF	Water fountain with filter & cooler	Corridor 154	4/23/2019	0608	P	<1.00	P	<1.00	
MAN-01-CF-37	CF	Classroom faucets	151	4/23/2019	0605	P	2.86	P	<1.00	
MAN-01-CF-38	CF	Classroom faucets	152	4/23/2019	0611	P	2.98	P	<1.00	
MAN-01-CF-39	CF	Classroom faucets	162	4/23/2019						Posted Hand Wash Only
MAN-01-MS-40	MS	Miscellaneous sinks	Corridor 157	4/23/2019	0621	P	6.21	P	<1.00	
MAN-01-TF-42	TF	Teacher's lounge sinks	163	4/23/2019	0617	P	5.38	P	<1.00	
MAN-01-WF-43	WF	Water fountain with filter & cooler	Corridor 108	4/23/2019	0618	P	<1.00	P	<1.00	
MAN-01-WF-45	WF	Water fountain with filter & cooler	Corridor 120	4/23/2019	0628	P	<1.00	P	<1.00	
MAN-02-CF-46	CF	Classroom faucets	212	4/23/2019	0643	P	8.66	P	1.11	
MAN-02-TF-48	TF	Teacher's lounge sinks	207	4/23/2019	0646	P	5.33	P	<1.00	
MAN-02-CF-49	CF	Classroom faucets	201	4/23/2019						Cold Water Not in Operation
MAN-02-WF-51	WF	Water fountain with filter & cooler	Corridor 213	4/23/2019	0648	P	<1.00	P	<1.00	
MAN-02-MS-53	MS	Miscellaneous sinks	222	4/23/2019	0630	F	20.3	P	1.84	
MAN-02-WF-58	WF	Water fountain with filter & cooler	Corridor 237	4/23/2019	0632	P	<1.00	P	<1.00	
MAN-02-CF-65	CF	Classroom faucets	239	4/23/2019	0636	P	11.4	P	1.09	
MAN-02-CF-66	CF	Classroom faucets	240	4/23/2019						Posted Hand Wash Only
MAN-02-CF-67	CF	Classroom faucets	241	4/23/2019	0638	F	17.7	P	1.60	
MAN-02-CF-68	CF	Classroom faucets	242	4/23/2019	0641	P	6.41	P	<1.00	
MAN-02-WF-69	WF	Water fountain with filter & cooler	Corridor 244	4/23/2019	0640	P	<1.00	P	<1.00	
MAN-02-CF-70	CF	Classroom faucets	200	4/23/2019	0653	P	3.55	P	<1.00	
MAN-01-WO-71	WO	Water Fountain Attached to Sink	128	4/23/2019						Not Testable - Low Flow
MAN-01-WO-73	WO	Water Fountain Attached to Sink	Corridor 157	4/23/2019						Not Testable - Low Flow

Lead in Drinking Water Sample Results

School: Pittsburgh Manchester PreK-8

Address: 1612 Manhattan Street, Pittsburgh, PA 15233

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First DrawPass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MAN-02-CF-74	CF	Classroom faucets	225	4/23/2019	0634	P	4.64	P	<1.00	
MAN-02-WO-75	WO	Water Fountain Attached to Sink	212	4/23/2019	0644	P	3.95	P	<1.00	
MAN-02-CF-76	CF	Classroom faucets	205	4/23/2019	0651	P	8.40	P	1.30	
MAN-02-WO-78	WO	Water Fountain Attached to Sink	111	4/23/2019						Not Testable - Low Flow
MAN-02-WO-79	WO	Water Fountain Attached to Sink	112	4/23/2019						Not in Operation
MAN-01-WO-80	WO	Water Fountain Attached to Sink	113	4/23/2019	0553	F	21.7	P	3.24	
MAN-02-WO-81	WO	Water Fountain Attached to Sink	114	4/23/2019						Not in Operation
MAN-01-WO-83	WO	Water Fountain Attached to Sink	150	4/23/2019						Not in Operation
MAN-02-WO-84	WO	Water Fountain Attached to Sink	151	4/23/2019						Not in Operation
MAN-02-WO-87	WO	Water Fountain Attached to Sink	200	4/23/2019						Not in Operation
MAN-02-WO-88	WO	Water Fountain Attached to Sink	201	4/23/2019						Not in Operation
MAN-02-WO-90	WO	Water Fountain Attached to Sink	239	4/23/2019						Not in Operation
MAN-02-WO-92	WO	Water Fountain Attached to Sink	241	4/23/2019						Not in Operation
MAN-01-WFC-96	WFC	Filtering water cooler w/ bottle filler	Corridor 108	4/23/2019	0619	P	<1.00	P	<1.00	
MAN-01-WF-97	WF	Water fountain with filter & cooler	Corridor 148	4/23/2019	0542	P	<1.00	P	<1.00	
MAN-02-WFC-100	WFC	Filtering water cooler w/ bottle filler	Corridor 213	4/23/2019	0649	P	<1.00	P	<1.00	
MAN-02-WO-101	WO	Water Fountain Attached to Sink	205	4/23/2019						Not in Operation
MAN-02-WF-102	WF	Water fountain with filter & cooler	Corridor 237	4/23/2019	0633	P	<1.00	P	<1.00	



Lead in Drinking Water Sample Results

School: Pittsburgh Miller PreK-5

Address: 2055 Bedford Avenue, Pittsburgh, PA 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MIL-GF-SL-00	SL	Service Line	17A	3/27/2019	0531	P	<1.00	N/A	N/A	
MIL-GF-WM-00	WM	Water Main	17A	3/27/2019	0534	P	<1.00	N/A	N/A	
MIL-GF-WF-01	WF	Water fountain with filter & cooler	Corridor 1A	3/27/2019	0530	P	<1.00	P	<1.00	
MIL-GF-WFC-02	WFC	Filtering water cooler w/ bottle filler	Corridor 1A	3/27/2019	0535	P	<1.00	P	<1.00	
MIL-GF-KF-09	KF	Kitchen faucets	2	3/27/2019	0537	P	1.44	P	<1.00	
MIL-GF-CF-12	CF	Classroom faucets	17	3/27/2019	0544	P	<1.00	P	<1.00	
MIL-GF-CF-13	CF	Classroom faucets	16	3/27/2019	0545	P	<1.00	P	<1.00	
MIL-GF-CF-15	CF	Classroom faucets	15	3/27/2019	0547	P	<1.00	P	<1.00	
MIL-GF-CF-17	CF	Classroom faucets	7	3/27/2019	0549	P	1.36	P	<1.00	
MIL-GF-WC-20	WC	Water fountain with cooler	Entry 1C	3/27/2019	0551	P	<1.00	P	<1.00	
MIL-GF-WC-21	WC	Water fountain with cooler	Entry 1C	3/27/2019	0552	P	<1.00	P	<1.00	
MIL-GF-CF-29	CF	Classroom faucets	11	3/27/2019	0554	P	1.25	P	<1.00	
MIL-01-TF-30	TF	Teacher's lounge sinks	116	3/27/2019	0558	P	<1.00	P	<1.00	
MIL-01-NF-33	NF	Nurse's office sink faucets	105	3/27/2019	0602	P	<1.00	P	<1.00	
MIL-01-CF-34	CF	Classroom faucets	114	3/27/2019	0606	P	5.1	P	<1.00	
MIL-01-CF-35	CF	Classroom faucets	106	3/27/2019	0608	P	3.82	P	1.25	
MIL-01-CF-36	CF	Classroom faucets	113	3/27/2019	0610	P	6.40	P	<1.00	
MIL-01-CF-39	CF	Classroom faucets	112	3/27/2019	0614	P	1.35	P	<1.00	
MIL-01-CF-40	CF	Classroom faucets	107	3/27/2019	0618	P	1.82	P	<1.00	
MIL-01-WF-44	WF	Water fountain with filter & cooler	Corridor 100	3/27/2019	0620	P	<1.00	P	<1.00	
MIL-01-WFC-45	WFC	Filtering water cooler w/ bottle filler	Corridor 100	3/27/2019	0621	P	<1.00	P	<1.00	
MIL-01-CF-49	CF	Classroom faucets	110	3/27/2019	0624	P	4.80	P	<1.00	
MIL-02-CF-50	CF	Classroom faucets	202	3/27/2019	0629	P	4.44	P	<1.00	
MIL-02-MS-51	MS	Miscellaneous sinks	203	3/27/2019	0633	P	8.00	P	1.20	
MIL-02-CF-53	CF	Classroom faucets	211	3/27/2019	0636	P	2.76	P	<1.00	
MIL-02-CF-55	CF	Classroom faucets	210	4/16/2019	0707	P	2.72	P	<1.00	
MIL-02-CF-57	CF	Classroom faucets	209	3/27/2019	0639	P	1.16	P	<1.00	
MIL-02-CF-59	CF	Classroom faucets	206	3/27/2019	0642	P	8.47	P	1.23	
MIL-02-WF-63	WF	Water fountain with filter & cooler	Corridor 200	3/27/2019	0650	P	<1.00	P	<1.00	
MIL-02-WFC-64	WFC	Filtering water cooler w/ bottle filler	Corridor 200	3/27/2019	0651	P	<1.00	P	<1.00	
MIL-GF-KF-68	KF	Kitchen faucets	2	3/27/2019	0538	P	2.16	P	<1.00	
MIL-GF-WO-70	WO	Water fountain without cooler	11	3/27/2019	0555	P	4.06	P	1.17	



## **Pittsburgh Millions 6-12**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Milliones 6-12

Address: 3117 Centre Avenue, Pittsburgh, PA 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MLO-02-SL-00	SL	Service Line	259	4/30/2019	0453	P	1.23	N/A	N/A	
MLO-02-WM-00	WM	Water Main	259	4/30/2019	0456	P	<1.00	N/A	N/A	
MLO-02-NF-03	NF	Nurse's office sink faucets	251	4/30/2019	0500	P	9.49	P	2.32	
MLO-02-NF-04	NF	Nurse's office sink faucets	253	4/30/2019	0501	P	6.71	P	1.21	
MLO-02-WFC-09	WFC	Filtering water cooler w/ bottle filler	Corridor 240	4/30/2019	0503	P	<1.00	P	<1.00	
MLO-02-WC-13	WC	Water fountain with cooler	242	4/30/2019	0506	P	1.80	P	2.57	
MLO-02-CF-28	CF	Classroom faucets	223	4/30/2019	0514	P	4.27	P	1.07	
MLO-02-WC-36	WC	Water fountain with cooler	220	4/30/2019	0517	P	1.56	P	3.66	
MLO-02-WFC-41	WFC	Filtering water cooler w/ bottle filler	Corridor 240	4/30/2019	0519	P	<1.00	P	<1.00	
MLO-02-KF-45	KF	Kitchen faucets	Kitchen (234)	4/30/2019	0509	P	5.60	P	1.37	
MLO-02-KF-47	KF	Kitchen faucets	Kitchen (234)	4/30/2019	0510	P	3.34	P	<1.00	
MLO-02-IM-49	IM	Ice machines	236	4/30/2019						Not in Operation
MLO-01-MS-55	MS	Miscellaneous sinks	118	4/30/2019	0524	P	3.01	P	1.46	
MLO-01-WFC-57	WFC	Filtering water cooler w/ bottle filler	129	4/30/2019	0526	P	<1.00	P	<1.00	
MLO-01-WF-64	WF	Water fountain with filter & cooler	Corridor 115	4/30/2019	0532	P	<1.00	P	<1.00	
MLO-01-CF-66	CF	Classroom faucets	110	4/30/2019	0534	P	1.03	P	<1.00	
MLO-01-CF-67	CF	Classroom faucets	110	4/30/2019	0535	P	<1.00	P	<1.00	
MLO-01-CF-68	CF	Classroom faucets	110	4/30/2019	0536	P	<1.00	P	<1.00	
MLO-03-WC-80	WC	Water fountain with cooler	Corridor 353	4/30/2019	0542	P	<1.00	P	<1.00	
MLO-03-WFC-87	WFC	Filtering water cooler w/ bottle filler	Corridor 329	4/30/2019	0550	P	<1.00	P	<1.00	
MLO-03-WC-114	WC	Water fountain with cooler	Outside 343	4/30/2019	0544	P	7.69	P	9.77	
MLO-04-TF-116	TF	Teacher's lounge sinks	437	4/30/2019	0554	P	<1.00	P	<1.00	
MLO-04-MS-119	MS	Miscellaneous sinks	430-A	4/30/2019	0557	P	<1.00	P	<1.00	
MLO-04-WFC-123	WFC	Filtering water cooler w/ bottle filler	Corridor 426	4/30/2019	0559	P	<1.00	P	<1.00	
MLO-04-WC-124	WC	Water fountain with cooler	Corridor 415	4/30/2019	0601	P	<1.00	P	<1.00	
MLO-05-WFC-149	WFC	Filtering water cooler w/ bottle filler	Corridor 506B	4/30/2019	0606	P	<1.00	P	<1.00	
MLO-05-MS-154	MS	Miscellaneous sinks	519	4/30/2019						Not in Operation
MLO-05-MS-155	MS	Miscellaneous sinks	519	4/30/2019						Not in Operation
MLO-05-WC-156	WC	Water fountain with cooler	Corridor 506A	4/30/2019	0608	P	<1.00	P	<1.00	
MLO-02-KF-161	KF	Kitchen faucets	Kitchen (234)	4/30/2019	0511	P	2.60	P	<1.00	
MLO-03-CF-163	CF	Classroom faucets	331	4/30/2019	0547	P	<1.00	P	<1.00	

## **Pittsburgh Montessori PreK-5**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Montessori PreK-5

Address: 201 S. Graham Street, Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MON-BS-SL-00	SL	Service Line	1	2/16/2019	0510	P	<1.00	N/A	N/A	
MON-BS-WM-00	WM	Water Main	1	2/16/2019	0513	P	<1.00	N/A	N/A	
MON-BS-NF-01	NF	Nurse's office sink faucets	Nurse's Office	2/16/2019	0509	P	1.06	P	<1.00	
MON-BS-CF-02	CF	Classroom faucets	9	2/16/2019	0515	P	<1.00	P	<1.00	
MON-BS-CF-03	CF	Classroom faucets	10	2/16/2019	0517	P	8.74	P	<1.00	MON-BS-CF-05
MON-BS-OF-04	OF	Office sink faucets	Custodian's Office	2/16/2019	0519	P	1.46	P	<1.00	MON-BS-RF-04
MON-GF-MS-05	MS	Miscellaneous sinks	Demountable Room 1	2/16/2019	0529	P	<1.00	P	<1.00	MON-GF-MS-53
MON-GF-WC-06	WC	Water fountain with cooler	Demountable Room 1	2/16/2019	0530	P	<1.00	P	<1.00	MON-GF-WC-51
MON-GF-CF-07	CF	Classroom faucets	Demountable Room 1	2/16/2019	0531	P	<1.00	P	<1.00	MON-GF-CF-08
MON-GF-CF-08	CF	Classroom faucets	Demountable Room 2	2/16/2019	0533	P	1.11	P	<1.00	MON-GF-CF-10
MON-GF-WC-09	WC	Water fountain with cooler	Demountable Room 2	2/16/2019	0534	P	<1.00	P	<1.00	MON-GF-WC-54
MON-GF-MS-10	MS	Miscellaneous sinks	Demountable Room 2	2/16/2019	0536	P	<1.00	P	<1.00	MON-GF-MS-55
MON-01-WC-11	WC	Water fountain with cooler	Corridor 100	2/16/2019	0540	P	<1.00	P	<1.00	MON-01-WC-15
MON-01-WC-12	WC	Water fountain with cooler	Corridor 100	2/16/2019	0541	P	<1.00	P	<1.00	MON-01-WC-16
MON-01-MS-13	MS	Miscellaneous sinks	103A	2/16/2019	0544	P	1.07	P	<1.00	MON-01-MS-11
MON-01-CF-14	CF	Classroom faucets	103	2/16/2019	0545	P	4.31	P	<1.00	MON-01-CF-49
MON-01-CF-15	CF	Classroom faucets	104	2/16/2019	0548	P	4.38	P	<1.00	MON-01-CF-20
MON-01-WF-16	WF	Water fountain with filter & cooler	Corridor 100A	2/16/2019	0550	P	<1.00	P	<1.00	MON-01-WF-21
MON-01-WFC-17	WFC	Filtering water cooler w/ bottle filler	Corridor 100A	2/16/2019	0551	P	<1.00	P	<1.00	MON-01-WFC-22
MON-01-KF-18	KF	Kitchen faucets	111B	2/16/2019	0553	P	1.48	P	<1.00	MON-01-KF-26
MON-01-OF-19	OF	Office sink faucets	Main office	2/16/2019	0558	P	4.43	P	<1.00	MON-01-OF-27
MON-01-WF-20	WF	Water fountain with filter & cooler	Corridor 100	2/16/2019	0600	P	<1.00	P	<1.00	MON-01-WF-29
MON-01-WFC-21	WFC	Filtering water cooler w/ bottle filler	Corridor 100	2/16/2019	0601	P	<1.00	P	<1.00	MON-01-WFC-30
MON-01-CF-22	CF	Classroom faucets	109	2/16/2019	0602	P	2.22	P	<1.00	MON-01-CF-28
MON-02-CF-23	CF	Classroom faucets	201	2/16/2019	0605	P	4.33	P	<1.00	MON-02-CF-34
MON-02-WF-24	WF	Water fountain with filter & cooler	Corridor 200	2/16/2019	0607	P	<1.00	P	<1.00	MON-02-WF-36
MON-02-WFC-25	WFC	Filtering water cooler w/ bottle filler	Corridor 200	2/16/2019	0608	P	<1.00	P	<1.00	MON-02-WFC-37
MON-02-CF-26	CF	Classroom faucets	203A	2/16/2019	0609	F	33.7	P	1.33	MON-02-CF-35 (Fixture not utilized, books observed on/in sink in storage closet)
MON-02-TF-27	TF	Teacher's lounge sinks	205	2/16/2019	0612	P	2.65	P	1.42	MON-02-TF-40
MON-02-CF-28	CF	Classroom faucets	207A	2/16/2019	0613	P	10.8	P	1.22	MON-02-CF-42
MON-02-WC-29	WC	Water fountain with cooler	Corridor 200	2/16/2019	0615	P	<1.00	P	<1.00	MON-02-WC-44

## **Pittsburgh Morrow Intermediate 5-8**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Morrow Intermediate 5-8

Address: 3530 Fleming Avenue, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MRN-BS-SL-00	SL	Service Line	018	6/13/2019	0539	P	<1.00	N/A	N/A	
MRN-BS-WM-00	WM	Water Main	018	6/13/2019	0541	P	<1.00	N/A	N/A	
MRN-BS-CF-01	CF	Classroom faucets	022	6/13/2019	0548	P	1.60	P	<1.00	
MRN-BS-CF-02	CF	Classroom faucets	002	6/13/2019						Cold Water Not in Operation
MRN-BS-CF-03	CF	Classroom faucets	002	6/13/2019	0547	P	<1.00	P	<1.00	
MRN-BS-CF-05	CF	Classroom faucets	001	6/13/2019	0538	P	<1.00	P	<1.00	
MRN-BS-CF-06	CF	Classroom faucets	001	6/13/2019	0542	P	<1.00	P	<1.00	
MRN-BS-CF-07	CF	Classroom faucets	001A	6/13/2019	0544	P	1.14	P	<1.00	
MRN-BS-WF-12	WF	Water fountain with filter & cooler	Corridor 022	6/13/2019	0551	P	<1.00	P	<1.00	
MRN-BS-WF-14	WF	Water fountain with filter & cooler	Corridor 022	6/13/2019	0559	P	<1.00	P	<1.00	
MRN-BS-CF-18	CF	Classroom faucets	003	6/13/2019	0601	P	<1.00	P	<1.00	
MRN-BS-CF-19	CF	Classroom faucets	003	6/13/2019						Not in Operation
MRN-BS-KF-24	KF	Kitchen faucets	Food Prep 033	6/13/2019	0554	P	1.36	P	<1.00	
MRN-BS-KF-25	KF	Kitchen faucets	Food Prep 033	6/13/2019	0555	P	<1.00	P	<1.00	
MRN-BS-IM-26	IM	Ice machines	031	6/13/2019	0556	P	<1.00	N/A	N/A	
MRN-BS-WF-37	WF	Water fountain with filter & cooler	Corridor B100	6/13/2019	0604	P	<1.00	P	<1.00	
MRN-BS-WFC-38	WFC	Filtering water cooler w/ bottle filler	Corridor B100	6/13/2019	0605	P	<1.00	P	<1.00	
MRN-01-WF-51	WF	Water fountain with filter & cooler	Corridor 114	6/13/2019	0610	P	<1.00	P	<1.00	
MRN-01-WF-61	WF	Water fountain with filter & cooler	Corridor 114	6/13/2019	0617	P	<1.00	P	<1.00	
MRN-02-WF-65	WF	Water fountain with filter & cooler	Corridor 218	6/13/2019	0621	P	<1.00	P	<1.00	
MRN-02-HF-68	HF	Home economics faucets (with cooking)	209	6/13/2019	0623	P	<1.00	P	<1.00	
MRN-02-HF-69	HF	Home economics faucets (with cooking)	209	6/13/2019	0625	P	<1.00	P	<1.00	
MRN-02-HF-70	HF	Home economics faucets (with cooking)	209	6/13/2019	0626	P	1.78	P	<1.00	
MRN-02-HF-71	HF	Home economics faucets (with cooking)	209	6/13/2019	0628	P	<1.00	P	<1.00	
MRN-02-MS-72	MS	Miscellaneous sinks	208A	6/13/2019	0630	P	<1.00	P	<1.00	
MRN-02-WF-76	WF	Water fountain with filter & cooler	Corridor 218	6/13/2019	0632	P	<1.00	P	<1.00	
MRN-03-WF-78	WF	Water fountain with filter & cooler	Corridor 312	6/13/2019	0636	P	<1.00	P	<1.00	
MRN-03-WF-79	WF	Water fountain with filter & cooler	Corridor 303	6/13/2019	0641	P	<1.00	P	<1.00	
MRN-03-MS-80	MS	Miscellaneous sinks	302	6/13/2019	0638	P	<1.00	P	<1.00	
MRN-01-NF-85	NF	Nurse's office sink faucets	109	6/13/2019	0615	P	<1.00	P	<1.00	
MRN-01-NF-86	NF	Nurse's office sink faucets	109B	6/13/2019	0616	P	<1.00	P	<1.00	
MRN-01-WFC-87	WFC	Filtering water cooler w/ bottle filler	Corridor 114	6/13/2019	0612	P	<1.00	P	<1.00	
MRN-02-WFC-88	WFC	Filtering water cooler w/ bottle filler	Corridor 218	6/13/2019	0633	P	<1.00	P	<1.00	

## **Pittsburgh Morrow PreK-8**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Morrow PreK-8

Address: 1611 Davis Avenue, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MOR-BS-SL-00	SL	Service Line	4A	3/29/2019	0534	P	<1.00	N/A	N/A	
MOR-BS-WM-00	WM	Water Main	4A	3/29/2019	0536	P	<1.00	N/A	N/A	
MOR-BS-WO-1	WO	Water fountain without cooler	1B	3/29/2019	0537	P	2.74	P	<1.00	
MOR-BS-WC-8	WC	Water fountain with cooler	Corridor 1	3/29/2019	0540	P	3.91	P	2.51	
MOR-BS-WC-9	WC	Water fountain with cooler	Corridor 1	3/29/2019	0541	P	2.60	P	1.75	
MOR-BS-MS-10	MS	Miscellaneous sinks	6	3/29/2019	0543	P	1.21	P	<1.00	
MOR-BS-CF-12	CF	Classroom faucets	Shop (8)	3/29/2019	0544	P	2.67	P	1.49	
MOR-BS-CF-13	CF	Classroom faucets	Shop (8)	3/29/2019	0546	P	3.98	P	<1.00	
MOR-BS-WF-17	WF	Water fountain with filter & cooler	Corridor 1G	3/29/2019	0548	P	<1.00	P	<1.00	
MOR-BS-WFC-18	WFC	Filtering water cooler w/ bottle filler	Corridor 1G	3/29/2019	0549	P	<1.00	P	<1.00	
MOR-BS-WO-19	WO	Water fountain without cooler	19A	3/29/2019	0551	P	3.82	P	1.34	
MOR-BS-CF-21	CF	Classroom faucets	19B Cloak Room	3/29/2019	0553	P	<1.00	P	<1.00	
MOR-01-CF-24	CF	Classroom faucets	105	4/16/2019	0744	P	3.48	P	<1.00	
MOR-01-CF-25	CF	Classroom faucets	104	3/29/2019	0601	P	5.41	P	1.39	
MOR-01-WO-26	WO	Water fountain without cooler	Corridor 100A	3/29/2019	0557	P	5.61	P	1.67	
MOR-01-WO-27	WO	Water fountain without cooler	Corridor 100A	3/29/2019	0559	P	2.52	P	<1.00	
MOR-01-CF-28	CF	Classroom faucets	102	3/29/2019	0604	P	7.32	P	3.13	
MOR-01-CF-29	CF	Classroom faucets	101	3/29/2019	0606	P	4.11	P	4.88	
MOR-01-WF-30	WF	Water fountain with filter & cooler	Corridor 100	3/29/2019	0608	P	<1.00	P	<1.00	
MOR-01-WF-31	WF	Water fountain with filter & cooler	Corridor 100	3/29/2019	0609	P	<1.00	P	<1.00	
MOR-01-NF-34	NF	Nurse's office sink faucets	109	3/29/2019	0611	P	6.45	P	1.31	
MOR-01-CF-37	CF	Classroom faucets	108	3/29/2019	0615	P	8.25	P	2.34	
MOR-01-WF-41	WF	Water fountain with filter & cooler	Corridor 100	3/29/2019	0617	P	<1.00	P	<1.00	
MOR-01-WFC-42	WFC	Filtering water cooler w/ bottle filler	Corridor 100	3/29/2019	0618	P	<1.00	P	<1.00	
MOR-01-MS-43	MS	Miscellaneous sinks	118	3/29/2019	0622	P	<1.00	P	<1.00	
MOR-01-CF-44	CF	Classroom faucets	116	3/29/2019	0624	P	<1.00	P	<1.00	
MOR-02-CF-45	CF	Classroom faucets	205	3/29/2019	0628	P	4.27	P	1.80	
MOR-02-CF-46	CF	Classroom faucets	204	3/29/2019	0632	P	3.03	P	1.22	
MOR-02-CF-47	CF	Classroom faucets	207	3/29/2019	0635	P	10.2	P	2.31	
MOR-02-CF-48	CF	Classroom faucets	201	3/29/2019	0636	P	10.1	P	1.52	
MOR-02-WC-49	WC	Water fountain with cooler	Corridor 200	3/29/2019	0639	P	<1.00	P	<1.00	
MOR-02-WC-50	WC	Water fountain with cooler	Corridor 200	3/29/2019	0640	P	<1.00	P	<1.00	
MOR-02-OF-53	OF	Office sink faucets	209	3/29/2019	0642	P	3.92	P	<1.00	
MOR-02-WF-58	WF	Water fountain with filter & cooler	Corridor 200	3/29/2019	0643	P	<1.00	P	<1.00	
MOR-02-WFC-59	WFC	Filtering water cooler w/ bottle filler	Corridor 200	3/29/2019	0644	P	<1.00	P	<1.00	
MOR-02-WO-61	WO	Water fountain without cooler	Corridor 200F	3/29/2019	0646	P	6.90	P	1.79	
MOR-02-WO-62	WO	Water fountain without cooler	Corridor 200F	3/29/2019	0647	P	4.07	P	1.93	
MOR-02-CF-63	CF	Classroom faucets	218	3/29/2019	0650	P	5.29	P	3.20	
MOR-01-CF-64	CF	Classroom faucets	106	3/29/2019	0613	P	2.56	P	1.56	
MOR-02-WO-67	WO	Water fountain without cooler	Corridor 200A	4/16/2019	0748	P	5.61	P	6.48	
MOR-02-WO-68	WO	Water fountain without cooler	Corridor 200A	3/29/2019	0630	P	4.05	P	1.70	



## **Pittsburgh Online Academy (South Annex)**

## Lead in Drinking Water Sample Results

School: Pittsburgh Online Academy (South Annex)

Address: 93 S. 10th Street, Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SOU-BS-SL-00	SL	Service Line	Utility Room (5)	6/18/2019	0604	P	<1.00	N/A	N/A	
SOU-BS-WM-00	WM	Water Main	Utility Room (5)	6/18/2019	0606	P	<1.00	N/A	N/A	
SOU-01-CF-02	CF	Classroom faucets	104	6/18/2019						Posted Hand Wash Only
SOU-01-CF-03	CF	Classroom faucets	104	6/18/2019						Posted Hand Wash Only / Not in Operation
SOU-01-CF-04	CF	Classroom faucets	104	6/18/2019						Posted Hand Wash Only / Not in Operation
SOU-01-CF-06	CF	Classroom faucets	110	6/18/2019						Not in Operation
SOU-01-CF-07	CF	Classroom faucets	110	6/18/2019	0617	P	1.43	P	<1.00	
SOU-01-WO-08	WO	Water fountain attached to sink	110	6/18/2019						Not Testable - Low Flow
SOU-01-WF-15	WF	Water fountain with filter & cooler	Corridor 100-A	6/18/2019	0609	P	<1.00	P	<1.00	
SOU-01-MS-18	MS	Miscellaneous sinks	108	6/18/2019	0612	P	2.07	P	2.52	
SOU-02-CF-20	CF	Classroom faucets	204	6/18/2019	0624	F	18.6	P	7.44	
SOU-02-CF-21	CF	Classroom faucets	204	6/18/2019	0625	P	14.8	P	2.05	
SOU-02-WC-22	WC	Water fountain with cooler	204	6/18/2019						Not in Operation
SOU-02-CF-25	CF	Classroom faucets	205	6/18/2019						Hand Wash Station / Not in Operation
SOU-02-WO-26	WO	Water fountain without cooler	203	6/18/2019						Not in Operation
SOU-02-CF-27	CF	Classroom faucets	203	6/18/2019						Not Testable - Low Flow
SOU-02-CF-28	CF	Classroom faucets	203	6/18/2019						Not Testable - Low Flow
SOU-02-CF-29	CF	Classroom faucets	210	6/18/2019						Not an Occupied Room
SOU-02-CF-30	CF	Classroom faucets	210	6/18/2019						Not an Occupied Room
SOU-02-WO-31	WO	Water fountain without cooler	210	6/18/2019						Not an Occupied Room
SOU-02-WC-32	WC	Water fountain with cooler	210	6/18/2019	0635	F	106	F	74.7	
SOU-02-CF-34	CF	Classroom faucets	210	6/18/2019						Not an Occupied Room
SOU-02-CF-35	CF	Classroom faucets	210	6/18/2019						Not an Occupied Room
SOU-02-WO-36	WO	Water fountain without cooler	210	6/18/2019						Not in Operation
SOU-02-WO-37	WO	Water fountain without cooler	202	6/18/2019						Not an Occupied Room
SOU-02-CF-38	CF	Classroom faucets	202	6/18/2019						Not an Occupied Room
SOU-02-CF-39	CF	Classroom faucets	202	6/18/2019						Not an Occupied Room
SOU-02-MS-40	MS	Miscellaneous sinks	201	6/18/2019						Posted Hand Wash Only
SOU-02-WC-44	WC	Water fountain with cooler	207	6/18/2019	0631	P	11.7	P	7.87	
SOU-02-WC-46	WC	Water fountain with cooler	205	6/18/2019	0621	F	45.1	P	6.09	
SOU-02-CF-47	CF	Classroom faucets	204	6/18/2019	0626	F	38.7	P	2.02	
SOU-02-CF-48	CF	Classroom faucets	204	6/18/2019	0628	F	15.0	P	11.8	
SOU-01-WFC-50	WFC	Filtering water cooler w/ bottle filler	Corridor 100-A	6/18/2019	0610	P	<1.00	P	<1.00	

## **Pittsburgh Perry Field House**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Perry Field House

Address: 119 Richards Street, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PFH-01-SL-00	SL	Service Line	Maintenance Room	6/1/2019	0702	P	<1.00	N/A	N/A	
PFH-01-WM-00	WM	Water Main	Maintenance Room	6/1/2019	0705	P	<1.00	N/A	N/A	
PFH-01-WC-01	WC	Water fountain with cooler	Maintenance Room	6/1/2019						Not in Operation
PFH-01-IM-02	IM	Ice machines	Maintenance Room	6/1/2019	0703	P	<1.00	N/A	N/A	
PFH-01-MS-05	MS	Miscellaneous Sinks	Office	6/1/2019	0707	P	5.16	P	1.84	
PFH-01-WC-06	WC	Water fountain with cooler	Office	6/1/2019	0708	P	4.40	P	3.08	
PFH-01-WFC-07	WFC	Filtering water cooler w/ bottle filler	Home Locker Room	6/1/2019	0711	P	<1.00	P	<1.00	
PFH-01-WFC-11	WFC	Filtering water cooler w/ bottle filler	Visiting Locker Room	6/1/2019	0715	P	<1.00	P	<1.00	

## **Pittsburgh Perry High School**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Perry High School

Address: 3875 Perrysville Avenue, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PER-BS-SL-00	SL	Service Line	Pipe Space 035	6/1/2019	0738	P	<1.00	N/A	N/A	
PER-BS-WM-00	WM	Water Main	Pipe Space 035	6/1/2019	0741	P	<1.00	N/A	N/A	
PER-BS-WF-02	WF	Water fountain with filter & cooler	Hall 021	6/1/2019	0742	P	<1.00	P	<1.00	
PER-BS-WFC-03	WFC	Filtering water cooler w/ bottle filler	Hall 021	6/1/2019	0743	P	<1.00	P	<1.00	
PER-BS-MS-04	MS	Miscellaneous sinks	024A	6/1/2019	0745	P	7.10	P	1.65	
PER-BS-WC-05	WC	Water fountain with cooler	Chorus (020)	6/1/2019	0747	P	<1.00	P	<1.00	
PER-SB-MS-06	MS	Miscellaneous sinks	019	6/1/2019						Posted Hand Wash Only
PER-SB-WF-08	WF	Water fountain with filter & cooler	RO13	6/1/2019	0752	P	<1.00	P	<1.00	
PER-01-WF-10	WF	Water fountain with filter & cooler	Corridor 131B	6/1/2019	0755	P	<1.00	P	<1.00	
PER-01-WFC-11	WFC	Filtering water cooler w/ bottle filler	Corridor 131B	6/1/2019	0757	P	<1.00	P	<1.00	
PER-01-MS-25	MS	Miscellaneous sinks	140E	6/1/2019	0759	P	2.75	P	1.51	
PER-01-TF-26	TF	Teacher's lounge sinks	142	6/1/2019	0802	P	<1.00	P	<1.00	
PER-01-WC-38	WC	Water fountain with cooler	Corridor 131B	6/1/2019	0804	P	<1.00	P	<1.00	
PER-01-WC-39	WC	Water fountain with cooler	Corridor 131B	6/1/2019	0805	P	<1.00	P	<1.00	
PER-01-MS-46	MS	Miscellaneous sinks	150A	6/1/2019	0806	P	1.70	P	<1.00	
PER-01-NF-49	NF	Nurse's office sink faucets	147D	6/1/2019	0810	P	3.14	P	<1.00	
PER-01-NF-50	NF	Nurse's office sink faucets	147A	6/1/2019	0811	P	11.0	P	3.35	
PER-01-KF-51	KF	Kitchen faucets	Food Prep (162)	6/1/2019	0815	P	3.97	P	1.75	
PER-01-KF-52	KF	Kitchen faucets	Food Prep (162)	6/1/2019	0817	P	8.63	P	<1.00	
PER-01-WFC-54	WFC	Filtering water cooler w/ bottle filler	Cafeteria (160)	6/1/2019	0818	P	<1.00	P	<1.00	
PER-01-WF-55	WF	Water fountain with filter & cooler	Cafeteria (160)	6/1/2019	0819	P	<1.00	P	<1.00	
PER-02-WC-59	WC	Water fountain with cooler	Corridor 200	6/1/2019	0825	P	1.87	P	<1.00	
PER-02-WC-60	WC	Water fountain with cooler	Corridor 200	6/1/2019	0826	P	<1.00	P	<1.00	
PER-02-WF-85	WF	Water fountain with filter & cooler	Corridor 200	6/1/2019	0828	P	<1.00	P	<1.00	
PER-02-WFC-86	WFC	Filtering water cooler w/ bottle filler	Corridor 200	6/1/2019	0829	P	<1.00	P	<1.00	
PER-02-WF-96	WF	Water fountain with filter & cooler	Corridor 200D	6/1/2019	0836	P	<1.00	P	<1.00	
PER-02-CF-117	CF	Classroom faucets	267	6/1/2019	0832	P	<1.00	P	<1.00	
PER-02-CF-118	CF	Classroom faucets	267	6/1/2019						Not in Operation
PER-02-CF-119	CF	Classroom faucets	267	6/1/2019	0833	P	2.17	P	<1.00	
PER-03-WC-131	WC	Water fountain with cooler	Corridor 300	6/1/2019	0842	P	<1.00	P	<1.00	
PER-03-WC-132	WC	Water fountain with cooler	Corridor 300	6/1/2019	0843	P	<1.00	P	<1.00	
PER-03-CF-134	CF	Classroom faucets	Art Room (326)	6/1/2019	0846	P	6.62	P	<1.00	
PER-03-CF-135	CF	Classroom faucets	Art Room (326)	6/1/2019	0847	F	22.5	P	2.19	
PER-03-HF-142	HF	Home economics faucets (with cooking)	Home Economics (333)	6/1/2019	0849	P	1.47	P	<1.00	
PER-03-HF-143	HF	Home economics faucets (with cooking)	Home Economics (333)	6/1/2019	0850	P	2.30	P	<1.00	
PER-03-HF-144	HF	Home economics faucets (with cooking)	Home Economics (333)	6/1/2019	0851	P	<1.00	P	<1.00	
PER-03-HF-145	HF	Home economics faucets (with cooking)	Home Economics (333)	6/1/2019	0852	P	5.57	P	1.05	
PER-03-CF-146	CF	Classroom faucets	338	6/1/2019	0853	P	2.86	P	1.73	
PER-03-CF-147	CF	Classroom faucets	342	6/1/2019	0856	P	<1.00	P	<1.00	
PER-03-CF-148	CF	Classroom faucets	342	6/1/2019	0857	P	1.35	P	<1.00	
PER-03-WC-149	WC	Water fountain with cooler	Corridor 300	6/1/2019	0858	P	<1.00	P	<1.00	
PER-03-WC-150	WC	Water fountain with cooler	Corridor 300	6/1/2019	0859	P	<1.00	P	<1.00	
PER-03-WFC-157	WFC	Filtering water cooler w/ bottle filler	Corridor 300E	6/1/2019	0901	P	<1.00	P	<1.00	

## Lead in Drinking Water Sample Results

School: Pittsburgh Perry High School

Address: 3875 Perrysville Avenue, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PER-02-SL-159	SL	Service Line	825	6/1/2019	0911	P	<1.00	N/A	N/A	
PER-02-WM-159	WM	Water Main	825	6/1/2019	0914	P	<1.00	N/A	N/A	
PER-02-WFC-176	WFC	Filtering water cooler w/ bottle filler	Corridor 800	6/1/2019	0915	P	<1.00	P	<1.00	
PER-02-WO-211	WO	Water fountain without cooler	Pool	6/1/2019						Not in Operation
PER-02-WO-236	WO	Water fountain without cooler	818B	6/1/2019	0923	P	<1.00	P	1.31	
PER-01-WO-246	WO	Water fountain without cooler	Corridor 700	6/1/2019	0927	P	<1.00	P	<1.00	
PER-03-WF-250	WF	Water fountain with filter & cooler	Outside 903	6/1/2019	0934	P	<1.00	P	<1.00	
PER-03-MS-251	MS	Miscellaneous sinks	903	6/1/2019	0933	P	5.18	P	2.64	
PER-01-KF-256	KF	Kitchen faucets	Food Prep (162)	6/1/2019	0816	P	1.79	P	<1.00	
PER-02-MS-258	MS	Miscellaneous sinks	823	6/1/2019	0918	P	4.26	P	1.17	
PER-02-IM-259	IM	Ice Machines	823	6/1/2019	0919	P	<1.00	N/A	N/A	
PER-02-WF-261	WF	Water fountain with filter & cooler	Corridor 200D	6/1/2019	0837	P	<1.00	P	<1.00	
PER-03-WF-292	WF	Water fountain with filter & cooler	Corridor 300E	6/1/2019	0902	P	<1.00	P	<1.00	
PER-03-WFC-294	WFC	Filtering water cooler w/ bottle filler	Outside 903	6/1/2019	0935	P	<1.00	P	<1.00	





## Lead in Drinking Water Sample Results

School: Pittsburgh Pioneer

Address: 775 Dunster Street, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PIO-BS-SL-00	SL	Service Line	Boiler Room	2/16/2019	0658	P	1.08	N/A	N/A	
PIO-BS-WM-00	WM	Water Main	Boiler Room	2/16/2019	0701	P	<1.00	N/A	N/A	
PIO-BS-MS-01	MS	Miscellaneous sinks	Corridor A011	2/16/2019	0702	P	1.04	P	<1.00	PIO-BS-MS-09
PIO-01-WC-02	WC	Water fountain with cooler	Corridor D	2/16/2019	0705	P	1.37	P	1.49	PIO-01-WC-12
PIO-01-WFC-03	WFC	Filtering water cooler w/ bottle filler	Corridor C	2/16/2019	0708	P	<1.00	P	<1.00	PIO-01-WFC-22
PIO-01-WFC-04	WFC	Filtering water cooler w/ bottle filler	Corridor E	2/16/2019	0711	P	<1.00	P	<1.00	PIO-01-WFC-43
PIO-01-HF-05	HF	Home economics faucets (with cooking)	108	2/16/2019	0713	P	<1.00	P	<1.00	PIO-01-HF-46
PIO-01-MS-06	MS	Miscellaneous sinks	108	2/16/2019	0714	P	<1.00	P	<1.00	PIO-01-MS-47



Lead in Drinking Water Sample Results

School: Pittsburgh Roosevelt 2-5

Address: 17 W. Cherryhill Street, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
RSV-BS-SL-00	SL	Service Line	Boiler Room	5/21/2019	0600	P	<1.00	N/A	N/A	
RSV-BS-WM-00	WM	Water Main	Boiler Room	5/21/2019	0603	P	<1.00	N/A	N/A	
RSV-BS-WF-06	WF	Water fountain with filter & cooler	Outside 005	5/21/2019	0604	P	<1.00	P	<1.00	
RSV-BS-WFC-07	WFC	Filtering water cooler w/ bottle filler	Outside 005	5/21/2019	0605	P	<1.00	P	<1.00	
RSV-01-WF-15	WF	Water fountain with filter & cooler	Corridor 100A	5/21/2019	0607	P	<1.00	P	<1.00	
RSV-01-WFC-16	WFC	Filtering water cooler w/ bottle filler	Corridor 100A	5/21/2019	0608	P	<1.00	P	<1.00	
RSV-01-MS-26	MS	Miscellaneous sinks	110	5/21/2019	0612	P	<1.00	P	<1.00	
RSV-02-WF-31	WF	Water fountain with filter & cooler	Corridor 200A	5/21/2019	0617	P	<1.00	P	<1.00	
RSV-02-WFC-32	WFC	Filtering water cooler w/ bottle filler	Corridor 200A	5/21/2019	0619	P	<1.00	P	<1.00	
RSV-02-MS-37	MS	Miscellaneous sinks	214B	5/21/2019	0621	P	<1.00	P	<1.00	
RSV-03-WF-43	WF	Water fountain with filter & cooler	Corridor 300A	5/21/2019	0625	P	<1.00	P	<1.00	
RSV-03-WFC-44	WFC	Filtering water cooler w/ bottle filler	Corridor 300A	5/21/2019	0626	P	<1.00	P	<1.00	
RSV-03-MS-49	MS	Miscellaneous sinks	309	5/21/2019	0628	P	1.59	P	<1.00	
RSV-03-CF-50	CF	Classroom faucets	311	5/21/2019	0630	P	<1.00	P	<1.00	
RSV-03-CF-51	CF	Classroom faucets	311	5/21/2019	0631	P	<1.00	P	<1.00	
RSV-01-CF-53	CF	Classroom faucets	108	5/21/2019	0610	P	<1.00	P	<1.00	
RSV-01-CF-54	CF	Classroom faucets	112	5/21/2019	0614	P	<1.00	P	<1.00	

## **Pittsburgh Schenley Field House**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Schenley Field House

Address: 3031 Iowa Street, Pittsburgh, PA 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SFH-BS-SL-00	SL	Service Line	Heater Room	4/30/2019	0646	P	1.03	N/A	N/A	
SFH-BS-WM-00	WM	Water Main	Heater Room	4/30/2019	0648	P	<1.00	N/A	N/A	
SFH-BS-IM-01	IM	Ice machines	Heater Room	4/30/2019						Not in Operation
SFH-GF-FF-02	FF	Field House sink faucets	Home Dressing Room	4/30/2019	0645	P	2.38	P	<1.00	
SFH-GF-FF-03	FF	Field House sink faucets	Home Dressing Room	4/30/2019	0649	P	3.34	P	<1.00	
SFH-GF-WFC-06	WFC	Filtering water cooler w/ bottle filler	Outside	4/30/2019	0651	P	<1.00	P	<1.00	
SFH-GF-WF-07	WF	Water fountain with filter & cooler	Outside	4/30/2019	0653	P	<1.00	P	<1.00	
SFH-GF-FF-12	FF	Field House sink faucets	Visitors Dressing Room	4/30/2019	0659	P	7.73	P	<1.00	
SFH-GF-FF-13	FF	Field House sink faucets	Visitors Dressing Room	4/30/2019	0700	F	25.9	P	1.03	
SFH-GF-MS-14	MS	Miscellaneous sinks	Outside	4/30/2019	0657	P	<1.00	P	<1.00	

## **Pittsburgh Science & Technology Academy 6-12**

Lead in Drinking Water Sample Results

School: Pittsburgh Science and Technology Academy 6-12

Address: 107 Thackery Avenue, Pittsburgh, PA 15213

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SAT-GF-SL-00	SL	Service Line	55B	4/25/2019	0500	P	<1.00	N/A	N/A	
SAT-GF-WM-00	WM	Water Main	55B	4/25/2019	0503	P	<1.00	N/A	N/A	
SAT-GF-WF-05	WF	Water fountain with filter & cooler	Corridor 32	4/25/2019	0505	P	<1.00	P	<1.00	
SAT-GF-WFC-06	WFC	Filtering water cooler w/ bottle filler	Corridor 32	4/25/2019	0506	P	<1.00	P	<1.00	
SAT-GF-WO-28	WO	Water fountain without cooler	Corridor 32	4/25/2019	0508	P	1.08	P	<1.00	
SAT-GF-WO-29	WO	Water fountain without cooler	Corridor 32	4/25/2019						Not Testable - Low Flow
SAT-GF-WO-35	WO	Water fountain without cooler	31	4/25/2019	0513	P	13.7	P	2.79	
SAT-GF-WO-36	WO	Water fountain without cooler	27	4/25/2019	0511	P	<1.00	P	<1.00	
SAT-GF-WO-37	WO	Water fountain without cooler	29	4/25/2019						Not in Operation
SAT-GF-WO-56	WO	Water fountain without cooler	67	4/25/2019	0516	P	<1.00	P	<1.00	
SAT-01-MS-58	MS	Miscellaneous sinks	144	4/25/2019	0528	P	<1.00	P	<1.00	
SAT-01-NF-60	NF	Nurse's office sink faucets	134A	4/25/2019	0526	P	<1.00	P	<1.00	
SAT-01-WC-62	WC	Water fountain with cooler	Corridor 120	4/25/2019	0530	P	<1.00	P	<1.00	
SAT-01-WC-63	WC	Water fountain with cooler	Corridor 120	4/25/2019	0531	P	<1.00	P	<1.00	
SAT-01-IM-82	IM	Ice machines	123	4/25/2019	0534	P	14.8	N/A	N/A	
SAT-01-WO-86	WO	Water fountain without cooler	Corridor 120	4/25/2019	0536	P	1.33	P	<1.00	
SAT-01-WO-87	WO	Water fountain without cooler	Corridor 120	4/25/2019	0538	P	<1.00	P	<1.00	
SAT-01-WF-88	WF	Water fountain with filter & cooler	Corridor 111	4/25/2019	0540	P	<1.00	P	<1.00	
SAT-01-WFC-89	WFC	Filtering water cooler w/ bottle filler	Corridor 111	4/25/2019	0541	P	<1.00	P	<1.00	
SAT-01-KF-90	KF	Kitchen faucets	108	4/25/2019	0546	P	2.02	P	<1.00	
SAT-01-KF-95	KF	Kitchen faucets	108	4/25/2019	0548	P	2.16	P	<1.00	
SAT-01-KF-96	KF	Kitchen faucets	109	4/25/2019	0549	P	3.89	P	<1.00	
SAT-01-KF-97	KF	Kitchen faucets	109	4/25/2019	0550	P	10.7	P	<1.00	
SAT-01-CF-107	CF	Classroom faucets	100	4/25/2019	0544	P	<1.00	P	<1.00	
SAT-02-WC-108	WC	Water fountain with cooler	Corridor 208	4/25/2019	0556	P	<1.00	P	<1.00	
SAT-02-WC-109	WC	Water fountain with cooler	Corridor 208	4/25/2019	0557	P	<1.00	P	<1.00	
SAT-02-MS-114	MS	Miscellaneous sinks	225	4/25/2019	0555	P	<1.00	P	<1.00	
SAT-02-WF-119	WF	Water fountain with filter & cooler	Corridor 208	4/25/2019	0600	P	<1.00	P	<1.00	
SAT-02-WFC-120	WFC	Filtering water cooler w/ bottle filler	Corridor 208	4/25/2019	0601	P	<1.00	P	<1.00	
SAT-03-WC-149	WC	Water fountain with cooler	Corridor 300	4/25/2019	0604	P	<1.00	P	<1.00	
SAT-03-WC-150	WC	Water fountain with cooler	Corridor 300	4/25/2019	0605	P	<1.00	P	<1.00	
SAT-03-WF-158	WF	Water fountain with filter & cooler	Corridor 300	4/25/2019	0608	P	<1.00	P	<1.00	
SAT-03-WFC-159	WFC	Filtering water cooler w/ bottle filler	Corridor 300	4/25/2019	0609	P	<1.00	P	<1.00	
SAT-GF-CF-162	CF	Classroom faucets	22	4/25/2019	0520	P	<1.00	P	<1.00	

## Pittsburgh Service Center

---



Lead in Drinking Water Sample Results

School: Pittsburgh Service Center

Address: 1305 Muriel Street, Pittsburgh, PA 15205

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SCN-01-SL-00	SL	Service Line	Lay Out Area	6/27/2019	0534	P	<1.00	N/A	N/A	
SCN-01-WM-00	WM	Water Main	Lay Out Area	6/27/2019	0536	P	<1.00	N/A	N/A	
SCN-01-MS-01	MS	Miscellaneous sinks	Food Service Shop	6/27/2019	0533	P	<1.00	P	<1.00	
SCN-01-WC-07	WC	Water fountain with cooler	Outside Custodian's Office	6/27/2019	0538	P	<1.00	P	<1.00	
SCN-01-IM-10	IM	Ice machines	Boiler Room	6/27/2019	0540	P	<1.00	N/A	N/A	
SCN-01-MS-13	MS	Miscellaneous sinks	Music Repair Shop	6/27/2019	0545	P	10.2	P	2.17	
SCN-01-WC-14	WC	Water fountain with cooler	Music Repair Shop	6/27/2019	0546	P	2.39	P	2.28	
SCN-01-MS-17	MS	Miscellaneous sinks	Call Center	6/27/2019	0543	P	<1.00	P	<1.00	
SCN-02-MS-18	MS	Miscellaneous sinks	Facilities Design / Const.	6/27/2019	0619	P	<1.00	P	<1.00	
SCN-02-MS-19	MS	Miscellaneous sinks	Next to Purchasing	6/27/2019	0551	P	1.69	P	1.27	
SCN-02-WC-29	WC	Water fountain with cooler	Plumbing	6/27/2019	0617	P	<1.00	P	<1.00	
SCN-02-MS-31	MS	Miscellaneous sinks	Shipping Office	6/27/2019	0610	P	2.89	P	1.67	
SCN-02-MS-33	MS	Miscellaneous sinks	General Office	6/27/2019	0606	P	1.41	P	9.70	
SCN-02-IM-34	IM	Ice machines	General Storage	6/27/2019	0556	P	<1.00	N/A	N/A	
SCN-02-WC-36	WC	Water fountain with cooler	Corridor	6/27/2019	0614	P	<1.00	P	<1.00	
SCN-02-WC-41	WC	Water fountain with cooler	Shipping Dock	6/27/2019	0608	P	2.45	P	2.83	
SCN-02-MS-46	MS	Miscellaneous sinks	Corridor	6/27/2019	0615	P	<1.00	P	<1.00	

## **Pittsburgh South Brook 6-8**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh South Brook 6-8

779 Dunster Street, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SBK-BS-SL-00	SL	Service Line	Boiler Room	6/4/2019	0558	P	1.92	N/A	N/A	
SBK-BS-WM-00	WM	Water Main	Boiler Room	6/4/2019	0601	P	<1.00	N/A	N/A	
SBK-01-NF-37	NF	Nurse's office sink faucets	151.6	6/4/2019	0605	P	<1.00	P	<1.00	
SBK-01-IM-39	IM	Ice machines	Receiving (158)	6/4/2019						Not in Operation
SBK-01-WF-41	WF	Water fountain with filter & cooler	Corridor 101	6/4/2019	0606	P	<1.00	P	<1.00	
SBK-01-WFC-42	WFC	Filtering water cooler w/ bottle filler	Corridor 101	6/4/2019	0607	P	<1.00	P	<1.00	
SBK-01-KF-45	KF	Kitchen faucets	Kitchen (157)	6/4/2019	0611	P	<1.00	P	<1.00	
SBK-01-TF-46	TF	Teacher's lounge sinks	159	6/4/2019	0612	P	<1.00	P	<1.00	
SBK-01-CF-47	CF	Classroom faucets	160	6/4/2019	0614	P	<1.00	P	<1.00	
SBK-01-CF-48	CF	Classroom faucets	161	6/4/2019	0615	P	<1.00	P	<1.00	
SBK-01-CF-49	CF	Classroom faucets	162	6/4/2019	0622	P	<1.00	P	<1.00	
SBK-01-CF-50	CF	Classroom faucets	162	6/4/2019	0623	P	<1.00	P	<1.00	
SBK-01-CF-51	CF	Classroom faucets	163	6/4/2019	0617	P	<1.00	P	<1.00	
SBK-01-CF-52	CF	Classroom faucets	164	6/4/2019	0619	P	<1.00	P	<1.00	
SBK-01-CF-53	CF	Classroom faucets	165	6/4/2019	0620	P	<1.00	P	<1.00	
SBK-01-WF-58	WF	Water fountain with filter & cooler	Gym Lobby	6/4/2019	0628	P	<1.00	P	<1.00	
SBK-01-WFC-59	WFC	Filtering water cooler w/ bottle filler	Gym Lobby	6/4/2019	0629	P	<1.00	P	<1.00	
SBK-02-CF-69	CF	Classroom faucets	206	6/4/2019	0632	P	<1.00	P	<1.00	
SBK-02-CF-70	CF	Classroom faucets	207	6/4/2019	0638	P	<1.00	P	<1.00	
SBK-02-CF-71	CF	Classroom faucets	208	6/4/2019	0640	P	<1.00	P	<1.00	
SBK-02-CF-72	CF	Classroom faucets	208	6/4/2019						Not in Operation
SBK-02-CF-73	CF	Classroom faucets	209	6/4/2019	0633	P	<1.00	P	<1.00	
SBK-02-CF-74	CF	Classroom faucets	210	6/4/2019	0635	P	<1.00	P	<1.00	
SBK-02-CF-75	CF	Classroom faucets	211	6/4/2019	0637	P	<1.00	P	<1.00	
SBK-02-WF-80	WF	Water fountain with filter & cooler	Corridor 219	6/4/2019	0641	P	<1.00	P	<1.00	
SBK-02-WFC-81	WFC	Filtering water cooler w/ bottle filler	Corridor 219	6/4/2019	0642	P	<1.00	P	<1.00	



Lead in Drinking Water Sample Results

School: Pittsburgh Sterrett 6-8

Address: 7100 Reynolds Street, Pittsburgh, PA 15208

Fixture ID	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
STE-GF-SL-00	Service Line	Janitor's Office	6/11/2019	0556	P	<1.00	N/A	N/A	
STE-GF-WM-00	Water Main	Janitor's Office	6/11/2019	0558	P	<1.00	N/A	N/A	
STE-GF-CF-03	Classroom faucets	G014	6/11/2019						Not in Operation
STE-GF-WFC-04	Filtering water cooler w/ bottle filler	Corridor 007	6/11/2019	0600	P	<1.00	P	<1.00	
STE-GF-CF-06	Classroom faucets	B01	6/11/2019	0601	P	1.05	P	<1.00	
STE-GF-CF-07	Classroom faucets	B01	6/11/2019	0602	P	3.72	P	1.07	
STE-GF-WF-31	Water fountain with filter & cooler	Outside Staff Restroom	6/11/2019	0604	P	<1.00	P	<1.00	
STE-GF-WFC-32	Filtering water cooler w/ bottle filler	Outside Staff Restroom	6/11/2019	0605	P	<1.00	P	<1.00	
STE-GF-WC-38	Water fountain with cooler	Cafeteria (115)	6/11/2019	0607	P	1.42	P	<1.00	
STE-GF-WC-39	Water fountain with cooler	Cafeteria (115)	6/11/2019	0608	P	<1.00	P	<1.00	
STE-GF-KF-40	Kitchen faucets	Kitchen (116)	6/11/2019	0610	P	<1.00	P	<1.00	
STE-GF-KF-42	Kitchen faucets	Kitchen (116)	6/11/2019	0611	P	<1.00	P	<1.00	
STE-01-WF-45	Water fountain with filter & cooler	Corridor 100	6/11/2019	0618	P	<1.00	P	<1.00	
STE-01-WFC-46	Filtering water cooler w/ bottle filler	Corridor 100	6/11/2019	0619	P	<1.00	P	<1.00	
STE-01-WO-49	Water fountain without cooler	Corridor 100	6/11/2019	0622	P	<1.00	P	<1.00	
STE-01-WO-50	Water fountain without cooler	Corridor 100	6/11/2019	0623	P	<1.00	P	<1.00	
STE-01-CF-52	Classroom faucets	105	6/11/2019	0625	P	2.88	P	<1.00	
STE-01-TF-53	Teacher's lounge sinks	Teacher's Lounge	6/11/2019	0620	P	<1.00	P	<1.00	
STE-01-NF-54	Nurse's office sink faucets	Nurse's Office	6/11/2019	0628	P	<1.00	P	<1.00	
STE-01-WC-62	Water fountain with cooler	Outside 122	6/11/2019	0629	P	<1.00	P	<1.00	
STE-01-WC-63	Water fountain with cooler	Outside 122	6/11/2019	0630	F	24.7	P	<1.00	
STE-02-WF-69	Water fountain with filter & cooler	Corridor 200	6/11/2019	0640	P	<1.00	P	<1.00	
STE-02-WFC-70	Filtering water cooler w/ bottle filler	Corridor 200	6/11/2019	0641	P	<1.00	P	<1.00	
STE-02-TF-75	Teacher's lounge sinks	208	6/11/2019						Posted Hand Wash Only
STE-02-WO-76	Water fountain without cooler	Corridor 200A	6/11/2019	0637	P	<1.00	P	<1.00	
STE-02-WO-77	Water fountain without cooler	Corridor 200A	6/11/2019	0638	P	<1.00	P	<1.00	
STE-02-CF-85	Classroom faucets	203	6/11/2019	0635	P	9.61	P	1.48	
STE-GF-KF-86	Kitchen faucets	Kitchen (116)	6/11/2019	0612	P	<1.00	P	<1.00	
STE-01-MS-87	Miscellaneous sinks	Library	6/11/2019	0632	P	<1.00	P	<1.00	
STE-GF-IM-88	Ice machines	Kitchen (116)	6/11/2019	0614	P	<1.00	N/A	N/A	

## **Pittsburgh Sunnyside PreK-8**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Sunnyside PreK-8

Address: 4801 Stanton Avenue, Pittsburgh, PA 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SUN-BS-SL-00	SL	Service Line	Boiler Room	4/10/2019	0540	P	<1.00	N/A	N/A	
SUN-BS-WM-00	WM	Water Main	Boiler Room	4/10/2019	0543	P	<1.00	N/A	N/A	
SUN-01-CF-02	CF	Classroom faucets	124	4/10/2019	0555	P	3.87	P	<1.00	
SUN-01-WO-05	WO	Water fountain without cooler	Corridor 103	4/10/2019	0547	P	2.07	P	<1.00	
SUN-01-WO-06	WO	Water fountain without cooler	Corridor 103	4/10/2019	0549	P	1.35	P	<1.00	
SUN-01-MS-15	MS	Miscellaneous sinks	115	4/10/2019	0552	P	10.2	P	<1.00	
SUN-01-TF-17	TF	Teacher's lounge sinks	112	4/10/2019	0613	P	6.51	P	<1.00	
SUN-01-MS-18	MS	Miscellaneous sinks	111A	4/10/2019	0615	P	7.36	P	<1.00	
SUN-01-NF-19	NF	Nurse's office sink faucets	110	4/10/2019	0618	P	2.95	P	<1.00	
SUN-01-WC-28	WC	Water fountain with cooler	Outside Café (190)	4/10/2019	0622	P	<1.00	P	<1.00	
SUN-01-WC-29	WC	Water fountain with cooler	Outside Café (190)	4/10/2019	0623	P	<1.00	P	<1.00	
SUN-01-KF-31	KF	Kitchen faucets	Kitchen (192)	4/10/2019	0629	P	1.53	P	<1.00	
SUN-01-KF-32	KF	Kitchen faucets	Kitchen (192)	4/10/2019	0630	P	2.05	P	<1.00	
SUN-01-WF-54	WF	Water fountain with filter & cooler	Corridor 102	4/10/2019	0634	P	<1.00	P	<1.00	
SUN-01-WFC-55	WFC	Filtering water cooler w/ bottle filler	Corridor 102	4/10/2019	0635	P	<1.00	P	<1.00	
SUN-01-CF-61	CF	Classroom faucets	149	4/10/2019	0637	P	2.22	P	<1.00	
SUN-01-CF-62	CF	Classroom faucets	147	4/10/2019	0638	P	8.39	P	1.42	
SUN-01-CF-63	CF	Classroom faucets	145	4/10/2019	0640	P	3.88	P	<1.00	
SUN-01-CF-64	CF	Classroom faucets	146	4/10/2019	0641	F	16.5	P	<1.00	
SUN-01-WF-65	WF	Water fountain with filter & cooler	Corridor 102	4/10/2019	0643	P	<1.00	P	<1.00	
SUN-01-WF-66	WF	Water fountain with filter & cooler	Corridor 102	4/10/2019	0644	P	<1.00	P	<1.00	
SUN-01-CF-67	CF	Classroom faucets	126	4/10/2019	0600	P	1.94	P	<1.00	
SUN-01-CF-68	CF	Classroom faucets	127	4/10/2019	0558	P	<1.00	P	<1.00	
SUN-01-CF-69	CF	Classroom faucets	128	4/10/2019	0604	P	<1.00	P	<1.00	
SUN-01-CF-70	CF	Classroom faucets	129	4/10/2019	0602	P	12.6	P	<1.00	
SUN-01-WF-71	WF	Water fountain with filter & cooler	Corridor 103	4/10/2019	0606	P	<1.00	P	<1.00	
SUN-01-WF-72	WF	Water fountain with filter & cooler	Corridor 103	4/10/2019	0607	P	<1.00	P	<1.00	
SUN-01-CF-73	CF	Classroom faucets	131	4/10/2019	0609	P	4.31	P	<1.00	
SUN-01-CF-75	CF	Classroom faucets	132	4/10/2019	0648	P	<1.00	P	<1.00	
SUN-01-CF-76	CF	Classroom faucets	132	4/10/2019	0649	P	1.33	P	<1.00	
SUN-01-CF-79	CF	Classroom faucets	136	4/10/2019	0652	P	<1.00	P	<1.00	
SUN-01-CF-85	CF	Classroom faucets	140	4/10/2019	0658	P	5.59	P	2.47	
SUN-01-WC-86	WC	Water fountain with cooler	Corridor 160	4/10/2019	0654	P	<1.00	P	<1.00	
SUN-01-WC-87	WC	Water fountain with cooler	Corridor 160	4/10/2019	0656	P	<1.00	P	<1.00	
SUN-01-CF-88	CF	Classroom faucets	140	4/10/2019	0700	P	<1.00	P	1.97	
SUN-01-CF-89	CF	Classroom faucets	140	4/10/2019	0702	P	<1.00	P	1.36	
SUN-01-CF-91	CF	Classroom faucets	142	4/10/2019	0705	P	<1.00	P	1.99	
SUN-01-CF-92	CF	Classroom faucets	142	4/10/2019	0706	P	<1.00	P	1.26	
SUN-01-WC-93	WC	Water fountain with cooler	180	4/10/2019	0620	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Sunnyside PreK-8

Address: 4801 Stanton Avenue, Pittsburgh, PA 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SUN-01-WC-94	WC	Water fountain with cooler	172	4/10/2019	0626	P	<1.00	P	<1.00	
SUN-01-CF-95	CF	Classroom faucets	140	4/10/2019	0659	P	3.55	P	1.79	
SUN-01-CF-96	CF	Classroom faucets	140	4/10/2019	0701	P	1.64	P	1.19	
SUN-01-KF-97	KF	Kitchen faucets	Kitchen (192)	4/10/2019	0631	P	2.16	P	<1.00	





Lead in Drinking Water Sample Results

School: Pittsburgh Weil PreK-5

Address: 2250 Centre Avenue, Pittsburgh, PA 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WEI-BS-SL-00	SL	Service Line	12	4/3/2019	0600	P	<1.00	N/A	N/A	
WEI-BS-WM-00	WM	Water Main	12	4/3/2019	0602	P	<1.00	N/A	N/A	
WEI-BS-MS-01	MS	Miscellaneous sinks	7	4/3/2019	0559	P	<1.00	P	<1.00	
WEI-01-WFC-09	WFC	Filtering water cooler w/ bottle filler	Corridor 100	4/3/2019	0606	P	<1.00	P	<1.00	
WEI-01-NF-11	NF	Nurse's office sink faucets	102	4/3/2019	0614	P	2.19	P	<1.00	
WEI-01-CF-15	CF	Classroom faucets	111A	4/3/2019	0625	P	12.7	P	1.27	
WEI-01-WO-17	WO	Water fountain without cooler	111B	4/3/2019	0627	P	<1.00	P	<1.00	
WEI-01-WFC-18	WFC	Filtering water cooler w/ bottle filler	Corridor 100	4/3/2019	0623	P	<1.00	P	<1.00	
WEI-01-WF-19	WF	Water fountain with filter & cooler	Corridor 100	4/3/2019	0622	P	<1.00	P	<1.00	
WEI-01-CF-24	CF	Classroom faucets	112	4/3/2019	0620	P	<1.00	P	<1.00	
WEI-01-CF-25	CF	Classroom faucets	113	4/3/2019	0617	P	1.08	P	<1.00	
WEI-01-CF-26	CF	Classroom faucets	114	4/3/2019	0612	F	15.6	P	1.62	
WEI-01-CF-27	CF	Classroom faucets	115	4/3/2019	0609	F	60.6	P	<1.00	
WEI-01-CF-28	CF	Classroom faucets	120	4/3/2019	0631	P	<1.00	P	<1.00	
WEI-01-CF-31	CF	Classroom faucets	121	4/3/2019	0634	P	1.01	P	<1.00	
WEI-01-KF-32	KF	Kitchen faucets	130	4/3/2019	0636	P	<1.00	P	<1.00	
WEI-02-TF-35	TF	Teacher's lounge sinks	209	4/3/2019	0641	P	<1.00	P	<1.00	
WEI-02-WFC-38	WFC	Filtering water cooler w/ bottle filler	Corridor 200	4/3/2019	0644	P	<1.00	P	<1.00	
WEI-02-WF-39	WF	Water fountain with filter & cooler	Corridor 200	4/3/2019	0643	P	<1.00	P	<1.00	
WEI-02-WO-40	WO	Water fountain without cooler	Corridor 200B	4/3/2019	0646	P	1.01	P	<1.00	
WEI-02-WO-41	WO	Water fountain without cooler	Corridor 200B	4/3/2019	0647	P	<1.00	P	<1.00	
WEI-02-CF-42	CF	Classroom faucets	210	4/3/2019	0650	P	2.50	P	<1.00	
WEI-02-CF-43	CF	Classroom faucets	210	4/3/2019	0652	P	3.06	P	<1.00	
WEI-02-CF-44	CF	Classroom faucets	208	4/3/2019	0655	F	38.5	P	4.30	
WEI-02-CF-45	CF	Classroom faucets	207	4/3/2019	0658	P	5.31	P	1.13	
WEI-02-CF-46	CF	Classroom faucets	206	4/3/2019						Not in Operation
WEI-02-WO-51	WO	Water fountain without cooler	Corridor 200	4/3/2019	0701	P	<1.00	P	<1.00	
WEI-02-WO-52	WO	Water fountain without cooler	Corridor 200	4/3/2019	0702	P	<1.00	P	<1.00	
WEI-03-WO-55	WO	Water fountain without cooler	Corridor 300A	4/3/2019	0709	P	1.72	P	1.06	
WEI-03-WO-56	WO	Water fountain without cooler	Corridor 300A	4/3/2019	0710	P	<1.00	P	<1.00	
WEI-03-WF-61	WF	Water fountain with filter & cooler	Corridor 300A	4/3/2019	0713	P	<1.00	P	<1.00	
WEI-03-WFC-62	WFC	Filtering water cooler w/ bottle filler	Corridor 300A	4/3/2019	0715	P	<1.00	P	<1.00	
WEI-02-MS-63	MS	Miscellaneous sinks	Library 205A	4/3/2019	0705	F	54.3	P	11.1	

## **Pittsburgh West Liberty PreK-5**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh West Liberty PreK-5

Address: 785 Dunster Street, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WLB-BS-SL-00	SL	Service Line	Boiler Room	5/22/2019	0554	P	<1.00	N/A	N/A	
WLB-BS-WM-00	WM	Water Main	Boiler Room	5/22/2019	0557	P	<1.00	N/A	N/A	
WLB-BS-TF-03	TF	Teacher's lounge sinks	B-11	5/22/2019	0558	P	1.52	P	<1.00	
WLB-01-WF-07	WF	Water fountain with filter & cooler	Corridor 100	5/22/2019	0604	P	<1.00	P	<1.00	
WLB-01-WFC-08	WFC	Filtering water cooler w/ bottle filler	Corridor 100	5/22/2019	0605	P	<1.00	P	<1.00	
WLB-01-NF-13	NF	Nurse's office sink faucets	Nurse's Office	5/22/2019	0607	P	1.12	P	<1.00	
WLB-02-WFC-17	WFC	Filtering water cooler w/ bottle filler	Vestibule 139	5/22/2019	0612	P	<1.00	P	<1.00	
WLB-01-KF-20	KF	Kitchen faucets	Kitchen-138	5/22/2019	0609	P	1.31	P	<1.00	
WLB-01-IM-21	IM	Ice machines	Kitchen-138	5/22/2019						Not in Operation
WLB-01-CF-23	CF	Classroom faucets	104	5/22/2019	0615	P	<1.00	P	<1.00	
WLB-01-CF-24	CF	Classroom faucets	104	5/22/2019	0616	P	1.58	P	<1.00	
WLB-01-WO-27	WO	Water fountain without cooler	Corridor 100	5/22/2019						Not Testable - Low Flow
WLB-01-WO-28	WO	Water fountain without cooler	Corridor 100	5/22/2019	0619	P	<1.00	P	<1.00	
WLB-02-WF-33	WF	Water fountain with filter & cooler	Corridor 200	5/22/2019	0622	P	<1.00	P	<1.00	
WLB-02-WFC-34	WFC	Filtering water cooler w/ bottle filler	Corridor 200	5/22/2019	0623	P	<1.00	P	<1.00	
WLB-02-CF-38	CF	Classroom faucets	203	5/22/2019	0625	P	1.55	P	<1.00	
WLB-02-MS-40	MS	Miscellaneous sinks	207	5/22/2019	0629	P	1.57	P	<1.00	
WLB-02-WO-41	WO	Water fountain with filter & cooler	Corridor 200	5/22/2019	0632	P	<1.00	P	<1.00	
WLB-02-WO-42	WO	Water fountain with filter & cooler	Corridor 200	5/22/2019	0633	P	<1.00	P	<1.00	
WLB-02-CF-46	CF	Classroom faucets	210	5/22/2019	0631	P	6.03	P	<1.00	
WLB-01-KF-47	KF	Kitchen faucets	Kitchen-138	5/22/2019	0610	P	<1.00	P	<1.00	
WLB-01-CF-48	CF	Classroom faucets	106	5/22/2019	0617	P	<1.00	P	<1.00	
WLB-02-CF-49	CF	Classroom faucets	203	5/22/2019	0626	P	<1.00	P	<1.00	
WLB-01-CF-51	CF	Classroom faucets	102	5/22/2019	0602	P	1.48	P	<1.00	

## **Pittsburgh Westinghouse Academy 6-12**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Academy 6-12

Address: 1101 N. Murtland Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WES-BS-SL-00	SL	Service Line	921	4/6/2019	0655	P	<1.00	N/A	N/A	
WES-BS-WM-00	WM	Water Main	921	4/6/2019	0657	P	<1.00	N/A	N/A	
WES-BS-WC-01	WC	Water fountain with cooler	Dining Area	4/6/2019	0654	P	<1.00	P	<1.00	
WES-BS-WFC-02	WFC	Filtering water cooler w/ bottle filler	Dining Area	4/6/2019	0658	P	<1.00	P	<1.00	
WES-BS-KF-05	KF	Kitchen faucets	Kitchen (935)	4/6/2019	0700	P	<1.00	P	<1.00	
WES-BS-KF-07	KF	Kitchen faucets	Kitchen (935)	4/6/2019	0703	P	<1.00	P	<1.00	
WES-BS-KF-08	KF	Kitchen faucets	Kitchen (935)	4/6/2019	0704	P	3.46	P	<1.00	
WES-BS-KF-09	KF	Kitchen faucets	Kitchen (935)	4/6/2019	0705	P	<1.00	P	<1.00	
WES-BS-WF-13	WF	Water fountain with filter & cooler	977	4/6/2019	0710	P	<1.00	P	<1.00	
WES-BS-IM-25	IM	Ice machines	976	4/6/2019	0712	P	<1.00	N/A	N/A	
WES-BS-WF-29	WF	Water fountain with filter & cooler	975	4/6/2019	0714	P	<1.00	P	<1.00	
WES-BS-WF-41	WF	Water fountain with filter & cooler	Corridor F	4/6/2019	0717	P	<1.00	P	<1.00	
WES-SB-MS-45	MS	Miscellaneous sinks	875B	4/6/2019	0729	P	<1.00	P	<1.00	
WES-SB-WF-66	WF	Water fountain with filter & cooler	Pool (872)	4/6/2019	0731	P	<1.00	P	<1.00	
WES-SB-WF-67	WF	Water fountain with filter & cooler	Pool (872)	4/6/2019	0734	P	<1.00	P	<1.00	
WES-GF-WF-74	WF	Water fountain with filter & cooler	Corridor B	4/6/2019	0746	P	<1.00	P	<1.00	
WES-GF-WF-75	WF	Water fountain with filter & cooler	Corridor B	4/6/2019	0747	P	<1.00	P	<1.00	
WES-GF-CF-76	CF	Classroom faucets	11	4/6/2019	0750	P	1.03	P	<1.00	
WES-GF-MS-79	MS	Miscellaneous sinks	58N	4/6/2019	0753	P	<1.00	P	<1.00	
WES-GF-WF-80	WF	Water fountain with filter & cooler	Corridor B	4/6/2019	0758	P	<1.00	P	<1.00	
WES-GF-WF-81	WF	Water fountain with filter & cooler	Corridor B	4/6/2019	0759	P	<1.00	P	<1.00	
WES-GF-CF-82	CF	Classroom faucets	18	4/6/2019	0803	P	4.30	P	<1.00	
WES-GF-MS-83	MS	Miscellaneous sinks	18	4/6/2019	0806	P	<1.00	P	<1.00	
WES-GF-CF-102	CF	Classroom faucets	22	4/6/2019	0756	P	<1.00	P	<1.00	
WES-GF-NF-105	NF	Nurse's office sink faucets	046C	4/6/2019	0826	F	19.2	P	1.25	
WES-GF-NF-106	NF	Nurse's office sink faucets	046D	4/6/2019	0827	P	<1.00	P	<1.00	
WES-GF-NF-107	NF	Nurse's office sink faucets	046E	4/6/2019	0828	P	11.6	P	<1.00	
WES-GF-WF-114	WF	Water fountain with filter & cooler	44	4/6/2019	0831	P	<1.00	P	<1.00	
WES-GF-WF-115	WF	Water fountain with filter & cooler	44	4/6/2019	0832	P	<1.00	P	<1.00	
WES-GF-NF-117	NF	Nurse's office sink faucets	52D	4/6/2019	0813	F	25.6	P	<1.00	
WES-GF-NF-118	NF	Nurse's office sink faucets	52C	4/6/2019	0814	P	14.0	P	1.00	
WES-GF-WF-128	WF	Water fountain with filter & cooler	Corridor D	4/6/2019	0816	P	<1.00	P	<1.00	
WES-GF-WF-129	WF	Water fountain with filter & cooler	Corridor D	4/6/2019	0817	P	<1.00	P	<1.00	
WES-GF-WF-163	WF	Water fountain with filter & cooler	Gym	4/6/2019	0836	P	<1.00	P	<1.00	
WES-GF-WF-169	WF	Water fountain with filter & cooler	77	4/6/2019	0838	P	<1.00	P	<1.00	
WES-GF-WF-172	WF	Water fountain with filter & cooler	Gym	4/6/2019	0841	P	<1.00	P	<1.00	
WES-GF-WF-173	WF	Water fountain with filter & cooler	Lobby	4/6/2019	0900	P	<1.00	P	<1.00	
WES-GF-WFC-174	WFC	Filtering water cooler w/ bottle filler	Lobby	4/6/2019	0901	P	<1.00	P	<1.00	
WES-GF-MS-183	MS	Miscellaneous sinks	Concession Stand (67)	4/6/2019	0845	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Academy 6-12

Address: 1101 N. Murtland Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WES-GF-KF-185	KF	Kitchen faucets	Kitchen (69)	4/6/2019	0848	P	<1.00	P	<1.00	
WES-GF-KF-187	KF	Kitchen faucets	Kitchen (69)	4/6/2019	0850	P	<1.00	P	<1.00	
WES-GF-KF-188	KF	Kitchen faucets	Kitchen (69)	4/6/2019	0851	P	1.54	P	<1.00	
WES-GF-KF-190	KF	Kitchen faucets	Kitchen (69)	4/6/2019	0852	P	<1.00	P	<1.00	
WES-GF-KF-191	KF	Kitchen faucets	Kitchen (69)	4/6/2019	0855	P	1.00	P	<1.00	
WES-GF-IM-192	IM	Ice machines	Kitchen (69)	4/6/2019	0856	P	<1.00	N/A	N/A	
WES-01-WF-198	WF	Water fountain with filter & cooler	Corridor B	4/6/2019	0909	P	<1.00	P	<1.00	
WES-01-WFC-199	WFC	Filtering water cooler w/ bottle filler	Corridor B	4/6/2019	0910	P	<1.00	P	<1.00	
WES-01-TF-205	TF	Teacher's lounge sinks	111	4/6/2019	0912	P	2.08	P	<1.00	
WES-01-CF-207	CF	Classroom faucets	125A	4/6/2019	0917	F	17.7	P	1.02	
WES-01-CF-208	CF	Classroom faucets	125A	4/6/2019	0918	P	11.2	P	<1.00	
WES-01-WF-209	WF	Water fountain with filter & cooler	125A	4/6/2019	0919	P	<1.00	P	<1.00	
WES-01-MS-212	MS	Miscellaneous sinks	125B	4/6/2019	0922	F	15.9	P	1.03	
WES-01-WF-216	WF	Water fountain with filter & cooler	Corridor D	4/6/2019	0930	P	<1.00	P	<1.00	
WES-01-WF-217	WF	Water fountain with filter & cooler	Corridor D	4/6/2019	0931	P	<1.00	P	<1.00	
WES-01-WF-243	WF	Water fountain with filter & cooler	Choir Room (149)	4/6/2019	0936	P	<1.00	P	<1.00	
WES-01-WF-244	WF	Water fountain with filter & cooler	Band Room (147)	4/6/2019	0940	P	<1.00	P	<1.00	
WES-01-CF-245	CF	Classroom faucets	Band Room (147)	4/6/2019	0942	P	2.59	P	<1.00	
WES-01-CF-246	CF	Classroom faucets	168	4/6/2019	0950	P	<1.00	P	<1.00	
WES-02-CF-273	CF	Classroom faucets	242	4/6/2019	1011	P	4.87	P	<1.00	
WES-02-CF-274	CF	Classroom faucets	235	4/6/2019	1007	P	11.4	P	4.45	
WES-02-WF-284	WF	Water fountain with filter & cooler	Corridor D	4/6/2019	1020	P	<1.00	P	<1.00	
WES-02-WFC-285	WFC	Filtering water cooler w/ bottle filler	Corridor D	4/6/2019	1021	P	<1.00	P	<1.00	
WES-03-WF-316	WF	Water fountain with filter & cooler	Corridor B	4/6/2019	1026	P	<1.00	P	<1.00	
WES-03-CF-318	CF	Classroom faucets	346	4/6/2019	1040	P	4.15	P	<1.00	
WES-03-WF-319	WF	Water fountain with filter & cooler	Corridor D	4/6/2019	1037	P	<1.00	P	<1.00	
WES-03-WFC-320	WFC	Filtering water cooler w/ bottle filler	Corridor D	4/6/2019	1038	P	<1.00	P	<1.00	
WES-03-CF-327	CF	Classroom faucets	312	4/6/2019	1031	P	12.2	P	<1.00	
WES-03-CF-328	CF	Classroom faucets	312	4/6/2019						Not in Operation
WES-02-WF-330	WF	Water fountain with filter & cooler	Corridor B	4/6/2019	0957	P	<1.00	P	<1.00	
WES-01-WC-332	WC	Water fountain with cooler	125E	4/6/2019	0923	P	<1.00	P	<1.00	
WES-01-CF-333	CF	Classroom faucets	125E	4/6/2019	0925	F	50.8	P	2.72	
WES-02-CF-336	CF	Classroom faucets	235	4/6/2019	1008	F	16.0	P	3.40	
WES-02-CF-337	CF	Classroom faucets	235	4/6/2019	1009	P	7.54	P	2.50	
WES-03-CF-338	CF	Classroom faucets	312	4/6/2019	1033	P	6.78	P	<1.00	
WES-03-CF-339	CF	Classroom faucets	312	4/6/2019	1034	P	6.55	P	<1.00	
WES-GF-CF-340	CF	Classroom faucets	18	4/6/2019	0804	P	2.88	P	<1.00	
WES-GF-CF-341	CF	Classroom faucets	18	4/6/2019	0805	P	1.64	P	<1.00	
WES-BS-WF-343	WF	Water fountain with filter & cooler	Auxillary Gym	4/6/2019	0720	P	<1.00	P	<1.00	

## Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Academy 6-12

Address: 1101 N. Murtland Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WES-BS-WFC-344	WFC	Filtering water cooler w/ bottle filler	Auxillary Gym	4/6/2019	0721	P	<1.00	P	<1.00	
WES-BS-WF-345	WF	Water fountain with filter & cooler	Auxillary Gym	4/6/2019	0723	P	<1.00	P	<1.00	
WES-BS-WFC-346	WFC	Filtering water cooler w/ bottle filler	Auxillary Gym	4/6/2019	0724	P	<1.00	P	<1.00	
WES-SB-WF-349	WF	Water fountain with filter & cooler	Pool (872)	4/6/2019	0732	P	<1.00	P	<1.00	
WES-SB-WF-350	WF	Water fountain with filter & cooler	Pool (872)	4/6/2019	0735	P	<1.00	P	<1.00	
WES-GF-WC-352	WC	Water fountain with cooler	41	4/6/2019	0820	P	<1.00	P	<1.00	
WES-GF-WC-353	WC	Water fountain with cooler	45	4/6/2019	0823	P	<1.00	P	<1.00	
WES-01-WF-354	WF	Water fountain with filter & cooler	Choir Room (149)	4/6/2019	0937	P	<1.00	P	<1.00	
WES-01-MS-355	MS	Miscellaneous sinks	Library (142A)	4/6/2019	0945	P	9.17	P	<1.00	
WES-02-CF-357	CF	Classroom faucets	228	4/6/2019	1000	P	2.58	P	<1.00	
WES-02-CF-358	CF	Classroom faucets	242	4/6/2019	1013	P	8.50	P	2.45	
WES-02-CF-359	CF	Classroom faucets	242	4/6/2019	1014	P	7.55	P	1.20	



## **Pittsburgh Westinghouse Field House**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Field House

Address: 1102 North Murtland Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Locations	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WFH-GF-SL-00	SL	Service Line	Mechanical Room	4/10/2019	0753	P	<1.00	NA	N/A	
WFH-GF-WM-00	WM	Water Main	Mechanical Room	4/10/2019	0756	P	<1.00	NA	N/A	
WFH-GF-MS-01	MS	Miscellaneous sinks	Mechanical Room	4/10/2019	0752	P	<1.00	P	<1.00	
WFH-GF-IM-02	IM	Ice machines	Mechanical Room	4/10/2019						Not in Operation
WFH-GF-MS-03	MS	Miscellaneous sinks	Office	4/10/2019	0757	P	4.29	P	<1.00	
WFH-GF-MS-09	MS	Miscellaneous sinks	Concession Room	4/10/2019	0759	F	16.9	P	<1.00	
WFH-GF-MS-10	MS	Miscellaneous sinks	Concession Room	4/10/2019	0800	P	4.25	P	<1.00	