

LEAD IN DRINKING WATER SAMPLING

of

Pittsburgh Public Schools

Survey Date: February 16 – August 14, 2019

Prepared for:

Pittsburgh Public Schools
Facilities
1305 Muriel Street
Pittsburgh, Pennsylvania 15203

Prepared by:



Skelly and Loy, Inc.
3280 William Pitt Way
Pittsburgh, PA 15238

August 21, 2019

TABLE OF CONTENTS

1. INTRODUCTION	1
2. SAMPLING METHODOLOGY	1
3. DRINKING WATER RESULTS AND DISCUSSION	2
4. BUILDING SUMMARY OF NUMBERS OF FIXTURES AND WATER SAMPLES	6
5. RECOMMENDATIONS	8
REPORT DISCLAIMER:	8

APPENDICES:

- APPENDIX A DRINKING WATER RESULTS TABLES
- APPENDIX B LABORATORY RESULTS
- APPENDIX C FIXTURE MAPS

1. INTRODUCTION

Skelly and Loy, Inc. was retained by Pittsburgh Public School (PPS) District to test for the presence of lead in drinking water at 33 School district buildings, including 29 school buildings, 3 athletic field houses, and the Administration Building.

A fixture verification and water sample collection were conducted at the 33 school district buildings from February 16 through August 14, 2019. The objective of the drinking water sampling and analytical testing was to screen the drinking water and cooking use fixtures and faucets for lead concentrations. For our scope, drinking water and cooking fixtures were defined as classroom faucets; home economic faucets; ice machines; kitchen faucets; cafeteria faucets; nurse's office sink faucets; office sink faucets; teacher's lounge sink faucets and water fountains; and miscellaneous sinks designated in field houses, classrooms and offices.

Fixtures that were not in operation, had insufficient water flow, or were observed to have **"Handwash Only"** signage were not sampled as part of this survey.

2. SAMPLING METHODOLOGY

Water sampling collection, delivery and analysis was conducted according to the Environmental Protection Agency's (EPA's) "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002," April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance," October 2018.

The Pennsylvania Public School Code, Act 39 - Section 742 as amended on June 22, 2018 states that the lead levels in drinking water should not exceed the EPA's National Primary Drinking Water Regulations, action level for lead, currently 15 parts per billion (ppb). The purpose of this water sampling effort is to help minimize exposure to school students and staff to lead in drinking water at PPS facilities.

All water samples were collected in 250 mL plastic containers that were prepackaged by the analytical laboratory. At each water sample location, the first draw water sample was collected after the water in the plumbing lines had been standing in the plumbing system for greater than eight (8) hours, but less than eighteen (18) hours. Each school building's water system was used the evening before the first-draw samples to follow the 3Ts water sampling protocols.

A second draw water sample was collected after the water in the system was discharged for 30 seconds after the first draw sample. This is called a purged-line or flushed sample. This water sample will show the lead content of water that has not been in contact with the fixture for an extended time.

All samples were analyzed for lead content by R.J. Lee, Inc., 350 Hochberg Road, Monroeville, Pennsylvania using EPA method 200.8 - Determination of Trace Elements in Waters and Wastes by Inductively Coupled Plasma - Mass Spectrometry (ICP-MS)." R.J. Lee is an independent Pennsylvania (PA) laboratory certified for drinking water analysis.

3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION

Analytic results of the water samples were received by Skelly and Loy and reviewed in relation to EPA's "EPA's National Primary Drinking Water Regulations, Action Level for lead of 15 parts per billion (ppb). Lead concentrations above 15 ppb were considered to be elevated and response actions recommended to PPS to reduce the lead in the affected fixture. Following mitigation of the fixtures that exceeded the lead in Drinking Water Action Level, retesting of the drinking water was conducted. Mitigation of the fixtures included replacement of aerators, replacement of the fixture, or flushing water lines in areas of buildings where use of the fixtures was infrequent.

If the retest of the drinking water indicated lead levels below the Drinking Water Action Level, no further actions were taken. If the retesting of the drinking water indicated lead levels above the Drinking Water Action Level, affected fixtures were posted with "**Handwash Only**" signage. Where fixtures were deemed unnecessary by PPS, the fixtures were shut off or removed. The results of the retesting can be found in a separate report.

Below is a summary of the initial and retesting of fixtures at the 33 surveyed School District buildings.

Administration Building:

At the PPS Administration Building, a total of 61 samples were collected from 32 drinking water and cooking use fixtures and faucets. The results of 4 water samples collected: **19-ADM-02-OF-37A and B, 19-ADM-02-OF-47A and B, 19-ADM-03-OF-58A, and 19-ADM-04-OF-84A and B** indicated lead concentrations above the lead in drinking water action level of 15 ppb.

Allderdice Field House:

At Pittsburgh Allderdice Field House, a total of 6 samples were collected from 4 drinking water fixtures and faucets. ***The results of all collected water samples indicated lead concentrations below the lead in drinking water action level of 15 ppb.***

Allderdice High School:

At Allderdice High School, a total of 152 samples were collected from 77 drinking water and cooking use fixtures and faucets. The results of 2 water samples collected: **19-ALD-03-CF-148A, and 19-ALD-04-CF-291A** indicated lead concentrations above the lead in drinking water action level of 15 ppb.

Allegheny Annex:

At Pittsburgh Allegheny Annex, a total of 16 samples were collected from 9 drinking water and cooking use fixtures and faucets. ***The results of all collected water samples were below the lead in drinking water action level of 15 ppb.***

Allegheny K-5/6-8:

At Pittsburgh Allegheny K-5/6-8, A total of 87 samples were collected from 45 drinking water and cooking use fixtures and faucets. The results of 2 water samples collected; **19-AGL-01-CF-34A** and **19-AGL-03-WB-94B** were above the lead in drinking water action level of 15 ppb.

Arsenal PreK-5/6-8:

At Pittsburgh Arsenal PreK-5/6-8, A total of 106 samples were collected from 54 drinking water and cooking use fixtures and faucets. The results of 2 water samples collected: **ARS-GF-NF-17A**, and **ARS-03-CF-120A** indicated lead concentrations above the lead in drinking water action level of 15 ppb.

Beechwood PreK-5:

At Pittsburgh Beechwood PreK-5, A total of 60 samples were collected from 31 drinking water and cooking use fixtures and faucets. ***All results from all collected water samples were below the lead in drinking water action level of 15 ppb.***

Brashear High School/South Hills 6-8:

At Pittsburgh Brashear High School/South Hills 6-8, A total of 166 samples were collected from 84 drinking water and cooking use fixtures and faucets. The results of 3 water samples collected: **19-BRA-BS-CF-38A**, **19-BRA-02-WC-186A**, and **19-BRA-03-CF-290A** indicated lead concentrations above the lead in drinking water action level of 15 ppb.

CAPA 6-12:

At Pittsburgh CAPA 6-12, A total of 119 samples were collected from 61 drinking water and cooking use fixtures and faucets. The results of 2 water samples collected: **19-CAP-06-CF-160A** and **19-CAP-06-CF-198A** indicated lead concentrations above the lead in drinking water action level of 15 ppb.

Carmalt PreK-8:

At Pittsburgh Carmalt PreK-8, a total of 84 samples were collected from 43 drinking water and cooking use fixtures and faucets. ***All results from the collected water samples were below the lead in drinking water action level of 15 ppb.***

Colfax K-8:

At Pittsburgh Colfax K-8, a total of 90 samples were collected from 46 drinking water cooking use fixtures and faucets. ***The results from all of the collected water samples were below the lead in drinking water action level of 15 ppb.***

Concord PreK-5:

At Pittsburgh Concord PreK-5, A total of 68 samples were collected from 35 drinking water and cooking use fixtures and faucets. The result for 1 water sample collected; **19-CON-01-WC-46A indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Conroy Education Center:

At Conroy Education Center, a total of 74 samples were collected from 38 drinking water and cooking use fixtures and faucets. The results for 3 water samples collected; **19-CNY-01-KF-38A, 19-CNY-01-KF-43A and 19-CNY-01-KF-44A indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Dilworth PreK-5:

At Pittsburgh Dilworth PreK-5, A total of 60 samples were collected from 31 drinking water and cooking use fixtures and faucets. The results of 3 water samples collected: **19-DIL-02-CF-36A, 19-DIL-02-WC-52A, and 19-DIL-02-CF-71A indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Fulton PreK-5:

At Pittsburgh Fulton PreK-5, a total of 36 samples were collected from 19 drinking water and cooking use fixtures and faucets. ***All results from the collected water samples were below the lead in drinking water action level of 15 ppb.***

Grandview K-5:

At Pittsburgh Grandview K-5, A total of 78 samples were collected from 40 drinking water and cooking use fixtures and faucets. The results for 5 water samples collected; **19-GRD-01-CF-16A, 19-GRD-01-CF-20A, 19-GRD-01-WO-21A, 19-GRD-02-CF-52A and 19-GRD-02-CF-67A indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Greenway (Classical-Gifted Center):

At Greenway – Classical Gifted Center, a total of 132 samples were collected from 67 drinking water and cooking use fixtures and faucets. The result of 1 sample collected; **19-GNW-2.4-CF-86A indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Langley Field House

At Langley field House, a total of 11 samples were collected from 8 drinking water fixtures and faucets. ***The results of all collected water samples indicated lead concentrations below the lead in drinking water action level of 15 ppb.***

Liberty K-5:

At Pittsburgh Liberty K-5, A total of 64 samples were collected from 33 drinking water and cooking use fixtures and faucets. The result of 1 water sample collected; **19-LIB-01-CF-29A indicated a lead concentration above the lead in drinking water action level of 15 ppb.**

Mifflin PreK-8:

At Pittsburgh Mifflin PreK-8, A total of 74 samples were collected from 38 drinking water and cooking use fixtures and faucets. ***All results from all collected water samples were below the lead in drinking water action level of 15 ppb.***

Minadeo PreK-5:

At Pittsburgh Minadeo PreK-5, A total of 104 samples were collected from 53 drinking water and cooking use fixtures and faucets. The results of 4 samples collected; **19-MIN-GF-TF-12A, 19-MIN-GF-CF-30A, 19-MIN-02-HF-59A, and 19-MIN-02-CF-72A indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Obama 6-12, ECC:

At Pittsburgh Obama 6-12, ECC, a total of 148 samples were collected from 74 drinking water and cooking use fixtures and faucets. **The results for 2 water samples collected; 19-OBA-01-KF-78A and 19-OBA-01-KF-79A indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Oliver Field House:

At Pittsburgh Oliver Field House, a total of 12 samples were collected from 7 drinking water fixtures and faucets. ***The results of all of the water samples collected indicated lead concentrations below the lead in drinking water action level of 15 ppb.***

Oliver:

At Pittsburgh Oliver, a total of 146 samples were collected from 74 drinking water and cooking use fixtures and faucets. **The results of 16 water samples collected; 19-OLI-GF-CF-41A and B, 19-OLI-02-KF-43A, 19-OLI-GF-OF-59A, 19-OLI-01-CF-130A, 19-OLI-01-CF-150A, 19-OLI-01-CF-164A and 19-OLI-01-CF-185A, 19-OLI-01-OF-218A, , 19-OLI-02-CF-224A and B, 19-OLI-02-MC-225A and B, 19-OLI-02-HF-230A, 19-OLI-02-KF-231A and 19-OLI-02-KF-237A indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Phillips K-5:

At Pittsburgh Phillips K-5, a total of 26 samples were collected from 14 drinking water and cooking use fixtures and faucets. ***The results from all collected water samples were below the lead in drinking water action level of 15 ppb.***

Roosevelt Pre K-1:

At Pittsburgh Roosevelt PreK-1, A total of 24 samples were collected from 13 drinking water and cooking use fixtures and faucets. ***All results from the collected water samples were below the lead in drinking water action level of 15 ppb.***

Schiller 6-8:

At Pittsburgh Schiller 6-8, a total number of 44 samples were collected from 23 drinking water and cooking use fixtures and faucets. The result of 1 water sample; **19-SCH-01-OF-39A indicated a result above the EPA lead in drinking water action level of 15 ppb.**

Spring Garden ECC:

At Pittsburgh Spring Garden ECC, a total of 36 samples were collected from 19 drinking water and cooking use fixtures and faucets. The results of 3 water samples collected; **19-SPG-01-CF-06A and 19-SPG-02-CF-27A and B indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Spring Hill K-5:

At Pittsburgh Spring Hill K-5, a total of 40 samples were collected from 21 drinking water and cooking use fixtures and faucets. ***The results from all collected water samples were below the lead in drinking water action level of 15 ppb.***

Student Achievement Center:

At Pittsburgh Student Achievement Center, A total of 48 samples were collected from 25 drinking water and cooking use fixtures and faucets. The results of 3 samples collected; **19-**

SAC-BS-WB-12A, 19-SAC-02-OF-34A, and 19-SAC-02-CF-36A indicated lead concentrations above the lead in drinking water action level of 15 ppb.

Westwood PreK-5:

At Pittsburgh Westwood PreK-5, a total of 64 samples were collected from 31 drinking water and cooking use fixtures and faucets. ***The results from all collected water samples were below the lead in drinking water action level of 15 ppb.***

Whittier K-5:

At Pittsburgh Whittier K-5, a total of 50 samples were collected from 26 drinking water and cooking use fixtures and faucets. The result for 1 water sample collected; **19-WHI-01-WB-32B indicated lead concentrations above the lead in drinking water action level of 15 ppb.**

Woolslair K-5:

At Pittsburgh Woolslair K-5 A total of 50 samples were collected from 26 drinking water and cooking use fixtures and faucets. ***All results from the collected water samples were below the lead in drinking water action level of 15 ppb.***

4. BUILDING SUMMARY OF NUMBERS OF FIXTURES AND WATER SAMPLES

A table listing each school sampled, the total number of the fixtures, and the number of water samples collected follows. Floor plans for fixture locations are provided in Appendix C.

Date Sampled	School/Building	Total # of Fixtures	# of Samples Collected
7/2/2019	Administration Building	32	61
4/16/2019	Allderdice Field House	4	6
4/16/2019	Allderdice High School	77	152
4/27/2019	Allegheny Annex	9	16
5/4/2019	Allegheny K-5/6-8	45	87
4/18/2019	Arsenal PreK-5/6-8	54	106
2/16/2019	Beechwood PreK-5	31	60
4/27/2019	Brashear High School/ South Hills 6-8	84	166
5/25/2019	CAPA 6-12	61	119
4/13/2019	Carmalt PreK-8	43	84
6/8/2019	Colfax K-8	46	90
4/6/2019	Concord PreK-5	35	68
5/11/2019	Conroy	38	74

Date Sampled	School/Building	Total # of Fixtures	# of Samples Collected
4/6/2019	Dilworth PreK-5	31	60
5/18/2019	Fulton PreK-5	19	36
6/5/2019	Grandview K-5	40	78
7/8/2019	Langley Field House	8	11
6/8/2019	Greenway (Classical-Gifted Center)	67	132
6/5/2019	Liberty K-5	33	64
5/18/2019	Mifflin PreK-8	38	74
4/18/2019	Minadeo PreK-5	53	104
3/30/2019	Obama 6-12, ECC	74	148
7/8/2019	Oliver Field House	7	12
6/13/2019	Oliver	74	146
6/1/2019	Phillips K-5	14	26
3/30/2019	Roosevelt PreK-1	13	24
1/14/2019	Schiller 6-8	23	44
2/16/2019	Spring Garden ECC	19	36
5/24/2019	Spring Hill K-5	21	40
6/15/2019	Student Achievement Center	25	48
2/16/2019	Westwood PreK-5	31	64
6/21/2019	Whittier K-5	26	50
6/21/2016	Woolslair K-5	26	50
	33 Buildings	1,202	2,338

In the 33 schools/buildings sampled; a total of 2,336 water samples were collected from 1,201 drinking water and cooking use fixtures and faucets.

The results of the water sample testing indicate that only **2.7%** of the fixtures tested had elevated lead concentrations above 15 ppb. This low percentage of fixtures with lead concentrations above 15 ppb indicates that the water supply into the buildings, from the various water authorities, is not elevated for lead, or is there a District wide lead concern. Based on water sample testing, our professional opinion is that the sources of the elevated lead concentrations exceeding 15 ppb can be attributed to several key factors such as the lack of routine fixture use, fixtures not routinely cleaned, and/or older outdated fixtures. Corrective actions, which included the removal of any fixture that exceeded the recommended action level of 15 ppb from service, were conducted by the School District. Following remediation of these fixtures that exceeded the recommended lead concentration, additional verification sampling was conducted to verify that lead concentrations in drinking water can be reduced below 15 ppb.

5.0 RECOMMENDATIONS

Skelly and Loy, Inc. recommends that Pittsburgh Public Schools follow good drinking water practices and follows the guidelines established in the EPA's "Lead in Drinking Water in Schools

and Non-Residential Buildings, EPA 812-B-94-002”, April 1994 and “3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance”, October 2018.

Based on the results of this drinking water sampling report, our recommendations, related to the fixtures, are as follows:

1. All fixtures with lead concentration at or above the EPA Action Limit of 15 ppb are to be remediated or the fixture shut off from use by the District.
2. Post signage stating that the non-filtered fixtures are to be used for only as a **“Handwash Only”** water source.

REPORT DISCLAIMER:

This Skelly and Loy, Inc. report is based on information supplied by the client, occupants, and on conditions readily observable or measurable on the date or dates of this study. The results and recommendations presented herein should not be relied upon exclusively for the prevention of all possible illnesses, injuries, or losses. These services are a supplement to, and not a substitute for, the client’s responsibility for protecting the health and safety of the occupants of the facility, and others, and for complying with applicable laws and regulations.

This report and the associated attachments and appendices have been produced and developed for, and at the request of, Pittsburgh Board of Public Education. It conveys the findings of Skelly and Loy, Inc. as of the date(s) noted herein. This report is intended for the exclusive use of Pittsburgh Board of Public Education (including its management, officers, and the School Board).

APPENDIX A

DRINKING WATER RESULTS TABLES

Administration Building

Lead in Drinking Water Sample Results

School: Pittsburgh Administration Building Address: 341 S. Bellefield Ave., Pittsburgh, PA, 15213

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-ADM-GF-WM-00	WM	Water Main	031	7/2/2019	07:30	<1.00	P		
19-ADM-GF-SL-00	SL	Service Line	031	7/2/2019	07:20	<1.00	P		
19-ADM-GF-KF-02	KF	Kitchen faucets	023	7/2/2019	07:38	3.73	P	< 1.00	P
19-ADM-GF-KF-03	KF	Kitchen faucets	022	7/2/2019	07:40	< 1.00	P	< 1.00	P
19-ADM-GF-KF-04	KF	Kitchen faucets	022	7/2/2019	07:42	1.59	P	< 1.00	P
19-ADM-GF-WF-05	WF	Water fountain without cooler	021	7/2/2019	07:55	< 1.00	P	< 1.00	P
19-ADM-GF-IM-07	IM	Ice machines	021	7/2/2019	07:59	< 1.00	P		
19-ADM-GF-WB-13	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	08:01	7.67	P	3.09	P
19-ADM-GF-WO-15	WO	Water fountain without cooler	Corridor	7/2/2019	08:07	4.29	P	1.37	P
19-ADM-01-OF-20	OF	Office sink faucets	OFF 107	7/2/2019	08:15	2.14	P	< 1.00	P
19-ADM-01-WB-21	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	08:19	9.68	P	4.05	P
19-ADM-01-OF-24	OF	Office sink faucets	123	7/2/2019	08:25	12.2	P	1.1	P
19-ADM-01-WB-26	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	08:29	4.04	P	1.26	P
19-ADM-01-WB-29	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	08:34	1.52	P	1.02	P
19-ADM-02-OF-37	OF	Office sink faucets	260	7/2/2019	08:42	40.8	F	29.8	F
19-ADM-02-WB-39	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	08:48	6.19	P	1.52	P
19-ADM-02-WB-43	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	08:52	6.2	P	1.97	P
19-ADM-02-WB-46	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	08:58	3.29	P	< 1.00	P
19-ADM-02-OF-47	OF	Office sink faucets	215	7/2/2019	09:05	17.6	F	16.2	F
19-ADM-03-WB-56	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	09:20	1.46	P	< 1.00	P
19-ADM-03-OF-58	OF	Office sink faucets	353A	7/2/2019	09:22	20.5	F	5.53	p
19-ADM-03-WO-61	WO	Water fountain without cooler	Corridor	7/2/2019	09:29	1.23	P	< 1.00	P
19-ADM-03-WO-64	WO	Water fountain without cooler	Corridor	7/2/2019	09:34	< 1.00	P	< 1.00	P
19-ADM-03-OF-65	OF	Office sink faucets	326	7/2/2019	09:37	1.26	P	< 1.00	P
19-ADM-03-WB-67	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	09:43	3.86	P	1.46	P
19-ADM-04-OF-69	OF	Office sink faucets	460	7/2/2019	09:49	10.5	P	< 1.00	P
19-ADM-04-WB-76	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	09:53	3.35	P	1.04	P
19-ADM-04-OF-77	OF	Office sink faucets	440A	7/2/2019	09:57	13.2	P	4.24	P
19-ADM-04-WB-82	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	10:02	1.62	P	< 1.00	P
19-ADM-04-OF-84	OF	Office sink faucets	419	7/2/2019	10:05	68.5	F	35.6	F
19-ADM-04-WB-86	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/2/2019	10:10	2.14	P	1.26	P
19-ADM-03-OF-87	OF	Office sink faucets	352	7/2/2019	09:25	7.83	P	5.76	P

Allderdice Field House

Lead in Drinking Water Sample Results

School: Pittsburgh Allderdice - Field House

Address: 2409 Shady Avenue, Pittsburgh, PA, 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-AFH-BS-WM-00	WM	Water main	Mechanical Room	4/16/2019	06:46	<1.00	P		
19-AFH-BS-SL-00	SL	Service line connection	Mechanical Room	4/16/2019	06:36	<1.00	P		
19-AFH-01-MS-04	MS	Hose Bib	Exterior	4/16/2019	06:52	1.23	P	1.43	P
19-AFH-BS-RF-05	RF	Restroom Faucet	Coaches Office	4/16/2019	06:48	8.07	P	<1.00	P

Allderdice High School

Lead in Drinking Water Sample Results

School: Pittsburgh Allderdice High School

Address: 2409 Shady Avenue, Pittsburgh, PA, 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-ALD-GF-WM-00	WM	Water Main	Crawlspace	4/16/2019	07:24	5.94	P		
19-ALD-GF-SL-00	SL	Service Line	Crawlspace	4/16/2019	07:19	3.59	P		
19-ALD-GF-WF-07	WF	Water fountain with cooler	026	4/16/2019	07:33	<1.00	P	<1.00	P
19-ALD-GF-WF-07.1	WF	Water fountain with cooler	26	4/17/2019	07:36	<1.00	P	<1.00	P
19-ALD-GF-NF-08	NF	Nurse's office sink faucets	028	4/16/2019	07:37	10.0	P	<1.00	P
19-ALD-GF-WC-09	WC	Water fountain with cooler	026	4/16/2019	07:38	3.35	P	<1.00	P
19-ALD-GF-WO-20	WO	Water fountain without cooler	POOL	4/16/2019	07:43	14.9	P	3.63	P
19-ALD-GF-WF-27	WF	Water fountain with cooler	004	4/16/2019	07:45	<1.00	P	<1.00	P
19-ALD-GF-WF-27.1	WF	Water fountain with cooler	004	4/16/2019	07:47	<1.00	P	<1.00	P
19-ALD-01-IM-30	IM	Ice machines	173	4/16/2019	07:59	<1.00	P		
19-ALD-01-KF-32	KF	Kitchen faucets	173	4/16/2019	07:54	7.13	P	1.20	P
19-ALD-01-KF-33	KF	Kitchen faucets	173	4/16/2019	08:02	9.29	P	<1.00	P
19-ALD-01-KF-34	KF	Kitchen faucets	173	4/16/2019	08:03	5.15	P	<1.00	P
19-ALD-01-KF-35	KF	Kitchen faucets	173	4/16/2019	08:04	2.85	P	<1.00	P
19-ALD-01-KF-36	KF	Kitchen faucets	173	4/16/2019	08:06	6.18	P	<1.00	P
19-ALD-01-KF-37	KF	Kitchen faucets	173	4/16/2019	08:11	2.17	P	<1.00	P
19-ALD-01-WF-38	WF	Water fountain with cooler	170	4/16/2019	08:16	<1.00	P	<1.00	P
19-ALD-01-WF-39	WF	Water fountain with cooler	170	4/16/2019	08:25	<1.00	P	<1.00	P
19-ALD-01-CF-50	CF	Classroom faucets	129	4/16/2019	08:29	10.5	P	2.90	P
19-ALD-01-WF-54	WF	Water fountain with cooler	100	4/16/2019	08:31	<1.00	P	<1.00	P
19-ALD-01-WF-55	WF	Water fountain with cooler	100	4/16/2019	08:34	<1.00	P	<1.00	P
19-ALD-01-MS-56	MS	Miscellaneous sinks	113	4/16/2019	08:36	6.54	P	1.75	P
19-ALD-01-TF-60	TF	Teacher's lounge sinks	Boiler Room	4/16/2019	08:46	3.38	P	<1.00	P
19-ALD-01-TF-61	TF	Teacher's lounge sinks	Nurse Area	4/16/2019	09:06	3.57	P	<1.00	P
19-ALD-01-NF-63	NF	Nurse's office sink faucets	Nurse Area	4/16/2019	09:08	12.1	P	1.05	P
19-ALD-01-WF-64	WF	Water fountain with cooler	Hallway	4/16/2019	09:05	<1.00	P	<1.00	P
19-ALD-01-WF-65	WF	Water fountain with cooler	Hallway	4/16/2019	09:05	<1.00	P	<1.00	P
19-ALD-01-WF-74	WF	Water fountain with cooler	185	4/16/2019	08:54	<1.00	P	<1.00	P
19-ALD-01-WF-75	WF	Water fountain with cooler	185	4/16/2019	08:54	<1.00	P	<1.00	P
19-ALD-01-CF-82	CF	Classroom faucets	188	4/16/2019	08:55	<1.00	P	<1.00	P
19-ALD-01-KF-83	KF	Kitchen faucets	188	4/16/2019	08:56	<1.00	P	<1.00	P
19-ALD-02-CF-84	CF	Classroom faucets	201	4/16/2019	09:18	7.81	P	1.08	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-ALD-02-WB-85	WB	Water fountain bubbler (Ceramic or Porcelain)	200	4/16/2019	09:25	<1.00	P	<1.00	P
19-ALD-02-WO-86	WO	Water fountain without cooler	200	4/16/2019	09:28	<1.00	P	<1.00	P
19-ALD-02-WC-91	WC	Water fountain with cooler	232	4/16/2019	09:32	<1.00	P	<1.00	P
19-ALD-02-TF-101	TF	Teacher's lounge sinks	244	4/16/2019	09:37	10.7	P	1.69	P
19-ALD-02-WB-102	WB	Water fountain bubbler (Ceramic or Porcelain)	256	4/16/2019	09:42	3.88	P	5.09	P
19-ALD-02-WC-104	WC	Water fountain with cooler	264	4/16/2019	09:45	1.82	P	4.58	P
19-ALD-02-WC-106	WC	Water fountain with cooler	267	4/16/2019	09:42	2.21	P	3.24	P
19-ALD-02-WC-108	WC	Water fountain with cooler	263	4/16/2019	09:46	5.11	P	7.23	P
19-ALD-02-WC-110	WC	Water fountain with cooler	255	4/16/2019	09:53	4.88	P	6.04	P
19-ALD-02-WO-115	WO	Water fountain without cooler	200	4/16/2019	09:53	4.63	P	1.53	P
19-ALD-02-WF-117	WF	Water fountain with cooler	Hallway	4/16/2019	09:58	<1.00	P	<1.00	P
19-ALD-02-WF-118	WF	Water fountain with cooler	Hallway	4/16/2019	09:59	<1.00	P	<1.00	P
19-ALD-02-OF-126	OF	Office sink faucets	285	4/16/2019	10:04	2.46	P	<1.00	P
19-ALD-03-WO-133	WO	Water fountain without cooler	380	4/16/2019	10:15	<1.00	P	<1.00	P
19-ALD-03-WF-137	WF	Water fountain with cooler	Hallway	4/16/2019	10:17	<1.00	P	<1.00	P
19-ALD-03-WF-138	WF	Water fountain with cooler	Hallway	4/16/2019	10:19	<1.00	P	<1.00	P
19-ALD-03-OF-139	OF	Office sink faucets	343	4/16/2019	10:23	11.8	P	1.67	P
19-ALD-03-WO-140	WO	Water fountain without cooler	300	4/16/2019	10:26	3.22	P	<1.00	P
19-ALD-03-MS-142	MS	Miscellaneous sinks	342	4/16/2019	10:29	7.19	P	1.56	P
19-ALD-03-CF-148	CF	Classroom faucets	301	4/16/2019	10:35	15.2	F	4.76	P
19-ALD-03-CF-150	CF	Classroom faucets	306	4/16/2019	10:48	4.29	P	7.33	P
19-ALD-03-CF-155	CF	Classroom faucets	308	4/16/2019	10:50	8.39	P	1.44	P
19-ALD-03-WF-156	WF	Water fountain with cooler	Hallway	4/16/2019	10:43	<1.00	P	<1.00	P
19-ALD-03-WF-157	WF	Water fountain with cooler	Hallway	4/16/2019	10:46	<1.00	P	<1.00	P
19-ALD-03-TF-158	TF	Teacher's lounge sinks	309	4/16/2019	10:50	4.22	P	1.41	P
19-ALD-04-WF-162	WF	Water fountain with cooler	440	4/16/2019	11:11	<1.00	P	<1.00	P
19-ALD-04-WF-163	WF	Water fountain with cooler	440	4/16/2019	11:12	<1.00	P	<1.00	P
19-ALD-04-WO-250	WO	Water fountain without cooler	Hallway	4/16/2019	11:13	<1.00	P	1.42	P
19-ALD-04-WO-251	WO	Water fountain without cooler	Hallway	4/16/2019	11:15	6.48	P	1.76	P
19-ALD-04-CF-278	CF	Classroom faucets	401	4/16/2019	11:22	2.31	P	1.48	P
19-ALD-04-CF-279	CF	Classroom faucets	401	4/16/2019	11:23	1.23	P	<1.00	P
19-ALD-04-WO-284	WO	Water fountain without cooler	400	4/16/2019	11:28	3.53	P	<1.00	P
19-ALD-04-CF-287	CF	Classroom faucets	425	4/16/2019	11:33	2.20	P	1.64	P
19-ALD-04-CF-288	CF	Classroom faucets	427	4/16/2019	11:34	2.63	P	1.21	P
19-ALD-04-CF-290	CF	Classroom faucets	430	4/16/2019	11:39	1.63	P	<1.00	P
19-ALD-04-CF-291	CF	Classroom faucets	428	4/16/2019	11:40	16.2	F	<1.00	P
19-ALD-04-CF-292	CF	Classroom faucets	428	4/16/2019	11:42	2.83	P	<1.00	P
19-ALD-04-CF-293	CF	Classroom faucets	422	4/16/2019	11:44	2.43	P	<1.00	P
19-ALD-04-HF-294	HF	Home economics faucets (with cooking)	418	4/16/2019	11:48	4.79	P	1.96	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-ALD-04-HF-295	HF	Home economics faucets (with cooking)	418	4/16/2019	11:50	4.56	P	1.82	P
19-ALD-04-HF-296	HF	Home economics faucets (with cooking)	418	4/16/2019	11:51	3.88	P	1.22	P
19-ALD-04-HF-297	HF	Home economics faucets (with cooking)	418	4/16/2019	11:53	5.85	P	1.63	P
19-ALD-04-HF-298	HF	Home economics faucets (with cooking)	418	4/16/2019	11:54	6.07	P	2.30	P
19-ALD-04-WF-369	WF	Water fountain with cooler	400	4/16/2019	11:56	<1.00	P	<1.00	P
19-ALD-04-WF-370	WF	Water fountain with cooler	400	4/16/2019	11:59	<1.00	P	<1.00	P

Allegheny Annex

Lead in Drinking Water Sample Results

School: Pittsburgh Allgheny Annex

Address: 811 Arch Street Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-ALX-BS-SL-00	SL	Service Line	064	4/27/2019	6:22	1.69	P		
19-ALX-BS-WM-00	WM	Water Main	064	4/27/2019	6:27	5.30	P		
19-ALX-01-WF-07	WF	Water fountain with filter & cooler	Corridor 157	4/27/2019	6:29	<1.00	P	<1.00	P
19-ALX-02-WF-12	WF	Water fountain with filter & cooler	Corridor 252	4/27/2019	6:34	<1.00	P	<1.00	P
19-ALX-02-CF-16	CF	Classroom faucets	258	4/27/2019	6:36	<1.00	P	<1.00	P
19-ALX-03-WF-20	WF	Water fountain with filter & cooler	Corridor 350	4/27/2019	6:48	<1.00	P	<1.00	P
19-ALX-03-CF-22	CF	Classroom faucets	358	4/27/2019	6:52	7.33	P	<1.00	P
19-ALX-03-CF-25	CF	Classroom faucets	360	4/27/2019	6:54	<1.00	P	<1.00	P
19-ALX-02-CF-33	CF	Classroom Faucets	256	4/27/2019	6:39	13.20	P	2.27	P

Allegheny K-5, 6-8

Lead in Drinking Water Sample Results

School: Pittsburgh Allegheny K-5/6-8

Address: 810 Arch Street, Pittsburgh, PA, 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-AGL-BS-WM-00	WM	Water Main	008	5/4/2019	7:20	<1.00	P		
19-AGL-BS-SL-01	SL	Service Line	004	5/4/2019	7:10	<1.00	P		
19-AGL-GF-WC-08	WC	Water fountain with cooler	010	5/4/2019	7:29	< 1.00	P	< 1.00	P
19-AGL-GF-WC-09	WC	Water fountain with cooler	010	5/4/2019	7:30	< 1.00	P	< 1.00	P
19-AGL-GF-CF-10	CF	Classroom faucets	12	5/4/2019	7:37	< 1.00	P	< 1.00	P
19-AGL-GF-CF-13	CF	Classroom faucets	011	5/4/2019	7:40	2.61	P	1.28	P
19-AGL-GF-CF-15	CF	Classroom faucets	030	5/4/2019	7:45	4.71	P	< 1.00	P
19-AGL-GF-CF-16	CF	Classroom faucets	030	5/4/2019	7:46	< 1.00	P	< 1.00	P
19-AGL-GF-KF-18	KF	Kitchen faucets	041	5/4/2019	8:10	3.10	P	1.21	P
19-AGL-GF-KF-19	KF	Kitchen faucets	041	5/4/2019	8:13	1.24	P	< 1.00	P
19-AGL-GF-KF-20	KF	Kitchen faucets	041	5/4/2019	8:15	4.88	P	1.40	P
19-AGL-GF-KF-21	KF	Kitchen faucets	041	5/4/2019	8:17	1.58	P	< 1.00	P
19-AGL-GF-KF-22	KF	Kitchen faucets	041	5/4/2019	8:20	1.54	P	< 1.00	P
19-AGL-GF-IM-23	IM	Ice machines	034	5/4/2019	8:22	< 1.00	P		P
19-AGL-GF-WF-26	WF	Water fountain with filter & cooler	039	5/4/2019	8:35	< 1.00	P	< 1.00	P
19-AGL-01-CF-30	CF	Classroom faucets	113	5/4/2019	8:50	< 1.00	P	< 1.00	P
19-AGL-01-WC-32	WC	Water fountain with cooler	100	5/4/2019	8:54	< 1.00	P	< 1.00	P
19-AGL-01-WC-33	WC	Water fountain with cooler	100	5/4/2019	8:56	< 1.00	P	< 1.00	P
19-AGL-01-CF-34	CF	Classroom faucets	105	5/4/2019	9:00	16.1	F	< 1.00	P
19-AGL-01-NF-38	NF	Nurse's office sink faucets	101	5/4/2019	9:06	< 1.00	P	< 1.00	P
19-AGL-01-CF-44	CF	Classroom faucets	134	5/4/2019	9:14	< 1.00	P	< 1.00	P
19-AGL-01-WC-47	WC	Water fountain with cooler	131	5/4/2019	9:18	< 1.00	P	< 1.00	P
19-AGL-01-WC-48	WC	Water fountain with cooler	131	5/4/2019	9:19	< 1.00	P	< 1.00	P
19-AGL-02-CF-49	CF	Classroom faucets	219	5/4/2019	9:33	8.62	P	1.30	P
19-AGL-02-CF-53	CF	Classroom faucets	228	5/4/2019	9:35	1.03	P	1.03	P
19-AGL-02-WC-56	WC	Water fountain with cooler	Outside 217	5/4/2019	9:40	< 1.00	P	< 1.00	P
19-AGL-02-WC-57	WC	Water fountain with cooler	Outside 217	5/4/2019	9:42	< 1.00	P	< 1.00	P
19-AGL-02-WC-60	WC	Water fountain with cooler	200	5/4/2019	9:47	< 1.00	P	< 1.00	P
19-AGL-02-WC-61	WC	Water fountain with cooler	200	5/4/2019	9:49	< 1.00	P	< 1.00	P
19-AGL-02-CF-62	CF	Classroom faucets	202	5/4/2019	9:56	2.37	P	< 1.00	P
19-AGL-02-WB-66	WB	Water fountain bubbler (Ceramic or Porcelain)	204	5/4/2019	9:59	7.85	P	2.15	P
19-AGL-03-WC-70	WC	Water fountain with cooler	Outside 329	5/4/2019	10:09	< 1.00	P	< 1.00	P
19-AGL-03-WC-71	WC	Water fountain with cooler	Outside 329	5/4/2019	10:11	< 1.00	P	< 1.00	P
19-AGL-03-WC-85	WC	Water fountain with cooler	Corridor 300	5/4/2019	10:18	< 1.00	P	< 1.00	P
19-AGL-03-WC-86	WC	Water fountain with cooler	Corridor 300	5/4/2019	10:19	< 1.00	P	< 1.00	P
19-AGL-03-CF-87	CF	Classroom faucets	305	5/4/2019	10:20	< 1.00	P	< 1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-AGL-03-WB-94	WB	Water fountain bubbler (Ceramic or Porcelain)	313	5/4/2019	10:23	6.26	P	372	F
19-AGL-04-WB-95	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 416	5/4/2019	10:55	< 1.00	P	< 1.00	P
19-AGL-04-WB-96	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 416	5/4/2019	10:56	< 1.00	P	< 1.00	P
19-AGL-04-WC-105	WC	Water fountain with cooler	414	5/4/2019	11:00	< 1.00	P	< 1.00	P
19-AGL-04-WC-106	WC	Water fountain with cooler	414	5/4/2019	11:01	< 1.00	P	< 1.00	P
19-AGL-04-TF-110	TF	Teacher's lounge sinks	401	5/4/2019	11:06	1.65	P	< 1.00	P
19-AGL-04-WC-111	WC	Water fountain with cooler	400	5/4/2019	11:08	< 1.00	P	< 1.00	P
19-AGL-04-WC-112	WC	Water fountain with cooler	400	5/4/2019	11:09	< 1.00	P	< 1.00	P
19-AGL-GF-WF-119	WF	Water fountain with filter & cooler	39	5/4/2019	8:36	< 1.00	P	< 1.00	P

Arsenal Pre-K-5, 6-8

Lead in Drinking Water Sample Results

School: Pittsburgh Arsenal Pre K-5/6-8

Address: 215 39th Street, Pittsburgh, PA 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-ARS-BS-SL-04	SL	Service Line	B-3	4/18/2019	07:05	<1.00	P		
19-ARS-BS-WM-04	WM	Water Main	B-3	4/18/2019	07:10	<1.00	P		
19-ARS-GF-OF-01	OF	Office faucet	11A	4/18/2019	06:55	<1.00	P	<1.00	P
19-ARS-GF-WF-02	WF	Water fountain with filter & cooler	1	4/18/2019	07:25	<1.00	P	<1.00	P
19-ARS-GF-WF-03	WF	Water fountain with filter & cooler	1	4/18/2019	07:26	<1.00	P	<1.00	P
19-ARS-BS-WO-07	WO	Water fountain without cooler	B-6	4/18/2019	07:27	2.76	P	<1.00	P
19-ARS-GF-CF-10	CF	Classroom faucets	9	4/18/2019	07:31	2.1	P	<1.00	P
19-ARS-GF-WC-14	WC	Water fountain with cooler	1G	4/18/2019	07:31	<1.00	P	1.32	P
19-ARS-GF-WC-15	WC	Water fountain with cooler	1G	4/18/2019	07:32	<1.00	P	<1.00	P
19-ARS-GF-NF-17	NF	Nurse's office sink faucets	26B	4/18/2019	07:35	18.5	F	2.13	P
19-ARS-GF-WC-21	WC	Water fountain with cooler	1G	4/18/2019	07:41	<1.00	P	1.32	P
19-ARS-GF-WC-22	WC	Water fountain with cooler	1G	4/18/2019	07:41	1.38	P	<1.00	P
19-ARS-GF-KF-23	KF	Kitchen faucets	32	4/18/2019	07:47	4.13	P	<1.00	P
19-ARS-GF-KF-24	KF	Kitchen faucets	32	4/18/2019	07:48	6.66	P	<1.00	P
19-ARS-GF-KF-25	KF	Kitchen faucets	32	4/18/2019	07:51	1.26	P	<1.00	P
19-ARS-GF-KF-26	KF	Kitchen faucets	32	4/18/2019	07:54	2.16	P	<1.00	P
19-ARS-GF-CF-30	CF	Classroom faucets	34	4/18/2019	07:56	2.47	P	<1.00	P
19-ARS-GF-WF-41	WF	Water fountain with filter & cooler	1-0	4/18/2019	08:01	<1.00	P	<1.00	P
19-ARS-GF-WF-42	WF	Water fountain with filter & cooler	1-0	4/18/2019	08:03	<1.00	P	<1.00	P
19-ARS-01-CF-60	CF	Classroom faucets	131	4/18/2019	08:16	<1.00	P	<1.00	P
19-ARS-01-WC-62	WC	Water fountain with cooler	100B	4/18/2019	08:19	<1.00	P	<1.00	P
19-ARS-01-WC-63	WC	Water fountain with cooler	100B	4/18/2019	08:21	<1.00	P	<1.00	P
19-ARS-01-CF-72	CF	Classroom faucets	141	4/18/2019	08:21	10.9	P	1.04	P
19-ARS-01-NF-73	NF	Nurse's office sink faucets	143A	4/18/2019	08:25	<1.00	P	<1.00	P
19-ARS-01-WC-74	WC	Water fountain with cooler	100	4/18/2019	08:27	<1.00	P	1.48	P
19-ARS-01-WC-75	WC	Water fountain with cooler	100	4/18/2019	08:28	<1.00	P	<1.00	P
19-ARS-01-CF-76	CF	Classroom faucets	122	4/18/2019	08:31	2.46	P	<1.00	P
19-ARS-01-CF-77	CF	Classroom faucets	122	4/18/2019	08:33	1.26	P	<1.00	P
19-ARS-01-CF-78	CF	Classroom faucets	120	4/18/2019	08:38	3.03	P	<1.00	P
19-ARS-01-CF-79	CF	Classroom faucets	120	4/18/2019	08:39	2.31	P	<1.00	P
19-ARS-01-WF-81	WF	Water fountain with filter & cooler	100	4/18/2019	08:43	<1.00	P	<1.00	P
19-ARS-01-WF-82	WF	Water fountain with filter & cooler	100	4/18/2019	08:44	<1.00	P	<1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-ARS-01-HF-83	HF	Home economics faucets (with cooking)	112	4/18/2019	08:46	2.85	P	5.43	P
19-ARS-01-HF-84	HF	Home economics faucets (with cooking)	112	4/18/2019	08:48	1.53	P	2.07	P
19-ARS-01-HF-85	HF	Home economics faucets (with cooking)	112	4/18/2019	08:50	1.54	P	1.17	P
19-ARS-01-HF-86	HF	Home economics faucets (with cooking)	112	4/18/2019	08:50	<1.00	P	<1.00	P
19-ARS-01-HF-87	HF	Home economics faucets (with cooking)	112	4/18/2019	08:53	<1.00	P	<1.00	P
19-ARS-02-WC-96	WC	Water fountain with cooler	200	4/18/2019	09:05	3.53	P	1.57	P
19-ARS-02-WC-97	WC	Water fountain with cooler	200	4/18/2019	09:07	1.43	P	1.65	P
19-ARS-02-WC-100	WC	Water fountain with cooler	200	4/18/2019	09:06	<1.00	P	<1.00	P
19-ARS-02-WC-101	WC	Water fountain with cooler	200	4/18/2019	09:08	<1.00	P	<1.00	P
19-ARS-03-CF-115	CF	Classroom faucets	312	4/18/2019	09:19	12.3	P	1.66	P
19-ARS-03-WC-116	WC	Water fountain with cooler	300	4/18/2019	09:20	<1.00	P	<1.00	P
19-ARS-03-WC-117	WC	Water fountain with cooler	300	4/18/2019	09:22	<1.00	P	<1.00	P
19-ARS-03-CF-118	CF	Classroom faucets	306	4/18/2019	09:26	5.88	P	5.89	P
19-ARS-03-CF-120	CF	Classroom faucets	302	4/18/2019	09:29	67.4	F	4.34	P
19-ARS-03-WC-121	WC	Water fountain with cooler	300	4/18/2019	09:32	4.45	P	2.16	P
19-ARS-03-WC-122	WC	Water fountain with cooler	300	4/18/2019	09:34	2.7	P	2.44	P
19-ARS-02-CF-123	CF	Classroom faucets	210	4/18/2019	09:13	5.55	P	2.13	P
19-ARS-BS-WB-124	WB	Water fountain bubbler (Ceramic or Porcelain)	M-4	4/18/2019	09:57	2.05	P	<1.00	P
19-ARS-BS-WF-131	WF	Water fountain with filter & cooler	B-20	4/18/2019	09:50	<1.00	P	<1.00	P
19-ARS-BS-WF-132	WF	Water fountain with filter & cooler	B-20	4/18/2019	09:52	<1.00	P	<1.00	P
19-ARS-BS-CF-138	CF	Classroom faucets	B-30	4/18/2019	09:57	<1.00	P	<1.00	P
19-ARS-BS-CF-144	CF	Classroom faucets	B-6	4/18/2019	09:59	5.99	P	<1.00	P

Beechwood PreK-5

Lead in Drinking Water Sample Results

School: Pittsburgh Beechwood Pre K-5

Address: 810 Rockland Avenue Pittsburgh, PA 15216

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing)
19-BEE-BS-SL-01	SL	Service Line	16	2/16/2019					
19-BEE-BS-WM-01	WM	Water Main	16	2/16/2019	6:36	3.83	P		
19-BEE-BS-WC-03	WC	Water fountain with cooler	Corr-1	2/16/2019	6:40	<1.00	P	<1.00	P
19-BEE-BS-WC-04	WC	Water fountain with cooler	Corr-1	2/16/2019	6:40	<1.00	P	<1.00	P
19-BEE-BS-CF-05	CF	Classroom faucets	14	2/16/2019	6:46	<1.00	P	<1.00	P
19-BEE-BS-SF-08	SF	Science lab faucets	14	2/16/2019	6:50	<1.00	P	<1.00	P
19-BEE-BS-WC-09	WC	Water fountain with cooler	Corr-1	2/16/2019	6:55	<1.00	P	<1.00	P
19-BEE-BS-WC-10	WC	Water fountain with cooler	Corr-1	2/16/2019	6:55	<1.00	P	<1.00	P
19-BEE-BS-CF-11	CF	Classroom faucets	12C	2/16/2019	6:59	3.85	P	2.75	P
19-BEE-BS-NF-21	NF	Nurse's office sink faucets	3	2/16/2019	7:03	1.21	P	<1.00	P
19-BEE-BS-CF-23	CF	Classroom faucets	2	2/16/2019	7:05	3.69	P	<1.00	P
19-BEE-01-OF-24	OF	Office sink faucets	16A	2/16/2019	7:10	1.25	P	<1.00	P
19-BEE-01-WC-25	WC	Water fountain with cooler	Corr-100	2/16/2019	7:13	<1.00	P	<1.00	P
19-BEE-01-WC-26	WC	Water fountain with cooler	Corr-100	2/16/2019	7:13	<1.00	P	<1.00	P
19-BEE-01-KF-27	KF	Kitchen faucets	100C	2/16/2019	7:17	1.7	P	<1.00	P
19-BEE-01-WC-28	WC	Water fountain with cooler	Corr-100	2/16/2019	7:22	<1.00	P	<1.00	P
19-BEE-01-CF-29	CF	Classroom faucets	109	2/16/2019	7:24	<1.00	P	<1.00	P
19-BEE-01-US-33	US	Utility sink	J	2/16/2019	7:30	<1.00	P	<1.00	P
19-BEE-01-OF-37	OF	Office sink faucets	102	2/16/2019	7:35	1.36	P	<1.00	P
19-BEE-02-CF-38	CF	Classroom faucets	216	2/16/2019	7:39	1.27	P	<1.00	P
19-BEE-02-WC-39	WC	Water fountain with cooler	Corr-200	2/16/2019	7:42	<1.00	P	<1.00	P
19-BEE-02-WC-40	WC	Water fountain with cooler	Corr-200	2/16/2019	7:42	<1.00	P	<1.00	P
19-BEE-02-CF-41	CF	Classroom faucets	215	2/16/2019	7:45	<1.00	P	<1.00	P
19-BEE-02-TF-42	TF	Teacher's lounge sinks	214	2/16/2019	7:47	<1.00	P	<1.00	P
19-BEE-02-WC-43	WC	Water fountain with cooler	Corr-200	2/16/2019	7:50	<1.00	P	<1.00	P
19-BEE-02-WC-44	WC	Water fountain with cooler	Corr-200	2/16/2019	7:50	<1.00	P	<1.00	P
19-BEE-02-CF-49	CF	Classroom faucets	204	2/16/2019	7:56	2.94	P	<1.00	P
19-BEE-DB-CF-53	CF	Classroom faucets	P-01	2/16/2019	8:04	<1.00	P	1.41	P
19-BEE-DB-WM-57	CF	Utility sink	P-02	2/16/2019	8:07	1.17	P	2.09	P
19-BEE-DB-CF-58	CF	Classroom faucets	P-03	2/16/2019	8:09	1.93	P	1.35	P
19-BEE-DB-CF-59	CF	Classroom faucets	P-04	2/16/2019	8:11	<1.00	P	1.41	P
19-BEE-DB-CF-64	CF	Classroom faucets	P-06	2/16/2019	8:16	1.4	P	1.07	P

Brashear High School
South Hills 6-8

Lead in Drinking Water Sample Results

School: Brashear South Hills 6-8

Address: 590 Crane Ave., Pittsburgh, PA, 15216

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-BRA-BS-WM-00	WM	Water Main	Crawlspace	4/27/2019	6:42	<1.00	P		
19-BRA-BS-SL-00	SL	Service Line	Crawlspace	4/27/2019	6:47	<1.00	P		
19-BRA-BS-WF-01	WF	Water fountain with filter & cooler	Main Hallway	4/27/2019	6:48	<1.00	P	<1.00	P
19-BRA-BS-WF-02	WF	Water fountain with filter & cooler	Main Hallway	4/27/2019	6:48	<1.00	P	<1.00	P
19-BRA-BS-WC-17	WC	Water fountain with cooler	Automotive	4/27/2019	6:54	<1.00	P	<1.00	P
19-BRA-BS-WC-21	WC	Water fountain with cooler	Automotive	4/27/2019	6:56	2.07	P	<1.00	P
19-BRA-BS-CF-24	CF	Classroom faucets	G5	4/27/2019	6:55	1.25	P	<1.00	P
19-BRA-BS-WC-26	WC	Water fountain with cooler	G6	4/27/2019	6:56	<1.00	P	<1.00	P
19-BRA-BS-CF-28	CF	Classroom faucets	G2	4/27/2019	7:04	1.08	P	<1.00	P
19-BRA-BS-WC-32	WC	Water fountain with cooler	G1	4/27/2019	7:05	<1.00	P	<1.00	P
19-BRA-BS-KF-37	KF	Kitchen faucets	G14	4/27/2019	7:04	<1.00	P	<1.00	P
19-BRA-BS-CF-38	CF	Classroom faucets	G14A	4/27/2019	7:04	140	F	<1.00	P
19-BRA-BS-WC-42	WC	Water fountain with cooler	G13	4/27/2019	7:14	2.34	P	<1.00	P
19-BRA-BS-CF-45	CF	Classroom faucets	G23	4/27/2019	7:19	6.31	P	4.30	P
19-BRA-BS-WF-46	WF	Water fountain with filter & cooler	Hallway	4/27/2019	7:20	<1.00	P	<1.00	P
19-BRA-BS-WF-47	WF	Water fountain with filter & cooler	Hallway	4/27/2019	7:21	<1.00	P	<1.00	P
19-BRA-BS-WC-48	WC	Water fountain with cooler	Hallway	4/27/2019	7:20	<1.00	P	<1.00	P
19-BRA-BS-OF-60	OF	Office sink faucets	G42M	4/27/2019	7:22	<1.00	P	<1.00	P
19-BRA-BS-MS-61	MS	Miscellaneous sinks	G45M	4/27/2019	7:25	5.09	P	<1.00	P
19-BRA-BS-WC-64	WC	Water fountain with cooler	Hallway	4/27/2019	7:23	<1.00	P	<1.00	P
19-BRA-BS-WC-65	WC	Water fountain with cooler	Hallway	4/27/2019	7:24	<1.00	P	<1.00	P
19-BRA-01-KF-68	KF	Kitchen faucets	102	4/27/2019	7:50	<1.00	P	<1.00	P
19-BRA-01-KF-69	KF	Kitchen faucets	102	4/27/2019	7:50	<1.00	P	<1.00	P
19-BRA-01-KF-70	KF	Kitchen faucets	102	4/27/2019	7:54	1.53	P	<1.00	P
19-BRA-01-KF-71	KF	Kitchen faucets	102	4/27/2019	7:55	<1.00	P	<1.00	P
19-BRA-01-KF-72	KF	Kitchen faucets	102	4/27/2019	7:57	<1.00	P	<1.00	P
19-BRA-01-TF-76	TF	Teacher's lounge sinks	111	4/27/2019	7:42	<1.00	P	<1.00	P
19-BRA-01-WF-85	WF	Water fountain with filter & cooler	Hallway	4/27/2019	7:43	<1.00	P	<1.00	P
19-BRA-01-WF-86	WF	Water fountain with filter & cooler	Hallway	4/27/2019	7:44	<1.00	P	<1.00	P
19-BRA-01-WC-94	WC	Water fountain with cooler	130	4/27/2019	7:43	<1.00	P	<1.00	P
19-BRA-01-OF-95	OF	Office sink faucets	134	4/27/2019	7:46	<1.00	P	<1.00	P
19-BRA-01-NF-97	NF	Nurse's office sink faucets	138	4/27/2019	7:53	<1.00	P	<1.00	P
19-BRA-01-TF-98	TF	Teacher's lounge sinks	138	4/27/2019	7:55	<1.00	P	<1.00	P
19-BRA-01-WC-99	WC	Water fountain with cooler	140	4/27/2019	8:01	1.43	P	1.59	P
19-BRA-01-TF-102	TF	Teacher's lounge sinks	125	4/27/2019	8:04	<1.00	P	<1.00	P
19-BRA-01-OF-104	OF	Office sink faucets	128	4/27/2019	8:01	6.95	P	<1.00	P
19-BRA-01-WF-106	WF	Water fountain with filter & cooler	LOBBY	4/27/2019	8:04	<1.00	P	<1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-BRA-01-WF-107	WF	Water fountain with filter & cooler	LOBBY	4/27/2019	8:01	<1.00	P	<1.00	P
19-BRA-01-OF-118	OF	Office sink faucets	113A	4/27/2019	8:05	1.39	P	1.51	P
19-BRA-01-TF-127	TF	Teacher's lounge sinks	108	4/27/2019	8:06	<1.00	P	<1.00	P
19-BRA-01-KF-128	KF	Kitchen faucets	109	4/27/2019	8:15	<1.00	P	<1.00	P
19-BRA-01-KF-129	KF	Kitchen faucets	109	4/27/2019	8:16	<1.00	P	<1.00	P
19-BRA-01-KF-130	KF	Kitchen faucets	109	4/27/2019	8:17	<1.00	P	<1.00	P
19-BRA-01-KF-131	KF	Kitchen faucets	109	4/27/2019	8:17	4.10	P	<1.00	P
19-BRA-01-KF-134	KF	Kitchen faucets	109	4/27/2019	8:19	2.16	P	<1.00	P
19-BRA-02-WF-164	WF	Water fountain with filter & cooler	LOBBY	4/27/2019	8:34	<1.00	P	<1.00	P
19-BRA-02-WF-165	WF	Water fountain with filter & cooler	LOBBY	4/27/2019	8:32	<1.00	P	<1.00	P
19-BRA-02-IM-177	IM	Ice machines	269	4/27/2019	8:42	<1.00	P	<1.00	P
19-BRA-02-WC-179	WC	Water fountain with cooler	265A	4/27/2019	8:44	<1.00	P	<1.00	P
19-BRA-02-WC-180	WC	Water fountain with cooler	265A	4/27/2019	8:45	1.42	P	<1.00	P
19-BRA-02-WC-186	WC	Water fountain with cooler	263	4/27/2019	8:42	30.7	F	<1.00	P
19-BRA-02-WC-187	WC	Water fountain with cooler	Hallway	4/27/2019	8:42	<1.00	P	<1.00	P
19-BRA-02-WC-191	WC	Water fountain with cooler	259	4/27/2019	8:48	<1.00	P	<1.00	P
19-BRA-02-WC-192	WC	Water fountain with cooler	259	4/27/2019	8:49	<1.00	P	<1.00	P
19-BRA-02-CF-194	CF	Classroom faucets	237	4/27/2019	8:48	1.17	P	<1.00	P
19-BRA-02-WF-203	WF	Water fountain with filter & cooler	Hallway	4/27/2019	8:50	<1.00	P	<1.00	P
19-BRA-02-WF-204	WF	Water fountain with filter & cooler	Hallway	4/27/2019	8:52	<1.00	P	<1.00	P
19-BRA-03-WF-269	WF	Water fountain with filter & cooler	Hallway	4/27/2019	9:13	<1.00	P	<1.00	P
19-BRA-03-WF-270	WF	Water fountain with filter & cooler	Hallway	4/27/2019	9:15	<1.00	P	<1.00	P
19-BRA-03-WO-287	WO	Water fountain without cooler	353	4/27/2019	9:14	5.92	P	1.20	P
19-BRA-03-CF-288	CF	Classroom faucets	340	4/27/2019	9:17	<1.00	P	<1.00	P
19-BRA-03-CF-289	CF	Classroom faucets	340	4/27/2019	9:16	<1.00	P	<1.00	P
19-BRA-03-CF-290	CF	Classroom faucets	344	4/27/2019	9:25	119	F	<1.00	P
19-BRA-03-CF-291	CF	Classroom faucets	344	4/27/2019	9:26	1.56	P	<1.00	P
19-BRA-03-CF-292	CF	Classroom faucets	344	4/27/2019	9:28	<1.00	P	<1.00	P
19-BRA-03-CF-293	CF	Classroom faucets	341	4/27/2019	9:20	1.96	P	<1.00	P
19-BRA-03-CF-294	CF	Classroom faucets	341	4/27/2019	9:20	<1.00	P	<1.00	P
19-BRA-03-CF-295	CF	Classroom faucets	342	4/27/2019	9:21	1.31	P	<1.00	P
19-BRA-03-CF-296	CF	Classroom faucets	342	4/27/2019	9:21	14.8	P	<1.00	P
19-BRA-03-CF-297	CF	Classroom faucets	343	4/27/2019	9:23	2.59	P	<1.00	P
19-BRA-03-CF-298	CF	Classroom faucets	343	4/27/2019	9:25	1.54	P	<1.00	P
19-BRA-03-TF-299	TF	Teacher's lounge sinks	328	4/27/2019	9:26	<1.00	P	<1.00	P
19-BRA-03-HF-303	HF	Home economics faucets (with cooking)	336	4/27/2019	9:35	3.57	P	<1.00	P
19-BRA-03-HF-304	HF	Home economics faucets (with cooking)	336	4/27/2019	9:36	3.22	P	<1.00	P
19-BRA-03-HF-305	HF	Home economics faucets (with cooking)	336	4/27/2019	9:40	4.24	P	<1.00	P
19-BRA-03-HF-306	HF	Home economics faucets (with cooking)	336	4/27/2019	9:39	8.98	P	<1.00	P
19-BRA-03-HF-309	HF	Home economics faucets (with cooking)	336	4/27/2019	9:42	3.77	P	<1.00	P
19-BRA-03-HF-310	HF	Home economics faucets (with cooking)	337	4/27/2019	9:34	1.56	P	<1.00	P
19-BRA-03-HF-311	HF	Home economics faucets (with cooking)	337	4/27/2019	9:35	13.7	P	<1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-BRA-03-HF-312	HF	Home economics faucets (with cooking)	337	4/27/2019	9:36	<1.00	P	<1.00	P
19-BRA-03-HF-313	HF	Home economics faucets (with cooking)	337	4/27/2019	9:38	5.07	P	<1.00	P
19-BRA-03-HF-314	HF	Home economics faucets (with cooking)	337	4/27/2019	9:38	<1.00	P	<1.00	P
19-BRA-03-WF-318	WF	Water fountain with filter & cooler	Hallway	4/27/2019	9:43	<1.00	P	<1.00	P
19-BRA-03-WF-319	WF	Water fountain with filter & cooler	Hallway	4/27/2019	9:44	<1.00	P	<1.00	P

CAPA 6-12

Lead in Drinking Water Sample Results

School: Pittsburgh CAPA

Address: 111 Ninth St. Pittsburgh, PA 15222

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-CAP-BS-WM-00	WM	Water Main	Parking Garage	5/25/2019	06:55	<1.00	P		
19-CAP-BS-SL-00	SL	Service Line	Parking Garage	5/25/2019	06:45	<1.00	P		
19-CAP-01-KF-12	KF	Kitchen faucets	Kitchen	5/25/2019	07:10	1.11	P	1.04	P
19-CAP-01-KF-13	KF	Kitchen faucets	Kitchen	5/25/2019	07:11	1.55	P	<1.00	P
19-CAP-01-KF-14	KF	Kitchen faucets	Kitchen	5/25/2019	07:14	1.01	P	<1.00	P
19-CAP-01-KF-15	KF	Kitchen faucets	Kitchen	5/25/2019	07:15	<1.00	P	<1.00	P
19-CAP-01-KF-16	KF	Kitchen faucets	Kitchen	5/25/2019	07:17	<1.00	P	<1.00	P
19-CAP-01-KF-17	KF	Kitchen faucets	Kitchen	5/25/2019	07:18	<1.00	P	<1.00	P
19-CAP-01-WF-22	WF	Water fountain with filter & cooler	Hallway	5/25/2019	07:07	<1.00	P	<1.00	P
19-CAP-01-WF-23	WF	Water fountain with filter & cooler	Hallway	5/25/2019	07:08	<1.00	P	<1.00	P
19-CAP-02-WF-42	WF	Water fountain with filter & cooler	Hallway	5/25/2019	07:27	<1.00	P	<1.00	P
19-CAP-02-WF-43	WF	Water fountain with filter & cooler	Hallway	5/25/2019	07:28	<1.00	P	<1.00	P
19-CAP-02-CF-47	CF	Classroom faucets	214	5/25/2019	07:27	<1.00	P	<1.00	P
19-CAP-03-WF-53	WF	Water fountain with filter & cooler	Hallway	5/25/2019	07:33	<1.00	P	<1.00	P
19-CAP-03-WF-54	WF	Water fountain with filter & cooler	Hallway	5/25/2019	07:34	<1.00	P	<1.00	P
19-CAP-03-CF-60	CF	Classroom faucets	311	5/25/2019	07:34	<1.00	P	<1.00	P
19-CAP-04-TF-61	TF	Teacher's lounge sinks	434	5/25/2019	07:41	<1.00	P	<1.00	P
19-CAP-04-OF-65	OF	Office sink faucets	417	5/25/2019	07:45	<1.00	P	<1.00	P
19-CAP-04-WF-66	WF	Water fountain with filter & cooler	Hallway	5/25/2019	07:43	<1.00	P	<1.00	P
19-CAP-04-WF-67	WF	Water fountain with filter & cooler	Hallway	5/25/2019	07:44	<1.00	P	<1.00	P
19-CAP-04-CF-73	CF	Classroom faucets	412	5/25/2019	07:52	<1.00	P	<1.00	P
19-CAP-04-KF-80	KF	Kitchen faucets	408	5/25/2019	07:52	<1.00	P	<1.00	P
19-CAP-04-KF-81	KF	Kitchen faucets	408	5/25/2019	07:55	2.39	P	1.14	P
19-CAP-04-KF-82	KF	Kitchen faucets	407	5/25/2019	07:59	2.39	P	<1.00	P
19-CAP-04-KF-83	KF	Kitchen faucets	401	5/25/2019	08:02	<1.00	P	<1.00	P
19-CAP-04-KF-84	KF	Kitchen faucets	401	5/25/2019	08:05	<1.00	P	<1.00	P
19-CAP-04-KF-85	KF	Kitchen faucets	401	5/25/2019	08:06	<1.00	P	<1.00	P
19-CAP-04-KF-86	KF	Kitchen faucets	401	5/25/2019	08:07	1.10	P	<1.00	P
19-CAP-04-KF-87	KF	Kitchen faucets	401	5/25/2019	08:08	<1.00	P	<1.00	P
19-CAP-04-IM-88	IM	Ice machines	401	5/25/2019	08:12	<1.00	P	<1.00	P
19-CAP-05-WC-93	WC	Water fountain with cooler	Outside 505	5/25/2019	08:20	<1.00	P	<1.00	P
19-CAP-05-WC-94	WC	Water fountain with cooler	500	5/25/2019	08:21	<1.00	P	<1.00	P
19-CAP-05-WC-95	WC	Water fountain with cooler	Weight Room	5/25/2019	08:23	<1.00	P	<1.00	P
19-CAP-05-WF-98	WF	Water fountain with filter & cooler	Hallway	5/25/2019	08:26	<1.00	P	<1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-CAP-05-WF-99	WF	Water fountain with filter & cooler	Hallway	5/25/2019	08:27	<1.00	P	<1.00	P
19-CAP-06-CF-139	CF	Classroom faucets	604	5/25/2019	08:40	<1.00	P	<1.00	P
19-CAP-06-CF-140	CF	Classroom faucets	603A	5/25/2019	08:40	2.00	P	<1.00	P
19-CAP-06-CF-141	CF	Classroom faucets	602	5/25/2019	08:43	<1.00	P	<1.00	P
19-CAP-06-CF-142	CF	Classroom faucets	606	5/25/2019	08:41	<1.00	P	<1.00	P
19-CAP-06-CF-143	CF	Classroom faucets	606	5/25/2019	08:42	<1.00	P	<1.00	P
19-CAP-06-CF-144	CF	Classroom faucets	607	5/25/2019	08:49	1.18	P	<1.00	P
19-CAP-06-WC-145	WC	Water fountain with cooler	Hallway	5/25/2019	08:54	<1.00	P	<1.00	P
19-CAP-06-WF-146	WF	Water fountain with filter & cooler	Hallway	5/25/2019	08:55	<1.00	P	<1.00	P
19-CAP-06-WF-147	WF	Water fountain with filter & cooler	Hallway	5/25/2019	08:56	<1.00	P	<1.00	P
19-CAP-06-CF-156	CF	Classroom faucets	624	5/25/2019	09:02	<1.00	P	<1.00	P
19-CAP-06-CF-157	CF	Classroom faucets	624-625	5/25/2019	09:02	<1.00	P	1.27	P
19-CAP-06-CF-158	CF	Classroom faucets	625	5/25/2019	09:03	<1.00	P	<1.00	P
19-CAP-06-CF-159	CF	Classroom faucets	620	5/25/2019	09:12	<1.00	P	<1.00	P
19-CAP-06-CF-160	CF	Classroom faucets	620	5/25/2019	09:13	33.6	F	<1.00	P
19-CAP-07-WF-162	WF	Water fountain with filter & cooler	714	5/25/2019	09:20	<1.00	P	<1.00	P
19-CAP-07-WF-163	WF	Water fountain with filter & cooler	714	5/25/2019	09:20	<1.00	P	<1.00	P
19-CAP-07-CF-164	CF	Classroom faucets	719	5/25/2019	09:21	1.44	P	1.59	P
19-CAP-08-TF-172	TF	Teacher's lounge sinks	Teachers Room	5/25/2019	09:28	<1.00	P	<1.00	P
19-CAP-08-OF-173	OF	Office sink faucets	Teachers Room	5/25/2019	09:31	4.56	P	<1.00	P
19-CAP-08-WF-177	WF	Water fountain with filter & cooler	Hallway	5/25/2019	09:29	<1.00	P	<1.00	P
19-CAP-08-WF-178	WF	Water fountain with filter & cooler	Hallway	5/25/2019	09:29	<1.00	P	<1.00	P
19-CAP-09-WF-185	WF	Water fountain with filter & cooler	Hallway	5/25/2019	09:37	<1.00	P	<1.00	P
19-CAP-09-WF-186	WF	Water fountain with filter & cooler	Hallway	5/25/2019	09:38	<1.00	P	<1.00	P
19-CAP-04-KF-196	KF	Kitchen faucets	407	5/25/2019	08:01	<1.00	P	<1.00	P
19-CAP-06-CF-197	CF	Classroom faucets	617	5/25/2019	09:14	2.63	P	6.52	P
19-CAP-06-CF-198	CF	Classroom faucets	617	5/25/2019	09:14	35.1	F	1.28	P

Carmalt PreK-8

Lead in Drinking Water Sample Results

School: Colfax K-8

Address: 2332 Beechwood Blvd., Pittsburgh, PA 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-COL-BS-WM-00	WM	Water Main	7A	6/8/19	06:37	<1.00	P		
19-COL-BS-SL-00	SL	Service Line	7A	6/8/19	06:32	<1.00	P		
19-COL-BS-CF-01	CF	Classroom faucets	6	6/8/19	06:27	4.06	P	<1.00	P
19-COL-BS-WF-04	WF	Water fountain with filter & cooler	Next to Stair A	6/8/19	06:37	<1.00	P	<1.00	P
19-COL-BS-WF-05	WF	Water fountain with filter & cooler	Next to Stair A	6/8/19	06:38	<1.00	P	<1.00	P
19-COL-BS-CF-11	CF	Classroom faucets	17	6/8/19	06:44	<1.00	P	<1.00	P
19-COL-BS-KF-13	KF	Kitchen faucets	Custodian	6/8/19	06:47	2.72	P	<1.00	P
19-COL-BS-CF-14	CF	Classroom faucets	15	6/8/19	06:50	7.79	P	3.08	P
19-COL-BS-CF-16	CF	Classroom faucets	16	6/8/19	06:53	14.2	P	<1.00	P
19-COL-01-CF-17	CF	Classroom faucets	105A	6/8/19	06:59	4.18	P	<1.00	P
19-COL-01-CF-18	CF	Classroom faucets	104A	6/8/19	07:02	4.69	P	3.42	P
19-COL-01-CF-19	CF	Classroom faucets	106A	6/8/19	07:05	3.63	P	<1.00	P
19-COL-01-WO-21	WO	Water fountain without cooler	Corridor 100	6/8/19	07:10	<1.00	P	<1.00	P
19-COL-01-WO-22	WO	Water fountain without cooler	Corridor 100	6/8/19	07:11	<1.00	P	<1.00	P
19-COL-01-CF-28	CF	Classroom faucets	102	6/8/19	07:14	2.65	P	<1.00	P
19-COL-01-NF-29	NF	Nurse's office sink faucets	101B	6/8/19	07:17	<1.00	P	<1.00	P
19-COL-01-WF-39	WF	Water fountain with filter & cooler	Corridor 100	6/8/19	07:23	<1.00	P	<1.00	P
19-COL-01-WF-40	WF	Water fountain with filter & cooler	Corridor 100	6/8/19	07:24	<1.00	P	<1.00	P
19-COL-01-CF-41	CF	Classroom faucets	113A	6/8/19	07:28	<1.00	P	2.58	P
19-COL-01-CF-43	CF	Classroom faucets	112A	6/8/19	07:32	<1.00	P	2.49	P
19-COL-01-CF-44	CF	Classroom faucets	111A	6/8/19	07:34	<1.00	P	3.15	P
19-COL-01-WC-52	WC	Water fountain with cooler	Corridor A	6/8/19	07:45	10.8	P	<1.00	P
19-COL-01-WC-53	WC	Water fountain with cooler	Corridor A	6/8/19	07:46	<1.00	P	<1.00	P
19-COL-01-WF-54	WF	Water fountain with filter & cooler	Cafeteria	6/8/19	07:52	<1.00	P	<1.00	P
19-COL-01-WF-55	WF	Water fountain with filter & cooler	Cafeteria	6/8/19	07:53	<1.00	P	<1.00	P
19-COL-01-KF-56	KF	Kitchen faucets	Servery	6/8/19	08:00	<1.00	P	1.28	P
19-COL-01-KF-57	KF	Kitchen faucets	Servery	6/8/19	08:02	<1.00	P	<1.00	P
19-COL-01-KF-58	KF	Kitchen faucets	Servery	6/8/19	08:03	<1.00	P	<1.00	P
19-COL-02-CF-59	CF	Classroom faucets	204A	6/8/19	08:08	<1.00	P	4.83	P
19-COL-02-CF-60	CF	Classroom faucets	205A	6/8/19	08:11	3.65	P	6.24	P
19-COL-02-CF-61	CF	Classroom faucets	203A	6/8/19	08:14	<1.00	P	1.52	P
19-COL-02-CF-62	CF	Classroom faucets	206A	6/8/19	08:16	1.25	P	2.63	P
19-COL-02-WO-63	WO	Water fountain without cooler	Corridor 200	6/8/19	08:22	<1.00	P	<1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-COL-02-WO-64	WO	Water fountain without cooler	Corridor 200	6/8/19	08:23	<1.00	P	<1.00	P
19-COL-02-CF-71	CF	Classroom faucets	201	6/8/19	08:30	<1.00	P	2.56	P
19-COL-02-CF-73	CF	Classroom faucets	214A	6/8/19	08:38	<1.00	P	4.87	P
19-COL-02-WF-77	WF	Water fountain with filter & cooler	Corridor 200	6/8/19	08:42	<1.00	P	<1.00	P
19-COL-02-WF-78	WF	Water fountain with filter & cooler	Corridor 200	6/8/19	08:43	<1.00	P	<1.00	P
19-COL-02-CF-79	CF	Classroom faucets	213A	6/8/19	08:48	<1.00	P	3.48	P
19-COL-02-CF-80	CF	Classroom faucets	210A	6/8/19	08:50	2.52	P	<1.00	P
19-COL-02-CF-81	CF	Classroom faucets	212A	6/8/19	08:52	4.06	P	<1.00	P
19-COL-02-CF-82	CF	Classroom faucets	211A	6/8/19	08:54	5.77	P	7.90	P
19-COL-02-WF-94	WF	Water fountain with filter & cooler	Outside Restrooms; New Building	6/8/19	09:03	<1.00	P	<1.00	P
19-COL-02-WF-95	WF	Water fountain with filter & cooler	Outside Restrooms; New Building	6/8/19	09:04	<1.00	P	<1.00	P
19-COL-02-OF-97	OF	Office sink faucets	Nurse	6/8/19	09:06	2.49	P	<1.00	P
19-COL-03-CF-99	CF	Classroom faucets	301	6/8/19	09:10	2.14	P	1.04	P

Concord PreK-5

Lead in Drinking Water Sample Results

School: Pittsburgh Concord Pre K-5

Address: 2350 Brownsville Road, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-CON-BS-SL-00	SL	Service Line	Rest Room	4/12/2019	6:45	<1.00	P		
19-CON-BS-WM-00	WM	Water Main	Rest Room	4/12/2019	7:00	<1.00	P		
19-CON-BS-WF-07	WF	Water fountain with filter & cooler	Outside Restroom	4/6/2019	7:22	< 1.00	P	< 1.00	P
19-CON-BS-WF-08	WF	Water fountain with filter & cooler	Outside Restroom	4/6/2019	7:23	< 1.00	P	< 1.00	P
19-CON-BS-TF-16	TF	Teacher's lounge sinks	Lounge	4/6/2019	7:28	< 1.00	P	< 1.00	P
19-CON-GF-WF-25	WF	Water fountain with filter & cooler	Outside Restroom	4/6/2019	7:55	< 1.00	P	< 1.00	P
19-CON-GF-WF-26	WF	Water fountain with filter & cooler	Outside Restroom	4/6/2019	7:56	< 1.00	P	< 1.00	P
19-CON-GF-WF-29	WF	Water fountain with filter & cooler	Outside Cafeteria	4/6/2019	8:01	< 1.00	P	< 1.00	P
19-CON-GF-KF-30	KF	Kitchen faucets	3	4/6/2019	8:07	13.2	P	< 1.00	P
19-CON-GF-KF-31	KF	Kitchen faucets	3	4/6/2019	8:09	< 1.00	P	< 1.00	P
19-CON-GF-KF-32	KF	Kitchen faucets	3	4/6/2019	8:12	< 1.00	P	< 1.00	P
19-CON-GF-KF-33	KF	Kitchen faucets	3	4/6/2019	8:14	< 1.00	P	< 1.00	P
19-CON-GF-WC-35	WC	Water fountain with cooler	Outside Restroom	4/6/2019	8:21	< 1.00	P	< 1.00	P
19-CON-GF-WC-36	WC	Water fountain with cooler	Outside Restroom	4/6/2019	8:22	< 1.00	P	< 1.00	P
19-CON-01-NF-43	NF	Nurse's office sink faucets	102B	4/6/2019	8:32	1.14	P	< 1.00	P
19-CON-01-CF-45	CF	Classroom faucets	X104	4/6/2019	8:41	3.95	P	< 1.00	P
19-CON-01-WC-46	WC	Water fountain with cooler	X104	4/6/2019	8:45	18.6	F	14.4	P
19-CON-01-WF-48	WF	Water fountain with filter & cooler	Outside Boys	4/6/2019	8:54	< 1.00	P	< 1.00	P
19-CON-01-WF-49	WF	Water fountain with filter & cooler	Outside Boys	4/6/2019	8:56	< 1.00	P	< 1.00	P
19-CON-01-CF-54	CF	Classroom faucets	X117	4/6/2019	9:04	< 1.00	P	< 1.00	P
19-CON-01-CF-55	CF	Classroom faucets	X117	4/6/2019	9:06	2.99	P	< 1.00	P
19-CON-01-CF-58	CF	Classroom faucets	X118	4/6/2019	9:15	8.33	P	< 1.00	P
19-CON-01-TF-60	TF	Teacher's lounge sinks	X119	4/6/2019	9:18	3.34	P	< 1.00	P
19-CON-01-CF-62	CF	Classroom faucets	X123	4/6/2019	9:26	< 1.00	P	< 1.00	P
19-CON-01-CF-63	CF	Classroom faucets	X123	4/6/2019	9:29	3.24	P	< 1.00	P
19-CON-01-CF-65	CF	Classroom faucets	X120	4/6/2019	9:41	< 1.00	P	< 1.00	P
19-CON-01-CF-68	CF	Classroom faucets	X122	4/6/2019	9:47	5.83	P	< 1.00	P
19-CON-01-CF-69	CF	Classroom faucets	X122	4/6/2019	9:49	4.87	P	< 1.00	P
19-CON-01-WC-70	WC	Water fountain with cooler	Outside Girls	4/6/2019	9:55	< 1.00	P	< 1.00	P
19-CON-01-WC-71	WC	Water fountain with cooler	Outside Girls	4/6/2019	9:55	< 1.00	P	< 1.00	P
19-CON-02-CF-85	CF	Classroom faucets		4/6/2019	10:20	8.83	P	1.38	P
19-CON-02-CF-86	CF	Classroom faucets		4/6/2019	10:25	5.43	P	1.35	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-CON-02-CF-87	CF	Classroom faucets		4/6/2019	10:26	2.52	P	1.41	P
19-CON-02-WC-88	WC	Water fountain with cooler	Outside Girls	4/6/2019	10:28	< 1.00	P	< 1.00	P
19-CON-02-WC-89	WC	Water fountain with cooler	Outside Girls	4/6/2019	10:28	< 1.00	P	< 1.00	P

Conroy

Lead in Drinking Water Sample Results

School: Pittsburgh Conroy

Address: 1398 Page St., Pittsburgh, PA 15233

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-CNY-GF-WM-00	WM	Water Main	14A	5/11/2019	6:05	14.0	P		
19-CNY-GF-SL-00	SL	Service Line	14A	5/11/2019	6:13	<1.00	P		
19-CNY-GF-OF-05	OF	Office sink faucets	20	5/11/2019	6:17	8.89	P	5.01	P
19-CNY-GF-WF-09	WF	Water fountain with filter and cooler	Corridor 10	5/11/2019	6:24	<1.00	P	<1.00	P
19-CNY-GF-WF-10	WF	Water fountain with filter and cooler	Corridor 10	5/11/2019	6:25	<1.00	P	<1.00	P
19-CNY-01-WO-21	WO	Water fountain without cooler	Corridor by auditorium	5/11/2019	6:32	5.36	P	<1.00	P
19-CNY-01-WO-22	WO	Water fountain without cooler	Corridor by auditorium	5/11/2019	6:33	5.80	P	<1.00	P
19-CNY-01-KF-23	KF	Kitchen faucets	122B	5/11/2019	6:36	3.48	P	<1.00	P
19-CNY-01-KF-32	KF	Kitchen faucets	108A	5/11/2019	6:37	<1.00	P	<1.00	P
19-CNY-01-NF-33	NF	Nurse's office sink faucets	105I	5/11/2019	6:49	3.27	P	<1.00	P
19-CNY-01-KF-36	KF	Kitchen faucets	108	5/11/2019	6:54	2.60	P	<1.00	P
19-CNY-01-KF-37	KF	Kitchen faucets	108	5/11/2019	6:56	3.50	P	<1.00	P
19-CNY-01-KF-38	KF	Kitchen faucets	108	5/11/2019	6:57	20.2	F	<1.00	P
19-CNY-01-KF-39	KF	Kitchen faucets	108	5/11/2019	6:58	3.66	P	<1.00	P
19-CNY-01-TF-40	TF	Teacher's faucet	102B	5/11/2019	7:03	<1.00	P	<1.00	P
19-CNY-01-KF-43	KF	Kitchen faucets	107A	5/11/2019	7:07	39.3	F	<1.00	P
19-CNY-01-KF-44	KF	Kitchen faucets	107A	5/11/2019	7:08	62.3	F	<1.00	P
19-CNY-01-KF-45	KF	Kitchen faucets	107A	5/11/2019	7:10	4.62	P	<1.00	P
19-CNY-01-WF-47	WF	Water fountain with filter and cooler	100C	5/11/2019	7:16	<1.00	P	<1.00	P
19-CNY-01-WF-48	WF	Water fountain with filter and cooler	100C	5/11/2019	7:17	<1.00	P	<1.00	P
19-CNY-02-WO-49	WO	Water fountain without cooler	200A	5/11/2019	7:24	2.95	P	<1.00	P
19-CNY-02-WO-50	WO	Water fountain without cooler	200A	5/11/2019	7:25	4.47	P	<1.00	P
19-CNY-01-WO-68	WO	Water fountain without cooler	Corridor by west stairs	5/11/2019	7:32	2.06	P	<1.00	P
19-CNY-01-WF-72	WF	Water fountain with filter and cooler	Corridor by east stairs	5/11/2019	7:36	<1.00	P	<1.00	P
19-CNY-01-CF-76	CF	Classroom faucets	101	5/11/2019	7:38	3.07	P	<1.00	P
19-CNY-02-WO-80	WO	Water fountain without cooler	200C (West)	5/11/2019	7:44	2.62	P	<1.00	P
19-CNY-02-WO-81	WO	Water fountain without cooler	200C (West)	5/11/2019	7:45	2.14	P	<1.00	P
19-CNY-02-WO-86	WO	Water fountain without cooler	200C (East)	5/11/2019	7:48	<1.00	P	<1.00	P
19-CNY-02-WO-87	WO	Water fountain without cooler	200C (East)	5/11/2019	7:49	<1.00	P	<1.00	P
19-CNY-03-WF-95	WF	Water fountain with filter and cooler	300C West	5/11/2019	7:55	<1.00	P	<1.00	P
19-CNY-03-WF-96	WF	Water fountain with filter and cooler	300C West	5/11/2019	7:56	<1.00	P	<1.00	P
19-CNY-03-CF-100	CF	Classroom faucets	307A	5/11/2019	7:58	3.64	P	<1.00	P
19-CNY-03-WO-104	WO	Water fountain without cooler	300C East	5/11/2019	8:04	5.14	P	2.14	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-CNY-03-WO-105	WO	Water fountain without cooler	300C East	5/11/2019	8:05	4.90	P	1.69	P
19-CNY-04-WF-111	WF	Water fountain with filter and cooler	400C West	5/11/2019	8:10	<1.00	P	<1.00	P
19-CNY-04-WF-112	WF	Water fountain with filter and cooler	400C West	5/11/2019	8:11	<1.00	P	<1.00	P
19-CNY-04-WO-115	WO	Water fountain without cooler	400C East	5/11/2019	8:14	8.23	P	1.64	P
19-CNY-04-WO-116	WO	Water fountain without cooler	400C East	5/11/2019	8:15	4.38	P	1.32	P

Dilworth PreK-5

Lead in Drinking Water Sample Results

School: Pittsburgh Dilworth Pre K-5

Address: 6200 Stanton Avenue, Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type/Comments	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw Pass/Fail (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)
19-DIL-BS-SL-00	SL	Service Line	11	4/6/2019	06:26	<1.00	P		
19-DIL-BS-WM-00	WM	Water Main	11	4/6/2019	06:26	<1.00	P		
19-DIL-BS-CF-01	CF	Classroom faucets	5	4/6/2019	06:21	1.77	P	<1.00	P
19-DIL-BS-WF-07	WF	New Water fountain with filter and cooler	Outside 2A	4/6/2019	06:27	<1.00	P	<1.00	P
19-DIL-BS-WF-08	WF	New Water fountain with filter and cooler	Outside 2A	4/6/2019	06:27	<1.00	P	<1.00	P
19-DIL-BS-MC-12	MC	Multi-Purpose Room/Cafeteria faucets	002	4/6/2019	06:30	<1.00	P	<1.00	P
19-DIL-BS-KF-14	KF	Kitchen faucets	002	4/6/2019	06:30	<1.00	P	<1.00	P
19-DIL-BS-WC-19	WC	Water fountain with cooler	Outside 16	4/6/2019	06:40	<1.00	P	<1.00	P
19-DIL-BS-WC-20	WC	Water fountain with cooler	Outside 16	4/6/2019	06:40	<1.00	P	<1.00	P
19-DIL-01-CF-28	CF	Classroom faucets	106-A	4/6/2019	07:03	<1.00	P	1.77	P
19-DIL-01-CF-29	CF	Classroom faucets	103-A	4/6/2019	07:03	5.01	P	2.65	P
19-DIL-01-WF-30	WF	New Water fountain with filter and cooler	Outside 102	4/6/2019	07:06	<1.00	P	<1.00	P
19-DIL-01-WF-31	WF	New Water fountain with filter and cooler	Outside 102	4/6/2019	07:06	<1.00	P	<1.00	P
19-DIL-01-NF-34	NF	Nurse's office sink faucets	115-A	4/6/2019	07:14	2.71	P	2.75	P
19-DIL-01-CF-36	CF	Classroom faucets	114-A	4/6/2019	07:16	16.1	F	1.74	P
19-DIL-01-CF-37	CF	Classroom faucets	114-A	4/6/2019	07:16	9.59	P	1.17	P
19-DIL-01-WC-38	WC	Water fountain with cooler	Outside 113	4/6/2019	07:21	7.18	P	13	P
19-DIL-01-WC-39	WC	Water fountain with cooler	Outside 113	4/6/2019	07:21	13.7	P	12.4	P
19-DIL-01-CF-48	CF	Classroom faucets	113-A	4/6/2019	07:25	3.79	P	<1.00	P
19-DIL-01-CF-49	CF	Classroom faucets	111-A	4/6/2019	07:28	9.91	P	<1.00	P
19-DIL-01-CF-50	CF	Classroom faucets	112	4/6/2019	07:30	2.63	P	1.15	P
19-DIL-02-CF-51	CF	Classroom faucets	206-A	4/6/2019	07:37	4.18	P	1.02	P
19-DIL-02-CF-52	CF	Classroom faucets	202	4/6/2019	07:40	20.3	F	1.03	P
19-DIL-02-WF-53	WF	New Water fountain with filter and cooler	Outside 201	4/6/2019	07:43	<1.00	P	<1.00	P
19-DIL-02-WF-54	WF	New Water fountain with filter and cooler	Outside 201	4/6/2019	07:44	<1.00	P	<1.00	P
19-DIL-02-TF-55	TF	Teacher's lounge sinks	215	4/6/2019	07:46	<1.00	P	1.32	P
19-DIL-02-CF-56	CF	Classroom faucets	214	4/6/2019	07:50	<1.00	P	1.55	P
19-DIL-02-CF-68	CF	Classroom faucets	212-A	4/6/2019	08:01	3.22	P	<1.00	P
19-DIL-02-WO-69	WO	Water fountain without cooler	212-A	4/6/2019	08:01	4.27	P	1.56	P
19-DIL-BS-CF-70	CF	Classroom faucets	16	4/7/2019	06:46	4.31	P	<1.00	P
19-DIL-02-CF-71	CF	Classroom faucets	214	4/8/2019	07:50	17.3	F	2.3	P

Fulton PreK-5

Lead in Drinking Water Sample Results

School: Pittsburgh Fulton Pre K-5

Address: 5799 Hampton Street Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-FUL-BS-SL-00	SL	Service Line (Brass Valve)	Crawlspace	5/18/2019	6:18	<1.00	P		
19-FUL-BS-WM-00	WM	Water Main	Crawlspace	5/18/2019	6:25	<1.00	P		
19-FUL-BS-CF-01	CF	Classroom faucets	7	5/18/2019	6:26	<1.00	P	<1.00	P
19-FUL-BS-WF-04	WF	Water fountain with filter & cooler	Outside 4	5/18/2019	6:29	<1.00	P	<1.00	P
19-FUL-BS-WF-05	WF	Water fountain with filter & cooler	Outside 4	5/18/2019	6:30	<1.00	P	<1.00	P
19-FUL-BS-CF-08	CF	Classroom faucets	1-A	5/18/2019	6:35	1.25	P	<1.00	P
19-FUL-01-WB-11	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 110	5/18/2019	6:41	2.03	P	<1.00	P
19-FUL-01-WO-12	WO	Water fountain without cooler	Outside 110	5/18/2019	6:43	<1.00	P	<1.00	P
19-FUL-01-WF-23	WF	Water fountain with filter & cooler	Outside 101	5/18/2019	6:47	<1.00	P	<1.00	P
19-FUL-01-WF-24	WF	Water fountain with filter & cooler	Outside 101	5/18/2019	6:48	<1.00	P	<1.00	P
19-FUL-01-TF-25	TF	Teacher's lounge sinks	102	5/18/2019	6:52	1.77	P	<1.00	P
19-FUL-02-NF-27	NF	Nurse's office sink faucets	214	5/18/2019	6:57	3.37	P	2.14	P
19-FUL-02-WB-28	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 211	5/18/2019	7:00	2.88	P	<1.00	P
19-FUL-02-WB-29	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 211	5/18/2019	7:02	<1.00	P	1.58	P
19-FUL-02-WF-38	WF	Water fountain with filter & cooler	Outside 201	5/18/2019	7:08	<1.00	P	<1.00	P
19-FUL-02-WF-39	WF	Water fountain with filter & cooler	Outside 201	5/18/2019	7:10	<1.00	P	<1.00	P
19-FUL-02-CF-40	CF	Classroom faucets	203	5/18/2019	7:12	7.75	P	<1.00	P
19-FUL-02-CF-41	CF	Classroom faucets	203	5/18/2019	7:13	<1.00	P	<1.00	P
19-FUL-02-CF-42	CF	Classroom faucets	203	5/18/2019	7:14	2.74	P	<1.00	P

Grandview K-5

Lead in Drinking Water Sample Results

School: Pittsburgh Grandview

Address: 845 McIn Street

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration	First Draw (fixture assembly)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing)
19-GRD-BS-WM-00	WM	Water Main	B-08	6/5/2019	5:08	<1.00	P		P
19-GRD-BS-SL-00	SL	Service Line	B-08	6/5/2019	5:11	<1.00	P		P
19-GRD-BS-KF-01	KF	Kitchen faucets	B-08	6/5/2019	5:13	<1.00	P	<1.00	P
19-GRD-BS-KF-02	KF	Kitchen faucets	B-08	6/5/2019	5:14	<1.00	P	<1.00	P
19-GRD-BS-KF-03	KF	Kitchen faucets	B-08	6/5/2019	5:12	5.41	P	<1.00	P
19-GRD-BS-WF-04	WF	Water fountain with filter and cooler	Basement Ramp	6/5/2019	5:15	<1.00	P	<1.00	P
19-GRD-BS-WF-05	WF	Water fountain with filter and cooler	Basement Ramp	6/5/2019	5:16	<1.00	P	<1.00	P
19-GRD-01-CF-16	CF	Classroom faucets	110	6/5/2019	5:26	18.2	F	4.06	P
19-GRD-01-WO-17	WO	Water fountain without cooler	110	6/5/2019	5:28	6.06	P	3.00	P
19-GRD-01-CF-18	CF	Classroom faucets	108	6/5/2019	5:25	8.11	P	1.28	P
19-GRD-01-WO-19	WO	Water fountain without cooler	108	6/5/2019	5:26	9.57	P	2.59	P
19-GRD-01-CF-20	CF	Classroom faucets	106	6/5/2019	5:32	274	F	3.75	P
19-GRD-01-WO-21	WO	Water fountain without cooler	106	6/5/2019	5:29	21.5	F	2.35	P
19-GRD-01-CF-24	CF	Classroom faucets	104	6/5/2019	5:33	5.14	P	1.31	P
19-GRD-01-CF-25	CF	Classroom faucets	104	6/5/2019	5:34	7.06	P	1.52	P
19-GRD-01-WB-26	WB	Water fountain bubbler (Ceramic or Porcelain)	Hall 111	6/5/2019	5:36	2.19	P	<1.00	P
19-GRD-01-WB-27	WB	Water fountain bubbler (Ceramic or Porcelain)	Hall 111	6/5/2019	5:36	1.08	P	<1.00	P
19-GRD-01-TF-32	TF	Teacher's lounge sinks	106	6/5/2019	5:44	9.91	P	2.31	P
19-GRD-01-CF-35	CF	Classroom faucets	103	6/5/2019	5:40	7.99	P	1.00	P
19-GRD-01-WB-36	WB	Water fountain bubbler (Ceramic or Porcelain)	103	6/5/2019	5:41	1.92	P	<1.00	P
19-GRD-01-WF-40	WF	Water fountain with filter and cooler	Corridor 124	6/5/2019	5:41	<1.00	P	<1.00	P
19-GRD-01-WF-41	WF	Water fountain with filter and cooler	Corridor 124	6/5/2019	5:43	<1.00	P	<1.00	P
19-GRD-01-CF-42	CF	Classroom faucets	105	6/5/2019	5:48	6.44	P	1.12	P
19-GRD-01-CF-43	CF	Classroom faucets	107B	6/5/2019	5:48	6.75	P	1.83	P
19-GRD-01-WB-45	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor 124	6/5/2019	5:50	2.47	P	<1.00	P
19-GRD-01-WB-46	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor 124	6/5/2019	5:51	1.22	P	<1.00	P
19-GRD-01-CF-50	CF	Classroom faucets	111	6/5/2019	5:52	14.3	P	2.83	P
19-GRD-02-CF-52	CF	Classroom faucets	218	6/5/2019	6:00	15.7	F	1.71	P
19-GRD-02-TF-54	TF	Teacher's lounge sinks	216	6/5/2019	5:59	4.00	P	<1.00	P
19-GRD-02-WB-58	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor 201	6/5/2019	6:02	3.41	P	1.22	P
19-GRD-02-WB-59	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor 201	6/5/2019	6:04	1.56	P	1.02	P
19-GRD-02-CF-60	CF	Classroom faucets	217	6/5/2019	6:06	7.93	P	1.47	P
19-GRD-02-WO-61	WO	Water fountain without cooler	217	6/5/2019	6:07	3.40	P	1.69	P
19-GRD-02-WF-62	WF	Water fountain with filter and cooler	Corridor 201	6/5/2019	6:10	<1.00	P	<1.00	P
19-GRD-02-WF-63	WF	Water fountain with filter and cooler	Corridor 201	6/5/2019	6:12	<1.00	P	<1.00	P
19-GRD-02-CF-67	CF	Classroom faucets	219	6/5/2019	6:10	289	F	3.04	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration	First Draw (fixture assembly)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing)
19-GRD-02-WO-68	WO	Water fountain without cooler	219	6/5/2019	6:11	6.92	P	1.96	P
19-GRD-BS-CF-70	CF	Classroom faucets	D-02	6/5/2019	6:24	3.08	P	<1.00	P
19-GRD-BS-WO-71	WO	Water fountain without cooler	D-02	6/5/2019	6:25	3.00	P	<1.00	P
19-GRD-BS-CF-73	CF	Classroom faucets	D-01	6/5/2019	6:23	3.53	P	<1.00	P

Greenway (Classical-Gifted Center)

Lead in Drinking Water Sample Results

School: Greenway Classical-Gifted Center

Address: 1400 Crucible Street Pittsburgh, PA 15205

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing)
19-GNW-2.6-WM-00	WM	Water Main	2-606	6/8/2019	6:28	< 1.00	P		
19-GNW-2.6-SL-00	SL	Service Line	2-606	6/8/2019	6:31	< 1.00	P		
19-GNW-2.6-WC-10	WC	Water fountain without cooler	2.601	6/8/2019	6:32	< 1.00	P	< 1.00	P
19-GNW-3.6-WF-13	WF	'Water fountain with filter and cooler	3.631	6/8/2019	6:34	< 1.00	P	< 1.00	P
19-GNW-3.6-WF-14	WF	'Water fountain with filter and cooler	3.631	6/8/2019	6:35	< 1.00	P	< 1.00	P
19-GNW-3.6-NF-20	NF	Nurse's office sink faucets	3.627	6/8/2019	6:37	< 1.00	P	< 1.00	P
19-GNW-3.6-WB-21	WB	Water fountain bubbler (Ceramic or Porcelain)	3.603	6/8/2019	6:43	9.75	P	3.39	P
19-GNW-3.6-WB-23	WB	Water fountain bubbler (Ceramic or Porcelain)	3.06	6/8/2019	6:45	< 1.00	P	< 1.00	P
19-GNW-3.5-WC-36	WC	Water fountain with cooler	3.519	6/8/2019	6:51	< 1.00	P	< 1.00	P
19-GNW-2.4-CF-42	CF	Classroom faucets	2.489	6/8/2019	6:56	1.40	P	<1.00	P
19-GNW-2.4-CF-52	CF	Classroom faucets	2.465	6/8/2019	7:00	2.80	P	<1.00	P
19-GNW-2.4-CF-53	CF	Classroom faucets	2.464	6/8/2019	7:00	7.35	P	1.60	P
19-GNW-2.4-WO-54	WO	Water fountain without cooler	2.415	6/8/2019	7:03	< 1.00	P	< 1.00	P
19-GNW-2.4-CF-55	CF	Classroom faucets	2.463	6/8/2019	7:06	4.17	P	< 1.00	P
19-GNW-2.4-WO-56	WO	Water fountain without cooler	Outside 2.435	6/8/2019	7:06	1.31	P	< 1.00	P
19-GNW-2.4-WF-57	WF	Water fountain with filter and cooler	2.401	6/8/2019	7:11	< 1.00	P	< 1.00	P
19-GNW-2.4-WC-67	WC	Water fountain with cooler	2.410	6/8/2019	7:11	< 1.00	P	< 1.00	P
19-GNW-2.4-WC-68	WC	Water fountain with cooler	2.410	6/8/2019	7:12	3.05	P	< 1.00	P
19-GNW-2.4-KF-71	KF	Kitchen faucets	Cafeteria	6/8/2019	7:18	< 1.00	P	< 1.00	P
19-GNW-2.4-KF-72	KF	Kitchen faucets	Cafeteria	6/8/2019	7:19	< 1.00	P	< 1.00	P
19-GNW-2.4-KF-73	KF	Kitchen faucets	Cafeteria	6/8/2019	7:20	2.34	P	< 1.00	P
19-GNW-2.4-CF-74	CF	Classroom faucets	2.472	6/8/2019	7:27	1.85	P	< 1.00	P
19-GNW-2.4-CF-75	CF	Classroom faucets	2.473	6/8/2019	7:29	1.11	P	< 1.00	P
19-GNW-2.4-WO-76	WO	Water fountain without cooler	2.417	6/8/2019	7:28	< 1.00	P	< 1.00	P
19-GNW-2.4-HF-77	HF	Home economics faucets (with cooking)	2.417	6/8/2019	7:30	5.12	P	< 1.00	P
19-GNW-2.4-HF-78	HF	Home economics faucets (with cooking)	2.417	6/8/2019	7:32	4.67	P	< 1.00	P
19-GNW-2.4-HF-79	HF	Home economics faucets (with cooking)	2.417	6/8/2019	7:33	5.07	P	< 1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing)
19-GNW-2.4-HF-80	HF	Home economics faucets (with cooking)	2.417	6/8/2019	7:34	3.83	P	< 1.00	P
19-GNW-2.4-CF-81	CF	Classroom faucets	2.469	6/8/2019	7:26	< 1.00	P	< 1.00	P
19-GNW-2.4-CF-82	CF	Classroom faucets	2.469	6/8/2019	7:27	2.68	P	< 1.00	P
19-GNW-2.4-WO-83	WO	Water fountain without cooler	2.418	6/8/2019	7:35	< 1.00	P	< 1.00	P
19-GNW-2.4-CF-84	CF	Classroom faucets	2.468	6/8/2019	7:38	1.47	P	< 1.00	P
19-GNW-2.4-CF-85	CF	Classroom faucets	2.468	6/8/2019	7:40	< 1.00	P	< 1.00	P
19-GNW-2.4-CF-86	CF	Classroom faucets	2.467	6/8/2019	7:39	349	F	< 1.00	P
19-GNW-2.4-CF-87	CF	Classroom faucets	2.467	6/8/2019	7:41	2.11	P	< 1.00	P
19-GNW-2.3-TF-88	TF	Teacher's lounge sinks	2.389	6/8/2019	7:49	< 1.00	P	< 1.00	P
19-GNW-2.3-WO-98	WO	Water fountain without cooler	Corridor by 2.367	6/8/2019	7:55	1.22	P	< 1.00	P
19-GNW-2.3-TF-105	TF	Teacher's lounge sinks	2.343	6/8/2019	8:00	3.00	P	< 1.00	P
19-GNW-2.3-WF-117	WF	Water fountain with filter and cooler	2.301	6/8/2019	7:28	< 1.00	P	< 1.00	P
19-GNW-2.3-WB-118	WB	Water fountain bubbler (Ceramic or Porcelain)	2.320	6/8/2019	8:03	< 1.00	P	< 1.00	P
19-GNW-2.1-WF-134	WF	Water fountain with filter and cooler	2.101	6/8/2019	8:40	< 1.00	P	< 1.00	P
19-GNW-1.1-MS-140	MS	Miscellaneous sinks	1.119	6/8/2019	8:16	4.25	P	1.28	P
19-GNW-1.1-WC-142	WC	Water fountain with cooler	1.106	6/8/2019	8:16	< 1.00	P	< 1.00	P
19-GNW-1.1-WC-143	WC	Water fountain with cooler	1.105	6/8/2019	8:19	< 1.00	P	< 1.00	P
19-GNW-1.1-WC-144	WC	Water fountain with cooler	1.151	6/8/2019	8:21	< 1.00	P	< 1.00	P
19-GNW-2.2-WF-156	WF	Water fountain with filter and cooler	2.201	6/8/2019	8:33	< 1.00	P	< 1.00	P
19-GNW-1.2-OF-157	OF	Office sink faucets	1.221	6/8/2019	8:36	< 1.00	P	< 1.00	P
19-GNW-1.2-MS-161	MS	Miscellaneous sinks	1.213	6/8/2019	8:38	< 1.00	P	< 1.00	P
19-GNW-1.1-KF-162	KF	Kitchen faucets	1.113	6/8/2019	8:40	< 1.00	P	< 1.00	P
19-GNW-1.1-KF-164	KF	Kitchen faucets	1.113	6/8/2019	8:42	< 1.00	P	< 1.00	P
19-GNW-1.1-KF-165	KF	Kitchen faucets	1.113	6/8/2019	8:44	< 1.00	P	< 1.00	P
19-GNW-2.1-WO-169	WO	Water fountain without cooler	2.120	6/8/2019	8:49	< 1.00	P	< 1.00	P
19-GNW-2.1-WO-170	WO	Water fountain without cooler	Outside 2.173	6/8/2019	8:51	< 1.00	P	< 1.00	P
19-GNW-2.1-TF-176	TF	Teacher's lounge sinks	2.188	6/8/2019	8:53	< 1.00	P	< 1.00	P
19-GNW-2.1-CF-186	CF	Classroom faucets	2.170	6/8/2019	8:55	1.08	P	< 1.00	P
19-GNW-2.1-WO-188	WO	Water fountain without cooler	2.114	6/8/2019	8:57	1.56	P	< 1.00	P
19-GNW-2.1-CF-189	CF	Classroom faucets	2.163	6/8/2019	8:59	< 1.00	P	< 1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing)
19-GNW-2.2-WO-190	WO	Water fountain without cooler	2.220	6/8/2019	9:04	< 1.00	P	< 1.00	P
19-GNW-2.2-WO-191	WO	Water fountain without cooler	near 2.218	6/8/2019	9:07	< 1.00	P	< 1.00	P
19-GNW-2.2-TF-192	TF	Teacher's lounge sinks	2.289	6/8/2019	9:14	< 1.00	P	< 1.00	P
19-GNW-2.2-CF-202	CF	Classroom faucets	2.268	6/8/2019	9:16	11.3	P	< 1.00	P
19-GNW-2.2-MS-204	MS	Miscellaneous sinks	Outside 2.226	6/8/2019	9:10	11.9	P	<1.00	P
19-GNW-2.1-WF-215	WF	Water fountain with filter and cooler	2.101	6/8/2019	8:41	< 1.00	P	< 1.00	P
19-GNW-2.2-WF-216	WF	Water fountain with filter and cooler	2.201	6/8/2019	8:34	< 1.00	P	< 1.00	P
19-GNW-1.2-WC-217	WC	Water fountain with cooler	1.204	6/8/2019	9:09	< 1.00	P	< 1.00	P
19-GNW-2.3-WF-221	WF	Water fountain with filter and cooler	2.301	6/8/2019	8:00	< 1.00	P	< 1.00	P
19-GNW-2.2-WF-222	WF	Water fountain with filter and cooler	2.401	6/8/2019	7:12	< 1.00	P	< 1.00	P

Langley Field House

Lead in Drinking Water Sample Results

School: Langley Field House

Address:

Pittsburgh, PA 15205

Fixture ID	Fixture Symbol	Fixture Type	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing)
19-LFH-GF-WM-00	WM	Water Main	7/8//2019	6:53	1.81	P		
19-LFH-GF-SL-00	SL	Service Line	7/8/2019	6:43	6.26	P		
19-LFH-GF-WF-01	WF	Water fountain with filter & cooler	7/8/2019	6:54	<1.00	P	<1.00	P
19-LFH-01-WM-00	WM	Water Main	7/8/2019	7:15	1.13	P		
19-LFH-01-SL-00	SL	Service Line	7/8/2019	7:05	<1.00	P		
19-LFH-02-WO-04	WO	'Water fountain without cooler	7/8/2019	7:16	4.33	P	2.12	P
19-LFH-02-IM-12	IM	Ice Machine	7/8/2019	7:19	<1.00	P		
19-LFH-02-WO-14	WO	'Water fountain without cooler	7/8/2019	7:21	10.2	P	5.43	P

Liberty K-5

Lead in Drinking Water Sample Results

School: Pittsburgh Liberty K-5

Address: 601 Filbert St. 15232

Fixture ID	Fixture Symbol	Fixture Type	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
19-LIB-BS-WM-00	WM	Water Main	6/5/2019	06:04	<1.00	P		
19-LIB-BS-SL-00	SL	Service Line	6/5/2019	06:04	<1.00	P		
19-LIB-BS-OF-01	OF	Office sink faucets	6/5/2019	05:59	<1.00	P	<1.00	P
19-LIB-GF-CF-02	CF	Classroom faucets	6/5/2019	06:08	1.50	P	<1.00	P
19-LIB-GF-CF-03	CF	Classroom faucets	6/5/2019	06:10	3.34	P	1.12	P
19-LIB-GF-CF-04	CF	Classroom faucets	6/5/2019	06:15	5.99	P	<1.00	P
19-LIB-GF-WF-13	WF	Water fountain with filter & cooler	6/5/2019	06:17	<1.00	P	<1.00	P
19-LIB-GF-WF-14	WF	Water fountain with filter & cooler	6/5/2019	06:18	<1.00	P	<1.00	P
19-LIB-GF-KF-19	KF	Kitchen faucets	6/5/2019	06:27	1.17	P	1.24	P
19-LIB-GF-CF-20	CF	Classroom faucets	6/5/2019	06:30	<1.00	P	<1.00	P
19-LIB-GF-WO-21	WO	Water fountain without cooler	6/5/2019	06:30	<1.00	P	<1.00	P
19-LIB-GF-OF-22	OF	Office sink faucets	6/5/2019	06:33	<1.00	P	<1.00	P
19-LIB-GF-CF-24	CF	Classroom faucets	6/5/2019	06:38	<1.00	P	<1.00	P
19-LIB-GF-WO-25	WO	Water fountain without cooler	6/5/2019	06:38	<1.00	P	<1.00	P
19-LIB-01-CF-28	CF	Classroom faucets	6/5/2019	06:49	3.20	P	<1.00	P
19-LIB-01-CF-29	CF	Classroom faucets	6/5/2019	06:54	15.3	F	1.88	P
19-LIB-01-CF-30	CF	Classroom faucets	6/5/2019	06:56	12.1	P	1.94	P
19-LIB-01-OF-31	OF	Office sink faucets	6/5/2019	06:53	1.13	P	<1.00	P
19-LIB-01-WF-40	WF	Water fountain with filter & cooler	6/5/2019	06:58	<1.00	P	<1.00	P
19-LIB-01-WF-41	WF	Water fountain with filter & cooler	6/5/2019	07:00	<1.00	P	<1.00	P
19-LIB-01-CF-43	CF	Classroom faucets	6/5/2019	07:00	<1.00	P	<1.00	P
19-LIB-01-CF-44	CF	Classroom faucets	6/5/2019	07:03	<1.00	P	<1.00	P
19-LIB-01-WO-45	WO	Water fountain without cooler	6/5/2019	07:03	<1.00	P	<1.00	P
19-LIB-01-CF-47	CF	Classroom faucets	6/5/2019	07:05	<1.00	P	<1.00	P
19-LIB-01-WO-48	WO	Water fountain without cooler	6/5/2019	07:07	<1.00	P	<1.00	P
19-LIB-01-NF-49	NF	Nurse's office sink faucets	6/5/2019	07:08	<1.00	P	<1.00	P
19-LIB-01-OF-51	OF	Office sink faucets	6/5/2019	07:09	<1.00	P	<1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
19-LIB-02-CF-52	CF	Classroom faucets	6/5/2019	07:16	4.27	P	1.33	P
19-LIB-02-TF-53	TF	Teacher's lounge sinks	6/5/2019	07:17	<1.00	P	<1.00	P
19-LIB-02-WF-63	WF	Water fountain with filter & cooler	6/5/2019	07:20	<1.00	P	<1.00	P
19-LIB-02-WF-64	WF	Water fountain with filter & cooler	6/5/2019	07:20	<1.00	P	<1.00	P
19-LIB-02-WO-70	WO	Water fountain without cooler	6/5/2019	07:21	<1.00	P	<1.00	P
19-LIB-02-CF-71	CF	Classroom faucets	6/5/2019	07:24	<1.00	P	<1.00	P

Mifflin PreK-8

Lead in Drinking Water Sample Results

School: Pittsburgh Mifflin Pre K-8

Address: 1290 Mifflin Road, Pittsburgh, PA , 15207

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-MIF-GF-WM-00	WM	Water Main	23D	5/18/2019	07:14	< 1.00	P		
19-MIF-GF-SL-00	SL	Service Line	23D	5/18/2019	07:04	< 1.00	P		
19-MIF-GF-WF-07	WF	Water fountain with filter & cooler	1st Floor Corridor	5/18/2019	07:16	< 1.00	P	< 1.00	P
19-MIF-GF-WF-08	WF	Water fountain with filter & cooler	1st Floor Corridor	5/18/2019	07:18	< 1.00	P	< 1.00	P
19-MIF-GF-KF-09	KF	Kitchen faucets	22A	5/18/2019	07:19	< 1.00	P	< 1.00	P
19-MIF-GF-KF-10	KF	Kitchen faucets	22A	5/18/2019	07:20	< 1.00	P	< 1.00	P
19-MIF-GF-CF-14	CF	Classroom faucets	35	5/18/2019	07:39	3.56	P	< 1.00	P
19-MIF-GF-WC-15	WC	Water fountain with cooler	1st Floor Corridor	5/18/2019	07:43	< 1.00	P	< 1.00	P
19-MIF-GF-WC-16	WC	Water fountain with cooler	1st Floor Corridor	5/18/2019	07:45	< 1.00	P	< 1.00	P
19-MIF-01-WF-27	WF	Water fountain with filter & cooler	125	5/18/2019	07:52	< 1.00	P	< 1.00	P
19-MIF-01-WF-28	WF	Water fountain with filter & cooler	125	5/18/2019	07:54	< 1.00	P	< 1.00	P
19-MIF-01-CF-29	CF	Classroom faucets	127	5/18/2019	08:01	3.82	P	< 1.00	P
19-MIF-01-CF-30	CF	Classroom faucets	121	5/18/2019	08:06	1.09	P	< 1.00	P
19-MIF-01-CF-31	CF	Classroom faucets	120	5/18/2019	08:09	1.40	P	< 1.00	P
19-MIF-01-CF-32	CF	Classroom faucets	128	5/18/2019	08:15	2.70	P	< 1.00	P
19-MIF-01-CF-33	CF	Classroom faucets	119	5/18/2019	08:18	1.95	P	< 1.00	P
19-MIF-01-CF-34	CF	Classroom faucets	129	5/18/2019	08:21	3.73	P	< 1.00	P
19-MIF-01-WC-41	WC	Water fountain with cooler	1st Floor Corridor	5/18/2019	08:29	< 1.00	P	< 1.00	P
19-MIF-01-WC-42	WC	Water fountain with cooler	1st Floor Corridor	5/18/2019	08:30	< 1.00	P	< 1.00	P
19-MIF-01-CF-43	CF	Classroom faucets	133	5/18/2019	08:37	< 1.00	P	< 1.00	P
19-MIF-01-CF-44	CF	Classroom faucets	133	5/18/2019	08:40	< 1.00	P	< 1.00	P
19-MIF-01-CF-45	CF	Classroom faucets	133	5/18/2019	Non-Functional				
19-MIF-01-NF-47	NF	Nurse's office sink faucets	116	5/18/2019	08:48	< 1.00	P	< 1.00	P
19-MIF-01-CF-51	CF	Classroom faucets	106	5/18/2019	08:54	6.34	P	< 1.00	P
19-MIF-01-WF-52	WF	Water fountain with filter & cooler	1st Floor Corridor	5/18/2019	09:00	< 1.00	P	< 1.00	P
19-MIF-01-WF-53	WF	Water fountain with filter & cooler	1st Floor Corridor	5/18/2019	09:02	< 1.00	P	< 1.00	P
19-MIF-01-TF-54	TF	Teacher's lounge sinks	109	5/18/2019	09:06	2.95	P	2.61	P
19-MIF-01-WC-56	WC	Water fountain with cooler	1st Floor Corridor	5/18/2019	09:10	3.43	P	1.81	P
19-MIF-01-WC-57	WC	Water fountain with cooler	1st Floor Corridor	5/18/2019	09:12	1.62	P	<1.00	P
19-MIF-02-WF-65	WF	Water fountain with filter & cooler	2nd Floor Corridor	5/18/2019	Non-Functional				

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-MIF-02-WF-66	WF	Water fountain with filter & cooler	2nd Floor Corridor	5/18/2019	Non-Functional				
19-MIF-02-CF-67	CF	Classroom faucets	205	5/18/2019	09:26	2.37	P	< 1.00	P
19-MIF-02-WC-68	WC	Water fountain with cooler	2nd Floor Corridor	5/18/2019	09:30	< 1.00	P	< 1.00	P
19-MIF-02-WC-69	WC	Water fountain with cooler	2nd Floor Corridor	5/18/2019	09:32	< 1.00	P	< 1.00	P
19-MIF-02-CF-74	CF	Classroom faucets	201	5/18/2019	09:40	11.6	P	< 1.00	P
19-MIF-03-WF-76	WF	Water fountain with filter & cooler	3rd Floor Corridor	5/18/2019	09:45	< 1.00	P	< 1.00	P
19-MIF-03-WF-77	WF	Water fountain with filter & cooler	3rd Floor Corridor	5/18/2019	09:47	< 1.00	P	< 1.00	P
19-MIF-03-WC-82	WC	Water fountain with cooler	3rd Floor Corridor	5/18/2019	09:52	2.80	P	1.57	P
19-MIF-03-WC-83	WC	Water fountain with cooler	3rd Floor Corridor	5/18/2019	09:54	1.32	P	< 1.00	P
19-MIF-03-CF-87	CF	Classroom faucets	301	5/18/2019	09:59	11.4	P	5.81	P
19-MIF-01-WC-88	WC	Water fountain with cooler	101B	5/18/2019	09:15	2.97	P	<1.00	P

Minadeo PreK-5

Lead in Drinking Water Sample Results

School: Pittsburgh Minadeo Pre K-5

Address: 6502 Lilac Street, Pittsburgh, PA 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-MIN-BS-SL-00	SL	Service Line	Under 002	4/18/2019	06:20	<1.00	P		
19-MIN-BS-WM-00	WM	Water Main	Under 002	4/18/2019	06:26	<1.00	P		
19-MIN-GF-CF-01	CF	Classroom faucets	002	4/18/2019	06:27	<1.00	P	9.76	P
19-MIN-GF-CF-02	CF	Classroom faucets	005	4/18/2019	06:32	1.41	P	1.38	P
19-MIN-GF-CF-03	CF	Classroom faucets	003	4/18/2019	06:33	6.50	P	<1.00	P
19-MIN-GF-CF-04	CF	Classroom faucets	006	4/18/2019	06:41	2.81	P	<1.00	P
19-MIN-GF-CF-08	CF	Classroom faucets	004	4/18/2019	06:43	5.77	P	<1.00	P
19-MIN-GF-WF-09	WF	Water fountain with filter & cooler	Outside 004	4/18/2019	06:50	<1.00	P	<1.00	P
19-MIN-GF-WF-10	WF	Water fountain with filter & cooler	Outside 004	4/18/2019	06:51	<1.00	P	<1.00	P
19-MIN-GF-TF-12	TF	Teacher's lounge sinks	032	4/18/2019	06:53	16.0	F	<1.00	P
19-MIN-GF-OF-15	OF	Office sink faucets	018	4/18/2019	06:57	1.89	P	1.06	P
19-MIN-GF-CF-19	CF	Classroom faucets	035	4/18/2019	07:03	6.42	P	1.04	P
19-MIN-GF-CF-20	CF	Classroom faucets	022	4/18/2019	07:05	2.13	P	<1.00	P
19-MIN-GF-CF-22	CF	Classroom faucets	023	4/18/2019	07:04	1.14	P	<1.00	P
19-MIN-GF-CF-23	CF	Classroom faucets	039	4/18/2019	07:10	8.61	P	1.09	P
19-MIN-GF-WF-24	WF	Water fountain with filter & cooler	Outside 023	4/18/2019	07:11	<1.00	P	<1.00	P
19-MIN-GF-WF-25	WF	Water fountain with filter & cooler	Outside 023	4/18/2019	07:12	<1.00	P	<1.00	P
19-MIN-GF-CF-26	CF	Classroom faucets	024	4/18/2019	07:13	3.74	P	<1.00	P
19-MIN-GF-CF-28	CF	Classroom faucets	025	4/18/2019	07:18	1.42	P	1.62	P
19-MIN-GF-CF-30	CF	Classroom faucets	027	4/18/2019	07:20	36.3	F	1.10	P
19-MIN-GF-CF-35	CF	Classroom faucets	031	4/18/2019	07:27	1.30	P	<1.00	P
19-MIN-GF-WF-37	WF	Water fountain with filter & cooler	Outside Cafeteria	4/18/2019	07:29	<1.00	P	<1.00	P
19-MIN-GF-WF-38	WF	Water fountain with filter & cooler	Outside Cafeteria	4/18/2019	07:30	<1.00	P	<1.00	P
19-MIN-GF-KF-39	KF	Kitchen faucets	045	4/18/2019	07:35	<1.00	P	<1.00	P
19-MIN-GF-KF-40	KF	Kitchen faucets	045	4/18/2019	07:36	<1.00	P	<1.00	P
19-MIN-GF-KF-41	KF	Kitchen faucets	045	4/18/2019	07:44	1.26	P	<1.00	P
19-MIN-02-CF-43	CF	Classroom faucets	102	4/18/2019	08:07	1.46	P	<1.00	P
19-MIN-02-CF-44	CF	Classroom faucets	104	4/18/2019	08:09	5.77	P	<1.00	P
19-MIN-02-CF-45	CF	Classroom faucets	103	4/18/2019	08:08	14.1	P	<1.00	P
19-MIN-02-CF-46	CF	Classroom faucets	105	4/18/2019	08:09	11.0	P	<1.00	P
19-MIN-02-WF-52	WF	Water fountain with filter & cooler	101	4/18/2019	08:14	<1.00	P	<1.00	P
19-MIN-02-WF-53	WF	Water fountain with filter & cooler	101	4/18/2019	08:15	<1.00	P	<1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-MIN-02-HF-59	HF	Home economics faucets (with cooking)	129	4/18/2019	08:14	20.1	F	1.07	P
19-MIN-02-CF-60	CF	Classroom faucets	128	4/18/2019	08:17	11.2	P	1.23	P
19-MIN-02-CF-62	CF	Classroom faucets	119	4/18/2019	08:27	1.08	P	<1.00	P
19-MIN-02-CF-63	CF	Classroom faucets	119	4/18/2019	08:29	<1.00	P	<1.00	P
19-MIN-02-CF-65	CF	Classroom faucets	119	4/18/2019	08:31	<1.00	P	<1.00	P
19-MIN-02-CF-66	CF	Classroom faucets	127	4/18/2019	08:27	6.83	P	<1.00	P
19-MIN-02-CF-67	CF	Classroom faucets	126	4/18/2019	08:28	5.33	P	<1.00	P
19-MIN-02-CF-68	CF	Classroom faucets	120	4/18/2019	08:35	2.82	P	<1.00	P
19-MIN-02-CF-69	CF	Classroom faucets	125	4/18/2019	08:36	10.3	P	1.45	P
19-MIN-02-WF-70	WF	Water fountain with filter & cooler	Outside 120	4/18/2019	08:42	<1.00	P	<1.00	P
19-MIN-02-WF-71	WF	Water fountain with filter & cooler	Outside 120	4/18/2019	08:43	<1.00	P	<1.00	P
19-MIN-02-CF-72	CF	Classroom faucets	121	4/18/2019	08:43	20.2	F	<1.00	P
19-MIN-02-CF-73	CF	Classroom faucets	124	4/18/2019	08:44	13.0	P	<1.00	P
19-MIN-02-CF-74	CF	Classroom faucets	123	4/18/2019	08:51	7.65	P	<1.00	P
19-MIN-02-CF-76	CF	Classroom faucets	135	4/18/2019	08:55	4.03	P	<1.00	P
19-MIN-02-OF-78	OF	Office sink faucets	140	4/18/2019	08:53	12.7	P	1.87	P
19-MIN-02-WF-80	WF	Water fountain with filter & cooler	Outside 149	4/18/2019	09:02	<1.00	P	<1.00	P
19-MIN-02-WF-81	WF	Water fountain with filter & cooler	Outside 149	4/18/2019	09:03	<1.00	P	<1.00	P
19-MIN-02-CF-92	CF	Classroom faucets	169	4/18/2019	09:02	3.33	P	<1.00	P
19-MIN-02-WO-93	WO	Water fountain without cooler	Outside 165	4/18/2019	09:12	<1.00	P	<1.00	P
19-MIN-02-WO-94	WO	Water fountain without cooler	Outside 165	4/18/2019	09:12	<1.00	P	<1.00	P

Obama 6-12, Early Childhood Center

Lead in Drinking Water Sample Results

School: Pittsburgh Obama

Address: 515 North Highland Ave, Pittsburgh, PA, 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-OBA-GF-WM-00	WM	Water Main	31	3/30/2019	6:17	<1.00	P		
19-OBA-GF-SL-00	SL	Service Line	31	3/30/2019	6:17	<1.00	p		
19-OBA-GF-WC-03	WC	Water fountain with cooler	020A	3/30/2019	6:21	< 1.00	P	< 1.00	P
19-OBA-GF-WC-04	WC	Water fountain with cooler	020A	3/30/2019	6:21	< 1.00	P	< 1.00	P
19-OBA-GF-CF-07	CF	Classroom faucets	023	3/30/2019	6:28	3.26	P	< 1.00	P
19-OBA-GF-CF-08	CF	Classroom faucets	023	3/30/2019	6:30	1.68	P	< 1.00	P
19-OBA-GF-WC-09	WC	Water fountain with cooler	023	3/30/2019	6:32	< 1.00	P	< 1.00	P
19-OBA-GF-CF-10	CF	Classroom faucets	017	3/30/2019	6:34	4.89	P	2.19	P
19-OBA-GF-CF-11	CF	Classroom faucets	017	3/30/2019	6:34	7.55	P	12.3	P
19-OBA-GF-WC-12	WC	Water fountain with cooler	017	3/30/2019	6:35	< 1.00	P	< 1.00	P
19-OBA-GF-CF-14	CF	Classroom faucets	011	3/30/2019	6:41	< 1.00	P	< 1.00	P
19-OBA-GF-WC-17	WC	Water fountain with cooler	03	3/30/2019	6:45	< 1.00	P	< 1.00	P
19-OBA-GF-WC-18	WC	Water fountain with cooler	03	3/30/2019	6:47	< 1.00	P	< 1.00	P
19-OBA-GF-CF-28	CF	Classroom faucets	020	3/30/2019	6:41	2.64	P	< 1.00	P
19-OBA-GF-CF-30	CF	Classroom faucets	030	3/30/2019	6:48	3.39	P	< 1.00	P
19-OBA-GF-CF-31	CF	Classroom faucets	030	3/30/2019	6:48	3.22	P	< 1.00	P
19-OBA-GF-CF-32	CF	Classroom faucets	030	3/30/2019	6:49	3.95	P	2.4	P
19-OBA-GF-CF-33	CF	Classroom faucets	030	3/30/2019	6:50	3.79	P	< 1.00	P
19-OBA-GF-WO-38	WO	Water fountain without cooler	Hallway	3/30/2019	7:01	1.69	P	< 1.00	P
19-OBA-GF-WB-41	WB	Water fountain bubbler (Ceramic or Porcelain)	Hallway	3/30/2019	7:03	< 1.00	P	< 1.00	P
19-OBA-GF-WB-46	WB	Water fountain bubbler (Ceramic or Porcelain)	Hallway	3/30/2019	7:06	< 1.00	P	< 1.00	P
19-OBA-01-OF-51	OF	Office sink faucets	101A	3/30/2019	7:16	7	P	< 1.00	P
19-OBA-01-CF-54	CF	Classroom faucets	102	3/30/2019	7:17	4.9	P	1.51	P
19-OBA-01-CF-55	CF	Classroom faucets	106	3/30/2019	7:21	10.5	P	< 1.00	P
19-OBA-01-CF-56	CF	Classroom faucets	108	3/30/2019	7:24	8.73	P	< 1.00	P
19-OBA-01-CF-57	CF	Classroom faucets	124	3/30/2019	7:25	2.52	P	< 1.00	P
19-OBA-01-CF-57.5	CF	Classroom faucets	124	3/30/2019	7:27	7.99	P	< 1.00	P
19-OBA-01-OF-58	OF	Office sink faucets	125	3/30/2019	7:30	3.56	P	< 1.00	P
19-OBA-01-HF-62	HF	Home economics faucets (with cooking)	147	3/30/2019	7:35	6.87	P	9.47	P
19-OBA-01-HF-63	HF	Home economics faucets (with cooking)	147	3/30/2019	7:35	4.43	P	1.44	P
19-OBA-01-HF-64	HF	Home economics faucets (with cooking)	147	3/30/2019	7:39	8.77	P	2.33	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-OBA-01-HF-65	HF	Home economics faucets (with cooking)	147	3/30/2019	7:36	3.81	P	2.8	P
19-OBA-01-HF-66	HF	Home economics faucets (with cooking)	147	3/30/2019	7:36	7.17	P	2.85	P
19-OBA-01-CF-67	CF	Classroom faucets	151	3/30/2019	7:46	< 1.00	P	< 1.00	P
19-OBA-01-CF-68	CF	Classroom faucets	132	3/30/2019	7:50	7.85	P	< 1.00	P
19-OBA-01-CF-69	CF	Classroom faucets	134	3/30/2019	7:52	7.9	P	< 1.00	P
19-OBA-01-CF-70	CF	Classroom faucets	149	3/30/2019	7:55	< 1.00	P	< 1.00	P
19-OBA-01-WC-71	WC	Water fountain with cooler	100A	3/30/2019	8:53	< 1.00	P	< 1.00	P
19-OBA-01-WC-72	WC	Water fountain with cooler	100A	3/30/2019	8:55	< 1.00	P	< 1.00	P
19-OBA-01-KF-76	KF	Kitchen faucets	138	3/30/2019	7:57	7.54	P	< 1.00	P
19-OBA-01-KF-77	KF	Kitchen faucets	138	3/30/2019	8:00	2.08	P	< 1.00	P
19-OBA-01-KF-78	KF	Home Economics faucets (Room not in use)	138	3/30/2019	8:01	18.2	F	2.4	P
19-OBA-01-KF-79	KF	Home Economics faucets (Room not in use)	138	3/30/2019	8:01	15.2	F	1.16	P
19-OBA-01-WC-81	WC	Water fountain with cooler	100	3/30/2019	8:06	< 1.00	P	< 1.00	P
19-OBA-01-WC-82	WC	Water fountain with cooler	100	3/30/2019	8:07	< 1.00	P	< 1.00	P
19-OBA-01-WC-89	WC	Water fountain with cooler	160	3/30/2019	8:27	< 1.00	P	< 1.00	P
19-OBA-01-WC-89.1	WC	Water fountain with cooler	160	3/30/2019	8:28	< 1.00	P	< 1.00	P
19-OBA-01-KF-89.5	KF	Kitchen faucets	160	3/30/2019	8:14	3.31	P	< 1.00	P
19-OBA-01-KF-90	KF	Kitchen faucets	158	3/30/2019	8:14	4.15	P	< 1.00	P
19-OBA-01-KF-91	KF	Kitchen faucets	158	3/30/2019	8:15	2.14	P	<1.00	P
19-OBA-01-KF-92	KF	Kitchen faucets	158	3/30/2019	8:15	2.18	P	1.10	P
19-OBA-01-WC-101	WC	Water fountain with cooler	100	3/30/2019	8:22	< 1.00	P	< 1.00	P
19-OBA-01-WC-102	WC	Water fountain with cooler	100	3/30/2019	8:23	< 1.00	P	< 1.00	P
19-OBA-01-WB-103	WB	Water Bubbler	Pool	3/30/2019	8:43	<1.00	P	<1.00	P
19-OBA-01-WC-106	WC	Water fountain with cooler	100B	3/30/2019	8:29	1.05	P	1.20	P
19-OBA-01-WC-107	WC	Water fountain with cooler	100B	3/30/2019	8:30	<1.00	P	< 1.00	P
19-OBA-01-CF-108	CF	Classroom faucets	163	3/30/2019	8:38	1.16	P	< 1.00	P
19-OBA-01-CF-109	CF	Classroom faucets	163	3/30/2019	8:38	<1.00	P	<1.00	P
19-OBA-01-CF-110	CF	Classroom faucets	163	3/30/2019	8:40	2.69	P	4.85	P
19-OBA-01-CF-111	CF	Classroom faucets	153	3/30/2019	8:36	4.13	P	<1.00	P
19-OBA-01-KF-112	KF	Kitchen faucets	138	3/30/2019	8:42	8.85	P	2.31	P
19-OBA-02-WC-114	WC	Water fountain with cooler	200A	3/30/2019	9:26	< 1.00	P	< 1.00	P
19-OBA-02-WC-115	WC	Water fountain with cooler	200A	3/30/2019	9:27	<1.00	P	<1.00	P
19-OBA-02-CF-120	CF	Classroom faucets	224	3/30/2019	9:23	<1.00	P	< 1.00	P
19-OBA-02-CF-121	CF	Classroom faucets	224	3/30/2019	9:24	<1.00	P	< 1.00	P
19-OBA-02-CF-122	CF	Classroom faucets	224	3/30/2019	9:25	<1.00	P	< 1.00	P
19-OBA-02-CF-123	CF	Classroom faucets	224	3/30/2019	9:27	<1.00	P	< 1.00	P
19-OBA-02-WC-126	WC	Water fountain with cooler	200	3/30/2019	9:16	<1.00	P	< 1.00	P
19-OBA-02-WC-127	WC	Water fountain with cooler	200	3/30/2019	9:17	<1.00	P	< 1.00	P
19-OBA-02-TF-129	TF	Teacher's lounge sinks	205	3/30/2019	9:30	2.10	P	< 1.00	P
19-OBA-02-WC-137	WC	Water fountain with cooler	200B	3/30/2019	9:37	< 1.00	P	< 1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-OBA-02-WC-138	WC	Water fountain with cooler	200B	3/30/2019	9:38	< 1.00	P	< 1.00	P
19-OBA-03-WC-166	WC	Water fountain with cooler	3008	3/30/2019	9:39	< 1.00	P	< 1.00	P
19-OBA-03-WC-167	WC	Water fountain with cooler	3008	3/30/2019	9:41	< 1.00	P	13.8	P
19-OBA-03-CF-193	CF	Classroom faucets	305	3/30/2019	9:43	6.93	P	< 1.00	P

Oliver Field House

Lead in Drinking Water Sample Results

School: Pittsburgh Oliver Fieldhouse

Address: 2323 Brighton Road Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing)
19-OFH-GF-WM-00	WM	Water Main	Heater Room	6/13/2019	08:00	<1.00	P		
19-OFH-GF-SL-00	SL	Service Line	Heater Room	6/13/2019	07:50	<1.00	P		
19-OFH-GF-WF-263	WF	Water fountain with filter & cooler	Outside	6/13/2019	08:04	<1.00	P	<1.00	P
19-OFH-GF-FF-270	FF	Field House sink faucets	Storage	6/13/2019	08:07	<1.00	P	<1.00	P
19-OFH-GF-FF-271	FF	Field House sink faucets	Men's restroom	6/13/2019	07:44	1.19	P	<1.00	P
19-OFH-GF-IM-272	IM	Ice machines	Men's restroom	6/13/2019	08:13	<1.00	P		
19-OFH-GF-WF-273	WF	Water fountain with filter & cooler	Outside	6/13/2019	08:05	<1.00	P	<1.00	P

Oliver

Lead in Drinking Water Sample Results

School: Pittsburgh Oliver

Address: 2323 Brighton Road Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-OLI-GF-WM-00	WM	Water Main	Under stair I	6/13/2019	06:46	<1.00	P		
19-OLI-GF-SL-00	SL	Service Line	Under stair I	6/13/2019	06:51	<1.00	P		
19-OLI-BS-MS-15	MS	Miscellaneous sinks	P26	6/13/2019	06:52	1.19	P	< 1.00	P
19-OLI-BS-WF-24	WF	Water fountain with filter and cooler	P30	6/13/2019	06:56	< 1.00	P	< 1.00	P
19-OLI-BS-WF-28	WF	Water fountain with filter and cooler	P44	6/13/2019	06:53	< 1.00	P	< 1.00	P
19-OLI-BS-WC-29	WC	Water fountain with cooler	B91	6/13/2019	07:07	< 1.00	P	< 1.00	P
19-OLI-GF-WF-35	WF	Water fountain with filter and cooler	Corridor by G41	6/13/2019	07:05	< 1.00	P	< 1.00	P
19-OLI-GF-WF-36	WF	Water fountain with filter and cooler	Corridor by G41	6/13/2019	07:05	< 1.00	P	< 1.00	P
19-OLI-GF-CF-38	CF	Classroom faucets	G64	6/13/2019	07:06	3.02	P	2.87	P
19-OLI-GF-CF-41	CF	Classroom faucets	G66	6/13/2019	07:08	110	F	15.6	F
19-OLI-02-KF-43	KF	Sink faucet (Culinary Arts - not in use)	202	6/13/2019	09:02	104	F	3.69	P
19-OLI-GF-KF-44	KF	Kitchen faucets	G01	6/13/2019	07:18	6.25	P	2.05	P
19-OLI-GF-CF-47	CF	Classroom faucets	G04	6/13/2019	07:17	1.6	P	< 1.00	P
19-OLI-GF-WF-48	WF	Water fountain with filter and cooler	G04	6/13/2019	07:19	< 1.00	P	< 1.00	P
19-OLI-GF-OF-49	OF	Office sink faucets	G02	6/13/2019	07:26	1.78	P	< 1.00	P
19-OLI-GF-WF-57	WF	Water fountain with filter and cooler	Corridor by G09	6/13/2019	07:31	< 1.00	P	< 1.00	P
19-OLI-GF-WF-58	WF	Water fountain with filter and cooler	Corridor by G09	6/13/2019	07:32	< 1.00	P	< 1.00	P
19-OLI-GF-OF-59	OF	Office sink faucets	G12	6/13/2019	07:30	31.3	F	6.85	P
19-OLI-GF-HF-64	HF	Home economics faucets (with cooking)	G14	6/13/2019	07:34	9.09	P	1.13	P
19-OLI-GF-HF-65	HF	Home economics faucets (with cooking)	G14A	6/13/2019	07:35	5.64	P	1.27	P
19-OLI-GF-CF-67	CF	Classroom faucets	G15	6/13/2019	07:36	3.19	P	1.77	P
19-OLI-GF-CF-68	CF	Classroom faucets	G15	6/13/2019	07:37	2.31	P	1.93	P
19-OLI-GF-CF-69	CF	Classroom faucets	G16	6/13/2019	07:38	3.3	P	2.28	P
19-OLI-GF-CF-70	CF	Classroom faucets	G16	6/13/2019	07:39	1.85	P	1.77	P
19-OLI-GF-WF-80	WF	Water fountain with filter and cooler	Outside G24	6/13/2019	07:46	< 1.00	P	< 1.00	P
19-OLI-GF-WF-81	WF	Water fountain with filter and cooler	Outside G24	6/13/2019	07:47	< 1.00	P	< 1.00	P
19-OLI-GF-WO-97	WO	Water fountain without cooler	Outside G30	6/13/2019	07:46	< 1.00	P	< 1.00	P
19-OLI-GF-WO-98	WO	Water fountain without cooler	Outside G30	6/13/2019	07:47	< 1.00	P	< 1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-OLI-GF-WF-108	WF	Water fountain with filter and cooler	Outside G40	6/13/2019	07:50	< 1.00	P	< 1.00	P
19-OLI-GF-WF-109	WF	Water fountain with filter and cooler	Outside G40	6/13/2019	07:51	< 1.00	P	< 1.00	P
19-OLI-GF-WF-110	WF	Water fountain with filter and cooler	G44	6/13/2019	07:53	< 1.00	P	< 1.00	P
19-OLI-GF-WF-111	WF	Water fountain with filter and cooler	G44	6/13/2019	07:53	< 1.00	P	< 1.00	P
19-OLI-GF-KF-120	KF	Kitchen faucets	G58D	6/13/2019	07:55	< 1.00	P	< 1.00	P
19-OLI-GF-OF-122	OF	Office sink faucets	G58	6/13/2019	06:58	3.18	P	1.37	P
19-OLI-GF-WF-123	WF	Water fountain with filter and cooler	G17	6/13/2019	08:04	< 1.00	P	< 1.00	P
19-OLI-GF-WF-125	WF	Water fountain with filter and cooler	G17	6/13/2019	08:04	< 1.00	P	< 1.00	P
19-OLI-GF-KF-126	KF	Kitchen faucets	G01C	6/13/2019	07:19	< 1.00	P	2.93	P
19-OLI-GF-KF-127	KF	Kitchen faucets	G01C	6/13/2019	07:20	1.28	P	< 1.00	P
19-OLI-01-CF-130	CF	Classroom faucets	152	6/13/2019	08:12	17.9	F	2.73	P
19-OLI-01-WF-131	WF	Water fountain with filter and cooler	Outside 143A	6/13/2019	08:15	< 1.00	P	< 1.00	P
19-OLI-01-WF-132	WF	Water fountain with filter and cooler	Outside 143A	6/13/2019	08:16	< 1.00	P	< 1.00	P
19-OLI-01-NF-134	NF	Nurse's office sink faucets	154A	6/13/2019	08:16	3.95	P	< 1.00	P
19-OLI-01-TF-136	TF	Teacher's lounge sinks	100C	6/13/2019	08:17	3.98	P	1.62	P
19-OLI-01-CF-137	CF	Classroom faucets	103	6/13/2019	08:14	4.85	P	1.74	P
19-OLI-01-WF-144	WF	Water fountain with filter and cooler	111	6/13/2019	08:15	< 1.00	P	< 1.00	P
19-OLI-01-CF-149	CF	Classroom faucets		6/13/2019	08:21	10	P	7.93	P
19-OLI-01-CF-150	CF	Classroom faucets	108A	6/13/2019	08:22	28.1	F	4.71	P
19-OLI-01-CF-152	CF	Classroom faucets	123A	6/13/2019	08:28	8.44	P	5.03	P
19-OLI-01-CF-159	CF	Classroom faucets	125	6/13/2019	08:28	6.71	P	< 1.00	P
19-OLI-01-WF-162	WF	Water fountain with filter and cooler	Outside 122	6/13/2019	08:29	4.65	P	< 1.00	P
19-OLI-01-WF-163	WF	Water fountain with filter and cooler	Outside 122	6/13/2019	08:30	< 1.00	P	< 1.00	P
19-OLI-01-CF-164	CF	Classroom faucets	124	6/13/2019	08:32	16.9	F	3.42	P
19-OLI-01-CF-185	CF	Classroom faucets	124A	6/13/2019	08:37	21.2	F	3.14	P
19-OLI-01-WF-210	WF	Water fountain with filter and cooler	Outside 128	6/13/2019	08:41	< 1.00	P	< 1.00	P
19-OLI-01-WF-211	WF	Water fountain with filter and cooler	Outside 128	6/13/2019	08:42	< 1.00	P	< 1.00	P
19-OLI-01-CF-214	CF	Classroom faucets	136	6/13/2019	08:14	6.31	P	1.7	P
19-OLI-01-OF-218	OF	Office sink faucets	121C	6/13/2019	08:45	81.6	F	9.64	P
19-OLI-02-WF-222	WF	Water fountain with filter and cooler	Outside A	6/13/2019	08:51	< 1.00	P	< 1.00	P
19-OLI-02-CF-224	CF	Classroom faucets	253	6/13/2019	08:54	72.8	F	18.5	F
19-OLI-02-MC-225	MC	Sink faucet (Culinary Arts - not in use)	200B	6/13/2019	08:36	66	F	55.5	F

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-OLI-02-HF-230	HF	Sink faucet (Culinary Arts - not in use)	203	6/13/2019	09:06	101	F	4.57	P
19-OLI-02-KF-231	KF	Sink faucet (Culinary Arts - not in use)	202	6/13/2019	09:04	36.6	F	7.56	P
19-OLI-02-KF-233	KF	Sink faucet (Culinary Arts - not in use)	202	6/13/2019	09:06	11.4	P	1.03	P
19-OLI-02-KF-237	KF	Sink faucet (Culinary Arts - not in use)	202	6/13/2019	09:03	58.9	F	12.2	P
19-OLI-02-WO-244	WO	Water fountain without cooler	209	6/13/2019	09:14	< 1.00	P	< 1.00	P
19-OLI-02-WO-245	WO	Water fountain without cooler	209	6/13/2019	09:15	< 1.00	P	< 1.00	P
19-OLI-02-OF-246	OF	Office sink faucets	209A	6/13/2019	09:14	9.94	P	1.86	P
19-OLI-02-CF-250	CF	Classroom faucets	227	6/13/2019	09:18	3.63	P	1.61	P
19-OLI-02-WO-256	WO	Water fountain without cooler	Outside 244	6/13/2019	09:23	3.59	P	1.75	P
19-OLI-02-WO-257	WO	Water fountain without cooler	Outside 244	6/13/2019	09:24	3.93	P	1.59	P
19-OLI-02-TF-261	TF	Teacher's lounge sinks	246	6/13/2019	09:36	1.81	P	< 1.00	P
19-OLI-GF-WF-266	WF	Water fountain with filter and cooler	G17	6/13/2019	08:05	< 1.00	P	< 1.00	P
19-OLI-GF-WF-267	WF	Water fountain with filter and cooler	G17	6/13/2019	08:05	< 1.00	P	10.4	P
19-OLI-GF-WC-37	WC	Water fountain with cooler	G54	6/13/2019	07:07	6.87	P	< 1.00	P

Phillips K-5

Lead in Drinking Water Sample Results

School: Pittsburgh Phillips K-5

Address: 1901 Sarah Street Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Number	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-PHI-01-SL-00	SL	00	Service Line	Room 112B	6/1/2019	6:45	<1.00	P		
19-PHI-01-WM-00	WM	00	Water Main	Room 112B	6/1/2019	6:55	<1.00	P		
19-PHI-01-WC-07	WC	07	Water fountain with cooler	Corridor 100	6/1/2019	7:05	<1.00	P	<1.00	P
19-PHI-01-WC-08	WC	08	Water fountain with cooler	Corridor 100	6/1/2019	7:06	<1.00	P	<1.00	P
19-PHI-01-CF-10	CF	10	Classroom faucets	Room 106	6/1/2019	7:12	<1.00	P	<1.00	P
19-PHI-01-NF-13	NF	13	Nurse's office sink faucets	Doc Rm. 101	6/1/2019	7:26	<1.00	P	<1.00	P
19-PHI-02-WC-17	WC	17	Water fountain with cooler	Corridor 200	6/1/2019	7:37	<1.00	P	<1.00	P
19-PHI-02-WC-18	WC	18	Water fountain with cooler	Corridor 200	6/1/2019	7:39	<1.00	P	<1.00	P
19-PHI-02-TF-20	TF	20	Teacher's lounge sinks	Room 202	6/1/2019	7:43	<1.00	P	<1.00	P
19-PHI-02-WF-27	WF	27	Water fountain with filter & cooler	Corridor 200	6/1/2019	7:52	<1.00	P	<1.00	P
19-PHI-02-WF-28	WF	28	Water fountain with filter & cooler	Corridor 200	6/1/2019	7:53	<1.00	P	<1.00	P
19-PHI-01-WF-31	WF	31	Water fountain with filter & cooler	Corridor 100	6/1/2019	7:22	<1.00	P	<1.00	P
19-PHI-01-WF-32	WF	32	Water fountain with filter & cooler	Corridor 100	6/1/2019	7:23	<1.00	P	<1.00	P
19-PHI-01-KF-36	KF	36	Kitchen faucet	Kitchen 112	6/1/2019	7:00	<1.00	P	<1.00	P

Roosevelt PreK-1

Lead in Drinking Water Sample Results

School: Roosevelt PreK-1

Address: 200 The Boulevard, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
19-ROS-01-SL-00	SL	Service Line	Outside - Adjacent Rm 105	3/30/2019	06:44	<1.00	P		
19-ROS-01-WM-00	WM	Water Main	Outside - Adjacent Rm 105	3/30/2019	06:39	<1.00	P		
19-ROS-01-KF-02	KF	Kitchen faucets	Teacher's Room 106	3/30/2019	06:34	2.35	P	<1.00	P
19-ROS-01-CF-11	CF	Classroom faucets	Classroom 105	3/30/2019	06:45	<1.00	P	<1.00	P
19-ROS-01-WF-12	WF	Water fountain with filter and cooler	Outside Room 103/130	3/30/2019	06:48	<1.00	P	<1.00	P
19-ROS-01-WF-13	WC	WaterFountain with filter and cooler	Outside Room 103/130	3/30/2019	06:48	<1.00	P	<1.00	P
19-ROS-01-WO-14	WO	Water fountain without cooler	Outside Room 114	3/30/2019	06:53	<1.00	P	<1.00	P
19-ROS-01-WC-15	WC	Water fountain with cooler	Outside Room 114	3/30/2019	06:53	<1.00	P	<1.00	P
19-ROS-01-MC-16	MC	Multi- Purpose Room/Cafeteria faucets	Multi-Purpose 101	3/30/2019	06:59	1.29	P	<1.00	P
19-ROS-01-WB-17	WB	Water fountain bubbler (Ceramic or Porcelain)	Multi-Purpose 101	3/30/2019	06:59	<1.00	P	<1.00	P
19-ROS-01-MC-18	MC	Multi- Purpose Room/Cafeteria faucets	Multi-Purpose 101	3/30/2019	06:59	<1.00	P	<1.00	P
19-ROS-01-NF-19	NF	Nurse's office sink faucets	Auxiliary 112-C	3/30/2019	07:06	<1.00	P	<1.00	P
19-ROS-01-CF-20	CF	Classroom faucets	Kindergarten 102	3/30/2019	07:09	<1.00	P	<1.00	P

Schiller 6-8

Lead in Drinking Water Sample Results

School: Pittsburgh Schiller

Address: 1018 Peralta Street, Pittsburgh, PA

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-SCH-01-WM-00	WM	Water Main	STORAGE 115-A	8/14/2019	06:45	2.18	P	N/A	N/A
19-SCH-01-SL-00	SL	Service Line	STORAGE 115-A	8/14/2019	06:50	1.42	P	N/A	N/A
19-SCH-01-KF-02	KF	Kitchen faucets	119-A	8/14/2019	06:54	<1.00	P	<1.00	P
19-SCH-01-KF-03	KF	Kitchen faucets	119-A	8/14/2019	06:54	<1.00	P	<1.00	P
19-SCH-GF-CF-06	CF	Classroom faucets	004	8/14/2019	06:40	8.70	P	1.43	P
19-SCH-02-CF-10	CF	Classroom faucets	216	8/14/2019	07:51	2.07	P	<1.00	P
19-SCH-02-CF-14	CF	Classroom faucets	213	8/14/2019	07:37	3.80	P	<1.00	P
19-SCH-02-CF-15	CF	Classroom faucets	213	8/14/2019	07:38	2.91	P	<1.00	P
19-SCH-02-CF-16	CF	Classroom faucets	213	8/14/2019	07:38	2.35	P	2.81	P
19-SCH-02-CF-17	CF	Classroom faucets	211	8/14/2019	07:32	5.53	P	<1.00	P
19-SCH-02-WF-19	WF	Water fountain with filter and cooler	CORRIDOR 200	8/14/2019	07:23	<1.00	P	<1.00	P
19-SCH-02-WF-20	WF	Water fountain with filter and cooler	CORRIDOR 200	8/14/2019	07:23	<1.00	P	<1.00	P
19-SCH-02-CF-23	CF	Classroom faucets	209	8/14/2019	07:28	11.4	P	<1.00	P
19-SCH-02-WF-25	WO	Water fountain with filter and cooler	CORRIDOR 200	8/14/2019	07:42	<1.00	P	<1.00	P
19-SCH-02-WF-26	WB	Water fountain with filter and cooler	CORRIDOR 200	8/14/2019	07:43	<1.00	P	<1.00	P
19-SCH-01-WF-31	WF	Water fountain with filter and cooler	CORRIDOR 100	8/14/2019	06:59	<1.00	P	<1.00	P
19-SCH-01-WF-32	WF	Water fountain with filter and cooler	CORRIDOR 100	8/14/2019	07:00	<1.00	P	<1.00	P
19-SCH-01-WF-36	WF	Water fountain with filter and cooler	Hallway	8/14/2019	07:11	<1.00	P	<1.00	P
19-SCH-01-WF-37	WF	Water fountain with filter and cooler	Hallway	8/14/2019	07:12	<1.00	P	<1.00	P
19-SCH-01-OF-39	OF	Office sink faucets	111	8/14/2019	07:16	65.0	F	1.72	P
19-SCH-01-TF-43	TF	Teacher's lounge sinks	103	8/14/2019	07:07	2.50	P	<1.00	P
19-SCH-01-OF-46	OF	Office sink faucets	101	8/14/2019	07:03	4.37	P	2.31	P
19-SCH-01-KF-49	KF	Kitchen faucets	120	8/14/2019	06:51	<1.00	P	2.44	P

Spring Garden Early Childhood Center

Lead in Drinking Water Sample Results

School:

Pittsburgh Spring Garden ECC

Address:

1501 Spring Garden Ave, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
19-SPG-BS-SL-00	SL	Service Line	B-8	2/16/2019	6:30	11.8	P		
19-SPG-BS-WM-00	WM	Water Main	B-8	2/16/2019	6:30	9.62	P		
19-SPG-01-WB-02	WB	Water fountain with cooler	Outside Boys Toilet (106)	2/16/2019	6:34	<1.00	P	<1.00	P
19-SPG-01-WB-03	WB	Water fountain with cooler	Outside Boys Toilet (106)	2/16/2019	6:35	<1.00	P	<1.00	P
19-SPG-01-CF-06	CF	Classroom faucets	Room 110-A	2/16/2019	6:45	20.5	F	7.51	P
19-SPG-01-KF-09	KF	Kitchen faucets	Room 103-A	2/16/2019	6:48am	2.81	P	2.15	P
19-SPG-01-WB-14	WB	Water fountain with cooler	Outside Girls Toilet (101)	2/16/2019	6:51	<1.00	P	<1.00	P
19-SPG-01-WB-15	WB	Water fountain with cooler	Outside Girls Toilet (101)	2/16/2019	6:52	<1.00	P	<1.00	P
19-SPG-01-KF-18	KF	Kitchen faucets	Stage 112-A	2/16/2019	6:58	7.69	P	4.42	P
19-SPG-02-WB-23	WB	Water fountain with cooler	Outside Boys Toilet (204)	2/16/2019	7:03	<1.00	P	<1.00	P
19-SPG-02-WB-24	WB	Water fountain with cooler	Outside Boys Toilet (204)	2/16/2019	7:05	<1.00	P	<1.00	P
19-SPG-02-CF-27	CF	Classroom faucets	Art Room 207	2/16/2019	7:12	69.1	F	25.5	F
19-SPG-02-CF-28	CF	Classroom faucets	Library Room 208	2/16/2019	7:14	2.06	P	<1.00	P
19-SPG-02-WB-29	WB	Water fountain with cooler	Outside Girls Toilet (201)	2/16/2019	7:17	<1.00	P	<1.00	P
19-SPG-02-WB-30	WB	Water fountain with cooler	Outside Girls Toilet (201)	2/16/2019	7:18	<1.00	P	<1.00	P
19-SPG-01-CF-31	CF	Classroom faucets	Demountable Classroom	2/16/2019	7:39	1.13	P	1.98	P
19-SPG-01-CF-32	CF	Classroom faucets	Demountable Classroom	2/16/2019	7:40	1.44	P	1.54	P
19-SPG-01-CF-33	CF	Water fountain with cooler	Demountable Classroom	2/16/2019	7:41	<1.00	P	1.43	P
19-SPG-01-WB-34	WB	Water fountain with cooler	Demountable Classroom	2/16/2019	7:42	1.51	P	<1.00	P

Spring Hill K-5

Lead in Drinking Water Sample Results

School: Pittsburgh Spring Hill K-5

Address: 1351 Damas Street Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-SRG-BS-WM-00	WM	Water Main	006	5/25/2019	6:35	3.31	P		
19-SRG-BS-SL-01	SL	Service Line	006	5/25/2019	6:40	<1.00	P		
19-SRG-BS-CF-04	CF	Classroom faucets	007	5/25/2019	6:43	<1.00	P	<1.00	P
19-SRG-BS-CF-07	CF	Classroom faucets	010	5/25/2019	6:48	1.88	P	<1.00	P
19-SRG-BS-CF-08	CF	Classroom faucets	011	5/25/2019	6:51	<1.00	P	<1.00	P
19-SRG-BS-CF-09	CF	Classroom faucets	011	5/25/2019	6:53	<1.00	P	<1.00	P
19-SRG-BS-WF-12	WF	Water fountain with filter and cooler	008	5/25/2019	6:56	<1.00	P	<1.00	P
19-SRG-BS-WF-13	WF	Water fountain with filter and cooler	008	5/25/2019	6:57	<1.00	P	<1.00	P
19-SRG-01-WF-20	WF	Water fountain with filter and cooler	129	5/25/2019	7:07	<1.00	P	<1.00	P
19-SRG-01-WF-21	WF	Water fountain with filter and cooler	129	5/25/2019	7:08	<1.00	P	<1.00	P
19-SRG-01-TF-22	TF	Teacher's lounge sinks	135	5/25/2019	7:10	<1.00	P	<1.00	P
19-SRG-01-NF-31	NF	Nurse's office sink faucets	104	5/25/2019	7:13	4.23	P	<1.00	P
19-SRG-01-WF-33	WF	Water fountain with filter and cooler	Hallway	5/25/2019	7:17	<1.00	P	<1.00	P
19-SRG-01-WF-34	WF	Water fountain with filter and cooler	Hallway	5/25/2019	7:18	<1.00	P	<1.00	P
19-SRG-02-CF-35	CF	Classroom faucets	219	5/25/2019	7:23	<1.00	P	<1.00	P
19-SRG-02-CF-36	CF	Classroom faucets	219	5/25/2019	7:24	8.40	P	<1.00	P
19-SRG-02-CF-37	CF	Classroom faucets	201	5/25/2019	7:28	10.9	P	<1.00	P
19-SRG-02-CF-38	CF	Classroom faucets	210	5/25/2019	7:31	4.06	P	<1.00	P
19-SRG-02-CF-39	CF	Classroom faucets	210	5/25/2019	7:32	<1.00	P	<1.00	P
19-SRG-02-WF-40	WF	Water fountain with filter and cooler	208	5/25/2019	7:35	<1.00	P	<1.00	P
19-SRG-02-WF-41	WF	Water fountain with filter and cooler	208	5/25/2019	7:36	<1.00	P	<1.00	P

Student Achievement Center

Lead in Drinking Water Sample Results

School: Pittsburgh Student Archievement Center

Address: 925 Brushton Ave., Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Lead Concentration (ppb)	First Draw (fixture assembly) (A)	Second Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)
19-SAC-BS-WM-00	WM	Water Main	21	6/15/2019	7:10	< 1.00	P		
19-SAC-SB-SL-00	SL	Service Line	B-1	6/15/2019	7:00	< 1.00	P		
19-SAC-BS-KF-03	KF	Kitchen faucets	27	6/15/2019	7:12	4.95	P	8.54	P
19-SAC-BS-KF-04	KF	Kitchen faucets	27	6/15/2019	7:14	6.37	P	5.75	P
19-SAC-BS-WC-07	WC	Water fountain with cooler	23	6/15/2019	7:18	< 1.00	P	< 1.00	P
19-SAC-BS-WB-12	WB	Water fountain bubbler (Ceramic or Porcelain)	29	6/15/2019	7:20	31	F	10.1	P
19-SAC-01-WF-13	WF	Water fountain with filter and cooler	120	6/15/2019	7:33	< 1.00	P	< 1.00	P
19-SAC-01-WF-14	WF	Water fountain with filter and cooler	120	6/15/2019	7:35	< 1.00	P	< 1.00	P
19-SAC-01-WC-22	WC	Water fountain with cooler	120	6/15/2019	7:37	2.33	P	6.16	P
19-SAC-01-WC-23	WC	Water fountain with cooler	121	6/15/2019	7:39	1.89	P	5.6	P
19-SAC-02-WF-29	WC	Water fountain with filter and cooler	CORRIDOR 200	6/15/2019	7:46	< 1.00	P	< 1.00	P
19-SAC-02-WF-30	WC	Water fountain with filter and cooler	CORRIDOR 200	6/15/2019	7:47	< 1.00	P	< 1.00	P
19-SAC-02-TF-33	TF	Teacher's lounge sinks	206	6/15/2019	7:52	14.7	P	1.53	P
19-SAC-02-OF-34	OF	Office sink faucets	205	6/15/2019	8:00	15.6	F	7.14	P
19-SAC-02-CF-36	CF	Classroom faucets	203	6/15/2019	8:03	15.7	F	1.68	P
19-SAC-02-WC-45	WC	Water fountain with cooler	220	6/15/2019	8:07	1.08	P	3	P
19-SAC-02-WC-46	WC	Water fountain with cooler	221	6/15/2019	8:08	1.29	P	4.13	P
19-SAC-03-WC-51	WC	Water fountain with cooler	320	6/15/2019	8:14	4.38	P	4.53	P
19-SAC-03-WC-54	WC	Water fountain with cooler	332	6/15/2019	8:17	3.26	P	3.52	P
19-SAC-03-WF-59	WF	Water fountain with filter and cooler	300	6/15/2019	8:26	< 1.00	P	< 1.00	P
19-SAC-03-WF-60	WF	Water fountain with filter and cooler	300	6/15/2019	8:27	< 1.00	P	< 1.00	P
19-SAC-03-HF-61	HF	Home economics faucets (with cooking)	303	6/15/2019	8:32	< 1.00	P	< 1.00	P
19-SAC-03-HF-62	HF	Home economics faucets (with cooking)	303	6/15/2019	8:34	< 1.00	P	< 1.00	P
19-SAC-03-HF-63	HF	Home economics faucets (with cooking)	303	6/15/2019	8:36	< 1.00	P	1.97	P
19-SAC-03-TF-64	TF	Teacher's lounge sinks	301	6/15/2019	8:41	13.1	P	3.86	P

Westwood PreK-5

Lead in Drinking Water Sample Results

School: Pittsburgh Westwood K-5

Address: 508 Shadyhill Road Pittsburgh, PA 15205

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
19-WWD-GF-SL-00	SL	Service Line	115	2/16/2019	6:17	1.97	P		
19-WWD-GF-WM-00	WM	Water Main	115	2/16/2019	6:17	1.03	P		
19-WWD-GF-CF-04	CF	Classroom faucets	106	2/16/2019	6:20	3.19	P	<1.00	P
19-WWD-GF-WC-06	WC	Water fountain with cooler	110C	2/16/2019	6:27	<1.00	P	<1.00	P
19-WWD-GF-WC-07	WC	Water fountain with cooler	110C	2/16/2019	6:28	<1.00	P	<1.00	P
19-WWD-GF-TF-11	TF	Teacher's lounge sinks	109	2/16/2019	6:34	3.36	P	<1.00	P
19-WWD-GF-CF-13	CF	Classroom faucets	104	2/16/2019	6:34	3.26	P	<1.00	P
19-WWD-GF-WC-16	WC	Water fountain with cooler	110	2/16/2019	6:43	<1.00	P	<1.00	P
19-WWD-GF-WC-17	WC	Water fountain with cooler	110	2/16/2019	6:44	<1.00	P	<1.00	P
19-WWD-GF-CF-27	CF	Classroom faucets	102	2/16/2019	6:49	3.64	P	<1.00	P
19-WWD-GF-CF-31	CF	Classroom faucets	100	2/16/2019	6:52	2.54	P	<1.00	P
19-WWD-GF-CF-32	CF	Classroom faucets	127	2/16/2019	6:59	1.20	P	<1.00	P
19-WWD-GF-CF-33	CF	Classroom faucets	127	2/16/2019	7:00	2.46	P	<1.00	P
19-WWD-01-WC-34	WC	Water fountain with cooler	200	2/16/2019	7:07	<1.00	P	<1.00	P
19-WWD-01-WC-35	WC	Water fountain with cooler	200	2/16/2019	7:09	<1.00	P	<1.00	P
19-WWD-01-CF-36	CF	Classroom faucets	208	2/16/2019	7:12	2.98	P	<1.00	P
19-WWD-01-CF-37	CF	Classroom faucets	206	2/16/2019	7:16	4.89	P	<1.00	P
19-WWD-01-CF-38	CF	Classroom faucets	209	2/16/2019	7:19	8.09	P	1.03	P
19-WWD-01-CF-42	CF	Classroom faucets	204	2/16/2019	7:24	5.65	P	<1.00	P
19-WWD-01-WC-50	WC	Water fountain with cooler	200C	2/16/2019	7:30	<1.00	P	<1.00	P
19-WWD-01-WC-51	WC	Water fountain with cooler	200C	2/16/2019	7:31	<1.00	P	<1.00	P
19-WWD-01-KF-57	KF	Kitchen faucets	221	2/16/2019	7:35	<1.00	P	<1.00	P
19-WWD-01-CF-59	CF	Classroom faucets	202	2/16/2019	7:45	1.50	P	<1.00	P
19-WWD-01-CF-60	CF	Classroom faucets	201	2/16/2019	7:49	<1.00	P	<1.00	P
19-WWD-01-WO-61	WO	Water fountain without cooler	201	2/16/2019	7:50	<1.00	P	<1.00	P
19-WWD-01-CF-62	CF	Classroom faucets	201A	2/16/2019	7:53	1.13	P	<1.00	P
19-WWD-01-WO-63	WO	Water fountain without cooler	201A	2/16/2019	7:54	<1.00	P	<1.00	P
19-WWD-01-OF-64	OF	Office sink faucets	222-A	2/16/2019	7:59	4.30	P	<1.00	P

Whittier K-5

Lead in Drinking Water Sample Results

School: Pittsburgh Whittier K-5

Address: 150 Meridan Street Pittsburgh, PA 15211

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-WHI-SB-SL-00	SL	Service Line	B-1	6/1/2019	06:17	<1.00	P		
19-WHI-SB-WM-00	WM	Water Main	B-1	6/1/2019	06:22	<1.00	P		
19-WHI-BS-OF-02	OF	Office sink faucets	10	6/1/2019	06:23	<1.00	P	<1.00	P
19-WHI-BS-CF-03	CF	Classroom faucets	9	6/1/2019	06:23	<1.00	P	<1.00	P
19-WHI-BS-WF-05	WF	Water fountain with filter & cooler	Bottom of Stairs	6/1/2019	06:25	<1.00	P	<1.00	P
19-WHI-01-WF-09	WF	Water fountain with filter & cooler	Outside Boys	6/1/2019	06:31	<1.00	P	<1.00	P
19-WHI-01-WC-12	WC	Water fountain with cooler	Boys	6/1/2019	06:31	<1.00	P	<1.00	P
19-WHI-01-NF-16	NF	Nurse's office sink faucets	114	6/1/2019	06:34	2.94	P	<1.00	P
19-WHI-01-OF-19	OF	Office sink faucets	107	6/1/2019	06:38	1.70	P	<1.00	P
19-WHI-01-KF-20	KF	Kitchen faucets	Kitchen	6/1/2019	06:40	1.26	P	<1.00	P
19-WHI-01-CF-22	CF	Classroom faucets	103	6/1/2019	06:47	1.21	P	<1.00	P
19-WHI-01-WF-23	WF	Water fountain with filter & cooler	Girls	6/1/2019	06:48	<1.00	P	<1.00	P
19-WHI-01-WC-25	WC	Water fountain with cooler	Outside Girls	6/1/2019	06:48	<1.00	P	<1.00	P
19-WHI-01-CF-29	CF	Classroom faucets	102	6/1/2019	06:57	7.50	P	1.13	P
19-WHI-01-CF-30	CF	Classroom faucets	102	6/1/2019	06:56	3.49	P	<1.00	P
19-WHI-01-WB-32	WB	Water fountain bubbler (Ceramic or Porcelain)	101A	6/1/2019	07:01	1.67	P	17.4	F
19-WHI-01-OF-33	OF	Office sink faucets	101B	6/1/2019	07:02	1.31	P	<1.00	P
19-WHI-02-CF-34	CF	Classroom faucets	205	6/1/2019	07:10	2.88	P	<1.00	P
19-WHI-02-CF-35	CF	Classroom faucets	205	6/1/2019	07:11	2.30	P	<1.00	P
19-WHI-02-WC-36	WC	Water fountain with cooler	Outside Boys	6/1/2019	07:16	<1.00	P	<1.00	P
19-WHI-02-WF-39	WF	Water fountain with filter & cooler	200BT	6/1/2019	07:16	<1.00	P	<1.00	P
19-WHI-02-CF-41	CF	Classroom faucets	208	6/1/2019	07:20	1.01	P	<1.00	P
19-WHI-02-TF-43	TF	Teacher's lounge sinks	209	6/1/2019	07:22	<1.00	P	<1.00	P
19-WHI-02-WF-44	WF	Water fountain with filter & cooler	200GT	6/1/2019	07:25	<1.00	P	<1.00	P
19-WHI-02-WC-46	WC	Water fountain with cooler	Outside Girls	6/1/2019	07:28	<1.00	P	<1.00	P
19-WHI-02-CF-50	CF	Classroom faucets	202	6/1/2019	07:30	<1.00	P	<1.00	P

Woolslair K-5

Lead in Drinking Water Sample Results

School: Pittsburgh Woolslair K-5

Address: 501 40th Street Pittsburgh, PA 15224

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
19-WOL-BS-SL-00	SL	Service Line	G1C	5/4/2019	06:42	2.18			
19-WOL-BS-WM-00	WM	Water Main	G1C	5/4/2019	06:47	1.06			
19-WOL-BS-WF-01	WF	Water fountain with filter & cooler	B1A	5/4/2019	06:47	<1.00	P	<1.00	P
19-WOL-BS-WF-02	WF	Water fountain with filter & cooler	B1A	5/4/2019	06:48	<1.00	P	<1.00	P
19-WOL-BS-NF-03	NF	Nurse's office sink faucets	G14	5/4/2019	06:53	1.91	P	<1.00	P
19-WOL-BS-KF-04	KF	Kitchen faucets	G10	5/4/2019	06:53	<1.00	P	1.19	P
19-WOL-BS-KF-05	KF	Kitchen faucets	G10	5/4/2019	06:54	8.78	P	1.83	P
19-WOL-BS-CF-11	CF	Classroom faucets	G3	5/4/2019	06:57	11.8	P	1.23	P
19-WOL-BS-CF-14	CF	Classroom faucets	G7	5/4/2019	07:01	4.28	P	2.08	P
19-WOL-BS-CF-15	CF	Classroom faucets	G6	5/4/2019	07:03	<1.00	P	<1.00	P
19-WOL-BS-WO-16	WO	Water fountain without cooler	B1B	5/4/2019	07:08	1.19	P	1.10	P
19-WOL-BS-WO-17	WO	Water fountain without cooler	B1B	5/4/2019	07:09	1.59	P	1.13	P
19-WOL-BS-CF-19	CF	Classroom faucets	G5	5/4/2019	07:12	1.67	P	<1.00	P
19-WOL-01-WO-20	WO	Water fountain without cooler	100A	5/4/2019	07:23	1.56	P	1.37	P
19-WOL-01-CF-23	CF	Classroom faucets	103	5/4/2019	07:26	3.97	P	<1.00	P
19-WOL-01-CF-24	CF	Classroom faucets	103	5/4/2019	07:27	1.93	P	<1.00	P
19-WOL-01-OF-27	OF	Office sink faucets	110	5/4/2019	07:30	6.39	P	1.20	P
19-WOL-01-WF-31	WF	Water fountain with filter & cooler	100B	5/4/2019	07:36	<1.00	P	<1.00	P
19-WOL-01-WF-32	WF	Water fountain with filter & cooler	100B	5/4/2019	07:37	<1.00	P	<1.00	P
19-WOL-02-CF-34	CF	Classroom faucets	201B	5/4/2019	07:43	12.9	P	2.22	P
19-WOL-02-WF-36	WF	Water fountain with filter & cooler	200A	5/4/2019	07:47	<1.00	P	<1.00	P
19-WOL-02-WF-37	WF	Water fountain with filter & cooler	200A	5/4/2019	07:48	<1.00	P	<1.00	P
19-WOL-02-CF-38	CF	Classroom faucets	203	5/4/2019	07:50	1.67	P	<1.00	P
19-WOL-02-CF-47	CF	Classroom faucets	207B	5/4/2019	07:57	2.71	P	<1.00	P
19-WOL-02-WO-48	WO	Water fountain without cooler	200B	5/4/2019	08:01	2.50	P	1.39	P
19-WOL-02-WO-49	WO	Water fountain without cooler	200B	5/4/2019	08:02	2.12	P	1.18	P