

# **LEAD IN DRINKING WATER SAMPLING**

*Of*

**Pittsburgh Public Schools**

*Survey Date: June 13 – August 9, 2016*

*Prepared for:*

Pittsburgh Public Schools  
Facilities  
1305 Muriel Street  
Pittsburgh, Pennsylvania 15203

*Prepared By:*



207 Pine Creek Road  
Wexford, PA 15090

## TABLE OF CONTENTS

1. INTRODUCTION.....	1
2. SAMPLING METHODOLOGY .....	1
3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION .....	2
4. RECOMENDATIONS.....	9
REPORT DISCLAIMER:.....	10

**APPENDIX A DRINKING WATER RESULTS TABLES**

**APPENDIX B LABORATORY RESULTS**

**APPENDIX C FACILITY MAPS**

## **1. INTRODUCTION**

AGX, Inc. was retained by Pittsburgh Public School District to test for the presence of Lead in drinking water.

Fixture verification and sampling were conducted at thirty-eight (38) facility buildings from June 13- August 9, 2016. The objective of the testing was to screen the drinking water and cooking use fixtures and faucets for lead concentrations.

## **2. SAMPLING METHODOLOGY**

Sample collection, delivery and analysis were conducted according to EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002", April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance", October 2006. As per 3Ts, the EPA recommends that if lead is found in any water outlet at levels above 20 parts per billion (ppb), action should be taken to reduce the lead in water concentration.

All designated cold water drinking and cooking use fixtures were tested for lead concentrations. Drinking water and cooking fixtures were defined as classroom faucets, home economic faucets, ice machines, kitchen faucets, cafeteria faucets, nurse's office sink faucets, office sink faucets, teacher's lounge sinks, water fountains and miscellaneous sinks found in classrooms and offices. All samples were collected in 250 mL plastic containers that were prepackaged by the analytical laboratory. At each sample location, a first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than eighteen hours. A second draw sample was collected after the water in the system was discharged for thirty (30) seconds. All samples were analyzed by RJ Lee, Inc., 350 Hochberg Road, Monroeville, PA 15146, an independent PA certified laboratory.

### **3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION**

Drinking water was tested for lead in thirty-eight (38) facility buildings and schools. A total of 2,273 of samples were collected from 1,180 of drinking water and cooking use fixtures and faucets. Analytic results were received by AGX and reviewed in relation to EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002", April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance", October 2006. Based on the EPA Publications lead concentrations at or above 20 parts per billion (ppb) were considered to be elevated.

The results of the testing indicate that 3.4% of the fixtures tested had elevated lead concentrations. The low percentage and isolated fixtures with lead concentrations at or above 20 ppb indicated that there were no source water or facility wide lead concerns. Based on testing and observation it is presumed that sources of elevated lead concentrations could be attributed to lack of routine use, fixtures not routinely cleaned and/or older outdated fixtures. Corrective actions, which included the removal of any fixture that exceeded the recommended action level of 20 parts per billion (ppb) from service, were conducted. Following remediation of fixtures that exceeded the recommended lead concentration, verification sampling was conducted to ensure the lead concentrations in drinking water was reduced below 20 parts per billion (ppb).

#### **Banksville:**

At Pittsburgh Banksville PreK-5 a total of forty-eight (48) samples were collected from twenty-five (25) drinking water and cooking use fixtures and faucets on June 23, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

#### **Brookline:**

At Pittsburgh Brookline K-8 a total of eighty-eight (88) samples were collected from forty-four (44) drinking water and cooking use fixtures and faucets on June 21, 2016. One (1) sample (BRO-01-CF-77) collected was above the EPA lead in drinking water action level of 20 ppb.

#### **Carrick:**

At Pittsburgh Carrick High School a total of one hundred and fifty-eight (158) samples were collected from eighty-one (81) drinking water and cooking use fixtures and faucets on July 6, 2016. One (1) sample (CAR-02-NF-172) collected was above the EPA lead in drinking water action level of 20 ppb.

#### **Carrick Field House:**

At Pittsburgh Carrick Field House a total of seven (7) samples were collected from five (5) drinking water and cooking use fixtures and faucets on July 6, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Central Operations:**

At Pittsburgh Central Operations a total of forty-four (44) samples were collected from twenty-three (23) drinking water and cooking use fixtures and faucets on July 6, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Chartiers:**

At Pittsburgh Chartiers ECC a total of thirty-four (34) samples were collected from eighteen (18) drinking water and cooking use fixtures and faucets on June 14, 2016. One (1) sample (CHA-01-WO-17) collected was above the EPA lead in drinking water action level of 20 ppb.

**Clayton:**

At Pittsburgh Clayton Academy a total of forty-two (42) samples were collected from twenty-two (22) drinking water and cooking use fixtures and faucets on July 1, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Crescent:**

At Pittsburgh Crescent ECC a total of fifty four (54) samples were collected from twenty eight (28) drinking water and cooking use fixtures and faucets on June 17, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Cupples Stadium:**

At Pittsburgh Cupples Stadium, a total of thirty-six (36) samples were collected from twenty-one (21) drinking water and cooking use fixtures and faucets on July 8, 2016. Two (2) samples (CUP-GF-WO-65 AND CUP-GF-WO-66) collected were above the EPA lead in drinking water action level of 20 ppb.

**Faison:**

At Pittsburgh Faison PreK-5 a total of eighty (80) samples were collected from forty-one (41) drinking water and cooking use fixtures and faucets on June 23, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Greenfield:**

At Pittsburgh Greenfield PreK-8 a total of fifty-three (53) samples were collected from twenty-eight (28) drinking water and cooking use fixtures and faucets on June 16, 2016. One (1) sample (GRE-01-CF-9) collected was above the EPA lead in drinking water action level of 20 ppb.

**King:**

At Pittsburgh King PreK-8 a total of one hundred ninety-two (192) samples were collected from ninety-seven (97) drinking water and cooking use fixtures and faucets on June 21, 2016. Two (2) samples (KIN-02-TF-64 and KIN-01-MS-29) collected were above the EPA lead in drinking water action level of 20 ppb.

**Langley:**

At Pittsburgh Langley K-8, a total of one hundred and twenty-seven (127) samples were collected from sixty-five (65) drinking water and cooking use fixtures and faucets on July 8, 2016. Eight (8) samples (LAN-01-CF-151, LAN-01-CF-157, LAN-01-CF-170, LAN-01-CF-274, LAN-02-CF-217, LAN-01-MS-136, LAN-02-WC-271 and LAN-02-WC-272) collected were above the EPA lead in drinking water action level of 20 ppb.

**Langley Field House:**

At Pittsburgh Langley Field House, a total of eleven (11) samples were collected from eight (8) drinking water and cooking use fixtures and faucets on July 8, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Lincoln:**

At Pittsburgh Lincoln K-5 a total of fifty (50) samples were collected from twenty-six (26) drinking water and cooking use fixtures and faucets on June 22, 2016. One (1) sample (LIN-01-MS-58) collected were above the EPA lead in drinking water action level of 20 ppb.

**Linden:**

At Pittsburgh Linden K-5 a total of forty-six (46) samples were collected from twenty-four (24) drinking water and cooking use fixtures and faucets on June 24, 2016. Three (3) samples (LND-BS-CF-8, LND-BS-MS-19 and LND-BS-CF-56) collected were above the EPA lead in drinking water action level of 20 ppb.

**Manchester:**

At Pittsburgh Manchester PreK-8 a total of eighty (80) samples were collected from forty one (41) drinking water and cooking use fixtures and faucets on June 17, 2016. Two (2) samples (MAN-01-CF-39 and MAN-02-CF-66) collected were above the EPA lead in drinking water action level of 20 ppb.

**Miller:**

At Pittsburgh Miller PreK-5 a total of fifty eight (58) samples were collected from thirty (30) drinking water and cooking use fixtures and faucets on June 15, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Milliones:**

At Pittsburgh Milliones 6-12 a total of fifty-seven (57) samples were collected from thirty (30) drinking water and cooking use fixtures and faucets on June 25, 2016. One (1) sample (MLO-02-NF-3) collected was above the EPA lead in drinking water action level of 20 ppb.

**Montessori:**

At Pittsburgh Montessori PreK-5 a total of fifty (50) samples were collected from twenty-six (26) drinking water and cooking use fixtures and faucets June 22, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Morrow:**

At Pittsburgh Morrow PreK-8 a total of eighty-eight (88) samples were collected from thirty-five (35) drinking water and cooking use fixtures and faucets on June 15, 2016. Three (3) samples (MOR-01-CF-38, MOR-01-WO-66 and MOR-02-OF-55) collected were above the EPA lead in drinking water action level of 20 ppb.

**Morrow Rooney:**

At Pittsburgh Morrow (Rooney) a total of fifty-seven (57) samples were collected from thirty (30) drinking water and cooking use fixtures and faucets on June 30, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Murray:**

At Pittsburgh Philip Murray, a total of forty-six (46) samples were collected from twenty-four (24) drinking water and cooking use fixtures and faucets on August 9, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Perry:**

At Pittsburgh Perry High School a total of ninety-nine (99) samples were collected from fifty-two (52) drinking water and cooking use fixtures and faucets on July 7, 2016. Two (2) samples (PER-03-CF-134 and PER-BS-MS-4) collected were above the EPA lead in drinking water action level of 20 ppb.

**Perry Field House:**

At Pittsburgh Perry Field House a total of fifteen (15) samples were collected from nine (9) drinking water and cooking use fixtures and faucets on July 7, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Pioneer:**

At Pittsburgh Pioneer a total of fifty-six (56) samples were collected from twenty-nine (29) drinking water and cooking use fixtures and faucets on June 29, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Roosevelt:**

At Pittsburgh Roosevelt 2-5 a total of thirty-four (34) samples were collected from eighteen (18) drinking water and cooking use fixtures and faucets on June 28, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Schenley Field House:**

At Pittsburgh Schenley Field House a total of seventeen (17) samples were collected from ten (10) drinking water and cooking use fixtures and faucets on June 25, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Science and Technology:**

At Pittsburgh Science and Technology 6-12 a total of sixty four (64) samples were collected from thirty three (33) drinking water and cooking use fixtures and faucets June, 18, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

**Service Center:**

At Pittsburgh Service Center, a total of thirty-two (32) samples were collected from eighteen (18) drinking water and cooking use fixtures and faucets July 13, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**South Annex:**

At Pittsburgh South Annex (Online) a total of twenty (20) samples were collected from eleven (11) drinking water and cooking use fixtures and faucets June 28, 2016. Four (4) samples (SOU-01-CF-2, SOU-01-CF-3, SOU-01-CF-5 and SOU-01-WO-41) collected were above the EPA lead in drinking water action level of 20 ppb.

**South Brook:**

At Pittsburgh South Brook a total of forty-seven (47) samples were collected from twenty-four (24) drinking water and cooking use fixtures and faucets June 29, 2016. No samples collected were above the EPA lead in drinking water action level of 20 ppb.

**Sterrett:**

At Pittsburgh Sterrett 6-8 a total of fifty-four (54) samples were collected from twenty-eight (28) drinking water and cooking use fixtures and faucets June 30, 2016. One (1) sample (STE-02-TF-75) collected was above the EPA lead in drinking water action level of 20 ppb.

**Sunnyside:**

At Pittsburgh Sunnyside PreK-8 a total of eighty-two (82) samples were collected from forty-two (42) drinking water and cooking use fixtures and faucets June 17, 2016. One (1) sample (SUN-01-CF-63) collected was above the EPA lead in drinking water action level of 20 ppb.

**Weil:**

At Pittsburgh Weil PreK-5 a total of sixty-four (64) samples were collected from thirty-three (33) drinking water and cooking use fixtures and faucets June 17, 2016. One (1) sample (WEI-02-CF-45) collected was above the EPA lead in drinking water action level of 20 ppb.

**West Liberty:**

At Pittsburgh West Liberty K-5 a total of forty-four (44) samples were collected from twenty-three (23) drinking water and cooking use fixtures and faucets on June 29, 2016. Two (2) samples (WLB-01-NF-15 and WLB-02-CF-49) collected were above the EPA lead in drinking water action level of 20 ppb.

**Westinghouse:**

At Pittsburgh Westinghouse 6-12 a total of one hundred twenty-eight (128) samples were collected from sixty-nine (69) drinking water and cooking use fixtures and faucets June 14, 2016. Two (2) samples (WES-01-MS-206 and WES-GF-NF-106) collected were above the EPA lead in drinking water action level of 20 ppb.

**Westinghouse Field House:**

At Pittsburgh Westinghouse Field House a total of eleven (11) samples were collected from seven (7) drinking water and cooking use fixtures and faucets June 14, 2016. One (1) sample (WFH-GF-MS-10) collected was above the EPA lead in drinking water action level of 20 ppb.

Table 1: Facility drinking water and cooking use fixtures and faucets along with total number of drinking water samples obtained.

School/Building	Date Sampled	Total # of Fixtures	# Samples Collected
Pittsburgh Banksville PreK-5	6/23/2016	25	48
Pittsburgh Brookline K-8	6/21/2016	46	88
Pittsburgh Carrick High School	7/6/2016	81	158
Pittsburgh Carrick Field House	7/6/2016	5	7
Pittsburgh Central Operations	7/6/2016	23	44
Pittsburgh Chartiers ECC	6/14/2016	18	34
Pittsburgh Clayton Academy	7/1/2016	22	42
Pittsburgh Crescent ECC	6/17/2016	28	54
Pittsburgh Cupples Stadium	7/8/2016	21	36
Pittsburgh Faison PreK-5	6/23/2016	41	80
Pittsburgh Greenfield PreK-8	6/16/2016	28	53
Pittsburgh King PreK-8	6/21/2016	97	192
Pittsburgh Langley K-8	7/8/2016	65	127
Pittsburgh Langley Field House	7/8/2016	8	11
Pittsburgh Lincoln K-5	6/22/2016	26	50
Pittsburgh Linden K-5	6/24/2016	24	46
Pittsburgh Manchester PreK-8	6/17/2016	41	80
Pittsburgh Miller PreK-8	6/15/2016	30	58
Pittsburgh Milliones 6-12	6/25/2016	30	57
Pittsburgh Montessori PreK-5	6/22/2016	26	50
Pittsburgh Morrow PreK-5	6/15/2016	35	88
Pittsburgh Morrow Rooney	6/30/2016	30	57
Pittsburgh Phillip Murray	8/9/2016	24	46
Pittsburgh Perry High School	7/7/2016	52	99
Pittsburgh Perry Field House	7/7/2016	9	15
Pittsburgh Pioneer	6/29/2016	29	56

School/Building	Date Sampled	Total # of Fixtures	# Samples Collected
Pittsburgh Roosevelt 2-5	6/28/2016	18	34
Pittsburgh Schenley Field House	6/25/2016	10	17
Pittsburgh Science and Technology	6/18/2016	33	64
Pittsburgh Service Center	7/13/2016	18	32
Pittsburgh South Annex (Online)	6/28/2016	11	20
Pittsburgh South Brook 6-8	6/29/2016	24	47
Pittsburgh Sterrett 6-8	6/30/2016	28	54
Pittsburgh Sunnyside PreK-8	6/17/2016	42	82
Pittsburgh Weil PreK-5	6/17/2016	33	64
Pittsburgh West Liberty K-5	6/29/2016	23	44
Pittsburgh Westinghouse 6-12	6/14/2016	69	128
Pittsburgh Westinghouse Field House	6/14/2016	7	11

#### 4. RECOMMENDATIONS

1. All drinking water sources that exceed the “3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance”, October 2006 recommended lead concentration of 20 parts per billion (ppb) or greater should be remediated to reduce lead concentrations. Remediation may include but not be limited to posting signs indicating “not for drinking”, cleaning fixtures, replace individual fixtures with lead free fixtures, replace the system or plumbing (lead solder joints or brass) with lead free materials, point of source filters and/or disabling fixtures. The remediation action will depend on the fixture and circumstances involved. Following remediation efforts before any drinking water source is placed back into service the fixture should be re-tested to ensure the lead level was reduced below the recommended lead concentration of 20 parts per billion (ppb).
2. Signs stating “Hand Wash Only” or “Not for Drinking” should be posted at designated non-drinking water sources (restrooms, science labs, utility sinks, wash sinks, etc.).

## **REPORT DISCLAIMER:**

This AGX, Inc. report is based on information supplied by the client, occupants and on conditions readily observable or measurable on the date or dates of this study. The results and recommendations presented herein should not be relied upon exclusively for the prevention of all possible illnesses, injuries, or losses. These services are a supplement to, and not a substitute for, the client's responsibility for protecting the health and safety of the occupants of the facility, and others, and for complying with applicable laws and regulations.

This report and the associated attachments and appendices have been produced and developed for, and at the request of, Pittsburgh Board of Public Education. It conveys the findings of AGX as of the date(s) noted herein. This report is intended for the exclusive use of Pittsburgh Board of Public Education (including its management, officers and the School Board).

**APPENDIX A**

**DRINKING WATER RESULTS TABLES**

## **Pittsburgh Banksville PreK-5**

---

Drinking Water Sample Results

School: Pittsburgh Banksville PreK-5

Address: 1001 Carnahan Road Pittsburgh, PA 15216

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
BAN-BS-SL-00	SL	Service Line		6/23/2016	0603	P	<1.00			
BAN-BS-WM-00	WM	Water Main		6/23/2016	0606	P	<1.00			
BAN-BS-TF-1	TF	Teacher's lounge sinks	B5	6/23/2016	0602	P	<1.00	P	<1.00	
BAN-GF-WO-5	WO	Water fountain without cooler	CORR 1	6/23/2016	0615	P	<1.00	P	<1.00	
BAN-GF-WO-6	WO	Water fountain without cooler	CORR 1	6/23/2016	0617	P	<1.00	P	<1.00	
BAN-GF-CF-7	CF	Classroom faucets	111	6/23/2016	0622	P	1.41	P	<1.00	
BAN-GF-CF-9	CF	Classroom faucets	113	6/23/2016	0623	P	2.32	P	<1.00	
BAN-GF-KF-12	KF	Kitchen faucets	12A	6/23/2016	0621	P	1.62	P	<1.00	
BAN-GF-WO-13	WO	Water fountain without cooler	MPR 12	6/23/2016	0620	P	1.53	P	<1.00	
BAN-GF-WC-17	WC	Water fountain with cooler	CORR 1	6/23/2016	0609	P	<1.00	P	<1.00	
BAN-GF-WC-18	WC	Water fountain with cooler	CORR 1	6/23/2016	0610	P	<1.00	P	<1.00	
BAN-GF-MS-19	MS	Miscellaneous sinks	NURSE	6/23/2016	0635	P	<1.00	P	<1.00	
BAN-GF-CF-21	CF	Classroom faucets	4A	6/23/2016	0638	P	<1.00	P	<1.00	
BAN-GF-CF-22	CF	Classroom faucets	7	6/23/2016	0612	P	1.68	P	<1.00	
BAN-GF-CF-23	CF	Classroom faucets	5	6/23/2016	0641	P	1.22	P	<1.00	
BAN-01-CF-28	CF	Classroom faucets	208	6/23/2016	0657	P	4.34	P	3.45	
BAN-01-WO-29	WO	Water fountain without cooler	CORR 101	6/23/2016	0654	P	<1.00	P	<1.00	
BAN-01-WO-30	WO	Water fountain without cooler	CORR 101	6/23/2016	0655	P	<1.00	P	<1.00	
BAN-01-CF-31	CF	Classroom faucets	211	6/23/2016	0700	P	6.49	P	<1.00	
BAN-01-WC-35	WC	Water fountain with cooler	CORR 101	6/23/2016	0647	P	<1.00	P	<1.00	
BAN-01-WC-36	WC	Water fountain with cooler	CORR 101	6/23/2016	0648	P	<1.00	P	<1.00	
BAN-GF-WO-43	WO	Water founain without cooler	4A	6/23/2016	0639	P	<1.00	P	<1.00	
BAN-01-CF-42	CF	Classroom faucets	109(209)	6/23/2016	0650	P	3.46	P	<1.00	
BAN-01-CF-40	CF	Classroom faucets	108(208)	6/23/2016	0658	P	14.2	P	2.01	
BAN-01-CF-41	CF	Classroom faucets	110(210)	6/23/2016	0701	P	<1.00	P	<1.00	

## **Pittsburgh Brookline K-8**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Brookline K-8

Address: 500 Woodbourne Avenue Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
BRO-GF-SL-00	SL	Service Line	15	6/21/2016	0600	P	< 1.00			
BRO-GF-WM-00	WM	Water Main	15	6/21/2016	0603	P	1.00			
BRO-GF-KF-6	KF	Kitchen faucets	3D	6/21/2016	0613	P	1.17	P	1.01	
BRO-GF-CF-24	CF	Classroom faucets	DEMOUNTABLE CLASSROOM	6/21/2016	0828	P	2.01	P	< 1.00	
BRO-GF-CF-27	CF	Classroom faucets	ANNEX BUILDING	6/21/2016	0837	P	3.71	P	< 1.00	
BRO-01-WC-32	WC	Water fountain with cooler	CORR 100	6/21/2016	0638	P	< 1.00	P	< 1.00	
BRO-01-WC-33	WC	Water fountain with cooler	CORR 100	6/21/2016	0639	P	< 1.00	P	< 1.00	
BRO-01-WC-43	WC	Water fountain with cooler	CORR 100B	6/21/2016	0709	P	< 1.00	P	< 1.00	
BRO-01-WC-44	WC	Water fountain with cooler	CORR 100B	6/21/2016	0710	P	< 1.00	P	< 1.00	
BRO-02-TF-48	TF	Teacher's lounge sinks	216	6/21/2016	0722	P	1.03	P	< 1.00	
BRO-02-WC-49	WC	Water fountain with cooler	CORR 200	6/21/2016	0728	P	< 1.00	P	< 1.00	
BRO-02-WC-50	WC	Water fountain with cooler	CORR 200	6/21/2016	0729	P	< 1.00	P	< 1.00	
BRO-02-CF-55	CF	Classroom faucets	202A							Not Functioning
BRO-02-NF-57	NF	Nurse's office sink faucets	219	6/21/2016	0727	P	2.40	P	< 1.00	
BRO-02-WC-64	WC	Water fountain with cooler	CORR 200B	6/21/2016	0754	P	< 1.00	P	< 1.00	
BRO-02-WC-65	WC	Water fountain with cooler	CORR 200B	6/21/2016	0755	P	< 1.00	P	< 1.00	
BRO-02-CF-66	CF	Classroom faucets	213	6/21/2016	0752	P	7.56	P	< 1.00	
BRO-GF-CF-71	CF	Classroom faucets	11F	6/21/2016	0626	P	1.31	P	1.33	
BRO-GF-CF-72	CF	Classroom faucets	11	6/21/2016	0630	P	1.77	P	1.43	
BRO-01-CF-73	CF	Classroom faucets	103	6/21/2016	0643	P	2.20	P	< 1.00	
BRO-01-WC-74	WC	Water fountain with cooler	CORR 100A	6/21/2016	0649	P	< 1.00	P	< 1.00	
BRO-01-WC-75	WC	Water fountain with cooler	CORR 100A	6/21/2016	0650	P	< 1.00	P	< 1.00	
BRO-01-CF-76	CF	Classroom faucets	104A	6/21/2016	0655	P	7.24	P	2.19	
BRO-01-CF-77	CF	Classroom faucets	107A	6/21/2016	0658	P	8.22	F	32.5	
BRO-01-CF-77R	CF	Classroom faucets	107A	6/21/2016	0605	P	3.87	P	<1.00	
BRO-01-CF-78	CF	Classroom faucets	105A	6/21/2016	0703	P	4.66	P	3.42	
BRO-01-CF-79	CF	Classroom faucets	106A	6/21/2016	0706	P	7.18	P	1.03	
BRO-01-MS-80	MS	Miscellaneous sinks	115	6/21/2016	0715	P	1.51	P	< 1.00	
BRO-02-WC-81	WC	Water fountain with cooler	200A	6/21/2016	0733	P	1.78	P	2.84	
BRO-02-WC-82	WC	Water fountain with cooler	200A	6/21/2016	0734	P	2.49	P	1.99	
BRO-02-CF-83	CF	Classroom faucets	206A	6/21/2016	0741	P	1.54	P	< 1.00	
BRO-02-CF-84	CF	Classroom faucets	205A	6/21/2016	0744	P	6.46	P	1.13	
BRO-GF-WO-85	WO	Water fountain without cooler	Demountable classroom	6/21/2016	0829	P	1.63	P	< 1.00	
BRO-GF-CF-86	CF	Classroom faucets	Demountable classroom	6/21/2016	0832	P	1.01	P	< 1.00	
BRO-GF-WO-87	WO	Water fountain without cooler	Demountable classroom	6/21/2016	0833	P	6.84	P	< 1.00	
BRO-GF-WO-88	WO	Water fountain without cooler	Annex	6/21/2016	0838	P	< 1.00	P	< 1.00	
BRO-GF-CF-89	CF	Classroom faucets	Annex	6/21/2016	0841	P	4.36	P	< 1.00	
BRO-GF-WO-90	WO	Water fountain without cooler	Annex	6/21/2016	0842	P	1.00	P	1.70	
BRO-GF-WC-91	WC	Water fountain with cooler	CORR 1	6/21/2016	0606	P	< 1.00	P	< 1.00	
BRO-GF-WC-92	WC	Water fountain with cooler	CORR 1	6/21/2016	0607	P	< 1.00	P	< 1.00	
BRO-GF-CF-93	CF	Classroom faucets	13	6/21/2016	0617	P	1.27	P	< 1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Brookline K-8

Address: 500 Woodbourne Avenue Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
BRO-GF-MS-94	MS	Miscellaneous sinks	11B	6/21/2016	0621	P	1.73	P	1.43	
BRO-GF-CF-95	CF	Classroom faucets	11F	6/21/2016	0625	P	1.92	P	1.32	
BRO-02-CF-96	CF	Classroom faucets	213	6/21/2016	0753	P	8.43	P	< 1.00	
BRO-GF-KF-97	KF	Kitchen faucets	3D	6/21/2016	0612	P	1.05	P	< 1.00	
BRO-GF-SL-98	SL	Service Line	STREET	6/21/2016	0813	P	1.05			
BRO-GF-WM-98	WM	Water Main	STREET	6/21/2016	0816	P	< 1.00			
BRO-02-CF-102	CF	Classroom faucets	203A	6/21/2016						Cold water not functioning

**Pittsburgh Carrick High School**

---

Drinking Water Sample Results

School: Pittsburgh Carrick High School

Address: 125 Parkfield Street, Pittsburgh PA, 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CAR-SB-SL-00	SL	Service Line	BOILER RM	7/6/2016	0603	P	< 1.00			
CAR-SB-WM-00	WM	Water Main	BOILER RM	7/6/2016	0606	P	< 1.00			
CAR-BS-WC-3	WC	Water fountain with cooler	B9	7/6/2016	0615	P	1.52	P	< 1.00	
CAR-BS-WC-5	WC	Water fountain with cooler	BS CORR	7/6/2016	0620	P	< 1.00	P	< 1.00	
CAR-BS-WC-8	WC	Water fountain with cooler	B1	7/6/2016	0618	P	< 1.00	P	1.17	
CAR-01-CF-9	CF	Classroom faucets	703	7/6/2016	0657	P	< 1.00	P	< 1.00	
CAR-01-CF-10	CF	Classroom faucets	703	7/6/2016	0656	P	< 1.00	P	< 1.00	
CAR-01-CF-11	CF	Classroom faucets	701	7/6/2016	0700	P	< 1.00	P	< 1.00	
CAR-01-WC-13	WC	Water fountain with cooler	CORR 700	7/6/2016	0730	P	< 1.00	P	< 1.00	
CAR-01-WC-14	WC	Water fountain with cooler	CORR 700	7/6/2016	0731	P	< 1.00	P	< 1.00	
CAR-01-WC-21	WC	Water fountain with cooler	CORR 700	7/6/2016	0706	P	< 1.00	P	< 1.00	
CAR-01-WC-22	WC	Water fountain with cooler	CORR 700	7/6/2016	0707	P	< 1.00	P	< 1.00	
CAR-01-WC-48	WC	Water fountain with cooler	715	7/6/2016	0714	P	< 1.00	P	< 1.00	
CAR-01-MS-56	MS	Miscellaneous sinks	704	7/6/2016	0724	P	2.89	P	< 1.00	
CAR-01-IM-57	IM	Ice machines	704	7/6/2016	0725	P	< 1.00			
CAR-01-WC-67	WC	Water fountain with cooler	728	7/6/2016	0722	P	< 1.00	P	< 1.00	
CAR-01-WC-68	WC	Water fountain with cooler	736	7/6/2016	0711	P	< 1.00	P	< 1.00	
CAR-01-WC-69	WC	Water fountain with cooler	736	7/6/2016	0712	P	< 1.00	P	< 1.00	
CAR-01-WC-84	WC	Water fountain with cooler	726	7/6/2016	0727	P	1.08	P	< 1.00	
CAR-01-WC-100	WC	Water fountain with cooler	CORR 100	7/6/2016	0644	P	3.19	P	< 1.00	
CAR-01-MS-105	MS	Miscellaneous sinks	116	7/6/2016	0646	P	< 1.00	P	< 1.00	
CAR-01-KF-107	KF	Kitchen faucets	KITCHEN	7/6/2016	0638	P	1.88	P	< 1.00	
CAR-01-KF-109	KF	Kitchen faucets	KITCHEN	7/6/2016	0639	P	1.13	P	< 1.00	
CAR-01-KF-110	KF	Kitchen faucets	KITCHEN	7/6/2016	0640	P	< 1.00	P	< 1.00	
CAR-01-KF-112	KF	Kitchen faucets	KITCHEN	7/6/2016	0641	P	1.34	P	< 1.00	
CAR-01-MS-116	MS	Miscellaneous sinks	202A	7/6/2016	0738	P	< 1.00	P	< 1.00	
CAR-01-TF-117	TF	Teacher's lounge sinks	201	7/6/2016	0737	P	1.10	P	< 1.00	
CAR-01-CF-120	CF	Classroom faucets	205	7/6/2016	0740	P	< 1.00	P	< 1.00	
CAR-01-CF-121	CF	Classroom faucets	205	7/6/2016	0741	P	< 1.00	P	< 1.00	
CAR-01-WC-122	WC	Water fountain with cooler	CORR 200	7/6/2016	0742	P	< 1.00	P	< 1.00	
CAR-01-WC-123	WC	Water fountain with cooler	CORR 200	7/6/2016	0743	P	< 1.00	P	< 1.00	
CAR-01-CF-127	CF	Classroom faucets	227	7/6/2016	0750	P	< 1.00	P	< 1.00	
CAR-01-CF-129	CF	Classroom faucets	230	7/6/2016	0752	P	2.38	P	< 1.00	
CAR-01-KF-130	KF	Kitchen faucets	226	7/6/2016	0753	P	4.06	P	< 1.00	
CAR-01-IM-131	IM	Ice machines	226	7/6/2016	0754	P	< 1.00			
CAR-01-CF-136	CF	Classroom faucets	228	7/6/2016	0803	P	< 1.00	P	< 1.00	

Drinking Water Sample Results

School: Pittsburgh Carrick High School

Address: 125 Parkfield Street, Pittsburgh PA, 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CAR-01-CF-137	CF	Classroom faucets	228	7/6/2016	0804	P	1.02	P	< 1.00	
CAR-01-CF-138	CF	Classroom faucets	228	7/6/2016	0805	P	< 1.00	P	< 1.00	
CAR-01-CF-139	CF	Classroom faucets	228	7/6/2016	0806	P	1.00	P	< 1.00	
CAR-01-CF-140	CF	Classroom faucets	228	7/6/2016	0807	P	2.68	P	< 1.00	
CAR-01-CF-141	CF	Classroom faucets	228	7/6/2016	0808	P	< 1.00	P	< 1.00	
CAR-01-KF-142	KF	Kitchen faucets	226	7/6/2016	0756	P	4.05	P	< 1.00	
CAR-01-KF-143	KF	Kitchen faucets	226	7/6/2016	0757	P	2.87	P	< 1.00	
CAR-01-KF-144	KF	Kitchen faucets	226	7/6/2016	0800	P	7.99	P	< 1.00	
CAR-01-CF-149	CF	Classroom faucets	206	7/6/2016	0747	P	1.07	P	< 1.00	
CAR-02-CF-150	CF	Classroom faucets	338	7/6/2016	0821	P	< 1.00	P	< 1.00	
CAR-02-CF-151	CF	Classroom faucets	338	7/6/2016	0820	P	< 1.00	P	< 1.00	
CAR-02-CF-152	CF	Classroom faucets	338	7/6/2016	0819	P	< 1.00	P	< 1.00	
CAR-02-WC-153	WC	Water fountain with cooler	CORR 300	7/6/2016	0825	P	< 1.00	P	< 1.00	
CAR-02-CF-154	CF	Classroom faucets	337	7/6/2016	0823	P	< 1.00	P	< 1.00	
CAR-02-CF-155	CF	Classroom faucets	337	7/6/2016	0822	P	< 1.00	P	< 1.00	
CAR-02-CF-156	CF	Classroom faucets	335	7/6/2016	0826	P	1.60	P	< 1.00	
CAR-02-WC-162	WC	Water fountain with cooler	CORR 300	7/6/2016	0829	P	< 1.00	P	1.23	
CAR-02-WC-163	WC	Water fountain with cooler	CORR 300	7/6/2016	0830	P	< 1.00	P	< 1.00	
CAR-02-MS-169	MS	Miscellaneous sinks	305	7/6/2016	0835	P	< 1.00	P	< 1.00	
CAR-02-NF-171	NF	Nurse's office sink faucets	301C	7/6/2016	0836	P	12.9	P	2.02	
CAR-02-NF-172	NF	Nurse's office sink faucets	301B	7/6/2016	0837	F	21.2	P	2.13	
CAR-02-NF-173	NF	Nurse's office sink faucets	301	7/6/2016	0838	P	< 1.00	P	< 1.00	
CAR-02-TF-174	TF	Teacher's lounge sinks	401	7/6/2016	0841	P	< 1.00	P	< 1.00	
CAR-02-WC-176	WC	Water fountain with cooler	CORR 400	7/6/2016						Not functioning
CAR-02-WC-177	WC	Water fountain with cooler	CORR 400	7/6/2016	0842	P	< 1.00	P	< 1.00	
CAR-03-WC-228	WC	Water fountain with cooler	CORR 500	7/6/2016	0854	P	< 1.00	P	< 1.00	
CAR-03-WC-339	WC	Water fountain with cooler	CORR 500	7/6/2016	0855	P	2.57	P	1.23	
CAR-03-WC-340	WC	Water fountain with cooler	CORR 500	7/6/2016	0856	P	< 1.00	P	< 1.00	
CAR-03-MS-354	MS	Miscellaneous sinks	502	7/6/2016	0858	P	< 1.00	P	< 1.00	
CAR-03-TF-355	TF	Teacher's lounge sinks	601	7/6/2016	0902	P	1.52	P	< 1.00	
CAR-03-WC-357	WC	Water fountain with cooler	CORR 600	7/6/2016	0903	P	< 1.00	P	< 1.00	
CAR-03-WC-358	WC	Water fountain with cooler	CORR 600	7/6/2016	0904	P	< 1.00	P	< 1.00	
CAR-03-MS-362	MS	Miscellaneous sinks	613	7/6/2016	0908	P	8.09	P	< 1.00	
CAR-04-TF-366	TF	Teacher's lounge sinks	801	7/6/2016	0915	P	< 1.00	P	< 1.00	
CAR-04-WC-368	WC	Water fountain with cooler	CORR 800	7/6/2016	0917	P	< 1.00	P	< 1.00	
CAR-04-WC-369	WC	Water fountain with cooler	CORR 800	7/6/2016	0918	P	< 1.00	P	1.30	

Drinking Water Sample Results

School: Pittsburgh Carrick High School

Address: 125 Parkfield Street, Pittsburgh PA, 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CAR-BS-MS-375	MS	Miscellaneous sinks	B-6	7/6/2016	0631	P	2.41	P	< 1.00	
CAR-01-WO-376	WO	Water fountain without cooler	701	7/6/2016	0659	P	< 1.00	P	< 1.00	
CAR-01-WO-377	WO	Water fountain without cooler	703	7/6/2016	0655	P	1.77	P	< 1.00	
CAR-03-WC-388	WC	Water fountain with cooler	OUTSIDE 328	7/6/2016	0921	P	1.19	P	< 1.00	
CAR-01-KF-390	KF	Kitchen faucets	226	7/6/2016	0758	P	7.15	P	< 1.00	
CAR-02-CF-393	CF	Classroom faucets	335	7/6/2016	0827	P	< 1.00	P	< 1.00	
CAR-02-CF-394	CF	Classroom faucets	338	7/6/2016	0818	P	< 1.00	P	< 1.00	
CAR-02-CF-395	CF	Classroom faucets	338	7/6/2016	0817	P	< 1.00	P	< 1.00	
CAR-02-WC-396	WC	Water fountain with cooler	418	7/6/2016	0845	P	< 1.00	P	< 1.00	
CAR-02-CF-397	CF	Classroom faucets	418	7/6/2016	0846	P	< 1.00	P	< 1.00	

**Pittsburgh Carrick Field House**

---

# Drinking Water Sample Results

School: Pittsburgh Carrick Field House

Address: Park Blvd, Pittsburgh PA, 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CFH-01-SL-00	SL	Service Line	UTILITY RM	7/6/2016	0609	P	1.09			
CFH-01-WM-00	WM	Water Main	UTILITY RM	7/6/2016	0612	P	< 1.00			
CFH-01-MS-4	MS	Miscellaneous sinks	UTILITY RM	7/6/2016	0608	P	2.52	P	< 1.00	
CFH-01-WO-16	WO	Water fountain without cooler	OUTSIDE FEILDHOUSE	7/6/2016	0613	P	< 1.00	P	< 1.00	
CFH-01-IM-19	IM	Ice machines	TRAINING ROOM	7/6/2016	0614	P	< 1.00			

## **Pittsburgh Central Operations**

---

Drinking Water Sample Results

School: Pittsburgh Central Operations

Address: 8 S 13th Street Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
COP-01-SL-00	SL	Service Line	131	7/6/2016	0434	P	<1.00			
COP-01-WM-00	WM	Water Main	131	7/6/2016	0437	P	<1.00			
COP-01-KF-4	KF	Kitchen faucets	106	7/6/2016	0443	P	<1.00	P	<1.00	
COP-01-WC-6	WC	Water fountain with cooler	CORR 117	7/6/2016	0439	P	4.38	P	1.23	
COP-01-WC-7	WC	Water fountain with cooler	CORR 117	7/6/2016	0440	P	1.37	P	<1.00	
COP-01-KF-14	KF	Kitchen faucets	154 CART WASH	7/6/2016	0507	P	1.55	P	<1.00	
COP-01-KF-15	KF	Kitchen faucets	155 CART WASH	7/6/2016	0508	P	5.40	P	<1.00	
COP-01-WC-18	WC	Water fountain with cooler	158 CART WASH	7/6/2016	0505	P	<1.00	P	1.15	
COP-01-WC-21	WC	Water fountain with cooler	147 PRODUCTION KITCHEN	7/6/2016	0449	P	1.39	P	1.67	
COP-01-KF-24	KF	Kitchen faucets	150 PRODUCTION KITCHEN	7/6/2016	0450	P	3.27	P	1.88	
COP-01-KF-25	KF	Kitchen faucets	151 PRODUCTION KITCHEN	7/6/2016	0503	P	1.73	P	<1.00	
COP-01-WC-26	WC	Water fountain with cooler	152 PRODUCTION KITCHEN	7/6/2016	0456	P	2.27	P	1.43	
COP-01-KF-28	KF	Kitchen faucets	154 PRODUCTION KITCHEN	7/6/2016	0454	P	6.87	P	<1.00	
COP-01-KF-29	KF	Kitchen faucets	155 PRODUCTION KITCHEN	7/6/2016	0455	P	2.72	P	<1.00	
COP-02-MS-30	MS	Miscellaneous sinks	CONFERENCE ROOM	7/6/2016	0515	P	1.48	P	1.51	
COP-02-WC-31	WC	Water fountain with cooler	ELEVATOR LOBBY	7/6/2016	0513	P	<1.00	P	<1.00	
COP-02-WC-32	WC	Water fountain with cooler	ELEVATOR LOBBY	7/6/2016	0514	P	<1.00	P	<1.00	
COP-03-MS-38	MS	Miscellaneous sinks	204 COFFEE	7/6/2016	0526	P	1.94	P	<1.00	
COP-03-WC-39	WC	Water fountain with cooler	OFFICE AREA	7/6/2016	0522	P	<1.00	P	<1.00	
COP-03-WC-40	WC	Water fountain with cooler	OFFICE AREA	7/6/2016	0523	P	<1.00	P	<1.00	
COP-03-MS-55	MS	Miscellaneous sinks	PLANT OPERATIONS	7/6/2016	0534	P	<1.00	P	<1.00	
COP-03-WC-58	WC	Water fountain with cooler	CORR 233	7/6/2016	0536	P	<1.00	P	<1.00	
COP-03-WC-59	WC	Water fountain with cooler	CORR 233	7/6/2016	0537	P	<1.00	P	<1.00	

## **Pittsburgh Chartiers Early Childhood Center**

Lead in Drinking Water Sample Results

School: Pittsburgh Chartiers Early Childhood Center

Address: 3799 Chartiers Avenue Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CHA-01-WM-00	WM	Water Main	113	6/14/2016	0609	P	< 1.00			
CHA-01-SL-00	SL	Service Line	113	6/14/2016	0606	P	< 1.00			
CHA-01-CF-1	CF	Classroom faucets	105	6/14/2016	0620	P	1.85	P	< 1.00	
CHA-01-WO-3	WO	Water fountain without cooler	101	6/14/2016	0624	P	3.54	P	1.11	
CHA-01-CF-4	CF	Classroom faucets	101	6/14/2016	0625	P	< 1.00	P	< 1.00	
CHA-01-WO-5	WO	Water fountain without cooler	Cor 100	6/14/2016	0604	P	1.71	P	< 1.00	
CHA-01-NF-11	NF	Nurse's office sink faucets	102	6/14/2016	0616	P	6.13	P	2.24	
CHA-01-WO-13	WO	Water fountain without cooler	Cor 100	6/14/2016	0613	P	1.72	P	1.01	
CHA-01-KF-15	KF	Kitchen faucets	121-B	6/14/2016	0632	P	< 1.00	P	< 1.00	
CHA-01-WO-16	WO	Water fountain without cooler	121	6/14/2016	0635	P	3.23	P	1.35	
CHA-01-WO-17	WO	Water fountain without cooler	121	6/14/2016	0638	F	34.6	P	11.5	
CHA-01-TF-23	TF	Teacher's lounge sinks	124	6/14/2016	0646	P	4.13	P	1.04	
CHA-01-WO-24	WO	Water fountain without cooler	ENTRY 101A	6/14/2016	0641	P	4.01	P	1.95	
CHA-01-WO-25	WO	Water fountain without cooler	ENTRY 101A	6/14/2016	0642	P	1.62	P	1.44	
CHA-01-CF-31	CF	Classroom faucets	202	6/14/2016	0651	P	2.43	P	1.32	
CHA-01-CF-32	CF	Classroom faucets	201	6/14/2016	0648	P	12.9	P	4.02	
CHA-01-CF-33	CF	Classroom faucets	204	6/14/2016	0654	P	5.32	P	1.17	
CHA-01-CF-34	CF	Classroom faucets	206	6/14/2016	0656	P	1.37	P	< 1.00	

## **Pittsburgh Clayton Academy**

---

Drinking Water Sample Results

School: Pittsburgh Clayton Academy

Address: 1901 Clayton Avenue Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CLA-BS-SL-00	SL	Service Line	BOILER ROOM	7/1/2016	0614	P	<1.00			
CLA-BS-WM-00	WM	Water Main	BOILER ROOM	7/1/2016	0617	P	<1.00			
CLA-BS-MS-2	MS	Miscellaneous sinks	BOOKROOM	7/1/2016	0618	P	<1.00	P	<1.00	
CLA-GF-WC-3	WC	Water fountain with cooler	GYM	7/1/2016	0622	P	<1.00	P	<1.00	
CLA-GF-KF-6	KF	Kitchen faucets	KITCHEN	7/1/2016	0625	P	1.29	P	<1.00	
CLA-GF-KF-9	KF	Kitchen faucets	KITCHEN	7/1/2016	0626	P	2.45	P	1.23	
CLA-01-NF-13	NF	Nurse's office sink faucets	NURSE	7/1/2016	0658	P	7.02	P	2.37	
CLA-01-WC-16	WC	Water fountain with cooler	OUTSIDE 104B	7/1/2016	0631	P	1.80	P	2.20	
CLA-01-WC-17	WC	Water fountain with cooler	OUTSIDE 104B	7/1/2016	0632	P	1.78	P	1.87	
CLA-01-MS-20	MS	Miscellaneous sinks	LUNCH AREA A	7/1/2016	0636	P	<1.00	P	<1.00	
CLA-01-WC-21	WC	Water fountain with cooler	LUNCH AREA A	7/1/2016	0638	P	<1.00	P	<1.00	
CLA-01-WC-23	WC	Water fountain with cooler	OUTSIDE 108	7/1/2016	0648	P	1.44	P	1.73	
CLA-01-WC-24	WC	Water fountain with cooler	OUTSIDE 108	7/1/2016	0649	P	1.20	P	1.31	
CLA-GF-MS-28	MS	Miscellaneous sinks	LUNCH AREA B	7/1/2016	0650	P	1.18	P	<1.00	
CLA-01-WC-29	WC	Water fountain with cooler	LUNCH AREA B	7/1/2016	0651	P	<1.00	P	<1.00	
CLA-02-WC-33	WC	Water fountain with cooler	LUNCH AREA D	7/1/2016	0701	P	<1.00	P	<1.00	
CLA-02-MS-34	MS	Miscellaneous sinks	LUNCH AREA D	7/1/2016	0700	P	<1.00	P	<1.00	
CLA-02-WC-39	WC	Water fountain with cooler	ACROSS 203	7/1/2016	0703	P	1.79	P	1.98	
CLA-02-WC-40	WC	Water fountain with cooler	ACROSS 203	7/1/2016	0704	P	1.76	P	1.98	
CLA-02-WC-42	WC	Water fountain with cooler	OUTSIDE 205	7/1/2016						Not Functioning
CLA-02-WC-43	WC	Water fountain with cooler	OUTSIDE 205	7/1/2016	0707	P	1.10	P	1.12	
CLA-02-WC-47	WC	Water fountain with cooler	LUNCH AREA C	7/1/2016	0710	P	<1.00	P	<1.00	
CLA-02-MS-48	MS	Miscellaneous sinks	LUNCH AREA C	7/1/2016	0709	P	1.20	P	<1.00	

**Pittsburgh Crescent Early Childhood Center**

Drinking Water Sample Results

School: Pittsburgh Crescent Early Childhood Center

Address: 8080 Bennett Street, Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)	Comments
CRE-BS-SL-00	SL	Service Line	Boiler Rm	6/17/2016	0602	P	2.00			
CRE-BS-WM-00	WM	Water Main	Boiler Rm	6/17/2016	0606	P	3.11			
CRE-BS-WC-1	WC	Water fountain with cooler	Corridor 9	6/17/2016	0600	P	14.2	P	6.63	
CRE-01-WO-8	WO	Water fountain without cooler	Corridor 100	6/17/2016	0623	P	1.05	P	<1.00	
CRE-01-WC-9	WC	Water fountain with cooler	Corridor 100	6/17/2016	0624	P	<1.00	P	<1.00	
CRE-01-WO-10	WO	Water fountain without cooler	Corridor 100	6/17/2016	0635	P	1.20	P	<1.00	
CRE-01-WC-11	WC	Water fountain with cooler	Corridor 100	6/17/2016	0637	P	<1.00	P	<1.00	
CRE-01-CF-15	CF	Classroom faucets	115	6/17/2016	0643	P	<1.00	P	1.54	
CRE-01-CF-16	CF	Classroom faucets	115	6/17/2016	0644	P	<1.00	P	<1.00	
CRE-01-CF-20	CF	Classroom faucets	105	6/17/2016	0617	P	<1.00	P	<1.00	
CRE-01-CF-23	CF	Classroom faucets	101	6/17/2016	0649	P	1.67	P	<1.00	
CRE-01-CF-24	CF	Classroom faucets	101	6/17/2016	0650	P	1.67	P	<1.00	
CRE-01-KF-28	KF	Kitchen faucets	Lobby	6/17/2016	0656	P	1.61	P	<1.00	
CRE-02-WO-34	WO	Water fountain without cooler	Corridor 200	6/17/2016	0700	P	1.25	P	<1.00	
CRE-02-WC-35	WC	Water fountain with cooler	Corridor 200	6/17/2016	0702	P	<1.00	P	<1.00	
CRE-02-CF-36	CF	Classroom faucets	Library	6/17/2016	0707	P	1.04	P	<1.00	
CRE-02-WO-37	WO	Water fountain without cooler	Corridor 200	6/17/2016	0704	P	<1.00	P	2.65	
CRE-02-WC-38	WC	Water fountain with cooler	Corridor 200	6/17/2016	0705	P	<1.00	P	<1.00	
CRE-02-CF-42	CF	Classroom faucets	207	6/17/2016	0710	P	3.20	P	<1.00	
CRE-03-WO-47	WO	Water fountain without cooler	Corridor 300	6/17/2016	0740	P	<1.00	P	<1.00	
CRE-03-WC-48	WC	Water fountain with cooler	Corridor 300	6/17/2016	0742	P	<1.00	P	<1.00	
CRE-03-CF-49	CF	Classroom faucets	304	6/17/2016	0758	P	3.63	P	1.59	
CRE-03-CF-50	CF	Classroom faucets	303	6/17/2016	0800	P	9.27	P	1.16	
CRE-03-WO-51	WO	Water fountain without cooler	Corridor 300	6/17/2016	0750	P	<1.00	P	<1.00	
CRE-03-WC-52	WC	Water fountain with cooler	Corridor 300	6/17/2016	0752	P	<1.00	P	<1.00	
CRE-02-CF-56	CF	Classroom faucets	207	6/17/2016	0711	P	5.97	P	1.04	
CRE-02-CF-57	CF	Classroom faucets	207	6/17/2016	0715	P	5.48	P	1.40	
CRE-03-CF-58	CF	Classroom faucets	303	6/17/2016	0801	P	<1.00	P	2.98	

## Pittsburgh Cupples Stadium

---

Drinking Water Sample Results

School: Pittsburgh Cupples Stadium

Address: 800 E. Carson Street, Pittsburgh PA, 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
CUP-GF-SL-00	SL	Service Line	STORAGE 102	7/8/2016	0611	P	< 1.00			
CUP-GF-WM-00	WM	Water Main	STORAGE 102	7/8/2016	0614	P	< 1.00			
CUP-GF-WO-1	WO	Water fountain without cooler	MENS RR	7/8/2016	0615	P	8.83	P	1.02	
CUP-GF-WO-4	WO	Water fountain without cooler	WOMENS RR	7/8/2016	0617	P	9.93	P	1.15	
CUP-GF-MS-5	MS	Miscellaneous sinks	FIRST AID	7/8/2016	0609	P	4.66	P	1.09	
CUP-GF-WC-20	WC	Water fountain with cooler	LOCKER ROOM	7/8/2016	0630	P	< 1.00	P	< 1.00	
CUP-GF-IM-21	IM	Ice machines	LOCKER ROOM	7/8/2016						Not functioning
CUP-GF-WC-25	WC	Water fountain with cooler	CORR 109	7/8/2016	0633	P	< 1.00	P	< 1.00	
CUP-GF-IM-31	IM	Ice machines	LOCKER ROOM	7/8/2016						Not functioning
CUP-GF-IM-32	IM	Ice machines	115	7/8/2016	0705	P	< 1.00			
CUP-GF-WC-34	WC	Water fountain with cooler	LOCKER ROOM	7/8/2016	0638	P	< 1.00	P	< 1.00	
CUP-GF-WO-47	WO	Water fountain without cooler	WOMENS RR	7/8/2016	0643	P	5.43	P	3.11	
CUP-GF-WO-50	WO	Water fountain without cooler	MENS RR	7/8/2016	0644	P	8.69	P	8.14	
CUP-01-MS-53	MS	Miscellaneous sinks	PRESSBOX	7/8/2016	0700	P	3.15	P	< 1.00	
CUP-GF-IM-58	IM	Ice machines	CONCESSION	7/8/2016	0712	P	< 1.00			
CUP-GF-KF-59	KF	Kitchen faucets	CONCESSION	7/8/2016	0710	P	9.74	P	< 1.00	
CUP-GF-KF-60	KF	Kitchen faucets	CONCESSION	7/8/2016	0711	P	11.7	P	< 1.00	
CUP-GF-WO-65	WO	Water fountain without cooler	PUBLIC RR	7/8/2016	0724	F	64.8	F	24.2	
CUP-GF-WO-66	WO	Water fountain without cooler	PUBLIC RR	7/8/2016	0725	F	45.1	P	8.14	
CUP-GF-KF-71	KF	Kitchen faucets	GROUNDKEEPER	7/8/2016	0636	P	< 1.00	P	< 1.00	
CUP-GF-SL-72	SL	Service Line	PUBLIC RR	7/8/2016	0718	P	4.53			
CUP-GF-WM-73	WM	Water Main	PUBLIC RR	7/8/2016	0721	P	2.67			



Drinking Water Sample Results

School: Pittsburgh Faison PreK-5

Address: 7430 Tioga Street, Pittsburgh PA, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
FAI-01-SL-00	SL	Service Line	133	6/23/2016	0606	P	<1.00			
FAI-01-WM-00	WM	Water Main	133	6/23/2016	0610	P	<1.00			
FAI-01-KF-3	KF	Kitchen faucets	125A	6/23/2016	0612	P	1.02	P	<1.00	
FAI-01-WC-4	WC	Water fountain with cooler	CAFÉ LOBBY	6/23/2016	0616	P	<1.00	P	<1.00	
FAI-01-WC-5	WC	Water fountain with cooler	CAFÉ LOBBY	6/23/2016	0617	P	<1.00	P	<1.00	
FAI-01-MS-16	MS	Miscellaneous sinks	139	6/23/2016	0623	P	<1.00	P	<1.00	
FAI-01-WC-17	WC	Water fountain with cooler	GALLERY 100	6/23/2016	0628	P	<1.00	P	<1.00	
FAI-01-WC-18	WC	Water fountain with cooler	GALLERY 100	6/23/2016	0629	P	<1.00	P	<1.00	
FAI-01-CF-22	CF	Classroom faucets	101	6/23/2016	0635	P	1.02	P	<1.00	
FAI-01-WC-23	WC	Water fountain with cooler	OUTSIDE 105A	6/23/2016	0637	P	<1.00	P	<1.00	
FAI-01-WC-24	WC	Water fountain with cooler	OUTSIDE 105A	6/23/2016	0638	P	<1.00	P	<1.00	
FAI-01-MS-27	MS	Miscellaneous sinks	105	6/23/2016	0639	P	<1.00	P	<1.00	
FAI-01-MS-30	MS	Miscellaneous sinks	122A	6/23/2016	0641	P	2.17	P	<1.00	
FAI-01-NF-32	NF	Nurse's office sink faucets	121B	6/23/2016	0642	P	<1.00	P	<1.00	
FAI-01-CF-33	CF	Classroom faucets	119	6/23/2016	0644	P	1.54	P	1.06	
FAI-01-CF-34	CF	Classroom faucets	119	6/23/2016	0645	P	1.80	P	1.23	
FAI-01-CF-35	CF	Classroom faucets	119	6/23/2016	0646	P	1.19	P	<1.00	
FAI-01-WC-36	WC	Water fountain with cooler	OUTSIDE 110A	6/23/2016	0649	P	<1.00	P	<1.00	
FAI-01-WC-37	WC	Water fountain with cooler	OUTSIDE 110A	6/23/2016	0650	P	<1.00	P	1.12	
FAI-01-MS-40	MS	Miscellaneous sinks	110	6/23/2016	0651	P	1.43	P	1.75	
FAI-01-MS-44	MS	Miscellaneous sinks	117A	6/23/2016	0654	P	1.29	P	1.19	
FAI-01-CF-45	CF	Classroom faucets	109	6/23/2016	0652	P	1.50	P	2.21	
FAI-01-CF-46	CF	Classroom faucets	111	6/23/2016	0657	P	1.45	P	1.42	
FAI-01-WC-48	WC	Water fountain with cooler	OUTSIDE 115A	6/23/2016	0659	P	1.15	P	1.19	
FAI-01-WC-49	WC	Water fountain with cooler	OUTSIDE 115A	6/23/2016	0700	P	1.36	P	1.41	
FAI-01-MS-52	MS	Miscellaneous sinks	115	6/23/2016	0702	P	1.96	P	1.92	
FAI-01-CF-57	CF	Classroom faucets	114	6/23/2016	0703	P	1.39	P	<1.00	
FAI-02-WC-59	WC	Water fountain with cooler	OUTSIDE 205A	6/23/2016	0710	P	<1.00	P	<1.00	
FAI-02-WC-60	WC	Water fountain with cooler	OUTSIDE 205A	6/23/2016	0711	P	<1.00	P	<1.00	
FAI-02-MS-63	MS	Miscellaneous sinks	205	6/23/2016	0712	P	1.17	P	1.56	
FAI-02-CF-66	CF	Classroom faucets	204	6/23/2016	0720	P	6.82	P	<1.00	
FAI-02-MS-67	MS	Miscellaneous sinks	204A	6/23/2016	0721	P	14.3	P	<1.00	
FAI-02-CF-68	CF	Classroom faucets	206	6/23/2016	0722	P	2.62	P	<1.00	
FAI-02-WC-69	WC	Water fountain with cooler	OUTSIDE 210A	6/23/2016	0724	P	<1.00	P	<1.00	
FAI-02-WC-70	WC	Water fountain with cooler	OUTSIDE 210A	6/23/2016	0725	P	<1.00	P	<1.00	
FAI-02-MS-73	MS	Miscellaneous sinks	210	6/23/2016	0726	P	1.69	P	1.51	

# Drinking Water Sample Results

School: Pittsburgh Faison PreK-5

Address: 7430 Tioga Street, Pittsburgh PA, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
FAI-02-TF-76	TF	Teacher's lounge sinks	221	6/23/2016	0728	P	1.77	P	1.78	
FAI-02-WC-82	WC	Water fountain with cooler	OUTSIDE 215A	6/23/2016	0732	P	<1.00	P	<1.00	
FAI-02-WC-83	WC	Water fountain with cooler	OUTSIDE 215A	6/23/2016	0733	P	<1.00	P	1.31	
FAI-02-MS-86	MS	Miscellaneous sinks	215	6/23/2016	0734	P	1.34	P	1.46	
FAI-01-KF-90	KF	Kitchen faucets	125 A	6/23/2016	0613	P	3.14	P	<1.00	

## **Pittsburgh Greenfield PreK-8**

---

## Drinking Water Sample Results

School: Pittsburgh Greenfield PreK-8

Address: 1 Alger Street, Pittsburgh PA, 15207

Fixture ID	Fixture Symbol	Fixture Type	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
GRE-BS-SL-0	SL	Service Line	6/16/2016	0624	P	<1.00			
GRE-BS-WM-0	WM	Water Main	6/16/2016	0627	P	<1.00			
GRE-BS-MS-2	MS	Miscellaneous sinks	6/16/2016	0755	P	1.10	P	<1.00	
GRE-BS-MS-3	MS	Miscellaneous sinks	6/16/2016	0753	P	1.26	P	<1.00	
GRE-BS-WC-4	WC	Water fountain with cooler	6/16/2016	0620	P	<1.00	P	<1.00	
GRE-BS-WC-5	WC	Water fountain with cooler	6/16/2016	0621	P	<1.00	P	<1.00	
GRE-BS-WC-6	WC	Water fountain with cooler	6/16/2016	0622	P	1.18	P	<1.00	
GRE-BS-WC-7	WC	Water fountain with cooler	6/16/2016	0623	P	<1.00	P	<1.00	
GRE-01-CF-9	CF	Classroom faucets	6/16/2016	0635	F	29	P	5.26	
GRE-01-WC-10	WC	Water fountain with cooler	6/16/2016	0636	P	<1.00	P	<1.00	
GRE-01-WC-12	WC	Water fountain with cooler	6/16/2016	0639	P	3.61	P	3.88	
GRE-01-WC-32	WC	Water fountain with cooler	6/16/2016	0648	P	1.90	P	2.24	
GRE-01-MS-37	MS	Miscellaneous sinks	6/16/2016	0643	P	16.0	P	2.56	
GRE-01-CF-39	CF	Classroom faucets	6/16/2016	0649	P	<1.00	P	<1.00	
GRE-01-CF-40	CF	Classroom faucets	6/16/2016	0650	P	4.97	P	2.07	
GRE-01-KF-41	KF	Kitchen faucets	6/16/2016	0658	P	1.52	P	1.89	
GRE-01-KF-42	KF	Kitchen faucets	6/16/2016	0659	P	1.86			
GRE-02-WC-47	WC	Water fountain with cooler	6/16/2016	0706	P	<1.00	P	<1.00	
GRE-02-MS-48	MS	Miscellaneous sinks	6/16/2016	0705	P	<1.00	P	<1.00	
GRE-02-NF-49	NF	Nurse's office sink faucets	6/16/2016	0710	P	<1.00	P	<1.00	
GRE-02-WC-51	WC	Water fountain with cooler	6/16/2016	0717	P	1.90	P	2.28	
GRE-02-TF-58	TF	Teacher's lounge sinks	6/16/2016	0716	P	<1.00	P	<1.00	
GRE-02-CF-59	CF	Classroom faucets	6/16/2016	0721	P	4.57	P	1.38	
GRE-02-WO-60	WO	Water fountain without cooler	6/16/2016	0720	P	4.77	P	1.27	
GRE-03-WC-66	WC	Water fountain with cooler	6/16/2016	0727	P	<1.00	P	<1.00	
GRE-03-CF-67	CF	Classroom faucets	6/16/2016	0730	P	18.6	P	2.70	
GRE-03-CF-69	CF	Classroom faucets	6/16/2016	0736	P	10.1	P	9.33	
GRE-03-WC-70	WC	Water fountain with cooler	6/16/2016	0739	P	1.92	P	2.49	
GRE-BS-WO-77	WO	Water fountain without cooler							Not Functioning
GRE-BS-WO-76	WO	Water fountain without cooler							Not Functioning





Drinking Water Sample Results

School: Pittsburgh King PreK-8

Address: 50 Montgomery Pl., Pittsburgh PA, 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
KIN-02-WC-88	WC	Water fountain with cooler	266	6/21/2016	0747	P	1.08	P	1.08	
KIN-02-CF-91	CF	Classroom faucets	268	6/21/2016	0751	P	4.59	P	4.44	
KIN-02-CF-92	CF	Classroom faucets	270	6/21/2016	0757	P	3.67	P	1.40	
KIN-03-CF-96	CF	Classroom faucets	A1	6/21/2016	0817	P	2.75	P	3.54	
KIN-03-CF-97	CF	Classroom faucets	A2	6/21/2016	0819	P	3.22	P	1.97	
KIN-03-CF-98	CF	Classroom faucets	A3	6/21/2016	0819	P	2.25	P	1.70	
KIN-03-CF-99	CF	Classroom faucets	A5	6/21/2016	0821	P	2.40	P	2.98	
KIN-03-CF-100	CF	Classroom faucets	A6	6/21/2016	0820	P	10.4	P	3.08	
KIN-03-CF-101	CF	Classroom faucets	A7	6/21/2016	0822	P	2.74	P	5.61	
KIN-03-CF-102	CF	Classroom faucets	B1	6/21/2016	0809	P	2.00	P	<1.00	
KIN-03-CF-103	CF	Classroom faucets	B2	6/21/2016	0808	P	5.34	P	7.75	
KIN-03-CF-104	CF	Classroom faucets	B3	6/21/2016	0810	P	4.19	P	1.45	
KIN-03-CF-105	CF	Classroom faucets	B5	6/21/2016	0811	P	5.73	P	1.99	
KIN-03-CF-106	CF	Classroom faucets	B6	6/21/2016	0810	P	6.85	P	1.63	
KIN-03-CF-107	CF	Classroom faucets	B7	6/21/2016	0813	P	7.40	P	3.33	
KIN-03-WC-113	WC	Water fountain with cooler	CORR 335	6/21/2016	0826	P	2.36	P	2.61	
KIN-03-WC-114	WC	Water fountain with cooler	CORR 335	6/21/2016	0827	P	1.48	P	3.16	
KIN-03-CF-126	CF	Classroom faucets	F3	6/21/2016	0830	P	5.49	P	3.48	
KIN-03-CF-127	CF	Classroom faucets	F2	6/21/2016	0829	P	4.63	P	1.08	
KIN-03-CF-128	CF	Classroom faucets	F1	6/21/2016	0831	P	6.26	P	1.16	
KIN-03-WC-129	WC	Water fountain with cooler	CORR 335	6/21/2016	0832	P	1.27	P	<1.00	
KIN-03-WC-130	WC	Water fountain with cooler	CORR 335	6/21/2016	0833	P	<1.00	P	<1.00	
KIN-03-CF-134	CF	Classroom faucets	E1	6/21/2016	0910	P	3.88	P	2.81	
KIN-03-CF-135	CF	Classroom faucets	E2	6/21/2016	0909	P	5.11	P	1.81	
KIN-03-CF-136	CF	Classroom faucets	E3	6/21/2016	0912	P	4.57	P	3.47	
KIN-03-CF-137	CF	Classroom faucets	E5	6/21/2016	0913	P	8.19	P	6.69	
KIN-03-CF-138	CF	Classroom faucets	E6	6/21/2016	0916	P	13.4	P	17.0	
KIN-03-CF-139	CF	Classroom faucets	E7	6/21/2016	0914	P	12.4	P	5.66	
KIN-03-CF-140	CF	Classroom faucets	D1	6/21/2016	0848	P	3.04	P	2.27	
KIN-03-CF-141	CF	Classroom faucets	D2	6/21/2016	0851	P	3.41	P	2.14	
KIN-03-CF-142	CF	Classroom faucets	D3	6/21/2016	0851	P	3.46	P	1.65	
KIN-03-CF-143	CF	Classroom faucets	D5	6/21/2016	0854	P	1.72	P	1.81	
KIN-03-CF-144	CF	Classroom faucets	D6	6/21/2016	0859	P	5.39	P	2.62	
KIN-03-CF-145	CF	Classroom faucets	D7	6/21/2016	0856	P	9.83	P	4.32	
KIN-03-WC-146	WC	Water fountain with cooler	CORR 358	6/21/2016	0837	P	<1.00	P	<1.00	
KIN-03-WC-147	WC	Water fountain with cooler	CORR 358	6/21/2016	0838	P	<1.00	P	<1.00	
KIN-03-CF-159	CF	Classroom faucets	C1	6/21/2016	0839	P	7.73	P	5.57	
KIN-03-CF-160	CF	Classroom faucets	C2	6/21/2016	0840	P	8.19	P	2.75	
KIN-03-CF-161	CF	Classroom faucets	C3	6/21/2016	0841	P	9.70	P	2.54	
KIN-03-WC-166	WC	Water fountain with cooler	CORR 358	6/21/2016	0837	P	1.61	P	1.11	
KIN-03-WC-167	WC	Water fountain with cooler	CORR 358	6/21/2016	0838	P	1.00	P	<1.00	
KIN-01-WO-168	WO	Water fountain without cooler	111	6/21/2016						Not Functioning

Drinking Water Sample Results

School: Pittsburgh King PreK-8

Address: 50 Montgomery Pl., Pittsburgh PA, 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
KIN-01-WO-169	WO	Water fountain without cooler	119	6/21/2016	0638	P	<1.00	P	<1.00	
KIN-01-WO-170	WO	Water fountain without cooler	184	6/21/2016	0651	P	4.44	P	7.70	
KIN-01-MS-171	MS	Miscellaneous sinks	181	6/21/2016	0656	P	19.6	P	8.60	
KIN-02-WO-173	WO	Water fountain without cooler	219	6/21/2016	0727	P	2.94	P	1.41	
KIN-02-WO-174	WO	Water fountain without cooler	217	6/21/2016						Not Functioning
KIN-02-CF-175	CF	Classroom faucets	268	6/21/2016	0757	P	6.26	P	2.52	
KIN-02-WO-176	WO	Water fountain without cooler	268	6/21/2016						Not Functioning
KIN-02-CF-177	CF	Classroom faucets	270	6/21/2016	0758	P	7.38	P	2.20	
KIN-02-WO-178	WO	Water fountain without cooler	270	6/21/2016	0759	P	1.72	P	1.20	
KIN-03-WO-179	WO	Water fountain without cooler	B3	6/21/2016	0811	P	2.65	P	3.56	
KIN-03-WO-180	WO	Water fountain without cooler	B5	6/21/2016						Not Functioning
KIN-03-WO-181	WO	Water fountain without cooler	B6	6/21/2016						Not Functioning
KIN-03-WO-182	WO	Water fountain without cooler	B7	6/21/2016						Not Functioning
KIN-03-WO-183	WO	Water fountain without cooler	B1	6/21/2016						Not Functioning
KIN-03-WO-184	WO	Water fountain without cooler	B2	6/21/2016						Not Functioning
KIN-03-WO-185	WO	Water fountain without cooler	A1	6/21/2016						Not Functioning
KIN-03-WO-186	WO	Water fountain without cooler	A2	6/21/2016						Not Functioning
KIN-03-WO-187	WO	Water fountain without cooler	A3	6/21/2016						Not Functioning
KIN-03-WO-188	WO	Water fountain without cooler	A5	6/21/2016						Not Functioning
KIN-03-WO-189	WO	Water fountain without cooler	A6	6/21/2016	0822	P	3.40	P	1.77	
KIN-03-WO-190	WO	Water fountain without cooler	A7	6/21/2016						Not Functioning
KIN-03-WO-191	WO	Water fountain without cooler	F3	6/21/2016	0831	P	4.71	P	5.68	
KIN-03-WO-192	WO	Water fountain without cooler	F2	6/21/2016						Not Functioning
KIN-03-WO-193	WO	Water fountain without cooler	F1	6/21/2016	0832	P	4.95	P	2.87	
KIN-03-WO-194	WO	Water fountain without cooler	C1	6/21/2016						Not Functioning
KIN-03-WO-195	WO	Water fountain without cooler	C2	6/21/2016						Not Functioning
KIN-03-WO-196	WO	Water fountain without cooler	C3	6/21/2016						Not Functioning
KIN-03-WO-197	WO	Water fountain without cooler	D1	6/21/2016						Not Functioning
KIN-03-WO-198	WO	Water fountain without cooler	D2	6/21/2016	0852	P	2.30	P	1.18	
KIN-03-WO-199	WO	Water fountain without cooler	D3	6/21/2016						Not Functioning
KIN-03-WO-200	WO	Water fountain without cooler	D5	6/21/2016	0855	P	1.62	P	1.55	
KIN-03-WO-201	WO	Water fountain without cooler	D6	6/21/2016	0902	P	1.92	P	1.74	
KIN-03-WO-202	WO	Water fountain without cooler	D7	6/21/2016						Not Functioning
KIN-03-WO-203	WO	Water fountain without cooler	E1	6/21/2016	0910	P	2.28	P	1.84	
KIN-03-WO-204	WO	Water fountain without cooler	E2	6/21/2016						Not Functioning
KIN-03-WO-205	WO	Water fountain without cooler	E3	6/21/2016	0913	P	2.24	P	2.74	
KIN-03-WO-206	WO	Water fountain without cooler	E5	6/21/2016						Not Functioning
KIN-03-WO-207	WO	Water fountain without cooler	E6	6/21/2016						Not Functioning
KIN-03-WO-208	WO	Water fountain without cooler	E7	6/21/2016	0915	P	10.6	P	5.93	





Lead in Drinking Water Sample Results

School: Pittsburgh Langley K-8

Address: 2940 Sheraden Blvd. Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LAN-02-CF-215	CF	Classroom faucets	210	7/8/2016	0830	P	2.28	P	<1.00	
LAN-02-CF-216	CF	Classroom faucets	210	7/8/2016	0831	P	4.19	P	1.03	
LAN-02-CF-217	CF	Classroom faucets	210	7/8/2016	0832	F		P	2.44	
LAN-02-CF-218	CF	Classroom faucets	210	7/8/2016	0833	P	8.56	P	1.48	
LAN-02-CF-219	CF	Classroom faucets	210	7/8/2016	0834	P	8.83	P	1.30	
LAN-02-WC-220	WC	Water fountain with cooler	CORR 200							REMOVED
LAN-02-WC-221	WC	Water fountain with cooler	CORR 200							REMOVED
LAN-02-CF-228	CF	Classroom faucets	216							NOT FUNCTIONING
LAN-02-MS-232	MS	Miscellaneous sinks	218	7/8/2016	0841	P	7.61	P	2.41	
LAN-02-CF-233	CF	Classroom faucets	219	7/8/2016	0844	P	3.36	P	<1.00	
LAN-02-CF-234	CF	Classroom faucets	219	7/8/2016	0845	P	6.48	P	1.29	
LAN-02-WC-239	WC	Water fountain with cooler	CORR 200C	7/8/2016	0846	P	5.21	P	3.75	
LAN-02-WC-240	WC	Water fountain with cooler	CORR 200C	7/8/2016	0847	P	2.59	P	2.26	
LAN-02-WC-245	WC	Water fountain with cooler	CORR 200B	7/8/2016	0851	P	<1.00	P	<1.00	
LAN-02-WC-246	WC	Water fountain with cooler	CORR 200B	7/8/2016	0852	P	<1.00	P	2.30	
LAN-02-TF-248	TF	Teacher's lounge sinks	234	7/8/2016	0855	P	<1.00	P	<1.00	
LAN-02-WC-250	WC	Water fountain with cooler	CORR 236A							REMOVED
LAN-02-WC-251	WC	Water fountain with cooler	CORR 236A							REMOVED
LAN-02-WC-259	WC	Water fountain with cooler	CORR 236E	7/8/2016	0858	P	<1.00	P	<1.00	
LAN-02-WC-260	WC	Water fountain with cooler	CORR 236E	7/8/2016	0859	P	<1.00	P	<1.00	
LAN-02-CF-261	CF	Classroom faucets	242	7/8/2016	0903	P	9.63	P	1.48	
LAN-02-CF-262	CF	Classroom faucets	242	7/8/2016	0904	P	3.12	P	1.79	
LAN-02-CF-263	CF	Classroom faucets	244	7/8/2016	0905	P	4.62	P	<1.00	
LAN-02-CF-264	CF	Classroom faucets	244	7/8/2016	0906	P	4.69	P	<1.00	
LAN-02-CF-265	CF	Classroom faucets	248	7/8/2016	0907	P	1.94	P	<1.00	
LAN-01-CF-266	CF	Classroom faucets	248	7/8/2016	0908	P	1.72	P	<1.00	
LAN-03-MS-267	MS	Miscellaneous sinks	301	7/8/2016	0914	P	18.5	P	<1.00	
LAN-02-CF-268	CF	Classroom faucets	217	7/8/2016	0843	P	1.17	P	9.48	
LAN-02-CF-270	CF	Classroom faucets	207	7/8/2016	0825	P	18.6	P	2.60	
LAN-02-WC-271	WC	Water fountain with cooler	CORR 200	7/8/2016	0822	F	112	F	161	
LAN-02-WC-272	WC	Water fountain with cooler	CORR 200	7/8/2016	0823	F	217	F	81.9	
LAN-01-CF-274	CF	Classroom faucets	131	7/8/2016	0751	F	20.8	P	17.2	
LAN-01-CF-275	CF	Classroom faucets	131	7/8/2016	0752	P	17.8	P	14.9	
LAN-GF-WC-277	WC	Water fountain with cooler	OUTSIDE 41	7/8/2016	0703	P	<1.00	P	<1.00	

## **Pittsburgh Langley Field House**

---

# Drinking Water Sample Results

School: Pittsburgh Langley Field House

Address: 2940 Sheradon Blvd. Pittsburgh, PA 15204

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LFH-01-SL-00	SL	Service Line	Lower Restroom	7/8/2016	0621	P	<1.00			
LFH-GF-SL-0	SL	Service Line	Utility Room	7/8/2016	0634	P	6.16			
LFH-01-WM-00	WM	Water Main	Lower Restroom	7/8/2016	0622	P	<1.00			
LFH-GF-WM-0	WM	Water Main	Utility Room	7/8/2016	0637	P	3.66			
LFH-GF-WC-1	WC	Water fountain with cooler	Locker Room	7/8/2016	0639	P	2.81	P	3.42	
LFH-01-WO-3	WO	Water fountain without cooler	Lower Storage Room	7/8/2016						Not Functioning
LFH-02-WO-4	WO	Water fountain without cooler	Restroom	7/8/2016	0620	P	3.41	P	1.25	
LFH-02-IM-12	IM	Ice machines	Men's Restroom	7/8/2016	0627	P	1.22			
LFH-02-WO-14	WO	Water fountain without cooler	Restroom	7/8/2016	0626	P	2.04	P	<1.00	



Drinking Water Sample Results

School: Pittsburgh Lincoln K-5

Address: 328 Lincoln Avenue, 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LIN-BS-SL-0	SL	Service Line	BOILER RM	6/22/2016	0616	P	1.67			
LIN-BS-WM-0	WM	Water Main	BOILER RM	6/22/2016	0619	P	1.68			
LIN-01-MS-3	MS	Miscellaneous sinks	110A	6/22/2016	0621	P	<1.00	P	<1.00	
LIN-01-WC-5	WC	Water fountain with cooler	CORR 100	6/22/2016	0623	P	3.50	P	3.33	
LIN-01-WC-6	WC	Water fountain with cooler	CORR 100	6/22/2016	0624	P	3.79	P	2.63	
LIN-01-CF-11	CF	Classroom faucets	115	6/22/2016	0626	P	<1.00	P	<1.00	
LIN-01-CF-13	CF	Classroom faucets	117	6/22/2016	0627	P	1.41	P	<1.00	
LIN-01-TF-15	TF	Teacher's lounge sinks	138	6/22/2016						Not Functioning
LIN-01-NF-16	NF	Nurse's office sink faucets	136	6/22/2016	0629	P	14.0	P	3.66	
LIN-01-WC-19	WC	Water fountain with cooler	CORR 100	6/22/2016	0632	P	1.44	P	1.51	
LIN-01-CF-20	CF	Classroom faucets	130	6/22/2016	0630	P	1.08	P	<1.00	
LIN-01-CF-21	CF	Classroom faucets	130	6/22/2016	0631	P	<1.00	P	<1.00	
LIN-01-KF-22	KF	Kitchen faucets	129	6/22/2016						Not Functioning
LIN-01-WC-23	WC	Water fountain with cooler	CORR 100G	6/22/2016	0635	P	1.06	P	1.24	
LIN-01-WC-24	WC	Water fountain with cooler	CORR 100G	6/22/2016	0636	P	1.17	P	<1.00	
LIN-01-KF-25	KF	Kitchen faucets	129	6/22/2016	0634	P	<1.00	P	<1.00	
LIN-02-WC-33	WC	Water fountain with cooler	CORR 200	6/22/2016	0641	P	2.64	P	3.26	
LIN-02-WC-34	WC	Water fountain with cooler	CORR 200	6/22/2016	0642	P	3.82	P	4.23	
LIN-02-CF-37	CF	Classroom faucets	216	6/22/2016	0640	p	1.11	P	<1.00	
LIN-02-CF-40	CF	Classroom faucets	205							Not Functioning
LIN-02-CF-41	CF	Classroom faucets	205	6/22/2016	0643	P	15.4	P	3.05	
LIN-02-WC-44	WC	Water fountain with cooler	CORR 200	6/22/2016	0644	P	<1.00	P	<1.00	
LIN-03-WC-46	WC	Water fountain with cooler	CORR 300	6/22/2016	0650	P	3.90	P	4.23	
LIN-03-WC-47	WC	Water fountain with cooler	CORR 300	6/22/2016	0651	P	3.48	P	2.98	
LIN-03-CF-50	CF	Classroom faucets	306	6/22/2016	0651	P	1.01	P	<1.00	
LIN-03-CF-51	CF	Classroom faucets	306	6/22/2016	0652	P	<1.00	P	<1.00	
LIN-03-WC-54	WC	Water fountain with cooler	CORR 300	6/22/2016	0655	P	<1.00	P	1.32	
LIN-03-CF-57	CF	Classroom faucets	306	6/22/2016	0653	P	<1.00	P	<1.00	
LIN-01-MS-58	MS	Miscellaneous sinks	107A	6/22/2016	0625	F	71.3	P	6.62	



Drinking Water Sample Results

School: Pittsburgh Linden K-5

Address: 725 S. Linden Avenue, Pittsburgh PA, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
LND-SB-SL-00	SL	Service Line	OUTSIDE B-11	6/24/2016	0613	P	<1.00			
LND-SB-WM-00	WM	Water Main	OUTSIDE B-11	6/24/2016	0616	P	<1.00			
LND-BS-CF-8	CF	Classroom faucets	1A	6/24/2016	0642	F	166	P	3.22	
LND-BS-NF-9	NF	Nurse's office sink faucets	2A	6/24/2016	0638	P	9.93	P	2.56	
LND-BS-WO-10	WO	Water fountain without cooler	CORR C	6/24/2016	0640	P	3.74	P	1.91	
LND-BS-WO-18	WO	Water fountain without cooler	CORR A	6/24/2016	0627	P	1.47	P	<1.00	
LND-BS-MS-19	MS	Miscellaneous sinks	3A	6/24/2016	0628	F	21.1	P	3.37	
LND-BS-CF-20	CF	Classroom faucets	11	6/24/2016	0631	P	5.38	P	<1.00	
LND-BS-CF-21	CF	Classroom faucets	9	6/24/2016	0633	P	3.88	P	<1.00	
LND-BS-CF-22	CF	Classroom faucets	10	6/24/2016	0634	P	2.10	P	<1.00	
LND-01-CF-27	CF	Classroom faucets	102							Not Functioning
LND-01-CF-30	CF	Classroom faucets	101	6/24/2016	0655	P	19.6	P	3.68	
LND-01-WO-34	WO	Water fountain without cooler	CORR 100	6/24/2016	0652	P	9.53	P	5.19	
LND-01-WO-40	WO	Water fountain without cooler	CORR 100	6/24/2016	0658	P	7.03	P	5.38	
LND-01-WO-41	WO	Water fountain without cooler	CORR 100	6/24/2016	0659	P	5.62	P	5.34	
LND-02-TF-42	TF	Teacher's lounge sinks	202B	6/24/2016	0706	P	5.06	P	<1.00	
LND-02-CF-44	CF	Classroom faucets	202	6/24/2016	0715	P	4.35	P	1.25	
LND-02-WO-47	WO	Water fountain without cooler	CORR 200	6/24/2016	0711	P	3.22	P	1.58	
LND-02-WO-48	WO	Water fountain without cooler	CORR 200	6/24/2016	0712	P	2.86	P	1.21	
LND-02-WO-49	WO	Water fountain without cooler	CORR 200	6/24/2016	0716	P	5.83	P	4.22	
LND-02-WO-50	WO	Water fountain without cooler	CORR 200	6/24/2016	0717	P	7.36	P	3.84	
LND-BS-WO-54	WO	Water fountain without cooler	B-13	6/24/2016	0611	P	<1.00	P	1.06	
LND-BS-WO-55	WO	Water fountain without cooler	B-12	6/24/2016	0620	P	1.05	P	<1.00	
LND-BS-CF-56	CF	Classroom faucets	1-A	6/24/2016	0643	F	31.2	P	3.77	
LND-02-WO-57	WO	Water fountain without cooler	CORR 200	6/24/2016	0709	P	1.92	P	3.44	
LND-02-WO-58	WO	Water fountain without cooler	CORR 200	6/24/2016						Not Functioning
LND-01-CF-59	CF	Classroom faucets	103	6/24/2016						Not Functioning

## **Pittsburgh Manchester PreK-8**

---

Drinking Water Sample Results

School: Pittsburgh Manchester PreK-8

Address: 1612 Manhattan Street, 15233

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MAN-01-SL-0	SL	Service Line	BOILER ROOM	6/17/2016	0601	P	1.41			
MAN-01-WM-0	WM	Water Main	BOILER ROOM	6/17/2016	0604	P	1.41			
MAN-01-NF-3	NF	Nurse's office sink faucets	115	6/17/2016	0607	P	<1.00	P	<1.00	
MAN-01-WO-4	WO	Water fountain without cooler	CORRIDOR 120	6/17/2016	0610	P	1.47	P	1.53	
MAN-01-CF-5	CF	Classroom faucets	114	6/17/2016	0613	P	3.33	P	1.87	
MAN-01-CF-6	CF	Classroom faucets	113	6/17/2016	0615	P	9.62	P	1.89	
MAN-01-CF-10	CF	Classroom faucets	112	6/17/2016	0620	P	7.31	P	2.32	
MAN-01-CF-12	CF	Classroom faucets	106	6/17/2016	0625	P	7.63	P	5.4	
MAN-01-WC-22	WC	Water fountain with cooler	CORR 148	6/17/2016	0608	P	2.37	P	2.95	
MAN-01-CF-28	CF	Classroom faucets	128	6/17/2016	0650	P	2.51	P	<1.00	
MAN-01-CF-31	CF	Classroom faucets	128	6/17/2016	0612	P	4.07	P	<1.00	
MAN-01-CF-32	CF	Classroom faucets	127	6/17/2016	0617	P	1.94	P	1.46	
MAN-01-CF-33	CF	Classroom faucets	127	6/17/2016	0653	P	3.27	P	<1.00	
MAN-01-CF-34	CF	Classroom faucets	149	6/17/2016	0623	P	6.13	P	1.46	
MAN-01-CF-35	CF	Classroom faucets	150	6/17/2016	0627	P	5.6	P	1.33	
MAN-01-WO-36	WO	Water fountain without cooler	CORRIDOR 154	6/17/2016						Not Functioning
MAN-01-CF-37	CF	Classroom faucets	151	6/17/2016	0632	P	4.25	P	1.68	
MAN-01-CF-38	CF	Classroom faucets	152	6/17/2016	0635	P	9.48	P	2.27	
MAN-01-CF-39	CF	Classroom faucets	162	6/17/2016	0638	F	26.8	P	4.4	
MAN-01-MS-40	MS	Miscellaneous sinks	CORRIDOR 157	6/17/2016	0639	P	7.67	P	1.8	
MAN-01-WO-43	WO	Water fountain without cooler	CORRIDOR 108	6/17/2016	0646	P	3.88	P	1.41	
MAN-02-WO-45	WO	Water fountain without cooler	CORRIDOR 220	6/17/2016	0700	P	2.61	P	1.5	
MAN-02-CF-46	CF	Classroom faucets	212	6/17/2016	0705	P	10.5	P	1.99	
MAN-02-TF-48	TF	Teacher's lounge sinks	207	6/17/2016	0716	P	5.75	P	1.59	
MAN-02-CF-49	CF	Classroom faucets	201	6/17/2016	0719	P	15.2	P	3.26	
MAN-02-WO-51	WO	Water fountain without cooler	CORRIDOR 213	6/17/2016	0721	P	2.25	P	<1.00	
MAN-02-WC-58	WC	Water fountain with cooler	CORRIDOR 237	6/17/2016	0701	P	1.87	P	2.2	
MAN-02-CF-65	CF	Classroom faucets	239	6/17/2016	0709	P	6.18	P	2.73	
MAN-02-CF-66	CF	Classroom faucets	240	6/17/2016	0711	F	21.4	P	6.15	
MAN-02-CF-67	CF	Classroom faucets	241	6/17/2016	0714	P	16.3	P	3.17	
MAN-02-CF-68	CF	Classroom faucets	242	6/17/2016	0717	P	7.51	P	1.42	
MAN-02-WO-69	WO	Water fountain without cooler	CORRIDOR 244	6/17/2016	0719	P	5.32	P	1.38	
MAN-02-CF-70	CF	Classroom faucets	200	6/17/2016	0722	P	5.31	P	<1.00	
MAN-01-WO-72	WO	Water fountain without cooler	127	6/17/2016	0618	P	5.01	P	1.72	
MAN-01-WO-71	WO	Water fountain without cooler	128	6/17/2016	0614	P	1.51	P	2.81	

Drinking Water Sample Results

School: Pittsburgh Manchester PreK-8

Address: 1612 Manhattan Street, 15233

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MAN-01-WO-73	WO	Water fountain without cooler	CORRIDOR 157	6/17/2016	0640	P	3.19	P	<1.00	
MAN-01-MS-42	MS	Miscellaneous sinks	163	6/17/2016	0634	P	1.55	P	<1.00	
MAN-01-MS-8	MS	Miscellaneous sinks	111	6/17/2016	0630	P	7.76	P	2.83	
MAN-02-MS-53	MS	Miscellaneous sinks	224	6/17/2016	0701	P	11.8	P	6.72	
MAN-02-CF-74	CF	Classroom faucets	225	6/17/2016	0703	P	8.31	P	1.74	
MAN-02-WO-75	WO	Water fountain without cooler	212	6/17/2016	0711	P	5.01	P	1.55	
MAN-02-CF-76	CF	Classroom faucets	205	6/17/2016	0725	P	2.66	P	1.71	
MAN-02-WO-77	WO	Water fountain without cooler	106	6/17/2016						Not Functioning
MAN-02-WO-78	WO	Water fountain without cooler	111	6/17/2016						Not Functioning
MAN-02-WO-79	WO	Water fountain without cooler	112	6/17/2016						Not Functioning
MAN-02-WO-80	WO	Water fountain without cooler	113	6/17/2016						Not Functioning
MAN-02-WO-81	WO	Water fountain without cooler	114	6/17/2016						Not Functioning
MAN-02-WO-82	WO	Water fountain without cooler	149	6/17/2016						Not Functioning
MAN-02-WO-83	WO	Water fountain without cooler	150	6/17/2016						Not Functioning
MAN-02-WO-84	WO	Water fountain without cooler	151	6/17/2016						Not Functioning
MAN-02-WO-85	WO	Water fountain without cooler	152	6/17/2016						Not Functioning
MAN-02-WO-86	WO	Water fountain without cooler	162	6/17/2016						Not Functioning
MAN-02-WO-87	WO	Water fountain without cooler	200	6/17/2016						Not Functioning
MAN-02-WO-88	WO	Water fountain without cooler	201	6/17/2016						Not Functioning
MAN-02-WO-89	WO	Water fountain without cooler	207	6/17/2016						Not Functioning
MAN-02-WO-90	WO	Water fountain without cooler	239	6/17/2016						Not Functioning
MAN-02-WO-91	WO	Water fountain without cooler	240	6/17/2016						Not Functioning
MAN-02-WO-92	WO	Water fountain without cooler	241	6/17/2016						Not Functioning



Drinking Water Sample Results

School: Pittsburgh Miller PreK-5

Address: 2055 Bedford Ave., Pittsburgh PA, 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)	Comments
MIL-GF-SL-00	SL	Service Line	17A	6/15/2016	0611	P	<1.00			
MIL-GF-WM-00	WM	Water Main	17A	6/15/2016	0615	P	<1.00			
MIL-GF-WO-1	WO	Water fountain without cooler	CORR 1A	6/15/2016	0610	P	1.43	P	<1.00	
MIL-GF-WO-2	WO	Water fountain without cooler	CORR 1A	6/15/2016	0616	P	1.11	P	<1.00	
MIL-GF-KF-9	KF	Kitchen faucets	2	6/15/2016	0621	P	1.53	P	<1.00	
MIL-GF-CF-12	CF	Classroom faucets	17	6/15/2016	0626	P	<1.00	P	<1.00	
MIL-GF-CF-13	CF	Classroom faucets	16	6/15/2016	0630	P	<1.00	P	<1.00	
MIL-GF-WO-14	WO	Water fountain without cooler	16	6/15/2016						Not Functioning
MIL-GF-CF-15	CF	Classroom faucets	15	6/15/2016	0634	P	<1.00	P	<1.00	
MIL-GF-CF-17	CF	Classroom faucets	7	6/15/2016	0636	P	<1.00	P	<1.00	
MIL-GF-WC-20	WC	Water fountain with cooler	ENTRY 1C	6/15/2016	0638	P	<1.00	P	<1.00	
MIL-GF-WC-21	WC	Water fountain with cooler	ENTRY 1C	6/15/2016	0639	P	<1.00	P	<1.00	
MIL-GF-CF-29	CF	Classroom faucets	11	6/15/2016	0643	P	1.56	P	1.77	
MIL-01-TF-30	TF	Teacher's lounge sinks	117	6/15/2016	0655	P	1.53	P	<1.00	
MIL-01-NF-33	NF	Nurse's office sink faucets	105	6/15/2016	0650	P	<1.00	P	<1.00	
MIL-01-CF-34	CF	Classroom faucets	114A	6/15/2016	0647	P	1.81	P	<1.00	
MIL-01-CF-35	CF	Classroom faucets	106A	6/15/2016	0659	P	2.7	P	1.96	
MIL-01-CF-36	CF	Classroom faucets	113A	6/15/2016	0701	P	13.8	P	2.69	
MIL-01-CF-39	CF	Classroom faucets	112A	6/15/2016	0708	P	1.57	P	<1.00	
MIL-01-CF-40	CF	Classroom faucets	107A	6/15/2016	0705	P	1.79	P	<1.00	
MIL-01-WC-44	WC	Water fountain with cooler	CORR 100	6/15/2016	0711	P	<1.00	P	<1.00	
MIL-01-WC-45	WC	Water fountain with cooler	CORR 100	6/15/2016	0712	P	<1.00	P	<1.00	
MIL-01-CF-49	CF	Classroom faucets	110	6/15/2016	0715	P	3.3	P	<1.00	
MIL-02-CF-50	CF	Classroom faucets	202A	6/15/2016	0720	P	4.49	P	2.49	
MIL-02-CF-52	CF	Classroom faucets	212	6/15/2016						Not Identified
MIL-02-CF-53	CF	Classroom faucets	211A	6/15/2016	0718	P	3.33	P	1.08	
MIL-02-CF-55	CF	Classroom faucets	210	6/15/2016						Not Functioning
MIL-02-CF-57	CF	Classroom faucets	209A	6/15/2016	0730	P	<1.00	P	<1.00	
MIL-02-CF-59	CF	Classroom faucets	206	6/15/2016	0727	P	10.7	P	1.44	
MIL-02-WC-63	WC	Water fountain with cooler	CORR 200	6/15/2016	0731	P	<1.00	P	<1.00	
MIL-02-WC-64	WC	Water fountain with cooler	CORR 200	6/15/2016	0732	P	<1.00	P	<1.00	
MIL-GF-KF-68	KF	Kitchen faucets	2	6/15/2016	0622	P	3.96	P	<1.00	
MIL-GF-WO-69	WO	Water fountain without cooler	7	6/15/2016	0637	P	<1.00	P	<1.00	

## **Pittsburgh Millions 6-12**

---

Drinking Water Sample Results

School: Pittsburgh Milliones 6-12

Address: 3117 Centre Avenue Pittsburgh, PA 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MLO-02-SL-00	SL	Service Line	259	6/25/2016	0644	P	1.48			
MLO-02-WM-00	WM	Water Main	259	6/25/2016	0647	P	1.13			
MLO-02-NF-3	NF	Nurse's office sink faucets	251	6/25/2016	0650	F	21.0	P	2.05	
MLO-02-NF-4	NF	Nurse's office sink faucets	253	6/25/2016	0651	P	6.16	P	1.44	
MLO-02-WFC-09	WC	Water fountain with cooler	CORR 240	6/25/2016	0654	P	< 1.00	P	< 1.00	
MLO-02-WC-13	WC	Water fountain with cooler	242	6/25/2016	0657	P	< 1.00	P	1.43	
MLO-02-CF-28	CF	Classroom faucets	223	6/25/2016	0700	P	4.05	P	< 1.00	
MLO-02-WC-36	WC	Water fountain with cooler	220	6/25/2016	0701	P	1.28	P	2.91	
MLO-02-WC-41	WC	Water fountain with cooler	CORR 240	6/25/2016	0705	P	< 1.00	P	< 1.00	
MLO-02-KF-45	KF	Kitchen faucets	234	6/25/2016	0710	P	7.42	P	1.54	
MLO-02-KF-47	KF	Kitchen faucets	234	6/25/2016	0712	P	2.09	P	< 1.00	
MLO-02-IM-49	IM	Ice machines	236	6/25/2016	0714	P	< 1.00			
MLO-01-MS-55	MS	Miscellaneous sinks	118	6/25/2016	0722	P	< 1.00	P	< 1.00	
MLO-01-WC-57	WC	Water fountain with cooler	129	6/25/2016	0720	P	2.35	P	4.47	
MLO-01-WC-64	WC	Water fountain with cooler	CORR 115	6/25/2016	0738	P	< 1.00	P	< 1.00	
MLO-01-CF-66	CF	Classroom faucets	110	6/25/2016	0733	P	2.44	P	< 1.00	
MLO-01-CF-67	CF	Classroom faucets	110	6/25/2016	0734	P	1.72	P	< 1.00	
MLO-01-CF-68	CF	Classroom faucets	110	6/25/2016	0735	P	3.13	P	1.44	
MLO-03-WC-80	WC	Water fountain with cooler	CORR 353	6/25/2016	0746	P	< 1.00	P	< 1.00	
MLO-03-WC-87	WC	Water fountain with cooler	CORR 329	6/25/2016	0748	P	< 1.00	P	1.25	
MLO-03-WC-114	WC	Water fountain with cooler	OUTSIDE 343	6/25/2016	0747	P	6.88	P	8.15	
MLO-04-TF-116	TF	Teacher's lounge sinks	437	6/25/2016	0756	P	< 1.00	P	< 1.00	
MLO-04-MS-119	MS	Miscellaneous sinks	430-A	6/25/2016	0759	P	< 1.00	P	< 1.00	
MLO-04-WC-123	WC	Water fountain with cooler	CORR 426	6/25/2016	0802	P	< 1.00	P	< 1.00	
MLO-04-WC-124	WC	Water fountain with cooler	CORR 415	6/25/2016	0804	P	< 1.00	P	1.02	
MLO-05-WC-149	WC	Water fountain with cooler	CORR 506B	6/25/2016	0810	P	< 1.00	P	< 1.00	
MLO-05-MS-154	MS	Miscellaneous sinks	519	6/25/2016	0812	P	1.01	P	< 1.00	
MLO-05-MS-155	MS	Miscellaneous sinks	519	6/25/2016	0813	P	1.70	P	3.79	
MLO-05-WC-156	WC	Water fountain with cooler	CORR 506A	6/25/2016	0815	P	< 1.00	P	< 1.00	
MLO-02-KF-161	KF	Kitchen faucets	234	6/25/2016	0713	P	2.00	P	< 1.00	

## **Pittsburgh Montessori PreK-5**

---

Drinking Water Sample Results

School: Pittsburgh Montessori PreK-5

Address: 201 S. Graham Street Pittsburgh, PA 15206

Fixture ID	School Code	Building Level	Fixture Symbol	Fixture Number	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MON-BS-SL-00	MON	BS	SL	00	Service Line	1	6/22/2016	0559	P	2.04			
MON-BS-WM-00	MON	BS	WM	00	Water Main	1	6/22/2016	0602	P	8.51			
MON-BS-NF-1	MON	BS	NF	1	Nurse's office sink faucets	Nurse	6/22/2016	0557	P	4.23	P	2.93	
MON-BS-CF-2	MON	BS	CF	2	Classroom faucets	Outside Rm 9	6/22/2016	0605	P	1.05	P	1.13	
MON-BS-CF-5	MON	BS	CF	5	Classroom faucets	10	6/22/2016	0606	P	11.0	P	1.72	
MON-GF-CF-8	MON	GF	CF	8	Classroom faucets	Remote ClassRm	6/22/2016	0615	P	1.66	P	1.38	
MON-GF-CF-10	MON	GF	CF	10	Classroom faucets	Remote ClassRm	6/22/2016	0614	P	1.33	P	1.33	
MON-01-MS-11	MON	01	MS	11	Miscellaneous sinks	103	6/22/2016	0626	P	7.29	P	1.47	
MON-01-WO-12	MON	01	WO	12	Water fountain without cooler	101	6/22/2016	0625	P	19.1	P	1.39	
MON-01-WO-15	MON	01	WO	15	Water fountain without cooler	CORR 100	6/22/2016	0634	P	2.71	P	1.45	
MON-01-WO-16	MON	01	WO	16	Water fountain without cooler	CORR 100	6/22/2016						Not Functioning
MON-01-CF-20	MON	01	CF	20	Classroom faucets	104	6/22/2016	0636	P	12.4	P	1.51	
MON-01-WO-21	MON	01	WO	21	Water fountain without cooler	100A	6/22/2016	0645	P	1.75	P	1.09	
MON-01-WO-22	MON	01	WO	22	Water fountain without cooler	100A	6/22/2016	0646	P	3.04	P	1.18	
MON-01-KF-26	MON	01	KF	26	Kitchen faucets	111B	6/22/2016	0648	P	1.97	P	1.17	
MON-01-CF-27	MON	01	CF	27	Classroom faucets	107 C	6/22/2016	0638	P	9.51	P	1.61	
MON-01-CF-28	MON	01	CF	28	Classroom faucets	109	6/22/2016	0642	P	7.69	P	1.51	
MON-01-WO-29	MON	01	WO	29	Water fountain without cooler	CORR 100	6/22/2016						Not Functioning
MON-01-WO-30	MON	01	WO	30	Water fountain without cooler	CORR 100	6/22/2016	0641	P	1.98	P	1.80	
MON-02-CF-34	MON	02	CF	34	Classroom faucets	201	6/22/2016	0657	P	4.03	P	4.25	
MON-02-CF-35	MON	02	CF	35	Classroom faucets	203A	6/22/2016						Not Functioning
MON-02-WF-36	MON	02	WF	36	Water fountain without cooler	CORR 200	6/22/2016	0659	P	2.34	P	2.68	
MON-02-WF-37	MON	02	WF	37	Water fountain without cooler	CORR 200	6/22/2016	0700	P	3.94	P	3.07	
MON-02-TF-40	MON	02	TF	40	Teacher's lounge sinks	205	6/22/2016	0702	P	2.81	P	4.08	
MON-02-CF-42	MON	02	CF	42	Classroom faucets	207A	6/22/2016	0703	P	17.9	P	4.73	
MON-02-CF-43	MON	02	CF	43	Classroom faucets	209A	6/22/2016	0705	P	6.60	P	1.83	
MON-02-WO-44	MON	02	WO	44	Water fountain without cooler	CORR 200	6/22/2016	0707	P	4.75	P	1.34	
MON-02-WO-45	MON	02	WO	45	Water fountain without cooler	CORR 200	6/22/2016						Not Functioning
MON-BS-CF-49	MON	BS	CF	49	Classroom faucets	103	6/22/2016	0628	P	1.22	P	<1.00	
MON-BS-WO-50	MON	BS	WO	50	Water fountain without cooler	103	6/22/2016	0629	P	1.22	P	3.26	
MON-BS-WO-51	MON	BS	WO	51	Water fountain without cooler	Remote ClassRm	6/22/2016						Not Functioning



## Lead in Drinking Water Sample Results

School: Pittsburgh Morrow PreK-8

Address: 1611 Davis Avenue Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MOR-BS-CF-12	CF	Classroom faucets	SHOP	6/15/2016	0608	P	4.12	P	<1.00	
MOR-BS-CF-13	CF	Classroom faucets	SHOP	6/15/2016	0609	P	2.95	P	<1.00	
MOR-BS-CF-21	CF	Classroom faucets	19B Cloak Room	6/15/2016	0617	P	<1.00	P	<1.00	
MOR-01-CF-24	CF	Classroom faucets	105	6/15/2016	0626	P	6.02	P	<1.00	
MOR-01-CF-25	CF	Classroom faucets	104	6/15/2016	0629	P	9.37	P	1.74	
MOR-01-CF-28	CF	Classroom faucets	102	6/15/2016	0636	P	7.33	P	1.89	
MOR-01-CF-29	CF	Classroom faucets	101	6/15/2016	0639	P	4.77	P	1.7	
MOR-01-CF-37	CF	Classroom faucets	108	6/15/2016	0649	P	10.7	P	4.85	
MOR-01-CF-38	CF	Classroom faucets	110	6/15/2016	0652	F	21.6	P	2.68	
MOR-01-CF-44	CF	Classroom faucets	116	6/15/2016	0655	P	3.4	P	<1.00	
MOR-02-CF-45	CF	Classroom faucets	205	6/15/2016	0702	P	4.28	P	1.33	
MOR-02-CF-46	CF	Classroom faucets	204	6/15/2016	0703	P	3.42	P	1.17	
MOR-02-CF-47	CF	Classroom faucets	207	6/15/2016	0706	P	18.9	P	3.21	
MOR-02-CF-48	CF	Classroom faucets	201	6/15/2016	0707	P	4.59	P	2.58	
MOR-02-CF-63	CF	Classroom faucets	218	6/15/2016	0718	P	3.96	P	2.01	
MOR-01-MS-43	MS	Miscellaneous sinks	118	6/15/2016	0657	P	1.13	P	<1.00	
MOR-01-NF-34	NF	Nurse's office sink faucets	109	6/15/2016	0642	P	5.51	P	1.39	
MOR-02-OF-53	OF	Office sink faucets	209	6/15/2016	0713	P	5.08	P	1.8	
MOR-02-OF-55	OF	Office sink faucets	213	6/15/2016	0714	F	34.8	P	6.3	
MOR-BS-SL-00	SL	Service Line	4A	6/15/2016	0556	P	1.35			
MOR-BS-WC-8	WC	Water fountain with cooler	CORR 1	6/15/2016	0600	P	3.88	P	11	
MOR-BS-WC-9	WC	Water fountain with cooler	CORR 1	6/15/2016	0601	P	2.89	P	13.6	
MOR-BS-WC-17	WC	Water fountain with cooler	CORR 1G	6/15/2016	0611	P	<1.00	P	<1.00	
MOR-BS-WC-18	WC	Water fountain with cooler	CORR 1G	6/15/2016	0612	P	<1.00	P	<1.00	
MOR-01-WC-30	WC	Water fountain with cooler	CORR 100	6/15/2016	0639	P	<1.00	P	<1.00	
MOR-01-WC-31	WC	Water fountain with cooler	CORR 100	6/15/2016	0640	P	<1.00	P	<1.00	
MOR-01-WC-41	WC	Water fountain with cooler	CORR 100	6/15/2016	0653	P	<1.00	P	1.23	
MOR-01-WC-42	WC	Water fountain with cooler	CORR 100	6/15/2016	0654	P	1.35	P	1.39	
MOR-02-WC-49	WC	Water fountain with cooler	CORR 200	6/15/2016	0710	P	<1.00	P	1.03	
MOR-02-WC-50	WC	Water fountain with cooler	CORR 200	6/15/2016	0711	P	1.09	P	<1.00	
MOR-02-WC-58	WC	Water fountain with cooler	CORR 200	6/15/2016	0715	P	1.11	P	1.39	
MOR-02-WC-59	WC	Water fountain with cooler	CORR 200	6/15/2016	0716	P	1.47	P	1.57	
MOR-BS-WO-1	WO	Water fountain without cooler	1B	6/15/2016	0559	P	2.63	P	1.51	
MOR-BS-WO-19	WO	Water fountain without cooler	19B	6/15/2016	0616	P	2.36	P	1.31	
MOR-01-WO-26	WO	Water fountain without cooler	CORR 100A	6/15/2016	0632	P	2.71	P	<1.00	
MOR-01-WO-27	WO	Water fountain without cooler	CORR 100A	6/15/2016	0633	P	4.28	P	1.15	
MOR-02-WO-61	WO	Water fountain without cooler	CORR 200F	6/15/2016	0720	P	4.55	P	3.44	
MOR-02-WO-62	WO	Water fountain without cooler	CORR 200F	6/15/2016	0721	P	5.17	P	3.22	
MOR-BS-WM-00	WM	Water Main	4A	6/15/2016	0558	P	1.41			
MOR-BS-MS-10	MS	Miscellaneous sinks	6	6/15/2016	0606	P	<1.00	P	<1.00	

Lead in Drinking Water Sample Results

School: Pittsburgh Morrow PreK-8

Address: 1611 Davis Avenue Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MOR-BS-CF-69	CF	Classroom faucets	19B	6/15/2016	0619	P	<1.00	P	<1.00	
MOR-01-CF-64	CF	Classroom faucets	106	6/15/2016	0645	P	4.48	P	2.22	
MOR-01-WO-66	WO	Water fountain without cooler	110	6/15/2016	0650	F	25.6	P	3.78	
MOR-02-WO-67	WO	Water fountain without cooler	CORR 200A	6/15/2016	0705	P	2.99	P	<1.00	
MOR-02-WO-68	WO	Water fountain without cooler	CORR 200A	6/15/2016	0706	P	2.51	P	1.15	

## **Pittsburgh Morrow (Rooney)**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Morrow (Rooney)

Address: 3530 Fleming Avenue Pittsburgh PA, 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
MRN-BS-SL-00	SL	Service Line	018	6/30/2016	0613	P	<1.00			
MRN-BS-WM-00	WM	Water Main	018	6/30/2016	0616	P	<1.00			
MRN-BS-CF-1	CF	Classroom faucets	22	6/30/2016	0632	P	4.13	P	<1.00	
MRN-BS-CF-2	CF	Classroom faucets	2	6/30/2016	0631	P	1.44	P	<1.00	
MRN-BS-CF-3	CF	Classroom faucets	2	6/30/2016	0629	P	2.31	P	<1.00	
MRN-BS-CF-5	CF	Classroom faucets	1	6/30/2016	0612	P	1.89	P	<1.00	
MRN-BS-CF-6	CF	Classroom faucets	1	6/30/2016	0617	P	3.37	P	<1.00	
MRN-BS-CF-7	CF	Classroom faucets	1A	6/30/2016	0618	P	11.2	P	1.23	
MRN-BS-WO-12	WO	Water fountain without cooler	CORR 022	6/30/2016						
MRN-BS-WO-14	WO	Water fountain without cooler	CORR 022	6/30/2016	0658	P	<1.00	P	<1.00	
MRN-BS-CF-18	CF	Classroom faucets	3	6/30/2016	0701	P	1.48	P	<1.00	
MRN-BS-CF-19	CF	Classroom faucets	3	6/30/2016	0702	P	<1.00	P	<1.00	
MRN-BS-CF-20	CF	Classroom faucets	3	6/30/2016						Not Observed
MRN-BS-KF-24	KF	Kitchen faucets	33	6/30/2016	0644	P	2.31	P	<1.00	
MRN-BS-KF-25	KF	Kitchen faucets	33	6/30/2016	0645	P	1.58	P	<1.00	
MRN-BS-IM-26	IM	Ice machines	31	6/30/2016	0646	P	<1.00	P		
MRN-BS-WO-37	WO	Water fountain without cooler	CORR B100	6/30/2016	0653	P	<1.00	P	<1.00	
MRN-BS-WO-38	WO	Water fountain without cooler	CORR B100	6/30/2016	0654	P	<1.00	P	<1.00	
MRN-01-WO-51	WO	Water fountain without cooler	CORR 114	6/30/2016	0716	P	1.62	P	<1.00	
MRN-01-WO-61	WO	Water fountain without cooler	CORR 114	6/30/2016	0706	P	<1.00	P	<1.00	
MRN-02-WO-65	WO	Water fountain without cooler	CORR 218	6/30/2016	0734	P	2.15	P	<1.00	
MRN-02-CF-68	CF	Classroom faucets	209	6/30/2016	0725	P	1.86	P	<1.00	
MRN-02-CF-69	CF	Classroom faucets	209	6/30/2016	0727	P	3.8	P	1.37	
MRN-02-CF-70	CF	Classroom faucets	209	6/30/2016	0728	P	4.08	P	<1.00	
MRN-02-CF-71	CF	Classroom faucets	209	6/30/2016	0729	P	3.87	P	<1.00	
MRN-02-MS-72	MS	Miscellaneous sinks	208A	6/30/2016	0731	P	1.08	P	1.15	
MRN-02-WO-76	WO	Water fountain without cooler	CORR 218	6/30/2016	0720	P	<1.00	P	<1.00	
MRN-03-WO-78	WO	Water fountain without cooler	CORR 312	6/30/2016	0739	P	2.4	P	<1.00	
MRN-03-WO-79	WO	Water fountain without cooler	CORR 303	6/30/2016	0743	P	1.29	P	<1.00	
MRN-03-MS-80	MS	Miscellaneous sinks	302	6/30/2016	0741	P	1.26	P	<1.00	
MRN-01-NF-85	NF		109	6/30/2016	0711	P	1.22	P	<1.00	
MRN-01-NF-86	NF		109B	6/30/2016	0712	P	1.91	P	1.03	

## **Pittsburgh Perry High School**

---

Drinking Water Sample Results

School: Pittsburgh Perry High School

Address: 3875 Perrysville Avenue, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PER-BS-SL-00	SL	Service Line	PIPE SPACE 035	7/7/16	0515	P	<1.00			
PER-BS-WM-00	WM	Water Main	PIPE SPACE 035	7/7/16	0518	P	<1.00			
PER-BS-WO-2	WO	Water fountain without cooler	HALL 021	7/7/16	0519	P	4.52	P	4.67	
PER-BS-WO-3	WO	Water fountain without cooler	HALL 021	7/7/16	0520	P	3.52	P	2.80	
PER-BS-MS-4	MS	Miscellaneous sinks	024A	7/7/16	0523	F	38.1	P	5.70	
PER-BS-WC-5	WC	Water fountain with cooler	20	7/7/16	0525	P	<1.00	P	<1.00	
PER-SB-MS-6	MS	Miscellaneous sinks	19	7/7/16	0530	P	2.11	P	<1.00	
PER-SB-WC-8	WC	Water fountain with cooler	RO13	7/7/16	0532	P	<1.00	P	<1.00	
PER-01-WC-10	WC	Water fountain with cooler	CORR 131B	7/7/16	0536	P	<1.00	P	<1.00	
PER-01-WC-11	WC	Water fountain with cooler	CORR 131B	7/7/16	0537	P	<1.00	P	<1.00	
PER-01-MS-25	MS	Miscellaneous sinks	140E	7/7/16	0544	P	9.07	P	1.96	
PER-01-MS-26	MS	Miscellaneous sinks	142	7/7/16	0548	P	<1.00	P	<1.00	
PER-01-WC-38	WC	Water fountain with cooler	CORR 131B	7/7/16	0550	P	1.47	P	1.26	
PER-01-WC-39	WC	Water fountain with cooler	CORR 131B	7/7/16	0551	P	<1.00	P	<1.00	
PER-01-MS-46	MS	Miscellaneous sinks	149	7/7/16	0553	P	<1.00	P	<1.00	
PER-01-NF-49	NF	Nurse's office sink faucets	147D	7/7/16	0555	P	2.54	P	<1.00	
PER-01-NF-50	NF	Nurse's office sink faucets	147A	7/7/16	0556	P	8.37	P	6.53	
PER-01-KF-51	KF	Kitchen faucets	162	7/7/16	0601	P	3.57	P	<1.00	
PER-01-KF-52	KF	Kitchen faucets	162	7/7/16	0600	P	2.84	P	<1.00	
PER-01-WO-54	WO	Water fountain without cooler	160	7/7/16	0606	P	3.27	P	2.66	
PER-01-WO-55	WO	Water fountain without cooler	160	7/7/16	0607	P	2.99	P	3.94	
PER-02-WC-59	WC	Water fountain with cooler	CORR 200	7/7/16	0613	P	<1.00	P	<1.00	
PER-02-WC-60	WC	Water fountain with cooler	CORR 200	7/7/16	0614	P	<1.00	P	<1.00	
PER-02-WC-85	WC	Water fountain with cooler	CORR 200	7/7/16	0616	P	<1.00	P	<1.00	
PER-02-WC-86	WC	Water fountain with cooler	CORR 200	7/7/16	0617	P	<1.00	P	<1.00	
PER-02-WO-96	WO	Water fountain without cooler	CORR 200D	7/7/16						Not Functioning
PER-02-CF-117	CF	Classroom faucets	267	7/7/16	0621	P	1.12	P	<1.00	
PER-02-CF-118	CF	Classroom faucets	267	7/7/16	0622	P	4.80	P	1.21	
PER-02-CF-119	CF	Classroom faucets	251	7/7/16	0620	P	2.50	P	<1.00	
PER-02-CF-129	CF	Classroom faucets	269	7/7/16						Not Functioning
PER-02-CF-130	CF	Classroom faucets	269C	7/7/16						Not Functioning
PER-03-WC-131	WC	Water fountain with cooler	CORR 300	7/7/16	0629	P	<1.00	P	<1.00	
PER-03-WC-132	WC	Water fountain with cooler	CORR 300	7/7/16	0630	P	<1.00	P	<1.00	
PER-03-CF-134	CF	Classroom faucets	326	7/7/16	0654	F	39.4	P	<1.00	
PER-03-CF-135	CF	Classroom faucets	326	7/7/16	0655	P	7.28	P	<1.00	
PER-03-CF-142	CF	Classroom faucets	333	7/7/16	0632	P	1.21	P	<1.00	
PER-03-CF-143	CF	Classroom faucets	333	7/7/16	0633	P	1.48	P	<1.00	
PER-03-CF-144	CF	Classroom faucets	333	7/7/16	0634	P	3.11	P	<1.00	
PER-03-CF-145	CF	Classroom faucets	333	7/7/16	0635	P	<1.00	P	<1.00	
PER-03-CF-146	CF	Classroom faucets	338	7/7/16	0640	P	2.61	P	<1.00	

Drinking Water Sample Results

School: Pittsburgh Perry High School

Address: 3875 Perrysville Avenue, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PER-03-CF-147	CF	Classroom faucets	342	7/7/16	0643	P	<1.00	P	1.38	
PER-03-CF-148	CF	Classroom faucets	342	7/7/16	0644	P	1.37	P	<1.00	
PER-03-WC-149	WC	Water fountain with cooler	CORR 300	7/7/16	0646	P	<1.00	P	<1.00	
PER-03-WC-150	WC	Water fountain with cooler	CORR 300	7/7/16	0647	P	<1.00	P	<1.00	
PER-03-WO-157	WO	Water fountain without cooler	CORR 300E	7/7/16	0649	P	2.26	P	2.10	
PER-02-SL-159	SL	Service Line	825	7/7/16	0708	P	<1.00			
PER-02-WM-159	WM	Water Main	825	7/7/16	0711	P	<1.00			
PER-02-WO-176	WO	Water fountain without cooler	CORR 800	7/7/16	0721	P	<1.00	P	<1.00	
PER-02-WO-203	WO	Water fountain without cooler	812B	7/7/16						Not Functioning
PER-02-WO-211	WO	Water fountain without cooler	POOL	7/7/16						Not Functioning
PER-02-WO-236	WO	Water fountain without cooler	818B	7/7/16	0730	P	<1.00	P	4.99	
PER-01-WO-246	WO	Water fountain without cooler	CORR 700	7/7/16	0707	P	<1.00	P	<1.00	
PER-03-WO-250	WO	Water fountain without cooler	OUTSIDE 903	7/7/16	0736	P	<1.00	P	<1.00	
PER-03-MS-251	MS	Miscellaneous sinks	903	7/7/16	0738	P	4.67	P	1.93	
PER-01-KF-256	KF	Kitchen faucets	162	7/7/16	0602	P	1.45	P	<1.00	
PER-02-MS-258	MS	Miscellaneous sinks	823	7/7/16	0723	P	4.63	P	1.12	
PER-02-IM-259	IM	Ice Machines	823	7/7/16	0725	P	<1.00			

## **Pittsburgh Perry Field House**

---

Drinking Water Sample Results

School: Pittsburgh Perry Field House

Address: 119 Richards Street, Pittsburgh, PA 15214

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PFH-01-MS-5	MS	Miscellaneous Sinks	Office	7/7/2016	0723	P	7.17	P	< 1.00	
PFH-01-IM-2	IM	Ice machines	Maintenance Room	7/7/2016	0714	P	3.40			
PFH-01-SL-00	SL	Service Line	Maintenance Room	7/7/2016	0710	P	< 1.00			
PFH-01-WC-1	WC	Water fountain with cooler	Maintenance Room	7/7/2016	0709	P	< 1.00	P	2.32	
PFH-01-WC-6	WC	Water fountain with cooler	Office	7/7/2016	0722	P	3.72	P	3.54	
PFH-01-WC-7	WC	Water fountain with cooler	Home Locker Room	7/7/2016	0727	P	1.82	P	2.00	
PFH-01-WC-11	WC	Water fountain with cooler	Visiting Locker Room	7/7/2016	0730	P	1.91	P	1.99	
PFH-01-WM-00	WM	Water Main	Maintenance Room	7/7/2016	0712	P	< 1.00			
PFH-01-MS-14	MS	Miscellaneous Sinks	Maintenance Room	7/7/2016	0717	P	3.14	P	2.17	



## Lead in Drinking Water Sample Results

School: Pittsburgh Phillip Murray

Address: 800 Reichtanwald Street, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PMU-GF-SL-1	SL	Service Line		8/9/2016	0614	P	<1.00			
PMU-GF-WM-1	WM	Water Main		8/9/2016	0617	P	1.06			
PMU-GF-WC-2	WC	Water fountain with cooler	CORR GA	8/9/2016	0619	P	1.03	P	<1.00	
PMU-GF-WC-3	WC	Water fountain with cooler	CORR GA	8/9/2016	0620	P	>1.00	P	<1.00	
PMU-GF-WC-13	WC	Water fountain with cooler	CORR GA	8/9/2016	0628	P	<1.00	P	<1.00	
PMU-GF-WC-14	WC	Water fountain with cooler	CORR GA	8/9/2016	0629	P	<1.00	P	<1.00	
PMU-GF-WC-30	WC	Water fountain with cooler	CORR GD	8/9/2016	0634	P	1.88	P	1.78	
PMU-GF-WC-31	WC	Water fountain with cooler	CORR GD	8/9/2016	0635	P	1.74	P	1.45	
PMU-BS-WC-39	WC	Water fountain with cooler	B1	8/9/2016	0721	P	<1.00	P	<1.00	
PMU-BS-WC-40	WC	Water fountain with cooler	B1	8/9/2016	0722	P	<1.00	P	<1.00	
PMU-BS-KF-42	KF	Kitchen faucets	B13	8/9/2016	0727	P	6.74	P	<1.00	
PMU-BS-KF-43	KF	Kitchen faucets	B13	8/9/2016	0726	P	1.9	P	1.05	
PMU-01-WC-45	WC	Water fountain with cooler	CORR 1A	8/9/2016	0644	P	<1.00	P	<1.00	
PMU-01-WC-46	WC	Water fountain with cooler	CORR 1A	8/9/2016	0645	P	<1.00	P	1.39	
PMU-01-CF-50	CF	Classroom faucets	108	8/9/2016	0651	P	1.13	P	<1.00	
PMU-01-MS-51	MS	Miscellaneous sinks	108	8/9/2016	0653	P	4.41	P	<1.00	
PMU-01-MS-53	MS	Miscellaneous sinks	110	8/9/2016	0657	P	5.33	P	<1.00	
PMU-01-CF-55	CF	Classroom faucets	110	8/9/2016	0656	P	3.67	P	<1.00	
PMU-01-WC-56	WC	Water fountain with cooler	CORR 1A	8/9/2016	0702	P	<1.00	P	<1.00	
PMU-01-WC-57	WC	Water fountain with cooler	CORR 1A	8/9/2016	0703	P	<1.00	P	<1.00	
PMU-01-WC-70	WC	Water fountain with cooler	CORR 1D	8/9/2016	0707	P	2.25	P	2.03	
PMU-01-WC-71	WC	Water fountain with cooler	CORR 1D	8/9/2016	0708	P	1.88	P	1.45	
PMU-GF-MS-78	MS	Miscellaneous sinks	12	8/9/2016	0624	P	3.34	P	<1.00	
PMU-GF-CF-83	CF	Classroom faucets	22	8/9/2016	0715	P	3.47	P	<1.00	



Drinking Water Sample Results

School: Pittsburgh Pioneer

Address: 775 Dunster Street, 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
PIO-BS-SL-00	SL	Service Line	BOILER ROOM	6/29/2016	0607	P	<1.00			
PIO-BS-WM-00	WM	Water Main	BOILER ROOM	6/29/2016	0609	P	<1.00			
PIO-01-CF-5	CF	Classroom faucets	A108	6/29/2016	0616	P	3.36	P	1.28	
PIO-01-MS-6	MS	Miscellaneous sinks	A107	6/29/2016	0613	P	1.11	P	<1.00	
PIO-01-MS-7	MS	Miscellaneous sinks	A107	6/29/2016	0614	P	<1.00	P	1.03	
PIO-01-MS-9	MS	Miscellaneous sinks	HALL	6/29/2016	0606	P	1.09	P	1.08	
PIO-01-WC-12	WC	Water fountain with cooler	CORR D	6/29/2016	0621	P	1.05	P	1.40	
PIO-01-CF-17	CF	Classroom faucets	A118	6/29/2016	0622	P	1.62	P	<1.00	
PIO-01-CF-20	CF	Classroom faucets	B107	6/29/2016	0625	P	1.58	P	<1.00	
PIO-01-CF-21	CF	Classroom faucets	B104	6/29/2016	0628	P	1.86	P	<1.00	
PIO-01-WFC-22	WFC	Water Filtering Chiller	CORR C	6/29/2016	0629	P	<1.00	P	1.06	
PIO-01-CF-23	CF	Classroom faucets	B107	6/29/2016	0626	P	<1.00	P	<1.00	
PIO-01-MS-25	MS	Miscellaneous sinks	B112	6/29/2016	0631	P	4.76	P	<1.00	
PIO-01-NF-28	NF	Nurse's office sink faucets	B114	6/29/2016	0632	P	2.64	P	1.31	
PIO-01-CF-33	CF	Classroom faucets	B151	6/29/2016	0635	P	1.41	P	<1.00	
PIO-01-CF-34	CF	Classroom faucets	B151	6/29/2016						Not Observed
PIO-01-CF-36	CF	Classroom faucets	B154	6/29/2016	0636	P	2.39	P	<1.00	
PIO-01-CF-37	CF	Classroom faucets	B146	6/29/2016	0644	P	3.02	P	<1.00	
PIO-01-CF-40	CF	Classroom faucets	B144	6/29/2016	0646	P	3.49	P	<1.00	
PIO-01-WC-43	WC	Water fountain with cooler	CORR E	6/29/2016	0648	P	<1.00	P	<1.00	
PIO-01-KF-46	KF	Kitchen faucets	B131	6/29/2016	0651	P	7.03	P	<1.00	
PIO-01-MS-47	MS	Miscellaneous sinks	B131	6/29/2016	0652	P	3.82	P	<1.00	
PIO-01-KF-48	KF	Kitchen faucets	B131	6/29/2016	0653	P	2.57	P	<1.00	
PIO-01-CF-49	CF	Classroom faucets	B142	6/29/2016	0657	P	1.90	P	<1.00	
PIO-01-CF-50	CF	Classroom faucets	B139	6/29/2016	0654	P	2.97	P	<1.00	
PIO-01-CF-51	CF	Classroom faucets	B132	6/29/2016	0655	P	4.00	P	<1.00	
PIO-01-CF-52	CF	Classroom faucets	B133	6/29/2016	0659	P	3.96	P	<1.00	
PIO-01-CF-53	CF	Classroom faucets	B134	6/29/2016	0701	P	4.11	P	<1.00	
PIO-01-CF-54	CF	Classroom faucets	B137	6/29/2016	0700	P	4.89	P	<1.00	
PIO-01-CF-55	CF	Classroom faucets	B136	6/29/2016	0702	P	3.67	P	<1.00	



Drinking Water Sample Results

School: Pittsburgh Roosevelt 2-5

Address: 17 W. Cherryhill Street Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
RSV-BS-SL-00	SL	Service Line	BOILER RM	6/28/2016	0604	P	<1.00			
RSV-BS-WM-00	WM	Water Main	BOILER RM	6/28/2016	0607	P	<1.00			
RSV-BS-KF-2	KF	Kitchen faucets	001A	6/28/2016	0608	P	1.22	P	<1.00	
RSV-BS-WC-6	WC	Water fountain with cooler	OUTSIDE 005	6/28/2016	0611	P	<1.00	P	<1.00	
RSV-BS-WC-7	WC	Water fountain with cooler	OUTSIDE 005	6/28/2016	0610	P	<1.00	P	<1.00	
RSV-GF-WC-15	WC	Water fountain with cooler	CORR 100A	6/28/2016	0615	P	<1.00	P	<1.00	
RSV-GF-WC-16	WC	Water fountain with cooler	CORR 100A	6/28/2016	0614	P	<1.00	P	<1.00	
RSV-GF-MS-26	MS	Miscellaneous sinks	110	6/28/2016	0620	P	<1.00	P	<1.00	
RSV-02-WC-31	WC	Water fountain with cooler	CORR 200A	6/28/2016	0628	P	<1.00	P	<1.00	
RSV-02-WC-32	WC	Water fountain with cooler	CORR 200A	6/28/2016	0627	P	<1.00	P	<1.00	
RSV-02-MS-37	MS	Miscellaneous sinks	214B	6/28/2016	0632	P	<1.00	P	<1.00	
RSV-03-WC-43	WC	Water fountain with cooler	CORR 300A	6/28/2016	0636	P	<1.00	P	<1.00	
RSV-03-WC-44	WC	Water fountain with cooler	CORR 300A	6/28/2016	0635	P	<1.00	P	<1.00	
RSV-03-MS-49	MS	Miscellaneous sinks	309	6/28/2016	0639	P	3.17	P	<1.00	
RSV-03-CF-50	CF	Classroom faucets	311	6/28/2016	0643	P	<1.00	P	<1.00	
RSV-03-CF-51	CF	Classroom faucets	311	6/28/2016	0642	P	1.14	P	<1.00	
RSV-01-CF-53	CF	Classroom faucets	108	6/28/2016	0617	P	<1.00	P	<1.00	
RSV-01-CF-54	CF	Classroom faucets	112	6/28/2016	0621	P	<1.00	P	<1.00	

## **Pittsburgh Schenley Field House**

---

Drinking Water Sample Results

School: Pittsburgh Schenly Field House

Address: 129 Denniston Avenue, 15206

Fixture ID	Fixture Symbol	Fixture Number	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SFH-BS-SL-00	SL	00	Service Line	HEATER RM	6/25/2016	0604	P	<1.00			
SFH-BS-WM-00	WM	00	Water Main	HEATER RM	6/25/2016	0607	P	<1.00			
SFH-BS-IM-1	IM	1	Ice machines	HEATER RM	6/25/2016	0622	P	<1.00			
SFH-GF-FF-2	FF	2	Field House sink faucets	DRESSING RM	6/25/2016	0608	P	2.77	P	<1.00	
SFH-GF-FF-3	FF	3	Field House sink faucets	DRESSING RM	6/25/2016	0603	P	3.64	P	<1.00	
SFH-GF-WO-6	WO	6	Water fountain without cooler	OUTSIDE	6/25/2016	0616	P	13.2	P	4.91	
SFH-GF-WO-7	WO	7	Water fountain without cooler	OUTSIDE	6/25/2016	0617	P	3.2	P	1.46	
SFH-GF-FF-12	FF	12	Field House sink faucets	DRESSING RM	6/25/2016	0613	P	11.1	P	2.19	
SFH-GF-FF-13	FF	13	Field House sink faucets	DRESSING RM	6/25/2016	0612	P	19.6	P	2.87	
SFH-GF-MS-14	MS	14	Miscellaneous sinks	OUTSIDE FIXTUR	6/25/2016	0620	P	3.32	P	<1.00	

## **Pittsburgh Science & Technology 6-12**

---



## Pittsburgh Service Center

---

Drinking Water Sample Results

School: Pittsburgh Service Center

Address: 1305 Muriel Street, Pittsburgh PA, 15205

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SCN-01-SL-00	SL	Service Line	LAYOUT AREA	7/13/2016	0626	P	<1.00			
SCN-01-WM-00	WM	Water Main	LAYOUT AREA	7/13/2016	0628	P	<1.00			
SCN-01-MS-1	MS	Miscellaneous sinks	FOOD SERVICE SHOP	7/13/2016	0625	P	<1.00	P	<1.00	
SCN-01-WC-7	WC	Water fountain with cooler	DOCK	7/13/2016	0630	P	1.33	P	1.32	
SCN-01-IM-10	IM	Ice machines	BOILER ROOM	7/13/2016	0631	P	<1.00			
SCN-01-MS-13	MS	Miscellaneous sinks	MUSIC REP. SHOP	7/13/2016						Not Functioning
SCN-01-MS-17	MS	Miscellaneous sinks	NEXT TO COMPUTER RM	7/13/2016	0633	P	<1.00	P	<1.00	
SCN-02-MS-18	MS	Miscellaneous sinks	CUBICLE AREA	7/13/2016	0638	P	<1.00	P	<1.00	
SCN-02-MS-19	MS	Miscellaneous sinks	NEXT TO STORAGE RMS	7/13/2016	0641	P	3.11	P	1.49	
SCN-02-WC-29	WC	Water fountain with cooler	GENERAL STORAGE	7/13/2016	0718	P	<1.00	P	<1.00	
SCN-02-US-30	US	Utility sinks	GENERAL STORAGE	7/13/2016	0717	P	2.91	P	<1.00	
SCN-02-MS-31	MS	Miscellaneous sinks	SHIPPING OFFICE	7/13/2016	0702	P	3.1	P	<1.00	
SCN-02-MS-33	MS	Miscellaneous sinks	GENERAL OFFICE	7/13/2016	0657	P	1.22	P	<1.00	
SCN-02-IM-34	IM	Ice machines	GENERAL STORAGE	7/13/2016	0716	P	<1.00			
SCN-02-WC-36	WC	Water fountain with cooler	CORRIDOR	7/13/2016	0712	P	<1.00	P	<1.00	
SCN-02-US-37	US	Utility sinks	METAL SHOP	7/13/2016	0714	P	3.08	P	<1.00	
SCN-02-US-38	US	Utility sinks	PAINT SHOP	7/13/2016	0654	P	9.62	P	<1.00	
SCN-02-US-39	US	Utility sinks	CARPENTER SHOP	7/13/2016	0700	P	11.6	P	1.23	
SCN-02-WC-41	WC	Water fountain with cooler	SHIPPING DOCK	7/13/2016	0652	P	2.96	P	2.42	

## **Pittsburgh South Annex (Online)**

---

Drinking Water Sample Results

School: Pittsburgh South Annex (Online)

Address: 93 S 10th Street, 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SOU-BS-SL-00	SL	Service Line	5	6/28/2016	0611	P	<1.00			
SOU-BS-WM-00	WM	Water Main	5	6/28/2016	0614	P	1.41			
SOU-01-CF-2	CF	Classroom faucets	104	6/28/2016	0619	F	48.2	P	4.29	
SOU-01-CF-3	CF	Classroom faucets	104	6/28/2016	0620	F	122	P	3.78	
SOU-01-CF-4	CF	Classroom faucets	104	6/28/2016	0621	P	17.6	P	3.08	
SOU-01-CF-5	CF	Classroom faucets	103	6/28/2016	0627	F	27.2	P	1.43	
SOU-01-WO-15	WO	Water fountain without cooler	CORR 100A	6/28/2016	0634	P	2.41	P	1.2	
SOU-01-MS-18	MS	Miscellaneous sinks	108	6/28/2016	0636	P	2.86	P	1.04	
SOU-02-WC-44	WC	Water fountain with cooler	207	6/28/2016	0643	P	<1.00	P	1.05	
SOU-01-WO-41	WO	Water fountain without cooler	104	6/28/2016	0623	F	24.6	P	4.79	
SOU-02-MS-40	MS	Miscellaneous sinks	201	6/28/2016	0728	P	12	P	1.57	

## **Pittsburgh South Brook 6-8**

---

Drinking Water Sample Results

School: Pittsburgh South Brook 6-8

779 Dunster Street, 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SBK-01-NF-37	NF	Nurse's office sink faucets	109	6/29/2016	0712	P	<1.00	P	<1.00	
SBK-01-IM-39	IM	Ice machines	121	6/29/2016	0725	P	<1.00			
SBK-01-WC-41	WC	Water fountain with cooler	101	6/29/2016	0716	P	<1.00	P	<1.00	
SBK-01-WC-42	WC	Water fountain with cooler	101	6/29/2016	0717	P	<1.00	P	<1.00	
SBK-01-KF-45	KF	Kitchen faucets	119	6/29/2016	0728	P	<1.00	P	<1.00	
SBK-01-TF-46	TF	Teacher's lounge sinks	122	6/29/2016	0729	P	1.03	P	<1.00	
SBK-01-CF-47	CF	Classroom faucets	131	6/29/2016	0730	P	1.33	P	<1.00	
SBK-01-CF-48	CF	Classroom faucets	132	6/29/2016	0731	P	<1.00	P	<1.00	
SBK-01-CF-49	CF	Classroom faucets	133	6/29/2016	0733	P	<1.00	P	<1.00	
SBK-01-CF-50	CF	Classroom faucets	133	6/29/2016	0734	P	<1.00	P	<1.00	
SBK-01-CF-51	CF	Classroom faucets	127	6/29/2016	0732	P	<1.00	P	<1.00	
SBK-01-CF-52	CF	Classroom faucets	128	6/29/2016	0735	P	<1.00	P	<1.00	
SBK-01-CF-53	CF	Classroom faucets	129	6/29/2016	0736	P	<1.00	P	<1.00	
SBK-01-WC-58	WC	Water fountain with cooler	GYM LOBBY	6/29/2016	0737	P	<1.00	P	<1.00	
SBK-01-WC-59	WC	Water fountain with cooler	GYM LOBBY	6/29/2016	0738	P	<1.00	P	<1.00	
SBK-02-CF-69	CF	Classroom faucets	217	6/29/2016	0743	P	1.28	P	<1.00	
SBK-02-CF-70	CF	Classroom faucets	218	6/29/2016	0744	P	<1.00	P	<1.00	
SBK-02-CF-71	CF	Classroom faucets	225	6/29/2016	0745	P	<1.00	P	<1.00	
SBK-02-CF-72	CF	Classroom faucets	225	6/29/2016	0746	P	<1.00	P	<1.00	
SBK-02-CF-73	CF	Classroom faucets	222	6/29/2016	0747	P	<1.00	P	<1.00	
SBK-02-CF-74	CF	Classroom faucets	223	6/29/2016	0748	P	<1.00	P	<1.00	
SBK-02-CF-75	CF	Classroom faucets	224	6/29/2016	0749	P	1.39	P	<1.00	
SBK-02-WC-80	WC	Water fountain with cooler	219	6/29/2016	0750	P	<1.00	P	<1.00	
SBK-02-WC-81	WC	Water fountain with cooler	219	6/29/2016	0751	P	1.04	P	1.83	Water Filtering Chiller with Bottle Filler



Drinking Water Sample Results

School: Pittsburgh Sterrett 6-8

Address: 7100 Reynolds Street, Pittsburgh PA, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
STE-GF-SL-00	SL	Service Line	JAN. OFFICE	6/30/2016	0644	P	< 1.00			
STE-GF-WM-00	WM	Water Main	JAN. OFFICE	6/30/2016	0647	P	< 1.00			
STE-GF-US-1	US	Utility sinks	BOILER ROOM	6/30/2016	0643	P	1.25	P	1.01	
STE-GF-CF-3	CF	Classroom faucets	E104	6/30/2016	0649	P	< 1.00	P	< 1.00	
STE-GF-WO-4	WO	Water fountain without cooler	OUTSIDE STAIRS	6/30/2016	0651	P	3.97	P	1.01	
STE-GF-WO-5	WO	Water fountain without cooler	OUTSIDE STAIRS	6/30/2016	0652	P	3.83	P	1.87	
STE-GF-CF-6	CF	Classroom faucets	881 SF	6/30/2016	0655	P	1.37	P	< 1.00	
STE-GF-CF-7	CF	Classroom faucets	881 SF	6/30/2016	0656	P	3.21	P	< 1.00	
STE-GF-WC-31	WC	Water fountain with cooler	OUTSIDE STAFF	6/30/2016	0657	P	1.06	P	< 1.00	
STE-GF-WC-32	WC	Water fountain with cooler	OUTSIDE STAFF	6/30/2016	0658	P	< 1.00	P	< 1.00	
STE-GF-WC-38	WC	Water fountain with cooler	115	6/30/2016	0701	P	< 1.00	P	< 1.00	
STE-GF-WC-39	WC	Water fountain with cooler	115	6/30/2016	0702	P	< 1.00	P	< 1.00	
STE-GF-KF-40	KF	Kitchen faucets	116	6/30/2016	0706	P	1.37	P	< 1.00	
STE-GF-KF-42	KF	Kitchen faucets	116	6/30/2016	0704	P	2.47	P	< 1.00	
STE-01-WO-45	WO	Water fountain without cooler	OUTSIDE RR	6/30/2016						Not Functioning
STE-01-WO-46	WO	Water fountain without cooler	OUTSIDE RR	6/30/2016	0710	P	< 1.00	P	< 1.00	
STE-01-WO-49	WO	Water fountain without cooler	ACROSS FROM RM 104	6/30/2016	0713	P	< 1.00	P	< 1.00	
STE-01-WO-50	WO	Water fountain without cooler	ACROSS FROM RM 104	6/30/2016						Not Functioning
STE-01-CF-52	CF	Classroom faucets	105	6/30/2016	0716	P	4.06	P	< 1.00	
STE-01-TF-53	TF	Teacher's lounge sinks	E202	6/30/2016	0711	P	1.21	P	< 1.00	
STE-01-NF-54	NF	Nurse's office sink faucets	201	6/30/2016	0718	P	< 1.00	P	1.35	
STE-01-WC-62	WC	Water fountain with cooler	OUTSIDE 205	6/30/2016	0721	P	< 1.00	P	< 1.00	
STE-01-WC-63	WC	Water fountain with cooler	OUTSIDE 205	6/30/2016	0722	P	< 1.00	P	< 1.00	
STE-02-WO-69	WO	Water fountain without cooler	OUTSIDE BOYS RR	6/30/2016						Not Functioning
STE-02-WO-70	WO	Water fountain without cooler	OUTSIDE BOYS RR	6/30/2016	0738	P	< 1.00	P	< 1.00	
STE-02-TF-75	TF	Teacher's lounge sinks	NEXT TO 207	6/30/2016	0740	F	24.6	P	2.34	
STE-02-WO-76	WO	Water fountain without cooler	OUTSIDE GIRLS RR	6/30/2016	0735	P	< 1.00	P	< 1.00	
STE-02-WO-77	WO	Water fountain without cooler	OUTSIDE GIRLS RR	6/30/2016	0736	P	< 1.00	P	< 1.00	
STE-02-CF-85	CF	Classroom faucets	203	6/30/2016	0733	P	15.0	P	1.42	
STE-GF-KF-86	KF	Kitchen faucets	116	6/30/2016	0705	P	2.00	P	< 1.00	
STE-01-MS-87	MS	Miscellaneous sinks	LIBRARY	6/30/2016	0725	P	1.71	P	< 1.00	

## **Pittsburgh Sunnyside PreK-8**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Sunnyside PreK-8

Address: 4801 Stanton Avenue, 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SUN-BS-SL-0	SL	Service Line	BOILER ROOM	6/17/2016	0609	P	<1.00			
SUN-BS-WM-0	WM	Water Main	BOILER ROOM	6/17/2016	0615	P	<1.00			
SUN-01-CF-2	CF	Classroom faucets	124	6/17/2016	0624	P	<1.00	P	<1.00	
SUN-01-WO-5	WO	Water fountain without cooler	CORR 103	6/17/2016	0619	P	2.21	P	1.14	
SUN-01-WO-6	WO	Water fountain without cooler	CORR 103	6/17/2016	0620	P	1.45	P	<1.00	
SUN-01-MS-15	MS	Miscellaneous sinks	115	6/17/2016	0721	P	1.84	P	<1.00	
SUN-01-TF-17	TF	Teacher's lounge sinks	112	6/17/2016	0720	P	6.53	P	<1.00	
SUN-01-MS-18	MS	Miscellaneous sinks	111	6/17/2016	0722	P	3.42	P	<1.00	
SUN-01-NF-19	NF	Nurse's office sink faucets	110	6/17/2016	0724	P	<1.00	P	<1.00	
SUN-01-WC-28	WC	Water fountain with cooler	190	6/17/2016	0734	P	<1.00	P	<1.00	
SUN-01-WC-29	WC	Water fountain with cooler	190	6/17/2016	0735	P	<1.00	P	<1.00	
SUN-01-KF-31	KF	Kitchen faucets	192	6/17/2016	0741	P	3.39	P	1.36	
SUN-01-KF-32	KF	Kitchen faucets	192	6/17/2016	0742	P	2.31	P	1.88	
SUN-01-WO-54	WO	Water fountain without cooler	CORR 102	6/17/2016	0750	P	2.97	P	1.47	
SUN-01-WO-55	WO	Water fountain without cooler	CORR 102	6/17/2016	0751	P	1.62	P	<1.00	
SUN-01-CF-61	CF	Classroom faucets	149	6/17/2016	0754	P	2.65	P	<1.00	
SUN-01-CF-62	CF	Classroom faucets	147	6/17/2016	0755	P	9.2	P	2.06	
SUN-01-CF-63	CF	Classroom faucets	145	6/17/2016	0758	F	48.7	P	4.16	
SUN-01-CF-64	CF	Classroom faucets	146	6/17/2016	0800	P	5.77	P	3.09	
SUN-01-WO-65	WO	Water fountain without cooler	CORR 102	6/17/2016	0802	P	5.25	P	1.9	
SUN-01-WO-66	WO	Water fountain without cooler	CORR 102	6/17/2016	0803	P	1.62	P	<1.00	
SUN-01-CF-67	CF	Classroom faucets	126	6/17/2016	0626	P	1.86	P	<1.00	
SUN-01-CF-68	CF	Classroom faucets	127	6/17/2016	0628	P	1.14	P	<1.00	
SUN-01-CF-69	CF	Classroom faucets	128	6/17/2016	0632	P	<1.00	P	<1.00	
SUN-01-CF-70	CF	Classroom faucets	129	6/17/2016	0634	P	<1.00	P	<1.00	
SUN-01-WO-71	WO	Water fountain without cooler	CORR 103							Not Functioning
SUN-01-WO-72	WO	Water fountain without cooler	CORR 103	6/17/2016	0637	P	6.79	P	1.32	
SUN-01-CF-73	CF	Classroom faucets	131	6/17/2016	0639	P	2.79	P	<1.00	
SUN-01-CF-75	CF	Classroom faucets	132	6/17/2016	0642	P	<1.00	P	<1.00	
SUN-01-CF-76	CF	Classroom faucets	132	6/17/2016	0643	P	9.75	P	1.65	
SUN-01-CF-79	CF	Classroom faucets	136	6/17/2016	0647	P	<1.00	P	<1.00	
SUN-01-CF-85	CF	Classroom faucets	140	6/17/2016	0654	P	<1.00	P	1.08	
SUN-01-WC-86	WC	Water fountain with cooler	CORR 160	6/17/2016	0650	P	10	P	8.59	
SUN-01-WC-87	WC	Water fountain with cooler	CORR 160	6/17/2016	0651	P	7.92	P	9.06	
SUN-01-CF-88	CF	Classroom faucets	140	6/17/2016	0659	P	16.5	P	3.29	
SUN-01-CF-89	CF	Classroom faucets	140	6/17/2016	0702	P	9.49	P	5.47	
SUN-01-CF-91	CF	Classroom faucets	142	6/17/2016	0708	P	<1.00	P	2.83	
SUN-01-CF-92	CF	Classroom faucets	142	6/17/2016	0709	P	1.9	P	<1.00	
SUN-01-CF-95	CF	Classroom faucets	140	6/17/2016	0700	P	11.4	P	4.49	
SUN-01-CF-96	CF	Classroom faucets	140	6/17/2016	0703	P	3.48	P	6.31	

Lead in Drinking Water Sample Results

School: Pittsburgh Sunnyside PreK-8

Address: 4801 Stanton Avenue, 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
SUN-01-WC-93	WC	Water fountain with cooler	180	6/17/2016	0727	P	<1.00	P	<1.00	
SUN-01-WC-94	WC	Water fountain with cooler	172	6/17/2016	0738	P	<1.00	P	<1.00	
SUN-01-KF-97	KF	Kitchen faucets	192	6/17/2016	0743	P	2.8	P	1.68	



Lead in Drinking Water Sample Results

School: Pittsburgh Weil PreK-5

Address: 2250 Centre Avenue, 15219

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WEI-BS-SL-0	SL	Service Line	12	6/16/2016	0612	P	<1.00			
WEI-BS-WM-0	WM	Water Main	12	6/16/2016	0615	P	<1.00			
WEI-BS-MS-1	MS	Miscellaneous sinks	7	6/16/2016	0610	P	<1.00	P	1.33	
WEI-01-WO-9	WO	Water fountain without cooler	CORRIDOR 100	6/16/2016	0620	P	<1.00	P	1.02	
WEI-02-WO-10	WO	Water fountain without cooler	CORRIDOR 100	6/16/2016	0622	P	1.17	P	1.36	
WEI-01-NF-11	NF	Nurse's office sink faucets	102	6/16/2016	0637	P	<1.00	P	<1.00	
WEI-01-CF-15	CF	Classroom faucets	111A	6/16/2016	0649	P	4.71	P	<1.00	
WEI-01-WO-17	WO	Water fountain without cooler	111B	6/16/2016	0650	P	<1.00	P	1.03	
WEI-01-WO-18	WO	Water fountain without cooler	CORRIDOR 100	6/16/2016	0645	P	<1.00	P	1.35	
WEI-01-WO-19	WO	Water fountain without cooler	CORRIDOR 100	6/16/2016	0646	P	1.21	P	1.17	
WEI-01-CF-24	CF	Classroom faucets	112	6/16/2016	0643	P	<1.00	P	<1.00	
WEI-01-CF-25	CF	Classroom faucets	113	6/16/2016	0641	P	1.41	P	<1.00	
WEI-01-CF-26	CF	Classroom faucets	114	6/16/2016	0639	P	12.4	P	2.63	
WEI-01-CF-27	CF	Classroom faucets	115	6/16/2016	0635	P	<1.00	P	<1.00	
WEI-01-CF-28	CF	Classroom faucets	120	6/16/2016	0630	P	<1.00	P	<1.00	
WEI-01-CF-31	CF	Classroom faucets	121	6/16/2016	0634	P	<1.00	P	<1.00	
WEI-01-KF-32	KF	Kitchen faucets	130	6/16/2016	0626	P	<1.00	P	<1.00	
WEI-02-TF-35	TF	Teacher's lounge sinks	209	6/16/2016	0658	P	<1.00	P	<1.00	
WEI-02-WO-38	WO	Water fountain without cooler	CORRIDOR 200	6/16/2016	0656	P	<1.00	P	1.21	
WEI-02-WO-39	WO	Water fountain without cooler	CORRIDOR 200	6/16/2016	0657	P	1.05	P	1.4	
WEI-02-WO-40	WO	Water fountain without cooler	CORRIDOR 200B	6/16/2016	0702	P	1.47	P	1.11	
WEI-02-WO-41	WO	Water fountain without cooler	CORRIDOR 200B	6/16/2016	0703	P	2.01	P	<1.00	
WEI-02-CF-42	CF	Classroom faucets	210	6/16/2016	0705	P	4.43	P	1.02	
WEI-02-CF-43	CF	Classroom faucets	210	6/16/2016	0706	P	2.11	P	1.05	
WEI-02-CF-44	CF	Classroom faucets	208	6/16/2016	0709	P	8.18	P	1.26	
WEI-02-CF-45	CF	Classroom faucets	207	6/16/2016	0712	F	20.8	P	1.71	
WEI-02-CF-46	CF	Classroom faucets	206	6/16/2016	0713	P	1.94	P	1.47	
WEI-02-WO-51	WO	Water fountain without cooler	CORRIDOR 200	6/16/2016	0716	P	<1.00	P	<1.00	
WEI-02-WO-52	WO	Water fountain without cooler	CORRIDOR 200	6/16/2016	0717	P	<1.00	P	<1.00	
WEI-03-WO-55	WO	Water fountain without cooler	CORRIDOR 300A	6/16/2016	0719	P	1.78	P	1.03	
WEI-03-WO-56	WO	Water fountain without cooler	CORRIDOR 300A	6/16/2016	0720	P	1.87	P	<1.00	
WEI-03-WO-61	WO	Water fountain without cooler	CORRIDOR 300A	6/16/2016	0723	P	<1.00	P	<1.00	
WEI-03-WO-62	WO	Water fountain without cooler	CORRIDOR 300A	6/16/2016	0724	P	<1.00	P	<1.00	

## **Pittsburgh West Liberty K-5**

---

Drinking Water Sample Results

School: Pittsburgh West Liberty K-5

Address: 785 Dunster Street, 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WLB-BS-SL-00	SL	Service Line	BOILER ROOM	6/29/2016	0609	P	<1.00			
WLB-BS-WM-00	WM	Water Main	BOILER ROOM	6/29/2016	0612	P	<1.00			
WLB-BS-MS-3	MS	Miscellaneous sinks	B-11	6/29/2016	0613	P	2.31	P	<1.00	
WLB-01-WO-7	WO	Water fountain without cooler	CORR 100	6/29/2016	0627	P	1.01	P	<1.00	
WLB-01-WO-8	WO	Water fountain without cooler	CORR 100	6/29/2016	0628	P	1.87	P	<1.00	
WLB-01-NF-13	NF	Nurse's office sink faucets	113	6/29/2016	0635	P	6.60	P	<1.00	
WLB-01-NF-15	NF	Nurse's office sink faucets	117	6/29/2016	0636	F	47.4	P	8.25	
WLB-02-WO-17	WO	Water fountain without cooler	139	6/29/2016	0618	P	<1.00	P	<1.00	
WLB-01-KF-20	KF	Kitchen faucets	138	6/29/2016	0620	P	2.82	P	<1.00	
WLB-01-IM-21	IM	Ice machines	138	6/29/2016						Not Functioning
WLB-01-CF-23	CF	Classroom faucets	123	6/29/2016	0640	P	<1.00	P	<1.00	
WLB-01-CF-24	CF	Classroom faucets	123	6/29/2016	0641	P	5.83	P	<1.00	
WLB-01-WO-27	WO	Water fountain without cooler	CORR 100	6/29/2016	0649	P	1.27	P	1.50	
WLB-01-WO-28	WO	Water fountain without cooler	CORR 100	6/29/2016	0650	P	<1.00	P	<1.00	
WLB-02-WO-33	WO	Water fountain without cooler	CORR 200	6/29/2016	0702	P	1.38	P	<1.00	
WLB-02-WO-34	WO	Water fountain without cooler	CORR 200	6/29/2016	0703	P	2.51	P	<1.00	
WLB-02-CF-38	CF	Classroom faucets	218	6/29/2016	0656	P	2.59	P	<1.00	
WLB-02-MS-40	MS	Miscellaneous sinks	207	6/29/2016	0707	P	2.31	P	<1.00	
WLB-02-WO-41	WO	Water fountain with filter & cooler	CORR 200	6/29/2016	0712	P	1.03	P	<1.00	
WLB-02-WO-42	WO	Water fountain with filter & cooler	CORR 200	6/29/2016	0713	P	<1.00	P	<1.00	
WLB-02-CF-46	CF	Classroom faucets	208	6/29/2016	0711	P	5.06	P	2.71	
WLB-01-KF-47	KF	Kitchen faucets	138	6/29/2016	0621	P	<1.00	P	<1.00	
WLB-01-CF-48	CF	Classroom faucets	128	6/29/2016	0645	P	<1.00	P	1.28	
WLB-02-CF-49	CF	Classroom faucets	218	6/29/2016	0657	F	23.3	P	2.83	

## **Pittsburgh Westinghouse 6-12**

---

## Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse 6-12

Address: 1101 N. Murtland Street, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WES-BS-SL-0	SL	Service Line	921	6/14/2016	0536	P	<1.00			
WES-BS-WM-0	WM	Water Main	921	6/14/2016	0538	P	<1.00			
WES-BS-WO-1	WO	Water fountain without cooler	DINING AREA	6/14/2016	0546	P	<1.00	P	<1.00	
WES-BS-WO-2	WO	Water fountain without cooler	DINING AREA	6/14/2016	0547	P	<1.00	P	<1.00	
WES-BS-KF-5	KF	Kitchen faucets	935	6/14/2016	0539	P	<1.00	P	<1.00	
WES-BS-KF-7	KF	Kitchen faucets	935	6/14/2016	0541	P	1.95	P	<1.00	
WES-BS-KF-8	KF	Kitchen faucets	935	6/14/2016	0542	P	1.44	P	<1.00	
WES-BS-KF-9	KF	Kitchen faucets	935	6/14/2016	0543	P	2.36	P	<1.00	
WES-BS-WO-13	WO	Water fountain without cooler	977	6/14/2016	0605	P	<1.00	P	<1.00	
WES-BS-IM-25	IM	Ice machines	976	6/14/2016	0606	P	<1.00	P		
WES-BS-WO-29	WO	Water fountain without cooler	975	6/14/2016	0604	P	1.17	P	<1.00	
WES-BS-WO-41	WO	Water fountain without cooler	CORR F	6/14/2016	0555	P	4.19	P	2.01	
WES-SB-MS-45	MS	Miscellaneous sinks	875B	6/14/2016	0848	P	1.28	P	<1.00	
WES-SB-WO-66	WO	Water fountain without cooler	872 POOL	6/14/2016	0612	P	<1.00	P	<1.00	
WES-SB-WO-67	WO	Water fountain without cooler	873 POOL	6/14/2016						Not Functioning
WES-GF-WO-74	WO	Water fountain without cooler	CORR B	6/14/2016						Not Functioning
WES-GF-WO-75	WO	Water fountain without cooler	CORR B	6/14/2016	0638	P	<1.00	P	<1.00	
WES-GF-CF-76	CF	Classroom faucets	11	6/14/2016	0637	P	<1.00	P	<1.00	
WES-GF-WO-80	WO	Water fountain without cooler	CORR B	6/14/2016	0641	P	3.13	P	<1.00	
WES-GF-WO-81	WO	Water fountain without cooler	CORR B	6/14/2016	0642	P	<1.00	P	<1.00	
WES-GF-CF-82	CF	Classroom faucets	67	6/14/2016	0644	P	<1.00	P	<1.00	
WES-GF-MS-83	MS	Miscellaneous sinks	67	6/14/2016	0842	P	6.51	P	1.12	
WES-GF-CF-102	CF	Classroom faucets	22	6/14/2016	0647	P	<1.00	P	<1.00	
WES-GF-NF-105	NF	Nurse's office sink faucets	046C	6/14/2016	0702	P	1.33	P	1.03	
WES-GF-NF-106	NF	Nurse's office sink faucets	046D	6/14/2016	0703	P	35.2	P	1.98	
WES-GF-NF-107	NF	Nurse's office sink faucets	046E	6/14/2016	0659	P	11.3	P	2.61	
WES-GF-NF-117	NF	Nurse's office sink faucets	52D	6/14/2016	0653	P	16	P	1.15	
WES-GF-NF-118	NF	Nurse's office sink faucets	52C	6/14/2016	0654	P	11.1	P	1.97	
WES-GF-WO-128	WO	Water fountain without cooler	CORR D	6/14/2016	0650	P	<1.00	P	<1.00	
WES-GF-WO-129	WO	Water fountain without cooler	CORR D	6/14/2016	0651	P	<1.00	P	<1.00	
WES-GF-WO-163	WO	Water fountain without cooler	GYM	6/14/2016	0614	P	<1.00	P	<1.00	
WES-GF-WO-169	WO	Water fountain without cooler	77	6/14/2016	0619	P	1.40	P	1.83	

## Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse 6-12

Address: 1101 N. Murtland Street, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WES-GF-WO-172	WO	Water fountain with cooler	GYM	6/14/2016	0615	P	<1.00	P	<1.00	
WES-GF-WC-173	WC	Water fountain with cooler	LOBBY	6/14/2016						Not Functioning
WES-GF-WC-174	WC	Water fountain with cooler	LOBBY	6/14/2016						Not Functioning
WES-GF-MS-183	MS	Miscellaneous sinks	67	6/14/2016	0624	P	<1.00	P	<1.00	
WES-GF-KF-185	KF	Kitchen faucets	69	6/14/2016	0627	P	<1.00	P	<1.00	
WES-GF-KF-186	KF	Kitchen faucets	69	6/14/2016						Not Functioning
WES-GF-KF-187	KF	Kitchen faucets	69	6/14/2016	0628	P	1.11	P	<1.00	
WES-GF-KF-188	KF	Kitchen faucets	69	6/14/2016	0629	P	3.32	P	<1.00	
WES-GF-KF-190	KF	Kitchen faucets	69	6/14/2016	0629	P	<1.00	P	<1.00	
WES-GF-KF-191	KF	Kitchen faucets	69	6/14/2016	0630	P	3.69	P	<1.00	
WES-GF-IM-192	IM	Ice machines	69	6/14/2016	0632	P	<1.00	P		
WES-01-WO-198	WO	Water fountain without cooler	CORR B	6/14/2016	0710	P	<1.00	P	<1.00	
WES-01-WO-199	WO	Water fountain without cooler	CORR B	6/14/2016	0711	P	<1.00	P	<1.00	
WES-01-TF-205	TF	Teacher's lounge sinks	111	6/14/2016	0708	P	2.26	P	<1.00	
WES-01-MS-206	MS	Miscellaneous sinks	121	6/14/2016	0727	P	24.0	P	1.88	
WES-01-CF-207	CF	Classroom faucets	125A	6/14/2016	0714	P	12.5	P	<1.00	
WES-01-CF-208	CF	Classroom faucets	125A	6/14/2016	0715	P	3.53	P	<1.00	
WES-01-WO-209	WO	Water fountain without cooler	125A	6/14/2016						Not Functioning
WES-01-MS-212	MS	Miscellaneous sinks	125B	6/14/2016	0718	P	12.6	P	<1.00	
WES-01-WO-216	WO	Water fountain without cooler	CORR D	6/14/2016	0730	P	<1.00	P	<1.00	
WES-01-WO-217	WO	Water fountain without cooler	CORR D	6/14/2016	0731	P	<1.00	P	<1.00	
WES-01-WO-243	WO	Water fountain without cooler	149	6/14/2016	0733	P	<1.00	P	<1.00	
WES-01-WO-244	WO	Water fountain without cooler	147	6/14/2016	0736	P	<1.00	P	<1.00	
WES-01-CF-245	CF	Classroom faucets	147	6/14/2016	0735	P	1.14	P	<1.00	
WES-01-CF-246	CF	Classroom faucets	168	6/14/2016	0741	P	<1.00	P	<1.00	
WES-02-CF-273	CF	Classroom faucets	242	6/14/2016						Sink Removed
WES-02-CF-274	CF	Classroom faucets	235	6/14/2016	0801	P	5.85	P	<1.00	
WES-02-WO-284	WO	Water fountain without cooler	CORR D	6/14/2016	0747	P	<1.00	P	<1.00	
WES-02-WO-285	WO	Water fountain without cooler	CORR D	6/14/2016	0749	P	<1.00	P	<1.00	
WES-03-WO-316	WO	Water fountain without cooler	CORR B	6/14/2016	0821	P	<1.00	P	<1.00	
WES-03-WO-317	WO	Water fountain without cooler	CORR B	6/14/2016	0822	P	<1.00	P	<1.00	
WES-03-CF-318	CF	Classroom faucets	346	6/14/2016	0832	P	7.16	P	2.73	

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse 6-12

Address: 1101 N. Murtland Street, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WES-03-WO-319	WO	Water fountain without cooler	CORR D	6/14/2016	0828	P	<1.00	P	<1.00	
WES-03-WO-320	WO	Water fountain without cooler	CORR D	6/14/2016	0829	P	<1.00	P	<1.00	
WES-03-CF-327	CF	Classroom faucets	312	6/14/2016	0825	P	6.28	P	<1.00	
WES-03-CF-328	CF	Classroom faucets	312	6/14/2016						Not Functioning
WES-02-WO-330	WO	Water fountain without cooler	CORR B	6/14/2016	0746	P	<1.00	P	<1.00	
WES-01-WO-332	WO	Water fountain without cooler	125E	6/14/2016	0719	P	1.80	P	<1.00	
WES-01-CF-333	CF	Classroom faucets	125E	6/14/2016	0721	P	1.59	P	4.78	
WES-02-CF-336	CF	Classroom faucets	235	6/14/2016	0802	P	1.85			
WES-02-CF-337	CF	Classroom faucets	235	6/14/2016	0803	P	2.1			
WES-03-CF-338	CF	Classroom faucets	312	6/14/2016	0825	P	2.91			
WES-03-CF-339	CF	Classroom faucets	312	6/14/2016	0825	P	2.21			
WES-GF-MS-340	MS	Miscellaneous sinks	67	6/14/2016	0842	P	3.01			
WES-GF-MS-341	MS	Miscellaneous sinks	67	6/14/2016	0842	P	3.9			

## **Pittsburgh Westinghouse Field House**

---

Lead in Drinking Water Sample Results

School: Pittsburgh Westinghouse Field House

Address: 1102 N. Murtland Street, 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Locations	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)	Comments
WFH-GF-SL-0	SL	Service Line	Mechanical Room	6/14/2016	1651	P	<1.00			
WFH-GF-WM-0	WM	Water Main	Mechanical Room	6/14/2016	1654	P	<1.00			
WFH-GF-MS-1	MS	Miscellaneous sinks	Mechanical Room	6/14/2016	1650	P	<1.00	P	<1.00	
WFH-GF-IM-2	IM	Ice machines	Mechanical Room	6/14/2016	1655	P	<1.00			
WFH-GF-MS-3	MS	Miscellaneous sinks	Office	6/14/2016	1657	P	2.58	P	<1.00	
WFH-GF-MS-9	MS	Miscellaneous sinks	Concession Room	6/14/2016	1700	P	16.6	P	1.35	
WFH-GF-MS-10	MS	Miscellaneous sinks	Concession Room	6/14/2016	1701	F	24.9	P	1.38	