

# LEAD IN DRINKING WATER SAMPLING

*of*

## Pittsburgh Public Schools

*Survey Date: June 13 – July 17, 2016*

*Prepared for:*

Pittsburgh Public Schools  
Facilities  
1305 Muriel Street  
Pittsburgh, Pennsylvania 15203

*Prepared by:*



Skelly and Loy, Inc.  
3280 William Pitt Way  
Pittsburgh, PA 15238

August 24, 2016

**TABLE OF CONTENTS**

1. INTRODUCTION ..... 1

2. SAMPLING METHODOLOGY ..... 1

3. DRINKING WATER RESULTS AND DISCUSSION..... 1

4. BUILDING SUMMARY OF NUMBERS OF FIXTURES AND WATER SAMPLES ..... 6

5. RECOMMENDATIONS..... 8

REPORT DISCLAIMER: ..... 8

APPENDICES:

- APPENDIX A DRINKING WATER RESULTS TABLES
- APPENDIX B LABORATORY RESULTS
- APPENDIX C MAPS

## **1. INTRODUCTION**

Skelly and Loy, Inc. was retained by Pittsburgh Public School (PPS) District to test for the presence of lead in drinking water.

A fixture verification and water sample collection were conducted at 32 school buildings from June 13 through July 17, 2016. The objective of the water sample testing was to screen the drinking water and cooking use fixtures and faucets for lead concentrations. For our scope, drinking water and cooking fixtures were defined as classroom faucets; home economic faucets; ice machines; kitchen faucets; cafeteria faucets; nurse's office sink faucets; office sink faucets; teacher's lounge sinks and water fountains; and miscellaneous sinks designated in classrooms and offices.

## **2. SAMPLING METHODOLOGY**

Water samples collected, delivered, and analyzed were conducted according to the Environmental Protection Agency's (EPA's) "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002," April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance," October 2006. As per 3Ts, the EPA recommends that if lead is found in any water outlet at levels above 20 parts per billion (ppb), action be taken to reduce the lead. The purpose of this work is to help minimize exposure to students and staff to lead in drinking water. Lead in drinking water can be a localized problem and can vary from tap to tap. The EPA strongly recommends that all water outlets in all schools that provide water for drinking or cooking meet a standard of 20 ppb.

All water samples were collected in 250 mL plastic containers that were prepackaged by the analytical laboratory. At each water sample location, the first draw water sample was taken after the water in the plumbing lines had been standing in the plumbing system for greater than eight hours, but less than eighteen hours. (Each school building's water system was used the evening before the first-draw samples for proper water sampling protocol.)

A second draw water sample was collected after the water in the system was discharged for 30 seconds. This is called a purged-line or flushed sample. This water sample will show the lead content of water that has not been in contact with the plumbing system for an extended time.

All samples were analyzed by RJ Lee, Inc., 350 Hochberg Road, Monroeville, Pennsylvania 15146, an independent Pennsylvania (PA) certified laboratory.

## **3. LEAD IN DRINKING WATER RESULTS AND DISCUSSION**

Analytic results of the water samples were received by Skelly and Loy and reviewed in relation to EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002," April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance," October 2006. Lead concentrations above 20 ppb were considered to be elevated and recommended actions should be taken to reduce the lead. Following mitigation of fixtures that exceeded the recommended lead concentration, retesting of the water will be conducted to ensure the lead in drinking water was reduced below 20 ppb.

#### **Administration Building:**

At Pittsburgh Administration Building, a total number of 88 samples were collected from 43 drinking water and cooking use fixtures and faucets sampled on July 17, 2016. **Of the 88 samples collected, results of 14 samples (ADM-01-OF-23, ADM-01-OF-24, ADM-01-OF-25, ADM-02-OF-37, ADM-02-OF-47, ADM-02-OF-50, ADM-02-OF-51, ADM-02-OF-52, ADM-03-OF-54, ADM-04-OF-68, ADM-04-OF-78, ADM-04-OF-79, ADM-04-OF-83, and ADM-04-OF-84) were above the EPA lead in drinking water action level of 20 ppb.**

#### **Allderdice Field House:**

At Pittsburgh Allderdice Field House, a total number of 10 samples were collected from four drinking water and cooking use fixtures and faucets sampled on June 29, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

#### **Allderdice High School:**

At Pittsburgh Allderdice High School, a total number of 154 samples were collected from 76 drinking water and cooking use fixtures and faucets sampled on June 29, 2016. **Of the 154 samples collected, results of 5 samples (ALD-GF-WC-27, ALD-02-WC-91, ALD-03-CF-143, ALD-03-CF-149, and ALD-04-CF-289) were above the EPA lead in drinking water action level of 20 ppb. These samples were resampled to verify the first and second draw results.**

#### **Allegheny Annex:**

At Pittsburgh Allegheny Annex, a total number of 16 samples were collected from seven drinking water and cooking use fixtures and faucets sampled on July 6, 2016. **Of the 16 samples collected, results of 3 samples (ALX-02-CF-16, ALX-03-CF-25, and ALX-BS-WB-32) were above the EPA lead in drinking water action level of 20 ppb. These samples were resampled to verify the first and second draw results.**

#### **Allegheny K-5/6-8:**

At Pittsburgh Allegheny K-5/6-8, a total number of 90 samples were collected from 43 drinking water and cooking use fixtures and faucets sampled on June 22, 2016. **Of the 94 samples collected, the result of 1 sample (AGL-02-CF-49) was above the EPA lead in drinking water action level of 20 ppb. This sample was resampled to verify the first and second draw results.**

#### **Arsenal PreK-5/6-8:**

At Pittsburgh Arsenal PreK-5/6-8, a total number of 120 samples were collected from 59 drinking water and cooking use fixtures and faucets sampled on June 17, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

#### **Beechwood PreK-5:**

At Pittsburgh Beechwood PreK-5, a total number of 60 samples were collected from 29 drinking water and cooking use fixtures and faucets sampled on June 24, 2016. **Of the 60**

**samples collected, the result of 1 sample (BEE-01-CF-29) was above the EPA lead in drinking water action level of 20 ppb.**

#### **Brashear High School/South Hills 6-8:**

At Pittsburgh Brashear High School/South Hills 6-8, a total number of 190 samples were collected from 94 drinking water and cooking use fixtures and faucets sampled on July 12, 2016. **Of the 190 samples collected, results of 3 samples (BRA-01-OF-104, BRA-03-CF-234, and BRA-03-HF-310) were above the EPA lead in drinking water action level of 20 ppb. These samples were resampled to verify the first and second draw results.**

#### **CAPA 6-12:**

At Pittsburgh CAPA 6-12, a total number of 114 samples were collected from 56 drinking water and cooking use fixtures and faucets sampled on July 8, 2016. **Of the 114 samples collected, the result of 1 sample (CAP-01-KF-16) was above the EPA lead in drinking water action level of 20 ppb. This sample was resampled to verify the first and second draw results.**

#### **Carmalt PreK-8:**

At Pittsburgh Carmalt PreK-8, a total number of 90 samples were collected from 44 drinking water and cooking use fixtures and faucets sampled on June 16, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

#### **Colfax K-8:**

At Pittsburgh Colfax K-8, a total number of 108 samples were collected from 53 drinking water and cooking use fixtures and faucets sampled on June 28, 2016. **Of the 108 samples collected, results of 2 samples (COL-02-CF-70 and COL-02-CF-71) were above the EPA lead in drinking water action level of 20 ppb. These samples were resampled to verify the first and second draw results.**

#### **Concord PreK-5:**

At Pittsburgh Concord PreK-5, a total number of 90 samples were collected from 44 drinking water and cooking use fixtures and faucets sampled on June 16, 2016. **Of the 90 samples collected, the results of 4 samples (CON-01-CF-58, CON-01CF-65, CON-01-CF-66, and CON-02-MS-84) were above the EPA lead in drinking water action level of 20 ppb.**

#### **Conroy:**

At Pittsburgh Conroy, a total number of 84 samples were collected from 41 drinking water and cooking use fixtures and faucets sampled on June 15, 2016. **Of the 84 samples collected, results of 2 samples (CNY-GF-MS-04 and CNY-03-CF-100) were above the EPA lead in drinking water action level of 20 ppb.**

#### **Dilworth PreK-5:**

At Pittsburgh Dilworth PreK-5, a total number of 66 samples were collected from 32 drinking water and cooking use fixtures and faucets sampled on June 15, 2016. **Of the 66 samples collected, the result of 1 sample (DIL-01CF-32A) was above the EPA lead in drinking water action level of 20 ppb.**

#### **Fulton PreK-5:**

At Pittsburgh Fulton PreK-5, a total number of 51 samples were collected from 22 drinking water and cooking use fixtures and faucets sampled on June 23 and 28, 2016. **Of the 51 samples collected, results of 2 samples (FUL-BS-CF-02 and FUL-BS-MS-03) were above the EPA lead in drinking water action level of 20 ppb. Samples FUL-BS-SL-00, FUL-BS-CF-01, and FUL-01-WO-23 were resampled to verify the first and second draw results.**

#### **Grandview K-5:**

At Pittsburgh Grandview K-5, a total number of 80 samples were collected from 39 drinking water and cooking use fixtures and faucets sampled on June 30, 2016. **Of the 80 samples collected, the result of 1 sample (GRD-BS-CF-70) was above the EPA lead in drinking water action level of 20 ppb. This sample was resampled to verify the first and second draw results.**

#### **Greenway (Classical-Gifted Center):**

At Pittsburgh Greenway (Classical-Gifted Center), a total number of 132 samples were collected from 65 drinking water and cooking use fixtures and faucets sampled on June 30, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

#### **Liberty K-5:**

At Pittsburgh Liberty K-5, a total number of 64 samples were collected from 31 drinking water and cooking use fixtures and faucets sampled on June 28, 2016. **Of the 64 samples collected, the result of 1 sample (LIB-01-CF-28) was above the EPA lead in drinking water action level of 20 ppb. This sample was resampled to verify the first and second draw results.**

#### **Mifflin PreK-8:**

At Pittsburgh Mifflin PreK-8, a total number of 82 samples were collected from 40 drinking water and cooking use fixtures and faucets sampled on June 23, 2016. **Of the 82 samples collected, results of 3 samples (MIL-02-CF-74, MIL-02-CF-75, and MIL-02-CF-87) were above the EPA lead in drinking water action level of 20 ppb.**

#### **Minadeo PreK-5:**

At Pittsburgh Minadeo PreK-5, a total number of 114 samples were collected from 56 drinking water and cooking use fixtures and faucets sampled on June 17, 2016. **Of the 114 samples collected, results of 7 samples (MIN-GF-CF-21, MIN-GF-29, MIN-GF-WB-34,**

**MIN-02-CF-66, MIN-02-CF-67, MIN-02-CF-68 and MIN-02-WB-85) collected were above the EPA lead in drinking water action level of 20 ppb.**

#### **Obama 6-12, ECC:**

At Pittsburgh Obama 6-12, ECC, a total number of 136 samples were collected from 67 drinking water and cooking use fixtures and faucets sampled on July 6, 2016. **Of the 136 samples collected, results of 5 samples (OBA-GF-WC-12, OBA-GF-WB-41, OBA-01-OF-58, OBA-01-WC-94, and OBA-02-CF-119) were above the EPA lead in drinking water action level of 20 ppb. These samples were resampled to verify the first and second draw results.**

#### **Oliver Field House:**

At Pittsburgh Oliver Field House, a total number of 10 samples were collected from four drinking water and cooking use fixtures and faucets sampled on July 1, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

#### **Oliver:**

At Pittsburgh Oliver, a total number of 172 samples were collected from 85 drinking water and cooking use fixtures and faucets sampled on July 1, 2016. **Of the 172 samples collected, results of 25 samples (OLI-BS-WB-07, OLI-BS-WB-014, OLI-BS-WB-15, OLI-BS-WB-16, OLI-BS-WB-24, OLI-BS-WO-28, OLI-BS-WC-29, OLI-GF-OF-49, OLI-GF-MS-72, OLI-GF-CF-73, OLI-GF-CF-75, OLI-GF-CF-76, OLI-GF-CF-77, OLI-GF-KF-112, OLI-01-CF-185, OLI-01-CF-206, OLI-01-CF-207, OLI-02-HF-226, OLI-02-HF-227, OLI-02-HF-228, OLI-02-HF-229, OLI-02-KF-232, OLI-02-KF-233, OLI-02-OF-243, and OLI-02-OF-246) were above the EPA lead in drinking water action level of 20 ppb. Several samples were resampled to verify the first and second draw results.**

#### **Phillips K-5:**

At Pittsburgh Phillips K-5, a total number of 26 samples were collected from 12 drinking water and cooking use fixtures and faucets sampled on June 21, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

#### **Roosevelt Pre K-1:**

At Pittsburgh Roosevelt Pre K-1, a total number of 24 samples were collected from 11 drinking water and cooking use fixtures and faucets sampled on June 14, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

#### **Schiller 6-8:**

At Pittsburgh Schiller 6-8, a total number of 46 samples were collected from 22 drinking water and cooking use fixtures and faucets sampled on July 7, 2016. **Of the 46 samples collected, results of 2 samples (SCH-02-CF-24 and SCH-01-CF-47) were above the EPA lead in drinking water action level of 20 ppb. These samples were resampled to verify the first and second draw results.**

### Spring Garden ECC:

At Pittsburgh Spring Garden ECC, a total number of 30 samples were collected from 14 drinking water and cooking use fixtures and faucets sampled on June 14, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

### Spring Hill K-5:

At Pittsburgh Spring Hill K-5, a total number of 40 samples were collected from 19 drinking water and cooking use fixtures and faucets sampled on June 24, 2016. **Of the 40 samples collected, results of 2 samples (SRG-02-CF-35 and SRG-02-CF-39) were above the EPA lead in drinking water action level of 20 ppb. These samples were resampled to verify the first and second draw results.**

### Student Achievement Center:

At Pittsburgh Student Achievement Center, a total number of 54 samples were collected from 26 drinking water and cooking use fixtures and faucets sampled on July, 8, 2016. **Of the 54 samples collected, the result of 1 sample (SAC-02-CF-43) was above the EPA lead in drinking water action level of 20 ppb. This sample was resampled to verify the first and second draw results.**

### Westwood PreK-5:

At Pittsburgh Westwood PreK-5, a total number of 64 samples were collected from 31 drinking water and cooking use fixtures and faucets sampled on June, 22, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

### Whittier K-5:

At Pittsburgh Whittier K-5, a total number of 76 samples were collected from 37 drinking water and cooking use fixtures and faucets sampled on June, 29, 2016. No results collected were above the EPA lead in drinking water action level of 20 ppb.

### Woolslair K-5:

At Pittsburgh Woolslair K-5, a total number of 58 samples were collected from 28 drinking water and cooking use fixtures and faucets sampled on June 21, 2016. **Of the 58 samples collected, results of 3 samples (WOL-01-OF-33, WOL-02-TF-45, and WOL-02-CF-46) were above the EPA lead in drinking water action level of 20 ppb.**

## 4. BUILDING SUMMARY OF NUMBERS OF FIXTURES AND WATER SAMPLES

A table listing each school sampled, the total number of the fixtures, and the number of water samples collected follows. Floor plans for fixture locations are provided in Appendix C.



<b>Date Sampled</b>	<b>School/Building</b>	<b>Total # of Fixtures</b>	<b># of Samples Collected</b>
7/17/2016	Administration Building	43	88
6/29/2016	Allderdice Field House	4	10
6/29/2016	Allderdice High School	76	154
7/6/2016	Allegheny Annex	7	16
6/22/2016	Allegheny K-5/6-8	43	90
6/17/2016	Arsenal PreK-5/6-8	59	120
6/24/2016	Beechwood PreK-5	29	60
7/12/2016	Brashear High School/ South Hills 6-8	94	190
7/8/2016	CAPA 6-12	56	114
6/16/2016	Carmalt PreK-8	44	90
6/28/2016	Colfax K-8	53	108
6/16/2016	Concord PreK-5	44	90
6/15/2016	Conroy	41	84
6/15/2016	Dilworth PreK-5	32	66
6/23/2016	Fulton PreK-5	22	51
6/30/2016	Grandview K-5	39	80
6/30/2016	Greenway (Classical-Gifted Center)	65	132
6/28/2016	Liberty K-5	31	64
6/23/2016	Mifflin PreK-8	40	82
6/17/2016	Minadeo PreK-5	56	114
7/6/2016	Obama 6-12, ECC	67	136
7/1/2016	Oliver Field House	4	10
7/1/2016	Oliver	85	172
6/21/2016	Phillips K-5	12	26
6/14/2016	Roosevelt PreK-1	11	24
7/7/2016	Schiller 6-8	22	46
6/14/2016	Spring Garden ECC	14	30
6/24/2016	Spring Hill K-5	19	40
7/8/2016	Student Achievement Center	26	54
6/22/2016	Westwood PreK-5	31	64
6/29/2016	Whittier K-5	37	76
6/21/2016	Woolslair K-5	28	58
	32	1,234	2,539

32 schools/buildings were sampled. A total of 2,539 water samples were collected from 1,234 drinking water and cooking use fixtures and faucets.

The results of the water sample testing indicate that only **3.3%** of the fixtures tested had elevated lead concentrations above 20 ppb. This low percentage of fixtures with lead concentrations at or above 20 ppb indicates that the water supply into the building, from the

various water authorities, is not elevated for lead, or is there a District wide lead concern. Based on water sample testing, our professional opinion is that the sources of the elevated lead concentrations exceeding 20 ppb can be attributed to several key factors such as the lack of routine fixture use, fixtures not routinely cleaned, and/or older outdated fixtures. Corrective actions, which included the removal of any fixture that exceeded the recommended action level of 20 ppb from service, were conducted by the School District. Following remediation of these fixtures that exceeded the recommended lead concentration of 20 ppb, additional verification sampling will be conducted to safeguard the lead concentrations in drinking water can be reduced below 20 ppb.

## **5.0 RECOMMENDATIONS**

Skelly and Loy, Inc. recommends that Pittsburgh Public Schools follow good drinking water practices and follows the guidelines established in the EPA's "Lead in Drinking Water in Schools and Non-Residential Buildings, EPA 812-B-94-002", April 1994 and "3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance", October 2006.

Based on the results of this water sampling report, our recommendations, related to the fixtures, are as follows:

1. All fixtures with lead concentration at or above the recommended action limit of 20 ppb are to be remediated or the fixture shut off from use by the District.
2. Post signage stating that the non-filtered fixtures are to be used for only as a "non-drinking water source."

Skelly and Loy, Inc. also recommends supplemental best practices regarding safe water drinking practices to sustain the good water standards for the School District.

1. Prepare a guidance policy to inform staff of best drinking water practices and protocols.
2. Design supplemental QA/QC retesting of the non-filtered water fixtures in each school building as part of the safe drinking water practices.
3. Prepare a maintenance guideline for routine cleaning of drinking water sources and water cooler filter replacement.

### **REPORT DISCLAIMER:**

This Skelly and Loy, Inc. report is based on information supplied by the client, occupants, and on conditions readily observable or measurable on the date or dates of this study. The results and recommendations presented herein should not be relied upon exclusively for the prevention of all possible illnesses, injuries, or losses. These services are a supplement to, and not a substitute for, the client's responsibility for protecting the health and safety of the occupants of the facility, and others, and for complying with applicable laws and regulations.

This report and the associated attachments and appendices have been produced and developed for, and at the request of, Pittsburgh Board of Public Education. It conveys the findings of Skelly and Loy, Inc. as of the date(s) noted herein. This report is intended for the exclusive use of Pittsburgh Board of Public Education (including its management, officers, and the School Board).

# **APPENDIX A**

## **DRINKING WATER RESULTS TABLES**

**Administration Building**

# Lead in Drinking Water Sample Results

School: Pittsburgh Administration Building

Address: 341 S. Bellefield Ave., Pittsburgh, PA, 15213

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
ADM-GF-WM-00	WM	Water Main	031	7/17/2016	0713	P	<1.00		
ADM-GF-SL-00	SL	Service Line	031	7/17/2016	0709	P	<1.00		
ADM-GF-KF-02	KF	Kitchen faucets	023	7/17/2016	0721	P	5.32	P	<1.00
ADM-GF-KF-03	KF	Kitchen faucets	022	7/17/2016	0723	P	<1.00	P	<1.00
ADM-GF-KF-04	KF	Kitchen faucets	022	7/17/2016	0724	P	<1.00	P	<1.00
ADM-GF-WO-05	WO	Water fountain without cooler	021	7/17/2016	0730	P	11.4	P	1.63
ADM-GF-WO-06	WO	Water fountain without cooler	021	7/17/2016	0730	P	2.62	P	1.26
ADM-GF-IM-07	IM	Ice machines	021	7/17/2016	0734	P	<1.00	P	
ADM-GF-WB-13	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0734	P	3.04	P	1.13
ADM-GF-WO-15	WO	Water fountain without cooler	Corridor	7/17/2016	0714	P	4.03	P	1.47
ADM-01-OF-20	OF	Office sink faucets	OFF 107	7/17/2016	0741	P	1.11	P	<1.00
ADM-01-WB-21	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0744	P	5.23	P	2.03
<b>ADM-01-OF-23</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>121</b>	<b>7/17/2016</b>	<b>0751</b>	<b>F</b>	<b>23.4</b>	P	7.70
<b>ADM-01-OF-24</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>123</b>	<b>7/17/2016</b>	<b>0753</b>	<b>F</b>	<b>41.7</b>	P	4.84
<b>ADM-01-OF-25</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>126</b>	<b>7/17/2016</b>	<b>0756</b>	<b>F</b>	<b>30.5</b>	P	6.15
ADM-01-WB-26	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0756	P	2.90	P	1.19
ADM-01-WB-29	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0757	P	1.39	P	1.88
ADM-01-WB-34	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0804	P	1.81	P	<1.00
<b>ADM-02-OF-37</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>260</b>	<b>7/17/2016</b>	<b>0807</b>	P	19.3	<b>F</b>	<b>26.4</b>
ADM-02-OF-38	OF	Office sink faucets	258	7/17/2016	0810	P	13.7	P	12.1
ADM-02-WB-39	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0811	P	4.93	P	1.18
ADM-02-WB-43	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0814	P	5.18	P	1.37
ADM-02-WB-46	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0817	P	3.59	P	<1.00
<b>ADM-02-OF-47</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>215</b>	<b>7/17/2016</b>	<b>0820</b>	<b>F</b>	<b>21.8</b>	P	19.7
ADM-02-WO-49	WO	Water fountain without cooler	Corridor	7/17/2016	0821	P	5.45	P	1.56
<b>ADM-02-OF-50</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>208</b>	<b>7/17/2016</b>	<b>0825</b>	<b>F</b>	<b>30.5</b>	<b>F</b>	<b>21.2</b>
<b>ADM-02-OF-51</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>207</b>	<b>7/17/2016</b>	<b>0826</b>	<b>F</b>	<b>21.5</b>	P	4.98
<b>ADM-02-OF-52</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>201</b>	<b>7/17/2016</b>	<b>0828</b>	<b>F</b>	<b>48.0</b>	<b>F</b>	<b>50.8</b>
<b>ADM-03-OF-54</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>361</b>	<b>7/17/2016</b>	<b>0831</b>	<b>F</b>	<b>25.1</b>	<b>F</b>	<b>23.0</b>
ADM-03-WB-56	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0834	P	2.99	P	<1.00
ADM-03-OF-58	OF	Office sink faucets	353A	7/17/2016	0835	P	10.3	P	4.91
ADM-03-WO-61	WO	Water fountain without cooler	Corridor	7/17/2016	0839	P	1.36	P	<1.00
ADM-03-WO-64	WO	Water fountain without cooler	Corridor	7/17/2016	0845	P	<1.00	P	<1.00
ADM-03-OF-65	OF	Office sink faucets	326	7/17/2016	0846	P	1.82	P	1.08

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
ADM-03-WB-67	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0851	P	4.94	P	1.82
<b>ADM-04-OF-68</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>467</b>	<b>7/17/2016</b>	<b>0855</b>	<b>F</b>	<b>28.3</b>	P	15.6
ADM-04-OF-69	OF	Office sink faucets	460	7/17/2016	0857	P	13.0	P	3.01
ADM-04-WO-70	WO	Water fountain without cooler	Corridor	7/17/2016	0858	P	1.89	P	<1.00
ADM-04-WB-76	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	Non Func.				
ADM-04-OF-77	OF	Office sink faucets	440A	7/17/2016	0902	P	7.66	P	3.40
<b>ADM-04-OF-78</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>439</b>	<b>7/17/2016</b>	<b>0905</b>	<b>F</b>	<b>38.0</b>	<b>F</b>	<b>36.8</b>
<b>ADM-04-OF-79</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>430</b>	<b>7/17/2016</b>	<b>0907</b>	<b>F</b>	<b>43.1</b>	<b>F</b>	<b>48.4</b>
ADM-04-WB-82	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0911	P	1.29	P	<1.00
<b>ADM-04-OF-83</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>420</b>	<b>7/17/2016</b>	<b>0912</b>	<b>F</b>	<b>36.7</b>	<b>F</b>	<b>27.3</b>
<b>ADM-04-OF-84</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>419</b>	<b>7/17/2016</b>	<b>0915</b>	<b>F</b>	<b>23.1</b>	<b>F</b>	<b>21.2</b>
ADM-04-WB-86	WB	Water fountain bubbler (Ceramic or Porcelain)	Corridor	7/17/2016	0916	P	1.79	P	1.28

**Allderdice Field House**

# Lead in Drinking Water Sample Results

School: Pittsburgh Allderdice

Address: 2409 Shady Avenue, Pittsburgh, PA, 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
AFH-BS-WM-00	WM	Water main	Mechanical Room	6/29/2016	0703	P	7.56		
AFH-BS-SL-00	SL	Service line connection		6/29/2016	0700	P	5.07		
AFH-01-WB-01	WB	Water fountain bubbler (Ceramin or Porcelain)	Exterior	6/29/2016	0711	P	4.61	P	1.02
AFH-01-WB-02	WB	Water fountain bubbler (Ceramin or Porcelain)	Exterior	6/29/2016	0713	P	<1.00	P	<1.00
AFH-BS-FF-03	FF	Field house faucet	Men's Room	6/29/2016	0708	P	7.05	P	2.43
AFH-01-MS-04	MS	Misc. sink	Exterior	6/29/2016	0717	P	5.85	P	<1.00



**Allderdice High School**

# Lead in Drinking Water Sample Results

School: Pittsburgh Allderdice High School

Address: 2409 Shady Avenue, Pittsburgh, PA, 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
ALD-GF-WM-00	WM	Water Main	Crawlspace	6/29/2016	0821	P	<1.00		
ALD-GF-SL-00	SL	Service Line	Crawlspace	6/29/2016	0818	P	7.28		
ALD-GF-WC-07	WC	Water fountain with cooler	026	6/29/2016	0825	P	2.79	P	<1.00
ALD-GF-NF-08	NF	Nurse's office sink faucets	028	6/29/2016	0828	P	9.89	P	<1.00
ALD-GF-WC-09	WC	Water fountain with cooler	026	6/29/2016	0832	P	2.01	P	<1.00
ALD-GF-WO-20	WO	Water fountain without cooler	POOL	6/29/2016	Non Func.				
<b>ALD-GF-WC-27</b>	<b>WC</b>	<b>Water fountain with cooler</b>	<b>004</b>	<b>6/29/2016</b>	<b>0835</b>	<b>F</b>	<b>20.8</b>	P	2.61
ALD-01-OF-29	OF	Office sink faucets	175	6/29/2016	0847	P	12.4	P	1.41
ALD-01-IM-30	IM	Ice machines	173	6/29/2016	0850	P	<1.00	P	3.19
ALD-01-KF-32	KF	Kitchen faucets	173	6/29/2016	0852	P	10.2	P	<1.00
ALD-01-KF-33	KF	Kitchen faucets	173	6/29/2016	0856	P	8.43	P	<1.00
ALD-01-KF-34	KF	Kitchen faucets	173	6/29/2016	0858	P	5.99	P	<1.00
ALD-01-KF-35	KF	Kitchen faucets	173	6/29/2016	0900	P	3.83	P	1.57
ALD-01-KF-36	KF	Kitchen faucets	173	6/29/2016	0903	P	8.14	P	<1.00
ALD-01-KF-37	KF	Kitchen faucets	173	6/29/2016	0905	P	2.39	P	<1.00
ALD-01-WO-38	WO	Water fountain without cooler	170	6/29/2016	0909	P	14.4	P	4.66
ALD-01-WO-39	WO	Water fountain without cooler	170	6/29/2016	0913	P	7.04	P	8.49
ALD-01-WB-47	WB	Water fountain bubbler (Ceramic or Porcelain)	118	6/29/2016	Non Func.				
ALD-01-WB-48	WB	Water fountain bubbler (Ceramic or Porcelain)	118	6/29/2016	0923	P	15.6	P	4.57
ALD-01-CF-50	CF	Classroom faucets	129	6/29/2016	0926	P	8.37	P	3.07
ALD-01-CF-51	CF	Classroom faucets	129	6/29/2016	0927	P	12.0	P	2.07
ALD-01-WB-54	WB	Water fountain bubbler (Ceramic or Porcelain)	100	6/29/2016	0933	P	<1.00	P	<1.00
ALD-01-WO-55	WO	Water fountain without cooler	100	6/29/2016	0934	P		P	1.39
ALD-01-MS-56	MS	Miscellaneous sinks	113	6/29/2016	0936	P	15.6	P	2.08
ALD-01-MS-57	MS	Miscellaneous sinks	113	6/29/2016	Non Func.				
ALD-01-TF-60	TF	Teacher's lounge sinks	-----	6/29/2016	0943	P	1.11	P	<1.00
ALD-01-TF-61	TF	Teacher's lounge sinks	Nurse Area	6/29/2016	0946	P	4.90	P	<1.00
ALD-01-NF-63	NF	Nurse's office sink faucets	Nurse Area	6/29/2016	0947	P	4.30	P	1.16
ALD-01-WO-64	WO	Water fountain without cooler	Hallway	6/29/2016	0955	P	2.73	P	<1.00
ALD-01-WO-65	WO	Water fountain without cooler	Hallway	6/29/2016	Non Func.				
ALD-01-WO-74	WO	Water fountain without cooler		6/29/2016	1001	P	<1.00	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
ALD-01-WO-75	WO	Water fountain without cooler		6/29/2016	1002	P	<1.00	P	<1.00
ALD-01-CF-82	CF	Classroom faucets	188	6/29/2016	1006	P	<1.00	P	<1.00
ALD-01-KF-83	KF	Kitchen faucets	188	6/29/2016	1007	P	<1.00	P	<1.00
ALD-02-CF-84	CF	Classroom faucets	201	6/29/2016	1028	P	4.17	P	1.68
ALD-02-WB-85	WB	Water fountain bubbler (Ceramic or Porcelain)	200	6/29/2016	1032	P	3.78	P	<1.00
ALD-02-WO-86	WO	Water fountain without cooler	200	6/29/2016	1033	P	<1.00	P	<1.00
ALD-02-CF-87	CF	Classroom faucets	215	6/29/2016	Non Func.				
ALD-02-WC-89	WC	Water fountain with cooler	237	6/29/2016	103	P	3.10	P	4.94
<b>ALD-02-WC-91</b>	<b>WC</b>	<b>Water fountain with cooler</b>	<b>232</b>	<b>6/29/2016</b>	<b>1038</b>	<b>F</b>	<b>26.8</b>	P	12.5
ALD-02-CF-95	CF	Classroom faucets	212	6/29/2016	Non Func.				
ALD-02-CF-96	CF	Classroom faucets	212	6/29/2016	Non Func.				
ALD-02-CF-97	CF	Classroom faucets	212	6/29/2016	Non Func.				
ALD-02-WB-98	WB	Water fountain bubbler (Ceramic or Porcelain)	212	6/29/2016	Non Func.				
ALD-02-TF-101	TF	Teacher's lounge sinks	244	6/29/2016	1052	P	8.89	P	1.52
ALD-02-WB-102	WB	Water fountain bubbler (Ceramic or Porcelain)	256	6/29/2016	Non Func.				
ALD-02-WC-104	WC	Water fountain with cooler	264	6/29/2016	1057	P	2.61	P	4.95
ALD-02-WC-106	WC	Water fountain with cooler	267	6/29/2016	1100	P	2.00	P	2.91
ALD-02-WC-108	WC	Water fountain with cooler	263	6/29/2016	1103	P	6.38	P	7.91
ALD-02-WC-110	WC	Water fountain with cooler	255	6/29/2016	1106	P	3.22	P	4.00
ALD-02-WO-115	WO	Water fountain without cooler	200	6/29/2016	1110	P	2.59	P	<1.00
ALD-02-WO-116	WO	Water fountain without cooler	200	6/29/2016	Non Func.				
ALD-02-WB-117	WB	Water fountain bubbler (Ceramic or Porcelain)	Hallway	6/29/2016	1113	P	7.75	P	2.00
ALD-02-WO-118	WO	Water fountain without cooler	Hallway	6/29/2016	1115	P	3.95	P	2.70
ALD-02-WO-122	WO	Water fountain without cooler	Hallway	6/29/2016	1120	P	7.06	P	2.96
ALD-02-OF-126	OF	Office sink faucets	285	6/29/2016	1120	P	10.2	P	6.90
ALD-03-WO-132	WO	Water fountain without cooler	380	6/29/2016	Non Func.				
ALD-03-WO-133	WO	Water fountain without cooler	380	6/29/2016	1149	P	<1.00	P	<1.00
ALD-03-WO-137	WO	Water fountain without cooler	Hallway	6/29/2016	1150	P	3.17	P	4.72
ALD-03-WO-138	WO	Water fountain without cooler	Hallway	6/29/2016	1152	P	3.46	P	1.78
ALD-03-OF-139	OF	Office sink faucets	343	6/29/2016	1155	P	10.7	P	1.91
ALD-03-WO-140	WO	Water fountain without cooler	300	6/29/2016	1200	P	2.69	P	<1.00
ALD-03-WO-141	WO	Water fountain without cooler	300	6/29/2016	1200	P	4.18	P	1.36
ALD-03-MS-142	MS	Miscellaneous sinks	342	6/29/2016	1201	P	16.0	P	1.73
<b>ALD-03-CF-143</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>346</b>	<b>6/29/2016</b>	<b>1204</b>	<b>F</b>	<b>36.3</b>	<b>F</b>	<b>21.4</b>
ALD-03-CF-148	CF	Classroom faucets	301	6/29/2016	1205	P	11.4	P	3.25
<b>ALD-03-CF-149</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>303</b>	<b>6/29/2016</b>	<b>1208</b>	<b>F</b>	<b>20.0</b>	P	12.5
ALD-03-CF-150	CF	Classroom faucets	306	6/29/2016	Non Func.				

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
ALD-03-CF-155	CF	Classroom faucets	308	6/29/2016	1214	P	7.34	P	5.26
ALD-03-WB-156	WB	Water fountain bubbler (Ceramic or Porcelain)		6/29/2016	1217	P	4.31	P	1.25
ALD-03-WO-157	WO	Water fountain without cooler	Hallway	6/29/2016	Non Func.				
ALD-03-TF-158	TF	Teacher's lounge sinks	309	6/29/2016	1220	P	5.78	P	1.34
ALD-04-WB-162	WB	Water fountain bubbler (Ceramic or Porcelain)	440	6/29/2016	Non Func.				
ALD-04-WB-163	WB	Water fountain bubbler (Ceramic or Porcelain)	440	6/29/2016	1230	P	4.93	P	3.22
ALD-04-WO-250	WO	Water fountain without cooler	Hallway	6/29/2016	Non Func.				
ALD-04-WO-251	WO	Water fountain without cooler	Hallway	6/29/2016	1242	P	<1.00	P	<1.00
ALD-04-CF-278	CF	Classroom faucets	401	6/29/2016	1242	P	5.86	P	2.15
ALD-04-CF-279	CF	Classroom faucets	401	6/29/2016	1242	P	3.72	P	1.86
ALD-04-WO-283	WO	Water fountain without cooler	400	6/29/2016	1248	P	3.51	P	1.04
ALD-04-WO-284	WO	Water fountain without cooler	400	6/29/2016	1249	P	2.26	P	<1.00
ALD-04-CF-285	CF	Classroom faucets	417	6/29/2016	Non Func.				
ALD-04-CF-287	CF	Classroom faucets	425	6/29/2016	1255	P	4.06	P	2.25
ALD-04-CF-288	CF	Classroom faucets	427	6/29/2016	1302	P	4.88	P	1.68
<b>ALD-04-CF-289</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>427</b>	<b>6/29/2016</b>	<b>1303</b>	<b>F</b>	<b>57.1</b>	P	5.11
ALD-04-CF-290	CF	Classroom faucets	430	6/29/2016	1302	P	3.00	P	1.37
ALD-04-CF-291	CF	Classroom faucets	428	6/29/2016	1306	P	5.03	P	1.55
ALD-04-CF-292	CF	Classroom faucets	428	6/29/2016	1306	P	1.66	P	1.11
ALD-04-CF-293	CF	Classroom faucets	422	6/29/2016	1308	P	3.82	P	1.28
ALD-04-HF-294	HF	Home economics faucets (with cooking)	418	6/29/2016	1314	P	10.1	P	2.40
ALD-04-HF-295	HF	Home economics faucets (with cooking)	418	6/29/2016	1315	P	6.92	P	2.16
ALD-04-HF-296	HF	Home economics faucets (with cooking)	418	6/29/2016	1316	P	10.7	P	6.99
ALD-04-HF-297	HF	Home economics faucets (with cooking)	418	6/29/2016	1317	P	14.3	P	2.51
ALD-04-HF-298	HF	Home economics faucets (with cooking)	418	6/29/2016	1318	P	8.82	P	3.24
ALD-04-WO-369	WO	Water fountain without cooler	400	6/29/2016	1312	P	2.44	P	<1.00
ALD-04-WB-370	WB	Water fountain bubbler (Ceramic or Porcelain)	400	6/29/2016	1312	P	2.33	P	<1.00

**Allegheny Annex**

# Lead in Drinking Water Sample Results

School: Pittsburgh Allgheny Annex

Address: 811 Arch Street Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
ALX-BS-SL-00	SL	Service Line	064	7/6/2016	0635	P	3.25		
ALX-BS-WM-00	WM	Water Main	064	7/6/2016	0640	P	2.68		
ALX-01-WF-07	WF	Water fountain with filter & cooler	157	7/6/2016	Removed				
ALX-02-WC-12	WC	Water fountain with cooler	252	7/6/2016	Removed				
<b>ALX-02-CF-16</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>258</b>	<b>7/6/2016</b>	<b>0659</b>	<b>F</b>	<b>24.9</b>	P	2.68
ALX-03-WC-20	WC	Water fountain with cooler		7/6/2016	Removed				
ALX-03-CF-22	CF	Classroom faucets	358	7/6/2016	0706	P	14.4	P	1.98
<b>ALX-03-CF-25</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>360</b>	<b>7/6/2016</b>	<b>0711</b>	<b>F</b>	<b>37.8</b>	P	2.91
ALX-BS-CF-29	CF	Classroom faucets	063	7/6/2016	0644	P	15.6	P	2.37
ALX-BS-CF-30	CF	Classroom faucets	063	7/6/2016	0647	P	7.02	P	2.76
ALX-BS-CF-31	CF	Classroom faucets	063	7/6/2016	0650	P	10.2	P	2.38
<b>ALX-BS-WB-32</b>	<b>WB</b>	<b>Water Bubbler</b>	<b>063</b>	<b>7/6/2016</b>	<b>0635</b>	<b>F</b>	<b>22.4</b>	P	2.96

**Allegheny K-5, 6-8**

# Lead in Drinking Water Sample Results

School: Pittsburgh Allegheny K-5/6-8

Address: 810 Arch Street, Pittsburgh, PA, 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
AGL-BS-WM-00	WM	Water Main	008	6/22/2016	0643	P	<1.00		
AGL-BS-SL-01	SL	Service Line	004	6/22/2016	0640	P	<1.00		
AGL-GF-WC-08	WC	Water fountain with cooler	010	6/22/2016	0645	P	<1.00	P	<1.00
AGL-GF-WC-09	WC	Water fountain with cooler	010	6/22/2016	0649	P	<1.00	P	<1.00
AGL-GF-CF-10	CF	Classroom faucets	12	6/22/2016	0652	P	<1.00	P	<1.00
AGL-GF-CF-13	CF	Classroom faucets	011	6/22/2016	0657	P	3.19	P	<1.00
AGL-GF-CF-15	CF	Classroom faucets	030	6/22/2016	0705	P	1.61	P	1.48
AGL-GF-CF-16	CF	Classroom faucets	030	6/22/2016	0708	P	<1.00	P	<1.00
AGL-GF-KF-18	KF	Kitchen faucets	041	6/22/2016	0719	P	9.90	P	1.78
AGL-GF-KF-19	KF	Kitchen faucets	041	6/22/2016	0723	P	2.43	P	2.61
AGL-GF-KF-20	KF	Kitchen faucets	041	6/22/2016	0726	P	2.55	P	<1.00
AGL-GF-KF-21	KF	Kitchen faucets	041	6/22/2016	0731	P	3.79	P	2.42
AGL-GF-KF-22	KF	Kitchen faucets	041	6/22/2016	0733	P	4.35	P	1.01
AGL-GF-IM-23	IM	Ice machines	034	6/22/2016	0736	P	9.94	P	3.18
AGL-GF-MC-24	MC	Multi-Purpose Room/Cafeteria faucets	037	6/22/2016	0758	P	5.96	P	<1.00
AGL-GF-WC-26	WC	Water fountain with cooler	039	6/22/2016	0801	P	<1.00	P	<1.00
AGL-01-CF-30	CF	Classroom faucets	113	6/22/2016	0820	P	1.41	P	<1.00
AGL-01-WC-32	WC	Water fountain with cooler	100	6/22/2016	0823	P	<1.00	P	<1.00
AGL-01-WC-33	WC	Water fountain with cooler	100	6/22/2016	0826	P	<1.00	P	<1.00
AGL-01-CF-34	CF	Classroom faucets	105	6/22/2016	0829	P	6.84	P	1.38
AGL-01-NF-38	NF	Nurse's office sink faucets	101	6/22/2016	0834	P	<1.00	P	<1.00
AGL-01-CF-44	CF	Classroom faucets	134	6/22/2016	0840	P	1.16	P	<1.00
AGL-01-WC-47	WC	Water fountain with cooler	131	6/22/2016	0846	P	<1.00	P	<1.00
AGL-01-WC-48	WC	Water fountain with cooler	131	6/22/2016	0849	P	<1.00	P	<1.00
<b>AGL-02-CF-49</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>219</b>	<b>6/22/2016</b>	<b>0900</b>	P	8.53	<b>F</b>	<b>29.3</b>
<b>AGL-02-CF-49</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>219</b>	<b>6/28/2016</b>	<b>0615</b>	<b>F</b>	<b>46.0</b>	P	11.8
AGL-02-CF-53	CF	Classroom faucets	228	6/22/2016	0905	P	1.49	P	<1.00
AGL-02-WC-56	WC	Water fountain with cooler		6/22/2016	0910	P	<1.00	P	<1.00



Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
AGL-02-WC-57	WC	Water fountain with cooler		6/22/2016	0914	P	<1.00	P	<1.00
AGL-02-WC-60	WC	Water fountain with cooler	200	6/22/2016	0920	P	<1.00	P	<1.00
AGL-02-WC-61	WC	Water fountain with cooler	200	6/22/2016	0923	P	<1.00	P	<1.00
AGL-02-CF-62	CF	Classroom faucets	202	6/22/2016	0927	P	1.30	P	<1.00
AGL-02-WB-66	WB	Water fountain bubbler (Ceramic or Porcelain)	204	6/22/2016	Non Func.	P	<1.00	P	<1.00
AGL-02-WB-67	WB	Water fountain bubbler (Ceramic or Porcelain)	207	6/22/2016	Non Func.	P	<1.00	P	<1.00
AGL-03-WC-70	WC	Water fountain with cooler		6/22/2016	0936	P	<1.00	P	<1.00
AGL-03-WC-71	WC	Water fountain with cooler		6/22/2016	0940	P	<1.00	P	<1.00
AGL-03-WC-85	WC	Water fountain with cooler		6/22/2016	0950	P	<1.00	P	<1.00
AGL-03-WC-86	WC	Water fountain with cooler		6/22/2016	0952	P	<1.00	P	<1.00
AGL-03-CF-87	CF	Classroom faucets	305	6/22/2016	0956	P	2.49	P	<1.00
AGL-03-WB-93	WB	Water fountain bubbler (Ceramic or Porcelain)	336	6/22/2016	1010	P	6.35	P	5.34
AGL-03-WB-94	WB	Water fountain bubbler (Ceramic or Porcelain)		6/22/2016	1011	P	4.38	P	1.90
AGL-04-WB-95	WB	Water fountain bubbler (Ceramic or Porcelain)		6/22/2016	1036	P	<1.00	P	<1.00
AGL-04-WB-96	WB	Water fountain bubbler (Ceramic or Porcelain)		6/22/2016	1041	P	1.03	P	<1.00
AGL-04-WC-105	WC	Water fountain with cooler	414	6/22/2016	1044	P	1.13	P	1.00
AGL-04-WC-106	WC	Water fountain with cooler	414	6/22/2016	1047	P	<1.00	P	<1.00
AGL-04-TF-110	TF	Teacher's lounge sinks	401	6/22/2016	1051	P	5.57	P	2.01
AGL-04-WC-111	WC	Water fountain with cooler	400	6/22/2016	1056	P	<1.00	P	<1.00
AGL-04-WC-112	WC	Water fountain with cooler	400	6/22/2016	1058	P	<1.00	P	<1.00

**Arsenal Pre-K-5, 6-8**

Lead in Drinking Water Sample Results

School: Pittsburgh Arsenal Pre K-5/6-8

Address: 215 39th Street, Pittsburgh, PA 15201

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
ARS-BS-SL-04	SL	Service Line	B-3	6/17/2016	0652	P	<1.00		
ARS-BS-WM-04	WM	Water Main	B-3	6/17/2016	0655	P	<1.00		
ARS-GF-OF-01	OF	Meters	11A	6/17/2016	0722	P	2.15	p	<1.00
ARS-GF-WB-02	WB	Water fountain bubbler (Ceramic or Porcelain)	1	6/17/2016	0731	P	1.07	p	<1.00
ARS-GF-WB-03	WB	Water fountain bubbler (Ceramic or Porcelain)	1	6/17/2016	0735	P	<1.00	P	<1.00
ARS-BS-WO-07	WO	Water fountain without cooler	B-6	6/17/2016	0711	P	3.26	P	1.01
ARS-GF-CF-10	CF	Classroom faucets	9	6/17/2016	0832	P	5.22	P	<1.00
ARS-GF-WC-14	WC	Water fountain with cooler	1G	6/17/2016	0838	P	<1.00	P	1.14
ARS-GF-WC-15	WC	Water fountain with cooler	1G	6/17/2016	0840	P	<1.00	P	<1.00
ARS-GF-NF-17	NF	Nurse's office sink faucets	26B	6/17/2016	0847	P	18.2	P	2.32
ARS-GF-WC-21	WC	Water fountain with cooler	1G	6/17/2016	0853	P	1.68	P	1.83
ARS-GF-WC-22	WC	Water fountain with cooler	1G	6/17/2016	0856	P	1.78	P	1.30
ARS-GF-KF-23	KF	Kitchen faucets	32	6/17/2016	0904	P	5.92	P	<1.00
ARS-GF-KF-24	KF	Kitchen faucets	32	6/17/2016	0909	P	6.11	P	<1.00
ARS-GF-KF-25	KF	Kitchen faucets	32	6/17/2016	0914	P	1.94	P	<1.00
ARS-GF-KF-26	KF	Kitchen faucets	32	6/17/2016	0917	P	1.47	P	<1.00
ARS-GF-IM-28	IM	Ice machines	32	6/17/2016	0920	P	<1.00	P	<1.00
ARS-GF-CF-30	CF	Classroom faucets	34	6/17/2016	0928	P	2.77	P	<1.00
ARS-GF-CF-31	CF	Classroom faucets	34	6/17/2016	0931	P	1.70	P	<1.00
ARS-GF-CF-32	CF	Classroom faucets	34	6/17/2016	0934	P	3.14	P	<1.00
ARS-GF-WC-41	WC	Water fountain with cooler	1-0	6/17/2016	0938	P	<1.00	P	<1.00
ARS-GF-WC-42	WC	Water fountain with cooler	1-0	6/17/2016	0942	P	<1.00	P	<1.00
ARS-01-CF-50	CF	Classroom faucets	113	6/17/2016	Non-Func.				
ARS-01-CF-60	CF	Classroom faucets	131	6/17/2016	1001	P	<1.00	P	<1.00
ARS-01-WC-62	WC	Water fountain with cooler	100B	6/17/2016	1004	P	<1.00	P	<1.00
ARS-01-WC-63	WC	Water fountain with cooler	100B	6/17/2016	1010	P	<1.00	P	<1.00
ARS-01-CF-72	CF	Classroom faucets	141	6/17/2016	1016	P	2.57	P	<1.00
ARS-01-NF-73	NF	Nurse's office sink faucets	143A	6/17/2016	1020	P	<1.00	P	<1.00
ARS-01-WC-74	WC	Water fountain with cooler	100	6/17/2016	1026	P	1.61	P	1.24
ARS-01-WC-75	WC	Water fountain with cooler	100	6/17/2016	1029	P	1.38	P	1.32
ARS-01-CF-76	CF	Classroom faucets	122	6/17/2016	1035	P	3.29	P	1.41

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
ARS-01-CF-77	CF	Classroom faucets	122	6/17/2016	1039	P	1.89	P	<1.00
ARS-01-CF-78	CF	Classroom faucets	120	6/17/2016	1042	P	9.16	P	1.18
ARS-01-CF-79	CF	Classroom faucets	120	6/17/2016	1045	P	6.12	P	<1.00
ARS-01-WC-81	WC	Water fountain with cooler	100	6/17/2016	1051	P	2.75	P	2.14
ARS-01-WC-82	WC	Water fountain with cooler	100	6/17/2016	1054	P	1.75	P	1.69
ARS-01-HF-83	HF	Home economics faucets (with cooking)	112	6/17/2016	1057	P	7.67	P	1.83
ARS-01-HF-84	HF	Home economics faucets (with cooking)	112	6/17/2016	1059	P	4.57	P	1.27
ARS-01-HF-85	HF	Home economics faucets (with cooking)	112	6/17/2016	1102	P	2.54	P	1.22
ARS-01-HF-86	HF	Home economics faucets (with cooking)	112	6/17/2016	1105	P	1.32	P	<1.00
ARS-01-HF-87	HF	Home economics faucets (with cooking)	112	6/17/2016	1109	P	<1.00	P	<1.00
ARS-02-WC-96	WC	Water fountain with cooler	200	6/17/2016	1117	P	3.64	P	2.22
ARS-02-WC-97	WC	Water fountain with cooler	200	6/17/2016	1119	P	2.23	P	2.34
ARS-02-WC-100	WC	Water fountain with cooler	200	6/17/2016	1124	P	3.10	P	2.30
ARS-02-WC-101	WC	Water fountain with cooler	200	6/17/2016	1126	P	1.33	P	1.88
ARS-03-CF-106	CF	Classroom faucets	301	6/17/2016	1133	P	15.2	P	19.2
ARS-03-CF-107	CF	Classroom faucets	301	6/17/2016	1136	P	5.38	P	18.6
ARS-03-CF-108	CF	Classroom faucets	303	6/17/2016	Non-Func.				
ARS-03-CF-109	CF	Classroom faucets	303	6/17/2016	Non-Func.				
ARS-03-CF-115	CF	Classroom faucets	312	6/17/2016	1143	P	18.5	P	2.04
ARS-03-WC-116	WC	Water fountain with cooler	300	6/17/2016	1149	P	<1.00	P	<1.00
ARS-03-WC-117	WC	Water fountain with cooler	300	6/17/2016	1151	P	<1.00	P	<1.00
ARS-03-CF-118	CF	Classroom faucets	306	6/17/2016	1157	P	6.86	P	2.75
ARS-03-CF-119	CF	Classroom faucets	304	6/17/2016	Non-Func.				
ARS-03-CF-120	CF	Classroom faucets	302	6/17/2016	1203	P	7.81	P	4.86
ARS-03-WC-121	WC	Water fountain with cooler	300	6/17/2016	1208	P	5.34	P	4.71
ARS-03-WC-122	WC	Water fountain with cooler	300	6/17/2016	1211	P	3.24	P	4.20
ARS-02-CF-123	CF	Classroom faucets	210	6/17/2016	1217	P	7.25	P	2.27
ARS-BS-WB-124	WB	Water fountain bubbler (Ceramic or Porcelain)	M-4	6/17/2016	0754	P	1.11	P	<1.00
ARS-BS-WB-125	WB	Water fountain bubbler (Ceramic or Porcelain)	M-4	6/17/2016	Non-Func.				
ARS-BS-WC-131	WC	Water fountain with cooler	B-20	6/17/2016	0758	P	<1.00	P	<1.00
ARS-BS-WC-132	WC	Water fountain with cooler	B-20	6/17/2016	0801	P	<1.00	P	<1.00
ARS-BS-CF-138	CF	Classroom faucets	B-30	6/17/2016	0805	P	<1.00	P	<1.00
ARS-BS-TF-139	TF	Teacher's lounge sinks	B-29	6/17/2016	0808	P	<1.00	P	<1.00
ARS-BS-CF-141	CF	Classroom faucets	B-34	6/17/2016	0810	P	2.44	P	<1.00
ARS-BS-CF-144	CF	Classroom faucets	B-6	6/17/2016	0812	P	4.78	P	<1.00

**Beechwood PreK-5**

### Lead in Drinking Water Sample Results

School: Pittsburgh Beechwood Pre K-5

Address: 810 Rockland Avenue Pittsburgh, PA 15216

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
BEE-BS-SL-01	SL	Service Line	16	6/24/2016	0738	P	<1.00		
BEE-BS-WM-01	WM	Water Main	16	6/24/2016	0741	P	<1.00		
BEE-BS-WC-03	WC	Water fountain with cooler	Corr-1	6/24/2016	0748	P	<1.00	P	<1.00
BEE-BS-WC-04	WC	Water fountain with cooler	Corr-1	6/24/2016	0751	P	<1.00	P	<1.00
BEE-BS-CF-05	CF	Classroom faucets	14	6/24/2016	0757	P	5.40	P	<1.00
BEE-BS-SF-08	SF	Science lab faucets	14	6/24/2016	0803	P	1.01	P	<1.00
BEE-BS-WC-09	WC	Water fountain with cooler	Corr-1	6/24/2016	0814	P	<1.00	P	<1.00
BEE-BS-WC-10	WC	Water fountain with cooler	Corr-1	6/24/2016	0817	P	<1.00	P	<1.00
BEE-BS-CF-11	CF	Classroom faucets	12C	6/24/2016	0821	P	9.64	P	1.44
BEE-BS-NF-21	NF	Nurse's office sink faucets	3	6/24/2016	0828	P	1.23	P	<1.00
BEE-BS-CF-23	CF	Classroom faucets	2	6/24/2016	0831	P	3.38	P	<1.00
BEE-01-OF-24	OF	Office sink faucets	16A	6/24/2016	0858	P	3.34	P	<1.00
BEE-01-WC-25	WC	Water fountain with cooler	Corr-100	6/24/2016	0857	P	<1.00	P	<1.00
BEE-01-WC-26	WC	Water fountain with cooler	Corr-100	6/24/2016	0900	P	1.35	P	<1.00
BEE-01-KF-27	KF	Kitchen faucets	100C	6/24/2016	0903	P	1.77	P	<1.00
BEE-01-WC-28	WC	Water fountain with cooler	Corr-100	6/24/2016	0915	P	<1.00	P	1.06
<b>BEE-01-CF-29</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>109</b>	<b>6/24/2016</b>	<b>0927</b>	<b>F</b>	<b>29.5</b>	P	3.12
BEE-01-US-33	US	Utility sink	J	6/24/2016	0920	P	1.55	P	<1.00
BEE-01-OF-37	OF	Office sink faucets	102	6/24/2016	0908	P	1.99	P	<1.00
BEE-02-CF-38	CF	Classroom faucets	216	6/24/2016	0938	P	2.69	P	1.07
BEE-02-WC-39	WC	Water fountain with cooler	Corr-200	6/24/2016	0942	P	<1.00	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
BEE-02-WC-40	WC	Water fountain with cooler	Corr-200	6/24/2016	0949	P	<1.00	P	<1.00
BEE-02-CF-41	CF	Classroom faucets	215	6/24/2016	0952	P	1.76	P	1.06
BEE-02-TF-42	TF	Teacher's lounge sinks	214	6/24/2016	0953	P	1.56	P	<1.00
BEE-02-WC-43	WC	Water fountain with cooler	Corr-200	6/24/2016	0955	P	1.48	P	1.17
BEE-02-WC-44	WC	Water fountain with cooler	Corr-200	6/24/2016	0958	P	<1.00	P	<1.00
BEE-02-CF-49	CF	Classroom faucets	204	6/24/2016	1003	P	7.54	P	1.31
BEE-DB-CF-53	CF	Classroom faucets	P-01	6/24/2016	0711	P	1.17	P	1.73
BEE-DB-CF-58	CF	Classroom faucets	P-02	6/24/2016	0714	P	2.54	P	1.87
BEE-DB-CF-59	CF	Classroom faucets	P-03	6/24/2016	0718	P	1.22	P	1.41
BEE-DB-CF-64	CF	Classroom faucets	P-04	6/24/2016	0723	P	1.08	P	<1.00

**Brashear High School**  
**South Hills 6-8**



# Lead in Drinking Water Sample Results

School: Pittsburgh Brashear / South Hills 6-8

Address: 590 Crane Ave., Pittsburgh, PA, 15216

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
BRA-BS-WM-00	WM	Water Main	Crawlspace	7/12/2016	0625	P	2.36		
BRA-BS-SL-00	SL	Service Line	Crawlspace	7/12/2016	0626	P	<1.00		
BRA-BS-WC-01	WC	Water fountain with cooler	Main Hallway	7/12/2016	0631	P	<1.00	P	1.83
BRA-BS-WC-02	WC	Water fountain with cooler	Main Hallway	7/12/2016	0631	P	3.05	P	<1.00
BRA-BS-WO-03	WO	Water fountain without cooler	Main Hallway	7/12/2016	Non Functional				
BRA-BS-WC-17	WC	Water fountain with cooler	Automotive	7/12/2016	0653	P	<1.00	P	<1.00
BRA-BS-WC-21	WC	Water fountain with cooler	Automotive	7/12/2016	0639	P	<1.00	P	<1.00
BRA-BS-CF-24	CF	Classroom faucets	G5	7/12/2016	0643	P	<1.00	P	<1.00
BRA-BS-WC-26	WC	Water fountain with cooler	G6	7/12/2016	0645	P	<1.00	P	<1.00
BRA-BS-CF-28	CF	Classroom faucets	G2	7/12/2016	0647	P	<1.00	P	<1.00
BRA-BS-WC-32	WC	Water fountain with cooler	G1	7/12/2016	0648	P	1.76	P	<1.00
BRA-BS-KF-37	KF	Kitchen faucets	G14	7/12/2016	0654	P	<1.00	P	<1.00
BRA-BS-CF-38	CF	Classroom faucets	G14A	7/12/2016	0656	P	18.2	P	8.41
BRA-BS-WC-42	WC	Water fountain with cooler	G13	7/12/2016	0658	P	6.54	P	3.15
BRA-BS-WC-43	WC	Water fountain with cooler	Hallway	7/12/2016	Non Functional				
BRA-BS-CF-45	CF	Classroom faucets	G23	7/12/2016	0703	P	5.21	P	1.13
BRA-BS-WC-46	WC	Water fountain with cooler	Hallway	7/12/2016	0706	P	<1.00	P	<1.00
BRA-BS-WC-47	WC	Water fountain with cooler	Hallway	7/12/2016	0707	P	<1.00	P	<1.00
BRA-BS-WC-48	WC	Water fountain with cooler	Hallway	7/12/2016	Non Functional				
BRA-BS-OF-60	OF	Office sink faucets	G42M	7/12/2016	0710	P	<1.00	P	<1.00
BRA-BS-MS-61	MS	Miscellaneous sinks	G45M	7/12/2016	0711	P	13.9	P	<1.00
BRA-BS-WC-64	WC	Water fountain with cooler	Hallway	7/12/2016	0714	P	<1.00	P	<1.00
BRA-BS-WC-65	WC	Water fountain with cooler	Hallway	7/12/2016	0714	P	<1.00	P	<1.00
BRA-01-KF-68	KF	Kitchen faucets	102	7/12/2016	0727	P	2.41	P	<1.00
BRA-01-KF-69	KF	Kitchen faucets	102	7/12/2016	0728	P	<1.00	P	<1.00
BRA-01-KF-70	KF	Kitchen faucets	102	7/12/2016	0728	P	2.35	P	<1.00
BRA-01-KF-71	KF	Kitchen faucets	102	7/12/2016	0729	P	<1.00	P	<1.00
BRA-01-KF-72	KF	Kitchen faucets	102	7/12/2016	0729	P	1.57	P	<1.00
BRA-01-TF-76	TF	Teacher's lounge sinks	111	7/12/2016	0732	P	<1.00	P	<1.00
BRA-01-TF-79	TF	Teacher's lounge sinks	109A	7/12/2016	0733	P	<1.00	P	<1.00
BRA-01-WC-85	WC	Water fountain with cooler	Hallway	7/12/2016	0737	P	1.42	P	<1.00
BRA-01-WC-86	WC	Water fountain with cooler	Hallway	7/12/2016	0738	P	1.12	P	<1.00
BRA-01-WC-87	WC	Water fountain with cooler	Hallway	7/12/2016	Non Functional				

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
BRA-01-WC-94	WC	Water fountain with cooler	130	7/12/2016	0741	P	<1.00	P	<1.00
BRA-01-OF-95	OF	Office sink faucets	134	7/12/2016	0742	P	<1.00	P	<1.00
BRA-01-NF-97	NF	Nurse's office sink faucets	138	7/12/2016	0743	P	<1.00	P	<1.00
BRA-01-TF-98	TF	Teacher's lounge sinks	138	7/12/2016	0744	P	<1.00	P	<1.00
BRA-01-WC-99	WC	Water fountain with cooler	140	7/12/2016	0747	P	3.58	P	1.65
BRA-01-TF-102	TF	Teacher's lounge sinks	125	7/12/2016	0749	P	<1.00	P	<1.00
<b>BRA-01-OF-104</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>128</b>	<b>7/12/2016</b>	<b>0748</b>	<b>F</b>	<b>27.9</b>	P	1.80
BRA-01-WC-106	WC	Water fountain with cooler	LOBBY	7/12/2016	0752	P	<1.00	P	<1.00
BRA-01-WC-107	WC	Water fountain with cooler	LOBBY	7/12/2016	0753	P	<1.00	P	<1.00
BRA-01-OF-118	OF	Office sink faucets	113A	7/12/2016	0754	P	<1.00	P	<1.00
BRA-01-TF-127	TF	Teacher's lounge sinks	108	7/12/2016	0758	P	<1.00	P	<1.00
BRA-01-KF-128	KF	Kitchen faucets	109	7/12/2016	0801	P	<1.00	P	<1.00
BRA-01-KF-129	KF	Kitchen faucets	109	7/12/2016	0801	P	<1.00	P	<1.00
BRA-01-KF-130	KF	Kitchen faucets	109	7/12/2016	0802	P	<1.00	P	<1.00
BRA-01-KF-131	KF	Kitchen faucets	109	7/12/2016	0805	P	<1.00	P	<1.00
BRA-01-MC-132	MC	Multi-Purpose Room/Cafeteria faucets	109	7/12/2016	Non Functional				
BRA-01-KF-134	KF	Kitchen faucets	109	7/12/2016	0806	P	2.36	P	<1.00
BRA-02-WC-164	WC	Water fountain with cooler	LOBBY	7/12/2016	0822	P	<1.00	P	<1.00
BRA-02-WC-165	WC	Water fountain with cooler	LOBBY	7/12/2016	0822	P	<1.00	P	<1.00
BRA-02-WC-166	WC	Water fountain with cooler	LOBBY	7/12/2016	0823	P	<1.00	P	<1.00
BRA-02-WC-167	WC	Water fountain with cooler	LOBBY	7/12/2016	0826	P	<1.00	P	<1.00
BRA-02-WC-168	WC	Water fountain with cooler	LOBBY	7/12/2016	0826	P	<1.00	P	<1.00
BRA-02-IM-177	IM	Ice machines	269	7/12/2016	Non Functional				
BRA-02-WC-179	WC	Water fountain with cooler	265A	7/12/2016	0833	P	<1.00	P	<1.00
BRA-02-WC-180	WC	Water fountain with cooler	265A	7/12/2016	0833	P	1.40	P	<1.00
BRA-02-WC-185	WC	Water fountain with cooler	263	7/12/2016	Non Functional				
BRA-02-WC-186	WC	Water fountain with cooler	263	7/12/2016	0838	P	3.01	P	<1.00
BRA-02-WC-187	WC	Water fountain with cooler	Hallway	7/12/2016	0841	P	<1.00	P	<1.00
BRA-02-WC-191	WC	Water fountain with cooler	259	7/12/2016	0843	P	<1.00	P	<1.00
BRA-02-WC-192	WC	Water fountain with cooler	259	7/12/2016	0843	P	1.00	P	<1.00
BRA-02-CF-194	CF	Classroom faucets	237	7/12/2016	0850	P	1.61	P	<1.00
BRA-02-CF-195	CF	Classroom faucets	233	7/12/2016	0851	P	2.89	P	<1.00
BRA-02-CF-196	CF	Classroom faucets	233	7/12/2016	0851	P	8.56	P	<1.00
BRA-02-WC-203	WC	Water fountain with cooler	Hallway	7/12/2016	0854	P	1.57	P	<1.00
BRA-02-WC-204	WC	Water fountain with cooler	Hallway	7/12/2016	0855	P	<1.00	P	<1.00
BRA-02-WC-205	WC	Water fountain with cooler	Hallway	7/12/2016	0855	P	1.24	P	<1.00
BRA-02-WC-206	WC	Water fountain with cooler	Hallway	7/12/2016	0857	P	<1.00	P	<1.00
BRA-02-WO-207	WO	Water fountain without cooler	Hallway	7/12/2016	Non Functional				
<b>BRA-03-CF-234</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>371</b>	<b>7/12/2016</b>	<b>0908</b>	<b>F</b>	<b>45.8</b>	P	1.05
BRA-03-WC-269	WC	Water fountain with cooler	Hallway	7/12/2016	0908	P	3.04	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
BRA-03-WC-270	WC	Water fountain with cooler	Hallway	7/12/2016	0909	P	<1.00	P	<1.00
BRA-03-WC-271	WC	Water fountain with cooler	Hallway	7/12/2016	0911	P	2.87	P	<1.00
BRA-03-WC-272	WC	Water fountain with cooler	Hallway	7/12/2016	0911	P	<1.00	P	<1.00
BRA-03-WO-273	WO	Water fountain without cooler	Hallway	7/12/2016	Non Functional				
BRA-03-WO-287	WO	Water fountain without cooler	353	7/12/2016	0917	P	6.61	P	1.55
BRA-03-CF-288	CF	Classroom faucets	340	7/12/2016	0917	P	14.4	P	<1.00
BRA-03-CF-289	CF	Classroom faucets	340	7/12/2016	0918	P	4.79	P	<1.00
BRA-03-CF-290	CF	Classroom faucets	344	7/12/2016	0921	P	6.44	P	<1.00
BRA-03-CF-291	CF	Classroom faucets	344	7/12/2016	0922	P	2.67	P	<1.00
BRA-03-CF-292	CF	Classroom faucets	344	7/12/2016	0922	P	2.09	P	<1.00
BRA-03-CF-293	CF	Classroom faucets	341	7/12/2016	0928	P	3.07	P	<1.00
BRA-03-CF-294	CF	Classroom faucets	341	7/12/2016	0928	P	2.36	P	<1.00
BRA-03-CF-295	CF	Classroom faucets	342	7/12/2016	0928	P	4.51	P	<1.00
BRA-03-CF-296	CF	Classroom faucets	342	7/12/2016	0931	P	2.27	P	<1.00
BRA-03-CF-297	CF	Classroom faucets	343	7/12/2016	0934	P	3.07	P	<1.00
BRA-03-CF-298	CF	Classroom faucets	343	7/12/2016	0934	P	<1.00	P	<1.00
BRA-03-TF-299	TF	Teacher's lounge sinks	328	7/12/2016	0941	P	2.77	P	<1.00
BRA-03-HF-303	HF	Home economics faucets (with cooking)	336	7/12/2016	0944	P	7.67	P	<1.00
BRA-03-HF-304	HF	Home economics faucets (with cooking)	336	7/12/2016	0946	P	<1.00	P	4.17
BRA-03-HF-305	HF	Home economics faucets (with cooking)	336	7/12/2016	0947	P	5.14	P	<1.00
BRA-03-HF-306	HF	Home economics faucets (with cooking)	336	7/12/2016	0949	P	2.68	P	1.66
BRA-03-HF-307	HF	Home economics faucets (with cooking)	336	7/12/2016	Non Functional				
BRA-03-HF-308	HF	Home economics faucets (with cooking)	336	7/12/2016	0950	P	3.45	P	1.11
BRA-03-HF-309	HF	Home economics faucets (with cooking)	336	7/12/2016	0952	P	5.73	P	<1.00
<b>BRA-03-HF-310</b>	<b>HF</b>	<b>Home economics faucets (with cooking)</b>	<b>337</b>	<b>7/12/2016</b>	<b>0956</b>	<b>F</b>	<b>23.6</b>	P	1.80
BRA-03-HF-311	HF	Home economics faucets (with cooking)	337	7/12/2016	0957	P	2.35	P	<1.00
BRA-03-HF-312	HF	Home economics faucets (with cooking)	337	7/12/2016	0958	P	1.45	P	<1.00
BRA-03-HF-313	HF	Home economics faucets (with cooking)	337	7/12/2016	0959	P	<1.00	P	<1.00
BRA-03-HF-314	HF	Home economics faucets (with cooking)	337	7/12/2016	1000	P	3.60	P	<1.00
BRA-03-WC-318	WC	Water fountain with cooler	Hallway	7/12/2016	1007	P	1.59	P	<1.00
BRA-03-WC-319	WC	Water fountain with cooler	Hallway	7/12/2016	1007	P	<1.00	P	<1.00
BRA-03-WC-320	WC	Water fountain with cooler	Hallway	7/12/2016	1008	P	<1.00	P	<1.00
BRA-03-WC-321	WC	Water fountain with cooler	Hallway	7/12/2016	1009	P	<1.00	P	<1.00
BRA-03-WO-322	WO	Water fountain without cooler	Hallway	7/12/2016	Non Functional				

**CAPA 6-12**

# Lead in Drinking Water Sample Results

School: Pittsburgh CAPA

Address: 111 Ninth St. Pittsburgh, PA 15222

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
CAP-BS-WM-00	WM	Water Main	NA	7/8/2016	0652	P	<1.0		
CAP-BS-SL-00	SL	Service Line	NA	7/8/2016	0652	P	<1.00		
CAP-01-KF-12	KF	Kitchen faucets	Kitchen	7/8/2016	0657	P	1.24	P	<1.00
CAP-01-KF-13	KF	Kitchen faucets	Kitchen	7/8/2016	0657	P	2.18	P	1.46
CAP-01-KF-14	KF	Kitchen faucets	Kitchen	7/8/2016	0700	P	1.37	P	<1.00
CAP-01-KF-15	KF	Kitchen faucets	Kitchen	7/8/2016	0700	P	3.23	P	<1.00
<b>CAP-01-KF-16</b>	<b>KF</b>	<b>Kitchen faucets</b>	<b>Kitchen</b>	<b>7/8/2016</b>	<b>0702</b>	<b>F</b>	<b>32.7</b>	P	1.18
CAP-01-KF-17	KF	Kitchen faucets	NA	7/8/2016	0702	P	4.04	P	<1.00
CAP-01-WC-22	WC	Water fountain with cooler	NA	7/8/2016	0708	P	<1.00	P	<1.00
CAP-01-WC-23	WC	Water fountain with cooler	NA	7/8/2016	0708	P	<1.00	P	<1.00
CAP-02-WC-42	WC	Water fountain with cooler	Hallway	7/8/2016	0714	P	<1.00	P	<1.00
CAP-02-WC-43	WC	Water fountain with cooler	Hallway	7/8/2016	0714	P	<1.00	P	<1.00
CAP-02-CF-47	CF	Classroom faucets	214	7/8/2016	0718	P	<1.00	P	<1.00
CAP-03-WC-53	WC	Water fountain with cooler	Hallway	7/8/2016	0721	P	<1.00	P	<1.00
CAP-03-WC-54	WC	Water fountain with cooler	Hallway	7/8/2016	0721	P	<1.00	P	<1.00
CAP-03-CF-60	CF	Classroom faucets	311	7/8/2016	0725	P	<1.00	P	<1.00
CAP-04-TF-61	TF	Teacher's lounge sinks	434	7/8/2016	0732	P	<1.00	P	<1.00
CAP-04-OF-65	OF	Office sink faucets	417	7/8/2016	0735	P	<1.00	P	<1.00
CAP-04-WC-66	WC	Water fountain with cooler	Hallway	7/8/2016	0737	P	<1.00	P	<1.00
CAP-04-WC-67	WC	Water fountain with cooler	Hallway	7/8/2016	0737	P	<1.00	P	<1.00
CAP-04-CF-73	CF	Classroom faucets	412	7/8/2016	0740	P	2.56	P	1.11
CAP-04-KF-80	KF	Kitchen faucets	408	7/8/2016	0747	P	1.10	P	<1.00
CAP-04-KF-81	KF	Kitchen faucets	408	7/8/2016	0747	P	1.25	P	<1.00
CAP-04-KF-82	KF	Kitchen faucets	407	7/8/2016	0749	P	4.24	P	<1.00
CAP-04-KF-83	KF	Kitchen faucets	401	7/8/2016	0749	P	<1.00	P	<1.00
CAP-04-KF-84	KF	Kitchen faucets	401	7/8/2016	0751	P	1.48	P	<1.00
CAP-04-KF-85	KF	Kitchen faucets	401	7/8/2016	0751	P	1.09	P	<1.00
CAP-04-KF-86	KF	Kitchen faucets	401	7/8/2016	0753	P	<1.00	P	<1.00
CAP-04-KF-87	KF	Kitchen faucets	401	7/8/2016	0753	P	<1.00	P	<1.00
CAP-04-IM-88	IM	Ice machines	401	7/8/2016	Non Functioning	P	<1.00	P	<1.00
CAP-05-WC-93	WC	Water fountain with cooler		7/8/2016	0802	P	<1.00	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
CAP-05-WC-94	WC	Water fountain with cooler	500	7/8/2016	0804	P	<1.00	P	<1.00
CAP-05-WC-95	WC	Water fountain with cooler		7/8/2016	0805	P	<1.00	P	<1.00
CAP-05-WC-98	WC	Water fountain with cooler		7/8/2016	0807	P	<1.00	P	<1.00
CAP-05-WC-99	WC	Water fountain with cooler		7/8/2016	0807	P	<1.00	P	<1.00
CAP-06-CF-139	CF	Classroom faucets	604	7/8/2016	0814	P	<1.00	P	<1.00
CAP-06-CF-140	CF	Classroom faucets	603A	7/8/2016	0818	P	2.81	P	<1.00
CAP-06-CF-141	CF	Classroom faucets	602	7/8/2016	0818	P	<1.00	P	<1.00
CAP-06-CF-142	CF	Classroom faucets	606	7/8/2016	0821	P	<1.00	P	<1.00
CAP-06-CF-143	CF	Classroom faucets	606	7/8/2016	0821	P	<1.00	P	<1.00
CAP-06-CF-144	CF	Classroom faucets	607	7/8/2016	0823	P	<1.00	P	<1.00
CAP-06-WC-145	WC	Water fountain with cooler	Hallway	7/8/2016	0825	P	<1.00	P	<1.00
CAP-06-WC-146	WC	Water fountain with cooler	Hallway	7/8/2016	0828	P	<1.00	P	<1.00
CAP-06-WC-147	WC	Water fountain with cooler	Hallway	7/8/2016	0828	P	<1.00	P	<1.00
CAP-06-CF-156	CF	Classroom faucets	624	7/8/2016	0832	P	<1.00	P	<1.00
CAP-06-CF-157	CF	Classroom faucets	624-625	7/8/2016	0832	P	<1.00	P	<1.00
CAP-06-CF-158	CF	Classroom faucets	625	7/8/2016	0834	P	<1.00	P	<1.00
CAP-06-CF-159	CF	Classroom faucets	620	7/8/2016	0837	P	<1.00	P	<1.00
CAP-06-CF-160	CF	Classroom faucets	620	7/8/2016	0837	P	<1.00	P	<1.00
CAP-07-WC-162	WC	Water fountain with cooler	714	7/8/2016	0842	P	<1.00	P	<1.00
CAP-07-WC-163	WC	Water fountain with cooler	714	7/8/2016	0842	P	<1.00	P	<1.00
CAP-07-CF-164	CF	Classroom faucets	719	7/8/2016	0847	P	3.37	P	3.72
CAP-08-TF-172	TF	Teacher's lounge sinks	Teachers Room	7/8/2016	0852	P	<1.00	P	<1.00
CAP-08-OF-173	OF	Office sink faucets	Teachers Room	7/8/2016	0853	P	6.60	P	<1.00
CAP-08-WC-177	WC	Water fountain with cooler	Hallway	7/8/2016	0857	P	<1.00	P	<1.00
CAP-08-WC-178	WC	Water fountain with cooler	Hallway	7/8/2016	0857	P	<1.00	P	<1.00
CAP-09-WC-185	WC	Water fountain with cooler	Hallway	7/8/2016	0905	P	<1.00	P	<1.00
CAP-09-WC-186	WC	Water fountain with cooler	Hallway	7/8/2016	0905	P	<1.00	P	<1.00
CAP-01-KF-194	KF	Kitchen faucets	Kitchen	7/8/2016	0711	P	<1.00	P	<1.00

**Carmalt PreK-8**

# Lead in Drinking Water Sample Results

School: Pittsburgh Carmalt Pre K-8

Address: 1550 Breining Street, Pittsburgh, PA 15226

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
CAR-GF-SL-00	SL	Service Line	G143	6/16/2016	6:42am	P	<1.00	N/A	
CAR-GF-WM-00	WM	Water Main	G143	6/16/2016	6:46am	P	<1.00	N/A	
CAR-GF-CF-06	CF	Classroom faucets	G132	6/16/2016	7:06am	P	2.13	P	<1.00
CAR-GF-CF-07	CF	Classroom faucets	G133	6/16/2016	7:09am	P	6.57	P	<1.00
CAR-GF-CF-08	CF	Classroom faucets	G127	6/16/2016	7:14am	P	2.42	P	<1.00
CAR-GF-WC-17	WC	Water fountain with cooler	Outside Boys	6/16/2016	7:20am	P	<1.00	P	<1.00
CAR-GF-WC-18	WC	Water fountain with cooler	Outside Girls	6/16/2016	7:24am	P	<1.00	P	<1.00
CAR-GF-CF-23	CF	Classroom faucets	G120	6/16/2016	7:29am	P	1.03	P	<1.00
CAR-GF-WO-24	WO	Water fountain without cooler	G120	6/16/2016	N/A				
CAR-GF-MC-25	MC	Multi-Purpose Room/Cafeteria faucets	G104	6/16/2016	7:36am	P	1.2	P	<1.00
CAR-GF-CF-26	CF	Classroom faucets	N/A	6/16/2016	7:39am	P	1.47	P	<1.00
CAR-GF-WO-27	WO	Water fountain without cooler	N/A	6/16/2016	7:41am	P	<1.00	P	<1.00
CAR-GF-CF-28	CF	Classroom faucets	G101	6/16/2016	7:46am	P	2.28	P	<1.00
CAR-GF-WO-29	WO	Water fountain without cooler	G101	6/16/2016	N/A				
CAR-01-WC-30	WC	Water fountain with cooler	Outside 179	6/16/2016	8:01am	P	<1.00	P	<1.00
CAR-01-WC-31	WC	Water fountain with cooler	Outside 177	6/16/2016	8:05am	P	<1.00	P	<1.00
CAR-01-WC-32	WC	Water fountain with cooler	Outside E115	6/16/2016	8:10am	P	<1.00	P	1.29
CAR-01-CF-37	CF	Classroom faucets	E105	6/16/2016	8:31am	P	6.02	P	1.23
CAR-01-CF-38	CF	Classroom faucets	E105	6/16/2016	8:33am	P	2.82	P	<1.00
CAR-01-WC-39	WC	Water fountain with cooler	Outside E106	6/16/2016	8:38am	P	<1.00	P	<1.00
CAR-01-TF-49	TF	Teacher's lounge sinks	160	6/16/2016	8:47am	P	3.16	P	<1.00
CAR-01-WC-57	WC	Water fountain with cooler	Outside 154	6/16/2016	8:55am	P	<1.00	P	<1.00
CAR-01-WC-58	WC	Water fountain with cooler	Outside 152	6/16/2016	9:01am	P	<1.00	P	<1.00
CAR-01-CF-59	CF	Classroom faucets	127	6/16/2016	9:04am	P	18.9	P	<1.00
CAR-01-WC-63	WC	Water fountain with cooler	143	6/16/2016	9:13am	P	<1.00	P	<1.00



Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
CAR-01-WC-73	WC	Water fountain with cooler	106	6/16/2016	9:47am	P	<1.00	P	<1.00
CAR-01-KF-74	KF	Kitchen faucets	113	6/16/2016	9:53am	P	<1.00	P	<1.00
CAR-01-KF-75	KF	Kitchen faucets	113	6/16/2016	9:59am	P	<1.00	P	<1.00
CAR-01-WC-76	WC	Water fountain with cooler	Outside 109	6/16/2016	10:05am	P	<1.00	P	<1.00
CAR-01-KF-77	KF	Kitchen faucets	109	6/16/2016	10:08am	P	4.62	P	<1.00
CAR-01-CF-82	CF	Classroom faucets	172	6/16/2016	10:21am	P	1.03	P	<1.00
CAR-02-WC-83	WC	Water fountain with cooler	Across Stair E	6/16/2016	10:31am	P	1.13	P	1.61
CAR-02-NF-84	NF	Nurse's office sink faucets	E219	6/16/2016	10:51am	P	<1.00	P	<1.00
CAR-02-NF-85	NF	Nurse's office sink faucets	E218	6/16/2016	10:55am	P	1.39	P	<1.00
CAR-02-WC-90	WC	Water fountain with cooler	Outside Mens	6/16/2016	10:39am	P	<1.00	P	<1.00
CAR-02-TF-92	TF	Teacher's lounge sinks	E209	6/16/2016	11:01am	P	3.1	P	<1.00
CAR-02-WC-93	WC	Water fountain with cooler	Outside Girls	6/16/2016	11:08am	P	<1.00	P	<1.00
CAR-02-WC-98	WC	Water fountain with cooler	Outside Boys	6/16/2016	11:12am	P	<1.00	P	<1.00
CAR-02-TF-102	TF	Teacher's lounge sinks	228	6/16/2016	11:17am	P	1.48	P	<1.00
CAR-02-WC-103	WC	Water fountain with cooler	Outside Girls	6/16/2016	11:22am	P	<1.00	P	<1.00
CAR-02-WC-111	WC	Water fountain with cooler	Outside Boys	6/16/2016	11:29am	P	<1.00	P	<1.00
CAR-02-CF-112	CF	Classroom faucets	211A	6/16/2016	11:33am	P	14.3	P	1.81
CAR-02-CF-113	CF	Classroom faucets	209	6/16/2016	11:36am	P	4.27	P	<1.00
CAR-02-CF-114	CF	Classroom faucets	209	6/16/2016	11:38am	P	5.48	P	<1.00
CAR-01-KF-35.5	KF	Kitchen faucets	Male Employees' Breakroom E114	6/16/2016	8:24am	P	<1.00	P	<1.00
CAR-01-WC-67.5	WC	Water fountain with cooler	Boys' Locker Room Toilet 137	6/16/2016	9:28am	P	<1.00	P	<1.00

**Colfax K-8**

## Lead in Drinking Water Sample Results

School: Colfax K-8

Address: 2332 Beechwood Blvd., Pittsburgh, PA 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
COL-BS-WM-00	WM	Water Main	7A	6/28/2016	8:11am	<1.00	P		
COL-BS-SL-00	SL	Service Line	7A	6/28/2016	8:07am	<1.00	P		
COL-BS-CF-01	CF	Classroom faucets	6	6/28/2016	8:15am	5.55	P	1.08	P
COL-BS-WO-04	WO	Water fountain without cooler	Next to Stair A	6/28/2016	8:21am	1.83	P	<1.00	P
COL-BS-WO-05	WO	Water fountain without cooler	Next to Stair A	6/28/2016	8:24am	4.83	P	<1.00	P
COL-BS-MS-06	MS	Miscellaneous sinks	10A	6/28/2016	8:29am	2.05	P	<1.00	P
COL-BS-CF-11	CF	Classroom faucets	17	6/28/2016	8:51am	<1.00	P	<1.00	P
COL-BS-WO-12	WO	Water fountain without cooler	Next to Stair B	6/28/2016	8:54am	4.02	P	<1.00	P
COL-BS-KF-13	KF	Kitchen faucets	Custodian	6/28/2016	8:58am	12.5	P	1.30	P
COL-BS-CF-14	CF	Classroom faucets	15	6/28/2016	9:01am	9.64	P	2.09	P
COL-BS-CF-15	CF	Classroom faucets	15	6/28/2016	9:03am	12.0	P	3.60	P
COL-BS-CF-16	CF	Classroom faucets	16	6/28/2016	9:06am	10.1	P	1.69	P
COL-01-CF-17	CF	Classroom faucets	105A	6/28/2016	9:20am	5.66	P	<1.00	P
COL-01-CF-18	CF	Classroom faucets	104A	6/28/2016	9:23am	4.02	P	1.79	P
COL-01-CF-19	CF	Classroom faucets	106A	6/28/2016	9:26am	12.7	P	1.68	P
COL-01-CF-20	CF	Classroom faucets	103A	6/28/2016	9:29am	1.87	P	<1.00	P
COL-01-WO-21	WO	Water fountain without cooler	Corridor 100	6/28/2016	9:34am	12.2	P	1.32	P
COL-01-WO-22	WO	Water fountain without cooler	Corridor 100	6/28/2016	9:36am	<1.00	P	<1.00	P
COL-01-CF-28	CF	Classroom faucets	102	6/28/2016	9:43am	3.03	P	<1.00	P
COL-01-NF-29	NF	Nurse's office sink faucets	101B	6/28/2016	9:47am	2.27	P	1.41	P
COL-01-CF-34	CF	Classroom faucets	108C	6/28/2016	9:53am	7.57	P	1.60	P
COL-01-WB-35	WB	Water fountain bubbler (Ceramic or Porcelain)	108C	6/28/2016	NF				
COL-01-WO-39	WO	Water fountain without cooler	Corridor 100	6/28/2016	9:59am	1.56	P	<1.00	P
COL-01-WO-40	WO	Water fountain without cooler	Corridor 100	6/28/2016	10:03am	1.71	P	<1.00	P
COL-01-CF-41	CF	Classroom faucets	113A	6/28/2016	10:44am	5.94	P	1.13	P
COL-01-CF-42	CF	Classroom faucets	110A	6/28/2016	10:46am	2.81	P	<1.00	P
COL-01-CF-43	CF	Classroom faucets	112A	6/28/2016	10:48am	4.10	P	1.22	P
COL-01-CF-44	CF	Classroom faucets	111A	6/28/2016	10:53am	3.02	P	1.33	P
COL-01-WC-52	WC	Water fountain with cooler	Corridor A	6/28/2016	11:03am	<1.00	P	<1.00	P
COL-01-WC-53	WC	Water fountain with cooler	Corridor A	6/28/2016	11:04am	<1.00	P	<1.00	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
COL-01-WC-54	WC	Water fountain with cooler	Cafeteria	6/28/2016	11:08am	<1.00	P	<1.00	P
COL-01-WC-55	WC	Water fountain with cooler	Cafeteria	6/28/2016	11:10am	<1.00	P	<1.00	P
COL-01-KF-56	KF	Kitchen faucets	Servery	6/28/2016	11:12am	1.96	P	<1.00	P
COL-01-KF-57	KF	Kitchen faucets	Servery	6/28/2016	11:14am	3.32	P	1.05	P
COL-01-KF-58	KF	Kitchen faucets	Servery	6/28/2016	11:15am	4.58	P	<1.00	P
COL-02-CF-59	CF	Classroom faucets	204A	6/28/2016	11:20am	10.6	P	4.31	P
COL-02-CF-60	CF	Classroom faucets	205A	6/28/2016	11:23am	6.99	P	1.12	P
COL-02-CF-61	CF	Classroom faucets	203A	6/28/2016	11:26am	5.21	P	1.85	P
COL-02-CF-62	CF	Classroom faucets	206A	6/28/2016	11:28am	7.54	P	1.53	P
COL-02-WO-63	WO	Water fountain without cooler	Corridor 200	6/28/2016	11:31am	1.79	P	1.50	P
COL-02-WO-64	WO	Water fountain without cooler	Corridor 200	6/28/2016	11:34am	1.22	P	<1.00	P
COL-02-CF-65	CF	Classroom faucets	202A	6/28/2016	11:37am	4.70	P	1.40	P
<b>COL-02-CF-70</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>201</b>	<b>6/28/2016</b>	11:44am	<b>37.1</b>	<b>F</b>	7.01	P
<b>COL-02-CF-71</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>201</b>	<b>6/28/2016</b>	11:47am	<b>99.4</b>	<b>F</b>	<b>68.2</b>	<b>F</b>
COL-02-OF-72	OF	Office sink faucets	208A	6/28/2016	11:58am	4.81	P	1.00	P
COL-02-CF-73	CF	Classroom faucets	214A	6/28/2016	12:07pm	4.00	P	1.11	P
COL-02-WO-77	WO	Water fountain without cooler	Corridor 200	6/28/2016	12:10pm	2.20	P	<1.00	P
COL-02-WO-78	WO	Water fountain without cooler	Corridor 200	6/28/2016	NF				
COL-02-CF-79	CF	Classroom faucets	213A	6/28/2016	12:12pm	4.84	P	2.34	P
COL-02-CF-80	CF	Classroom faucets	210A	6/28/2016	12:15pm	2.86	P	<1.00	P
COL-02-CF-81	CF	Classroom faucets	212A	6/28/2016	12:18pm	4.04	P	1.06	P
COL-02-CF-82	CF	Classroom faucets	211A	6/28/2016	12:21pm	6.74	P	3.58	P
COL-02-WC-94	WC	Water fountain with cooler	tside Restrooms; New Build	6/28/2016	12:35pm	3.02	P	2.20	P
COL-02-WC-95	WC	Water fountain with cooler	tside Restrooms; New Build	6/28/2016	12:37pm	2.11	P	1.66	P
COL-02-OF-97	OF	Office sink faucets	Nurse	6/28/2016	12:30pm	9.82	P	2.90	P
COL-03-CF-99	CF	Classroom faucets	301	6/28/2016	11:52am	15.9	P	1.98	P
COL-03-WB-100	WB	Water fountain bubbler (Ceramic or Porcelain)	301	6/28/2016	11:53am	5.06	P	1.57	P

**Concord PreK-5**

# Lead in Drinking Water Sample Results

School: Pittsburgh Concord Pre K-5

Address: 2350 Brownsville Road, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
CON-BS-SL-00	SL	Service Line		6/16/2016	0705	P	<1.00		
CON-BS-WM-00	WM	Water Main		6/16/2016	0708	P	<1.00		
CON-BS-WC-07	WC	Water fountain with cooler	Outside Restroom	6/16/2016	0711	P	<1.00	P	<1.00
CON-BS-WC-08	WC	Water fountain with cooler	Outside Restroom	6/16/2016	0714	P	<1.00	P	<1.00
CON-BS-TF-16	TF	Teacher's lounge sinks	Lounge	6/16/2016	0720	P	<1.00	P	1.18
CON-GF-WC-25	WC	Water fountain with cooler	Outside Restroom	6/16/2016	0731	P	<1.00	P	<1.00
CON-GF-WC-26	WC	Water fountain with cooler	Outside Restroom	6/16/2016	0734	P	<1.00	P	<1.00
CON-GF-WC-29	WC	Water fountain with cooler	Outside Cafeteria	6/16/2016	0742	P	<1.00	P	<1.00
CON-GF-KF-30	KF	Kitchen faucets	3	6/16/2016	0748	P	<1.00	P	<1.00
CON-GF-KF-31	KF	Kitchen faucets	3	6/16/2016	0752	P	<1.00	P	<1.00
CON-GF-KF-32	KF	Kitchen faucets	3	6/16/2016	0755	P	<1.00	P	<1.00
CON-GF-KF-33	KF	Kitchen faucets	3	6/16/2016	0759	P	<1.00	P	<1.00
CON-GF-KF-34	KF	Kitchen faucets	3	6/16/2016	0804	P	1.14	P	<1.00
CON-GF-WC-35	WC	Water fountain with cooler	Outside Restroom	6/16/2016	0808	P	<1.00	P	<1.00
CON-GF-WC-36	WC	Water fountain with cooler	Outside Restroom	6/16/2016	0811	P	<1.00	P	<1.00
CON-01-NF-43	NF	Nurse's office sink faucets	102B	6/16/2016	0819	P	<1.00	P	<1.00
CON-01-CF-45	CF	Classroom faucets	X104	6/16/2016	0825	P	11.1	P	2.85
CON-01-WC-46	WC	Water fountain with cooler	X104	6/16/2016	0830	P	6.05	P	4.56
CON-01-WC-48	WC	Water fountain with cooler	Outside Boys	6/16/2016	0836	P	<1.00	P	<1.00
CON-01-WC-49	WC	Water fountain with cooler	Outside Boys	6/16/2016	0839	P	<1.00	P	<1.00
CON-01-CF-54	CF	Classroom faucets	X117	6/16/2016	0847	P	2.26	P	<1.00
CON-01-CF-55	CF	Classroom faucets	X117	6/16/2016	0851	P	11.9	P	1.41
CON-01-CF-57	CF	Classroom faucets	X118	6/16/2016	0857	P	9.99	P	<1.00
CON-01-CF-58	CF	Classroom faucets	X118	6/16/2016	0900	F	62.8	P	5.77
CON-01-TF-60	TF	Teacher's lounge sinks	X119	6/16/2016	0907	P	1.25	P	<1.00
CON-01-CF-62	CF	Classroom faucets	X123	6/16/2016	0912	P	1.58	P	<1.00
CON-01-CF-63	CF	Classroom faucets	X123	6/16/2016	0917	P	2.25	P	<1.00
CON-01-CF-65	CF	Classroom faucets	X120	6/16/2016	0926	F	115.0	P	8.3
CON-01-CF-66	CF	Classroom faucets	X120	6/16/2016	0930	F	23.0	P	2.57

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
CON-01-CF-68	CF	Classroom faucets	X122	6/16/2016	0937	P	1.71	P	<1.00
CON-01-CF-69	CF	Classroom faucets	X122	6/16/2016	0942	P	2.29	P	<1.00
CON-01-WC-70	WC	Water fountain with cooler	Outside Girls	6/16/2016	0947	P	<1.00	P	<1.00
CON-01-WC-71	WC	Water fountain with cooler	Outside Girls	6/16/2016	0951	P	<1.00	P	<1.00
CON-02-WC-78	WC	Water fountain with cooler	Outside Boys	6/16/2016	0958	P	<1.00	P	<1.00
CON-02-WC-79	WC	Water fountain with cooler	Outside Boys	6/16/2016	1002	P	<1.00	P	<1.00
<b>CON-02-MS-84</b>	<b>MS</b>	<b>Miscellaneous sinks</b>	<b>X209</b>	<b>6/16/2016</b>	<b>1006</b>	<b>F</b>	<b>48.9</b>	P	9.4
CON-02-CF-85	CF	Classroom faucets		6/16/2016	1013	P	12.5	P	1.09
CON-02-CF-86	CF	Classroom faucets		6/16/2016	1018	P	6.72	P	<1.00
CON-02-CF-87	CF	Classroom faucets		6/16/2016	1022	P	3.40	P	<1.00
CON-02-WC-88	WC	Water fountain with cooler	Outside Girls	6/16/2016	1025	P	1.90	P	1.23
CON-02-WC-89	WC	Water fountain with cooler	Outside Girls	6/16/2016	1029	P	1.07	P	<1.00

**Conroy**



# Lead in Drinking Water Sample Results

School: Pittsburgh Conroy

Address: 1398 Page St., Pittsburgh, PA 15233

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
CNY-GF-WM-00	WM	Water Main	14A	6/15/2016	0611	2.30	P		
CNY-GF-SL-00	SL	Service Line	14A	6/15/2016	0613	10.00	P		
<b>CNY-GF-MS-04</b>	<b>MS</b>	<b>Miscellaneous sinks</b>	<b>20</b>	<b>6/15/2016</b>	<b>0631</b>	<b>133</b>	<b>F</b>	14.4	P
CNY-GF-OF-05	OF	Office sink faucets	20	6/15/2016	0636	9.52	P	3.69	P
CNY-GF-WO-09	WO	Water fountain without cooler		6/15/2016	0640	8.28	P	2.45	P
CNY-GF-WO-10	WO	Water fountain without cooler		6/15/2016	0645	13.0	P	2.37	P
CNY-01-WO-21	WO	Water fountain without cooler		6/15/2016	0652	8.01	P	1.31	P
CNY-01-WO-22	WO	Water fountain without cooler		6/15/2016	0655	8.33	P	1.86	P
CNY-01-KF-23	KF	Kitchen faucets	122B	6/15/2016	0705	5.48	P	1.79	P
CNY-01-MS-24	MS	Miscellaneous sinks	122D	6/15/2016	0708	10.6	P	1.22	P
CNY-01-KF-32	KF	Kitchen faucets	108A	6/15/2016	0714	1.83	P	<1.00	P
CNY-01-NF-33	NF	Nurse's office sink faucets	105I	6/15/2016	0730	5.83	P	1.56	P
CNY-01-KF-36	KF	Kitchen faucets	108	6/15/2016	0737	3.40	P	1.05	P
CNY-01-KF-37	KF	Kitchen faucets	108	6/15/2016	0740	3.05	P	<1.00	P
CNY-01-KF-38	KF	Kitchen faucets	108	6/15/2016	0744	3.11	P	1.56	P
CNY-01-KF-39	KF	Kitchen faucets	108	6/15/2016	0746	2.43	P	<1.00	P
CNY-01-KF-40	KF	Kitchen faucets	102B	6/15/2016	0753	2.95	P	<1.00	P
CNY-01-KF-43	KF	Kitchen faucets	107A	6/15/2016	0800	3.28	P	<1.00	P
CNY-01-KF-44	KF	Kitchen faucets	107A	6/15/2016	0802	1.06	P	<1.00	P
CNY-01-KF-45	KF	Kitchen faucets	107A	6/15/2016	0806	2.00	P	<1.00	P
CNY-01-KF-46	KF	Kitchen faucets	107	6/15/2016	0808	4.51	P	<1.00	P
CNY-01-WO-47	WO	Water fountain without cooler	100C	6/15/2016	0813	3.01	P	<1.00	P
CNY-01-WO-48	WO	Water fountain without cooler	100C	6/15/2016	0816	4.04	P	1.02	P
CNY-02-WO-49	WO	Water fountain without cooler	200A	6/15/2016	0822	3.84	P	1.34	P
CNY-02-WO-50	WO	Water fountain without cooler	200A	6/15/2016	0825	6.41	P	1.66	P
CNY-01-WO-68	WO	Water fountain without cooler		6/15/2016	0832	4.68	P	1.55	P
CNY-01-WO-72	WO	Water fountain without cooler		6/15/2016	0836	2.81	P	<1.00	P
CNY-01-CF-76	CF	Classroom faucets	101	6/15/2016	0842	2.40	P	<1.00	P
CNY-02-WO-80	WO	Water fountain without cooler	200C (West)	6/15/2016	0850	4.37	P	1.55	P
CNY-02-WO-81	WO	Water fountain without cooler	200C (West)	6/15/2016	0851	3.91	P	1.10	P

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
CNY-02-WO-86	WO	Water fountain without cooler	200C (East)	6/15/2016	0857	2.71	P	1.52	P
CNY-02-WO-87	WO	Water fountain without cooler	200C (East)	6/15/2016	0859	1.28	P	<1.00	P
CNY-03-WO-95	WO	Water fountain without cooler	300C West	6/15/2016	0907	5.58	P	1.85	P
CNY-03-WO-96	WO	Water fountain without cooler	300C West	6/15/2016	0911	2.22	P	1.01	P
<b>CNY-03-CF-100</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>307A</b>	<b>6/15/2016</b>	<b>0914</b>	<b>20.1</b>	<b>F</b>	2.4	P
CNY-03-WO-104	WO	Water fountain without cooler	300C East	6/15/2016	0919	3.80	P	1.77	P
CNY-03-WO-105	WO	Water fountain without cooler	300C East	6/15/2016	0922	3.81	P	1.72	P
CNY-04-WO-111	WO	Water fountain without cooler	400C West	6/15/2016	0930	7.89	P	1.99	P
CNY-04-WO-112	WO	Water fountain without cooler	400C West	6/15/2016	0933	2.89	P	1.73	P
CNY-04-WO-115	WO	Water fountain without cooler	400C East	6/15/2016	0938	8.48	P	1.90	P
CNY-04-WO-116	WO	Water fountain without cooler	400C East	6/15/2016	0941	4.29	P	1.54	P
CNY-GF-WO-122	WO	Water fountain without cooler	Corridor 10	6/15/2016	0620	3.91	P	2.29	P
CNY-GF-WO-123	WO	Water fountain without cooler	Corridor 10	6/15/2016	0625	7.70	P	1.99	P

**Dilworth PreK-5**

# Lead in Drinking Water Sample Results

School: Pittsburgh Dilworth Pre K-5

Address: 6200 Stanton Avenue, Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)
DIL-BS-SL-00	SL	Service Line	11	6/15/2016	0618	P	4.96		
DIL-BS-WM-00	WM	Water Main	11	6/15/2016	0619	P	2.89		
DIL-BS-CF-01	CF	Classroom faucets		6/15/2016	0621	P	1.44	P	<1.00
DIL-BS-WC-07	WC	Water fountain with cooler	Outside 2A	6/15/2016	0629	P	<1.00	P	<1.00
DIL-BS-WC-08	WC	Water fountain with cooler	Outside 2A	6/15/2016	0631	P	<1.00	P	<1.00
DIL-BS-MC-12	MC	Multi-Purpose Room/Cafeteria faucets	002	6/15/2016	0636	P	<1.00	P	<1.00
DIL-BS-KF-14	KF	Kitchen faucets	002	6/15/2016	0637	P	<1.00	P	<1.00
DIL-BS-WC-19	WC	Water fountain with cooler	Outside 16	6/15/2016	0646	P	<1.00	P	<1.00
DIL-BS-WC-20	WC	Water fountain with cooler	Outside 16	6/15/2016	0647	P	<1.00	P	<1.00
DIL-01-CF-26	CF	Classroom faucets	104-A	6/15/2016	0747	P	1.12	P	<1.00
DIL-01-CF-27	CF	Classroom faucets	105-A	6/15/2016	0756	P	6.60	P	<1.00
DIL-01-CF-28	CF	Classroom faucets	106-A	6/15/2016	0744	P	1.85	P	<1.00
DIL-01-CF-29	CF	Classroom faucets	103-A	6/15/2016	0741	P	4.99	P	<1.00
DIL-01-WC-30	WC	Water fountain with cooler	Outside 102	6/15/2016	0737	P	4.92	P	2.59
DIL-01-WC-31	WC	Water fountain with cooler	Outside 102	6/15/2016	0738	P	2.20	P	4.05
<b>DIL-01-CF-32</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>102-A</b>	<b>6/15/2016</b>	<b>0732</b>	<b>F</b>	<b>32.0</b>	P	1.22
DIL-01-NF-34	NF	Nurse's office sink faucets	115-A	6/15/2016	0704	P	2.68	P	<1.00
DIL-01-CF-36	CF	Classroom faucets	114-A	6/15/2016	0706	P	9.06	P	1.29
DIL-01-CF-37	CF	Classroom faucets	114-A	6/15/2016	0708	P	18.7	P	2.34
DIL-01-WC-38	WC	Water fountain with cooler	Outside 113	6/15/2016	0712	P	1.93	P	3.32
DIL-01-WC-39	WC	Water fountain with cooler	Outside 113	6/15/2016	0713	P	2.94	P	2.28
DIL-01-CF-48	CF	Classroom faucets	113-A	6/15/2016	0724	P	4.57	P	<1.00
DIL-01-CF-49	CF	Classroom faucets	111-A	6/15/2016	0726	P	2.61	P	<1.00
DIL-01-CF-50	CF	Classroom faucets		6/15/2016	0727	P	2.35	P	<1.00
DIL-02-CF-51	CF	Classroom faucets	206-A	6/15/2016	0828	P	1.80	P	<1.00
DIL-02-CF-52	CF	Classroom faucets	202	6/15/2016	0826	P	7.35	P	1.97
DIL-02-WC-53	WC	Water fountain with cooler	Outside 201	6/15/2016	0821	P	2.16	P	3.64

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw Pass/Fail (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw Pass/Fail (plumbing) (B)	Second Draw Lead Concentration (ppb)
DIL-02-WC-54	WC	Water fountain with cooler	Outside 201	6/15/2016	0822	P	2.98	P	2.91
DIL-02-TF-55	TF	Teacher's lounge sinks	215	6/15/2016	0809	P	<1.00	P	<1.00
DIL-02-CF-56	CF	Classroom faucets	214	6/15/2016	0811	P	2.67	P	1.14
DIL-02-WC-58	WC	Water fountain with cooler		6/15/2016	0815	P	2.96	P	4.12
DIL-02-WC-59	WC	Water fountain with cooler		6/15/2016	0816	P	3.48	P	4.20
DIL-02-CF-68	CF	Classroom faucets	212-A	6/15/2016	0836	P	4.27	P	<1.00
DIL-02-WO-69	WO	Water fountain without cooler	212-A	6/15/2016	0837	P	5.17	P	1.33

**Fulton PreK-5**

# Lead in Drinking Water Sample Results

School: Pittsburgh Fulton Pre K-5

Address: 5799 Hampton Street Pittsburgh, PA 15206

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
FUL-BS-SL-00	SL	Service Line (Brass Valve)	Crawlspace	6/23/2016	0712	F	64.4		
FUL-BS-SL-00	SL	Service Line (Brass Valve)	Crawlspace	6/28/2016	0623	P	17.7		
FUL-BS-WM-00	WM	Water Main	Crawlspace	6/23/2016	0715	P	1.80		
FUL-BS-CF-01	CF	Classroom faucets	7	6/23/2016	0720	P	1.94	P	<1.00
FUL-BS-SL-00	SL	Service Line	7	6/28/2016	0627	P	2.69	P	1.70
<b>FUL-BS-CF-02</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>6</b>	<b>6/23/2016</b>	<b>0720</b>	<b>F</b>	<b>23.0</b>	P	2.47
<b>FUL-BS-MS-03</b>	<b>MS</b>	<b>Miscellaneous sinks</b>	<b>8</b>	<b>6/23/2016</b>	<b>0730</b>	<b>F</b>	<b>36.1</b>	<b>F</b>	<b>30.2</b>
FUL-BS-WB-04	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 4	6/23/2016	0734	P	7.83	P	1.40
FUL-BS-WB-05	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 4	6/23/2016	0737	P	1.93	P	1.22
FUL-BS-MS-07	MS	Miscellaneous sinks	1-C	6/23/2016	0742	P	<1.00	P	11.4
FUL-BS-CF-08	CF	Classroom faucets	1-A	6/23/2016	0747	P	1.80	P	1.92
FUL-01-MC-10	MC	Multi-Purpose Room/Cafeteria faucets	108-A	6/23/2016	0754	P	2.60	P	<1.00
FUL-01-WB-11	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 110	6/23/2016		Not Functional			
FUL-01-WO-12	WO	Water fountain without cooler	Outside 110	6/23/2016	0800	P	1.20	P	<1.00
FUL-01-NF-21	NF	Nurse's office sink faucets	112	6/23/2016	0807	P	6.63	P	1.51
FUL-01-WO-23	WO	Water fountain without cooler	Outside 101	6/23/2016	0811	P	4.67	F	20.5
FUL-01-WO-23	WO	Water fountain without cooler	Outside 101	6/28/2016	0633	P	9.69	P	4.64
FUL-01-WO-24	WO	Water fountain without cooler	Outside 101	6/23/2016	0813	P	6.10	P	4.07
FUL-01-TF-25	TF	Teacher's lounge sinks	102	6/23/2016	0817	P	5.46	P	2.13
FUL-02-NF-27	NF	Nurse's office sink faucets	214	6/23/2016	0824	P	5.39	P	2.69
FUL-02-WB-28	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 211	6/23/2016	0830	P	2.47	P	<1.00
FUL-02-WB-29	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 211	6/23/2016	0823	P	1.23	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
FUL-02-WB-38	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 201	6/23/2016	0840	P	14.2	P	4.85
FUL-02-WB-39	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 201	6/23/2016	0843	P	10.9	P	5.68
FUL-02-CF-40	CF	Classroom faucets	203	6/23/2016		Not Functional			
FUL-02-CF-41	CF	Classroom faucets	203	6/23/2016	0847	P	7.40	P	3.43
FUL-02-CF-42	CF	Classroom faucets	203	6/23/2016	0850	P	4.91	P	<1.00



**Grandview K-5**

# Lead in Drinking Water Sample Results

School: Pittsburgh Grandview

Address: 845 McLain Street

Total fixtures tested #:

Total samples collected:

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
GRD-BS-WM-00	BS	WM	Water Main	6/30/2016	0741	P	9.21		
GRD-BS-SL-00	BS	SL	Service Line	6/30/2016	0741	P	1.83		
GRD-BS-KF-01	BS	KF	Kitchen faucets	6/30/2016	0749	P	5.80	P	1.13
GRD-BS-KF-02	BS	KF	Kitchen faucets	6/30/2016	0749	P	3.05	P	1.12
GRD-BS-KF-03	BS	KF	Kitchen faucets	6/30/2016	0752	P	9.47	P	1.56
GRD-BS-WO-04	BS	WO	Water fountain without cooler	6/30/2016	0756	P	<1.00	P	1.47
GRD-BS-WO-05	BS	WO	Water fountain without cooler	6/30/2016	0756	P	1.52	P	2.16
GRD-BS-WO-10	BS	WO	Water fountain without cooler	6/30/2016	Non Func.				
GRD-01-CF-16	01	CF	Classroom faucets	6/30/2016	0805	P	6.61	P	1.20
GRD-01-WO-17	01	WO	Water fountain without cooler	6/30/2016	0805	P	2.35	P	1.40
GRD-01-CF-18	01	CF	Classroom faucets	6/30/2016	0813	P	5.98	P	1.74
GRD-01-WO-19	01	WO	Water fountain without cooler	6/30/2016	0813	P	3.73	P	2.59
GRD-01-CF-20	01	CF	Classroom faucets	6/30/2016	Non Func.				
GRD-01-WO-21	01	WO	Water fountain without cooler	6/30/2016	0818	P	16.3	P	3.15
GRD-01-CF-22	01	CF	Classroom faucets	6/30/2016	Non Func.				
GRD-01-WO-23	01	WO	Water fountain without cooler	6/30/2016	Non Func.				
GRD-01-CF-24	01	CF	Classroom faucets	6/30/2016	0823	P	6.97	P	2.65
GRD-01-CF-25	01	CF	Classroom faucets	6/30/2016	0823	P	10.1	P	3.13
GRD-01-WB-26	01	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0829	P	3.82	P	2.13
GRD-01-WB-27	01	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0829	P	2.73	P	2.13
GRD-01-TF-32	01	TF	Teacher's lounge sinks	6/30/2016	0834	P	8.22	P	3.44
GRD-01-CF-33	01	CF	Classroom faucets	6/30/2016	0837	P	7.39	P	1.96
GRD-01-CF-35	01	CF	Classroom faucets	6/30/2016	0837	P	11.7	P	1.56
GRD-01-WB-36	01	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0837	P	1.62	P	<1.00
GRD-01-WB-40	01	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0846	P	3.38	P	1.81
GRD-01-WB-41	01	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0846	P	1.97	P	1.58
GRD-01-CF-42	01	CF	Classroom faucets	6/30/2016	0853	P	8.43	P	5.71
GRD-01-CF-43	01	CF	Classroom faucets	6/30/2016	0855	P	9.57	P	3.74
GRD-01-WO-44	01	WO	Water fountain without cooler	6/30/2016	Non Func.				
GRD-01-WB-45	01	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0900	P	3.74	P	2.16
GRD-01-WB-46	01	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0900	P	1.15	P	1.84
GRD-01-CF-50	01	CF	Classroom faucets	6/30/2016	0908	P	8.49	P	4.16
GRD-01-WO-51	01	WO	Water fountain without cooler	6/30/2016	Non Func.				
GRD-02-CF-52	02	CF	Classroom faucets	6/30/2016	0916	P	10.4	P	1.91
GRD-02-WO-53	02	WO	Water fountain without cooler	6/30/2016	0916	P	4.01	P	1.95

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
GRD-02-TF-54	02	TF	Teacher's lounge sinks	6/30/2016	0923	P	3.61	P	1.78
GRD-02-WB-58	02	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0926	P	3.39	P	2.88
GRD-02-WB-59	02	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0926	P	2.74	P	2.61
GRD-02-CF-60	02	CF	Classroom faucets	6/30/2016	0934	P	7.69	P	4.27
GRD-02-WO-61	02	WO	Water fountain without cooler	6/30/2016	0934	P	5.24	P	4.24
GRD-02-WB-62	02	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0940	P	4.16	P	2.72
GRD-02-WB-63	02	WB	Water fountain bubbler (Ceramic or Porcelain)	6/30/2016	0940	P	3.99	P	3.19
GRD-02-CF-67	02	CF	Classroom faucets	6/30/2016	0946	P	14.7	P	2.70
GRD-02-WO-68	02	WO	Water fountain without cooler	6/30/2016	0946	P	4.83	P	2.16
<b>GRD-BS-CF-70</b>	<b>BS</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>6/30/2016</b>	<b>0959</b>	<b>F</b>	<b>38.6</b>	P	2.52
GRD-BS-WO-71	BS	WO	Water fountain without cooler	6/30/2016	0959	P	4.08	P	2.61
GRD-BS-CF-73	BS	CF	Classroom faucets	6/30/2016	1004	P	3.35	P	2.44
GRD-BS-WO-74	BS	WO	Water fountain without cooler	6/30/2016	Non Func.				

**Greenway (Classical-Gifted Center)**

Lead in Drinking Water Sample Results

School: Greenway Classical-Gifted Center

Address: 1400 Crucible Street Pittsburgh, PA 15205

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
GNW-2.6-WM-00	WM	Water Main	2-606	6/30/2016	6:21	P	1.22		
GNW-2.6-SL-00	SL	Service Line	2-606	6/30/2016	6:21	P	<1.00		
GNW-2.6-WC-10	WC	Water fountain with cooler	2.601	6/30/2016	6:24	P	<1.00	P	<1.00
GNW-3.6-WB-13	WB	Water fountain bubbler (Ceramic or Porcelain)	3.631	6/30/2016	6:35	P	<1.00	P	<1.00
GNW-3.6-WO-14	WO	Water fountain without cooler	3.631	6/30/2016	6:37	P	<1.00	P	<1.00
GNW-3.6-NF-20	NF	Nurse's office sink faucets	3.627	6/30/2016	6:41	P	<1.00	P	<1.00
GNW-3.6-WB-21	WB	Water fountain bubbler (Ceramic or Porcelain)	3.603	6/30/2016	6:46	P	10.6	P	2.39
GNW-3.6-WB-22	WB	Water fountain bubbler (Ceramic or Porcelain)	3.603	Non-functional					
GNW-3.6-WB-23	WB	Water fountain bubbler (Ceramic or Porcelain)	3.06	6/30/2016	6:51	P	<1.00	P	<1.00
GNW-3.5-WC-36	WC	Water fountain with cooler	3.519	6/30/2016	6:58	P	<1.00	P	<1.00
GNW-2.4-CF-42	CF	Classroom faucets	2.489	6/30/2016	7:04	P	2.55	P	<1.00
GNW-2.4-CF-52	CF	Classroom faucets	2.465	6/30/2016	7:09	P	3.41	P	<1.00
GNW-2.4-CF-53	CF	Classroom faucets	2.464	6/30/2016	7:13	P	4.95	P	<1.00
GNW-2.4-WO-54	WO	Water fountain without cooler	2.415	6/30/2016	7:17	P	<1.00	P	<1.00
GNW-2.4-CF-55	CF	Classroom faucets	2.463	6/30/2016	7:23	P	3.49	P	<1.00
GNW-2.4-WO-56	WO	Water fountain without cooler	Outside 2.435	6/30/2016	7:29	P	2.50	P	<100
GNW-2.4-WC-57	WC	Water fountain with cooler	2.401	6/30/2016	7:35	P	<1.00	P	<1.00
GNW-2.4-WC-67	WC	Water fountain with cooler		6/30/2016	7:38	P	<1.00	P	<1.00
GNW-2.4-WC-68	WC	Water fountain with cooler		6/30/2016	7:41	P	<1.00	P	<1.00
GNW-2.4-KF-71	KF	Kitchen faucets	Cafeteria	6/30/2016	7:45	P	<1.00	P	<1.00
GNW-2.4-KF-72	KF	Kitchen faucets	Cafeteria	6/30/2016	7:51	P	<1.00	P	<1.00
GNW-2.4-KF-73	KF	Kitchen faucets	Cafeteria	6/30/2016	7:55	P	1.72	P	1.33
GNW-2.4-CF-74	CF	Classroom faucets	2.472	6/30/2016	7:59	P	3.58	P	<1.00
GNW-2.4-CF-75	CF	Classroom faucets	2.473	6/30/2016	8:03	P	1.79	P	<1.00
GNW-2.4-WO-76	WO	Water fountain without cooler	2.417	6/30/2016	8:08	P	<1.00	P	<1.00
GNW-2.4-HF-77	HF	Home economics faucets (with cooking)	2.417	6/30/2016	8:12	P	1.55	P	<1.00
GNW-2.4-HF-78	HF	Home economics faucets (with cooking)	2.417	6/30/2016	8:15	P	4.18	P	<1.00
GNW-2.4-HF-79	HF	Home economics faucets (with cooking)	2.417	6/30/2016	8:18	P	5.63	P	9.64
GNW-2.4-HF-80	HF	Home economics faucets (with cooking)	2.417	6/30/2016	8:20	P	3.69	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
GNW-2.4-CF-81	CF	Classroom faucets	2.469	6/30/2016	8:24	P	<1.00	P	<1.00
GNW-2.4-CF-82	CF	Classroom faucets	2.469	6/30/2016	8:28	P	1.67	P	<1.00
GNW-2.4-WO-83	WO	Water fountain without cooler	2.418	6/30/2016	8:32	P	<1.00	P	<1.00
GNW-2.4-CF-84	CF	Classroom faucets	2.468	6/30/2016	8:36	P	1.28	P	<1.00
GNW-2.4-CF-85	CF	Classroom faucets	2.468	6/30/2016	8:38	P	1.98	P	1.91
GNW-2.4-CF-86	CF	Classroom faucets	2.467	6/30/2016	8:43	P	<1.00	P	4.48
GNW-2.4-CF-87	CF	Classroom faucets	2.467	6/30/2016	8:44	P	4.57	P	<1.00
GNW-2.3-TF-88	TF	Teacher's lounge sinks	2.389	6/30/2016	9:12	P	<1.00	P	<1.00
GNW-2.3-TF-105	TF	Teacher's lounge sinks	2.343	6/30/2016	9:17	P	1.54	P	<1.00
GNW-2.3-WC-117	WC	Water fountain with cooler	2.301	6/30/2016	9:38	P	<1.00	P	<1.00
GNW-2.3-WB-118	WB	Water fountain bubbler (Ceramic or Porcelain)	2.320	6/30/2016	9:32	P	<1.00	P	<1.00
GNW-2.3-WB-119	WB	Water fountain bubbler (Ceramic or Porcelain)	2.319	6/30/2016	9:29	P	<1.00	P	<1.00
GNW-1.1-MS-140	MS	Miscellaneous sinks	1.119	6/30/2016	11:41	P	10.6	P	1.70
GNW-1.1-WC-142	WC	Water fountain with cooler	1.106	6/30/2016	11:19	P	<1.00	P	<1.00
GNW-1.1-WC-143	WC	Water fountain with cooler	1.105	6/30/2016	11:14	P	<1.00	P	<1.00
GNW-1.1-WC-144	WC	Water fountain with cooler	1.151	6/30/2016	11:11	P	<1.00	P	<1.00
GNW-2.2-WC-156	WC	Water fountain with cooler		6/30/2016	10:18	P	<1.00	P	<1.00
GNW-1.2-OF-157	OF	Office sink faucets		6/30/2016	10:23	P	<1.00	P	<1.00
GNW-1.2-MS-161	MS	Miscellaneous sinks	1.213	6/30/2016	10:28	P	<1.00	P	<1.00
GNW-1.1-KF-162	KF	Kitchen faucets	1.113	6/30/2016	11:32	P	<1.00	P	<1.00
GNW-1.1-KF-163	KF	Kitchen faucets	1.113	6/30/2016	11:27	P	<1.00	P	<1.00
GNW-1.1-KF-164	KF	Kitchen faucets	1.113	6/30/2016	11:27	P	<1.00	P	<1.00
GNW-1.1-KF-165	KF	Kitchen faucets	1.113	6/30/2016	11:25	P	<1.00	P	<1.00
GNW-2.1-WO-169	WO	Water fountain without cooler	2.120	6/30/2016	11:00	P	<1.00	P	<1.00
GNW-2.1-WO-170	WO	Water fountain without cooler		6/30/2016	10:57	P	<1.00	P	1.08
GNW-2.1-TF-176	TF	Teacher's lounge sinks	2.188	6/30/2016	10:43	P	1.44	P	<1.00
GNW-2.1-CF-186	CF	Classroom faucets	2.170	6/30/2016	10:47	P	<1.00	P	<1.00
GNW-2.1-WO-187	WO	Water fountain without cooler	2.116	6/30/2016	10:50	P	1.24	P	<1.00
GNW-2.1-WO-188	WO	Water fountain without cooler	2.114	6/30/2016	10:52	P	1.29	P	<1.00
GNW-2.1-CF-189	CF	Classroom faucets	2.163	6/30/2016	10:55	P	<1.00	P	<1.00
GNW-2.2-WO-190	WO	Water fountain without cooler	2.220	6/30/2016	10:07	P	1.41	P	<1.00
GNW-2.2-WO-191	WO	Water fountain without cooler	near 2.218	6/30/2016	10:03	P	<1.00	P	3.18
GNW-2.2-TF-192	TF	Teacher's lounge sinks	2.289	6/30/2016	9:50	P	<1.00	P	<1.00
GNW-2.2-CF-202	CF	Classroom faucets	2.268	6/30/2016	10:11	P	4.23	P	<1.00
GNW-2.2-WO-203	WO	Water fountain without cooler		6/30/2016	9:55	P	4.57	P	<1.00
GNW-2.2-WO-205	WO	Water fountain without cooler		6/30/2016	9:58	P	<1.00	P	1.34
GNW-2.3-WO-98	WO	Water fountain without cooler		6/30/2016	9:24	P	<1.00	P	<1.00
GNW-2.2-WC-214	WO	Water fountain with cooler		6/30/2016	10:26	P	<1.00	P	<1.00
GNW-2.1-WC-134	WO	Water fountain with cooler		6/30/2016	11:04	P	<1.00	P	<1.00

**Liberty K-5**

# Lead in Drinking Water Sample Results

School:

Pittsburgh Liberty K-5

Address:

601 Filbert St. 15232

Total fixtures tested <sup>#</sup>:

Total samples collected:

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
LIB-BS-WM-00	BS	WM	Water Main	6/28/2016	0706	P	1.65		
LIB-BS-SL-00	BS	SL	Service Line	6/28/2016	0703	P	<1.00		
LIB-BS-OF-01	BS	OF	Office sink faucets	6/28/2016	0702	P	<1.00	P	<1.00
LIB-GF-CF-02	GF	CF	Classroom faucets	6/28/2016	0710	P	12.4	P	2.02
LIB-GF-CF-03	GF	CF	Classroom faucets	6/28/2016	0715	P	12.5	P	2.83
LIB-GF-CF-04	GF	CF	Classroom faucets	6/28/2016	0719	P	8.78	P	1.64
LIB-GF-WC-13	GF	WC	Water fountain with cooler	6/28/2016	0722	P	<1.00	P	<1.00
LIB-GF-WC-14	GF	WC	Water fountain with cooler	6/28/2016	0727	P	<1.00	P	<1.00
LIB-GF-KF-19	GF	KF	Kitchen faucets	6/28/2016	0731	P	1.84	P	1.84
LIB-GF-CF-20	GF	CF	Classroom faucets	6/28/2016	0736	P	<1.00	P	<1.00
LIB-GF-WO-21	GF	WO	Water fountain without cooler	6/28/2016	0736	P	<1.00	P	<1.00
LIB-GF-OF-22	GF	OF	Office sink faucets	6/28/2016	0744	P	<1.00	P	<1.00
LIB-GF-CF-24	GF	CF	Classroom faucets	6/28/2016	0748	P	<1.00	P	1.12
LIB-GF-WO-25	GF	WO	Water fountain without cooler	6/28/2016	0748	F	<1.00	P	1.09
<b>LIB-01-CF-28</b>	<b>01</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>6/28/2016</b>	<b>0759</b>	<b>P</b>	<b>24.9</b>	P	2.99
LIB-01-CF-29	01	CF	Classroom faucets	6/28/2016	0805	P	13.5	P	3.03
LIB-01-CF-30	01	CF	Classroom faucets	6/28/2016	0805	P	19.8	P	3.89
LIB-01-OF-31	01	OF	Office sink faucets	6/28/2016	0813	P	2.86	P	<1.00
LIB-01-WC-40	01	WC	Water fountain with cooler	6/28/2016	0817	P	1.33	P	1.34
LIB-01-WC-41	01	WC	Water fountain with cooler	6/28/2016	0817	P	1.55	P	1.32
LIB-01-CF-43	01	CF	Classroom faucets	6/28/2016	0828	P	2.08	P	<1.00
LIB-01-CF-44	01	CF	Classroom faucets	6/28/2016	0833	P	<1.00	P	1.23
LIB-01-WO-45	01	WO	Water fountain without cooler	6/28/2016	0833	P	1.11	P	1.31
LIB-01-CF-47	01	CF	Classroom faucets	6/28/2016	0841	P	<1.00	P	<1.00
LIB-01-WO-48	01	WO	Water fountain without cooler	6/28/2016	0841	P	<1.00	P	<1.00
LIB-01-NF-49	01	NF	Nurse's office sink faucets	6/28/2016	0852	P	<1.00	P	<1.00
LIB-01-OF-51	01	OF	Office sink faucets	6/28/2016	0903	P	1.64	P	7.62
LIB-02-CF-52	02	CF	Classroom faucets	6/28/2016	0909	P	2.37	P	<1.00
LIB-02-TF-53	02	TF	Teacher's lounge sinks	6/28/2016	0913	P	1.05	P	1.26
LIB-02-IM-55	02	IM	Ice machines	6/28/2016	0917	P	<1.00	P	1.29



Fixture ID	Building Level	Fixture Symbol	Fixture Type	Estimated Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
LIB-02-WC-63	02	WC	Water fountain with cooler	6/28/2016	Non Func.	P		P	
LIB-02-WC-64	02	WC	Water fountain with cooler	6/28/2016	0923	P	<1.00	P	<1.00
LIB-02-WO-70	02	WO	Water fountain without cooler	6/28/2016	0927	P	<1.00	P	<1.00
LIB-02-CF-71	02	CF	Classroom faucets	6/28/2016	0931	P	<1.00	P	1.07

**Mifflin PreK-8**

# Lead in Drinking Water Sample Results

School: Pittsburgh Mifflin

Address: 1290 Mifflin Road, Pittsburgh, PA , 15207

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
MIF-GF-WM-00	WM	Water Main	23D	6/23/2016	0655	P	<1.00		
MIF-GF-SL-00	SL	Service Line	23D	6/23/2016	0655	P	<1.00		
MIF-GF-WC-07	WC	Water fountain with cooler		6/23/2016	0705	P	<1.00	P	<1.00
MIF-GF-WC-08	WC	Water fountain with cooler		6/23/2016	0708	P	<1.00	P	<1.00
MIF-GF-KF-09	KF	Kitchen faucets	22A	6/23/2016	0713	P	<1.00	P	<1.00
MIF-GF-KF-10	KF	Kitchen faucets	22A	6/23/2016	0718	P	<1.00	P	<1.00
MIF-GF-KF-11	KF	Kitchen faucets	22A	6/23/2016	0720	P	3.17	P	<1.00
MIF-GF-CF-14	CF	Classroom faucets	35	6/23/2016	0727	P	2.36	P	<1.00
MIF-GF-WC-15	WC	Water fountain with cooler		6/23/2016	0733	P	<1.00	P	<1.00
MIF-GF-WC-16	WC	Water fountain with cooler		6/23/2016	0738	P	<1.00	P	<1.00
MIF-01-WC-27	WC	Water fountain with cooler	125	6/23/2016	0746	P	<1.00	P	<1.00
MIF-01-WC-28	WC	Water fountain with cooler	125	6/23/2016	0751	P	<1.00	P	<1.00
MIF-01-CF-29	CF	Classroom faucets	127	6/23/2016	0757	P	6.10	P	<1.00
MIF-01-CF-30	CF	Classroom faucets	121	6/23/2016	0805	P	1.22	P	<1.00
MIF-01-CF-31	CF	Classroom faucets	120	6/23/2016	0811	P	1.76	P	<1.00
MIF-01-CF-32	CF	Classroom faucets	128	6/23/2016	0811	P	9.46	P	<1.00
MIF-01-CF-33	CF	Classroom faucets	119	6/23/2016	0830	P	4.54	P	<1.00
MIF-01-CF-34	CF	Classroom faucets	129	6/23/2016	0834	P	4.17	P	<1.00
MIF-01-WC-41	WC	Water fountain with cooler		6/23/2016	0838	P	<1.00	P	<1.00
MIF-01-WC-42	WC	Water fountain with cooler		6/23/2016	0841	P	<1.00	P	<1.00
MIF-01-CF-43	CF	Classroom faucets	133	6/23/2016	0844	P	<1.00	P	<1.00
MIF-01-CF-44	CF	Classroom faucets	133	6/23/2016	0848	P	<1.00	P	<1.00
MIF-01-CF-45	CF	Classroom faucets	133	6/23/2016	0852	P	<1.00	P	<1.00
MIF-01-NF-47	NF	Nurse's office sink faucets	116	6/23/2016	0859	P	<1.00	P	<1.00
MIF-01-CF-51	CF	Classroom faucets	106	6/23/2016	0903	P	13.5	P	1.79
MIF-01-WC-52	WC	Water fountain with cooler		6/23/2016	0906	P	4.19	P	1.74
MIF-01-WC-53	WC	Water fountain with cooler		6/23/2016	0910	P	1.48	P	<1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
MIF-01-TF-54	TF	Teacher's lounge sinks	109	6/23/2016	0915	P	3.41	P	<1.00
MIF-01-WC-56	WC	Water fountain with cooler		6/23/2016	0919	P	1.42	P	1.15
MIF-01-WC-57	WC	Water fountain with cooler		6/23/2016	0922	P	<1.00	P	<1.00
MIF-02-WC-65	WC	Water fountain with cooler		6/23/2016	0930	P	4.03	P	1.99
MIF-02-WC-66	WC	Water fountain with cooler		6/23/2016	0934	P	1.77	P	<1.00
MIF-02-CF-67	CF	Classroom faucets	205	6/23/2016	0937	P	2.51	P	<1.00
MIF-02-WC-68	WC	Water fountain with cooler		6/23/2016	0942	P	1.28	P	1.03
MIF-02-WC-69	WC	Water fountain with cooler		6/23/2016	0946	P	<1.00	P	<1.00
<b>MIF-02-CF-74</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>201</b>	<b>6/23/2016</b>	<b>0949</b>	<b>F</b>	<b>30.2</b>	P	2.94
<b>MIF-02-CF-75</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>213</b>	<b>6/23/2016</b>	<b>0953</b>	<b>F</b>	<b>21.0</b>	P	1.62
MIF-03-WC-76	WC	Water fountain with cooler		6/23/2016	1004	P	3.55	P	2.18
MIF-03-WC-77	WC	Water fountain with cooler		6/23/2016	1006	P	1.71	P	1.02
MIF-03-WC-82	WC	Water fountain with cooler		6/23/2016	1007	P	1.71	P	1.17
MIF-03-WC-83	WC	Water fountain with cooler		6/23/2016	1009	P	1.02	P	<1.00
<b>MIF-03-CF-87</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>301</b>	<b>6/23/2016</b>	<b>1014</b>	<b>F</b>	<b>20.6</b>	P	11.30

**Minadeo PreK-5**

Lead in Drinking Water Sample Results

School: Pittsburgh Minadeo Pre K-5

Address: 6502 Lilac Street, Pittsburgh, PA 15217

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
MIN-BS-SL-00	SL	Service Line	Under 002	6/17/2016	6:56am	P	<1.00		
MIN-BS-WM-00	WM	Water Main	Under 002	6/17/2016	6:59am	P	< 1.00		
MIN-GF-CF-01	CF	Classroom faucets	002	6/17/2016	6:53am	P	3.52	P	< 1.00
MIN-GF-CF-02	CF	Classroom faucets	005	6/17/2016	7:01am	P	17.8	P	3.48
MIN-GF-CF-03	CF	Classroom faucets	003	6/17/2016	7:04am	P	3.48	P	< 1.00
MIN-GF-CF-04	CF	Classroom faucets	006	6/17/2016	7:07am	P	< 1.00	P	2.83
MIN-GF-CF-08	CF	Classroom faucets	004	6/17/2016	7:13am	P	9.88	P	1.47
MIN-GF-WB-09	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 004	6/17/2016	7:15am	P	1.9	P	< 1.00
MIN-GF-WO-10	WO	Water fountain without cooler	Outside 004	6/17/2016	7:18am	P	1.07	P	< 1.00
MIN-GF-TF-12	TF	Teacher's lounge sinks	032	6/17/2016	7:22am	P	6.64	P	< 1.00
MIN-GF-OF-15	OF	Office sink faucets	018	6/17/2016	7:29am	P	9.86	P	3.46
MIN-GF-CF-19	CF	Classroom faucets	035	6/17/2016	7:34am	P	3.94	P	1.35
MIN-GF-CF-20	CF	Classroom faucets	022	6/17/2016	7:36am	P	2.38	P	< 1.00
<b>MIN-GF-CF-21</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>036</b>	<b>6/17/2016</b>	<b>7:39am</b>	<b>F</b>	<b>147</b>	P	11.3
MIN-GF-CF-22	CF	Classroom faucets	023	6/17/2016	7:42am	P	3.38	P	< 1.00
MIN-GF-CF-23	CF	Classroom faucets	039	6/17/2016	7:45am	P	17.1	P	1.9
MIN-GF-WB-24	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 023	6/17/2016	7:49am	P	8.97	P	1.21
MIN-GF-WB-25	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 023	6/17/2016	7:51am	P	3.87	P	1.21
MIN-GF-CF-26	CF	Classroom faucets	024	6/17/2016	7:55am	P	8.82	P	< 1.00
MIN-GF-CF-27	CF	Classroom faucets	040	6/17/2016	7:58am	P	12.5	P	2.85
MIN-GF-CF-28	CF	Classroom faucets	025	6/17/2016	8:01am	P	2.89	P	2.13
<b>MIN-GF-CF-29</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>041</b>	<b>6/17/2016</b>	<b>8:05am</b>	<b>F</b>	<b>20.4</b>	P	3.13
MIN-GF-CF-30	CF	Classroom faucets	027	6/17/2016	8:10am	P	5.89	P	< 1.00
MIN-GF-WB-31	WB	Water fountain bubbler (Ceramic or Porcelain)	027	6/17/2016	8:17am	P	7.99		
<b>MIN-GF-WB-34</b>	<b>WB</b>	<b>Water fountain bubbler (Ceramic or Porcelain)</b>	<b>031</b>	<b>6/17/2016</b>	<b>8:23am</b>	<b>F</b>	<b>46.8</b>	P	8.85
MIN-GF-CF-35	CF	Classroom faucets	031	6/17/2016	8:26am	P	5.27	P	< 1.00
MIN-GF-WO-37	WO	Water fountain without cooler	Outside Cafeteria	6/17/2016	8:31am	P	< 1.00	P	< 1.00
MIN-GF-WO-38	WO	Water fountain without cooler	Outside Cafeteria	6/17/2016	8:34am	P	2.19	P	< 1.00
MIN-GF-KF-39	KF	Kitchen faucets	045	6/17/2016	8:38am	P	2.7	P	< 1.00
MIN-GF-KF-40	KF	Kitchen faucets	045	6/17/2016	8:41am	P	3.75	P	< 1.00

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
MIN-GF-KF-41	KF	Kitchen faucets	045	6/17/2016	8:44am	P	1.78	P	< 1.00
MIN-02-CF-43	CF	Classroom faucets	102	6/17/2016	8:53am	P	5.14	P	< 1.00
MIN-02-CF-44	CF	Classroom faucets	104	6/17/2016	8:56am	P	14.8	P	< 1.00
MIN-02-CF-45	CF	Classroom faucets	103	6/17/2016	8:59am	P	14	P	1.14
MIN-02-CF-46	CF	Classroom faucets	105	6/17/2016	9:02am	P	17.7	P	1.45
MIN-02-WO-52	WO	Water fountain without cooler	101	6/17/2016	9:09am	P	2	P	< 1.00
MIN-02-WC-53	WC	Water fountain with cooler	101	6/17/2016	9:26am	P	1.3	P	< 1.00
MIN-02-HF-59	HF	Home economics faucets (with cooking)	129	6/17/2016	9:31am	P	12.6	P	1.58
MIN-02-CF-60	CF	Classroom faucets	128	6/17/2016	9:35am	P	11.6	P	< 1.00
MIN-02-CF-62	CF	Classroom faucets	119	6/17/2016	Non-Func.				
MIN-02-CF-63	CF	Classroom faucets	119	6/17/2016	9:41am	P	1.18	P	< 1.00
MIN-02-CF-64	CF	Classroom faucets	119	6/17/2016	Non-Func.				
MIN-02-CF-65	CF	Classroom faucets	119	6/17/2016	9:43am	P	1.07	P	< 1.00
<b>MIN-02-CF-66</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>127</b>	<b>6/17/2016</b>	<b>9:47am</b>	<b>F</b>	<b>36.3</b>	P	3.55
<b>MIN-02-CF-67</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>126</b>	<b>6/17/2016</b>	<b>9:50am</b>	<b>F</b>	<b>34</b>	P	3.24
<b>MIN-02-CF-68</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>120</b>	<b>6/17/2016</b>	<b>9:53am</b>	<b>F</b>	<b>23</b>	P	2.27
MIN-02-CF-69	CF	Classroom faucets	125	6/17/2016	9:57am	P	11.8	P	1.59
MIN-02-WO-70	WO	Water fountain without cooler	Outside 120	6/17/2016	10:12am	P	3.47	P	< 1.00
MIN-02-WC-71	WC	Water fountain with cooler	Outside 120	6/17/2016	10:16am	P	1.77	P	< 1.00
MIN-02-CF-72	CF	Classroom faucets	121	6/17/2016	10:19am	P	6.36	P	1.32
MIN-02-CF-73	CF	Classroom faucets	124	6/17/2016	10:22am	P	8.5	P	1.33
MIN-02-CF-74	CF	Classroom faucets	123	6/17/2016	10:25am	P	3.5	P	1.35
MIN-02-CF-76	CF	Classroom faucets	135	6/17/2016	Non-Func.				
MIN-02-NF-77	NF	Nurse's office sink faucets	136	6/17/2016	10:35am	P	6.98	P	< 1.00
MIN-02-OF-78	OF	Office sink faucets	140	6/17/2016	10:39am	P	6.57	P	1.01
MIN-02-WO-80	WO	Water fountain without cooler	Outside 149	6/17/2016	10:43am	P	3.81	P	< 1.00
MIN-02-WB-81	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 149	6/17/2016	10:45am	P	3.37	P	< 1.00
<b>MIN-02-WB-85</b>	<b>WB</b>	<b>Water fountain bubbler (Ceramic or Porcelain)</b>	<b>154</b>	<b>6/17/2016</b>	<b>10:56am</b>	<b>F</b>	<b>62.5</b>	P	8.51
MIN-02-CF-92	CF	Classroom faucets	169	6/17/2016	11:04am	P	< 1.00	P	< 1.00
MIN-02-WO-93	WO	Water fountain without cooler	Outside 165	6/17/2016	11:07am	P	< 1.00	P	< 1.00
MIN-02-WO-94	WO	Water fountain without cooler	Outside 165	6/17/2016	11:09am	P	< 1.00	P	< 1.00

**Obama 6-12, Early Childhood Center**



# Lead in Drinking Water Sample Results

School: Pittsburgh Obama

Address: 515 North Highland Ave, Pittsburgh, PA, 15206

Fixture ID	School Code	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
OBA-GF-WM-00		WM	Water Main	31	7/6/2016	0615	P	< 1.00		
OBA-GF-SL-00		SL	Service Line	31	7/6/2016	0617	P	< 1.00		
OBA-GF-WC-03		WC	Water fountain with cooler	020A	7/6/2016	0618	P	< 1.00	P	< 1.00
OBA-GF-WC-04		WC	Water fountain with cooler	020A	7/6/2016	0619	P	1.88	P	< 1.00
OBA-GF-CF-07		CF	Classroom faucets	023	7/6/2016	0637	P	8.30	P	< 1.00
OBA-GF-CF-08		CF	Classroom faucets	023	7/6/2016	0638	P	1.94	P	< 1.00
OBA-GF-WC-09		WC	Water fountain with cooler	023	7/6/2016	0640	P	2.70	P	2.35
OBA-GF-CF-10		CF	Classroom faucets	017	7/6/2016	0646	P	9.80	P	< 1.00
OBA-GF-CF-11		CF	Classroom faucets	017	7/6/2016	0647	P	6.53	P	1.15
OBA-GF-WC-12		WC	Water fountain with cooler	017	7/6/2016	0648	P	8.53	F	37.7
OBA-GF-CF-14		CF	Classroom faucets	011	7/6/2016	0652	P	1.32	P	< 1.00
OBA-GF-WC-17		WC	Water fountain with cooler	03	7/6/2016	0654	P	3.71	P	< 1.00
OBA-GF-WC-18		WC	Water fountain with cooler	03	7/6/2016	0655	P	7.46	P	3.21
OBA-GF-CF-28		CF	Classroom faucets	020	7/6/2016	0706	P	< 1.00	P	< 1.00
OBA-GF-CF-30		CF	Classroom faucets	030	7/6/2016	0712	P	11.4	P	1.85
OBA-GF-CF-31		CF	Classroom faucets	030	7/6/2016	0713	P	8.37	P	1.02
OBA-GF-CF-32		CF	Classroom faucets	030	7/6/2016	0715	P	17.1	P	1.72
OBA-GF-CF-33		CF	Classroom faucets	030	7/6/2016	0716	P	13.8	P	2.93
OBA-GF-WO-38		WO	Water fountain without cooler	Hallway	7/6/2016	0721	P	2.08	P	< 1.00
OBA-GF-WB-41		WB	Water fountain bubbler (Ceramic or Porcelain)	Hallway	7/6/2016	0723	F	24.9	P	5.40
OBA-GF-WB-46		WB	Water fountain bubbler (Ceramic or Porcelain)	Hallway	7/6/2016	0729	P	3.76	P	3.94
OBA-01-OF-51		OF	Office sink faucets	101A	7/6/2016	0741	P	8.39	P	1.08
OBA-01-CF-54		CF	Classroom faucets	102	7/6/2016	0742	P	5.83	P	< 1.00
OBA-01-CF-55		CF	Classroom faucets	106	7/6/2016	0745	P	9.87	P	1.33
OBA-01-CF-56		CF	Classroom faucets	108	7/6/2016	0746	P	7.50	P	< 1.00
OBA-01-CF-57		CF	Classroom faucets	124	7/6/2016	0747	P	2.70	P	< 1.00
OBA-01-CF-57.5		CF	Classroom faucets	124	7/6/2016	0756	P	11.1	P	1.28
OBA-01-OF-58		OF	Office sink faucets	125	7/6/2016	0753	F	32.6	P	3.04
OBA-01-HF-62		HF	Home economics faucets (with cooking)	147	7/6/2016	0804	P	4.71	P	5.23
OBA-01-HF-63		HF	Home economics faucets (with cooking)	147	7/6/2016	0804	P	3.26	P	< 1.00
OBA-01-HF-64		HF	Home economics faucets (with cooking)	147	7/6/2016	0807	P	5.60	P	1.27

Fixture ID	School Code	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
OBA-01-HF-65		HF	Home economics faucets (with cooking)	147	7/6/2016	0807	P	2.36	P	1.49
OBA-01-HF-66		HF	Home economics faucets (with cooking)	147	7/6/2016	0808	P	9.26	P	1.77
OBA-01-CF-67		CF	Classroom faucets	151	7/6/2016	0818	P	< 1.00	P	< 1.00
OBA-01-CF-68		CF	Classroom faucets	132	7/6/2016	0815	P	10.3	P	1.73
OBA-01-CF-69		CF	Classroom faucets	134	7/6/2016	0817	P	5.08	P	< 1.00
OBA-01-CF-70		CF	Classroom faucets	149	7/6/2016	0821	P	4.77	P	1.04
OBA-01-KF-76		KF	Kitchen faucets	138	7/6/2016	0828	P	12.3	P	1.69
OBA-01-KF-77		KF	Kitchen faucets	138	7/6/2016	0829	P	< 1.00	P	< 1.00
OBA-01-KF-78		KF	Kitchen faucets	138	7/6/2016	0832	P	4.18	P	< 1.00
OBA-01-KF-79		KF	Kitchen faucets	138	7/6/2016	0833	P	12.1	P	< 1.00
OBA-01-WC-81		WC	Water fountain with cooler	100	7/6/2016	0851	P	< 1.00	P	< 1.00
OBA-01-WC-82		WC	Water fountain with cooler	100	7/6/2016	0852	P	< 1.00	P	< 1.00
OBA-01-KF-89.5		KF	Kitchen faucets	160	7/6/2016	0853	P	4.57	P	< 1.00
OBA-01-KF-90		KF	Kitchen faucets	158	7/6/2016	0858	P	5.60	P	< 1.00
OBA-01-KF-91		KF	Kitchen faucets	158	7/6/2016	0900	P	3.97	P	< 1.00
OBA-01-KF-92		KF	Kitchen faucets	158	7/6/2016	0901	P	2.78	P	1.02
OBA-01-WB-93		WB	Water fountain bubbler (Ceramic or Porcelain)	GYM	7/6/2016	0901	P	3.85	P	< 1.00
<b>OBA-01-WC-94</b>		<b>WC</b>	<b>Water fountain with cooler</b>	<b>GYM</b>	<b>7/6/2016</b>	<b>0903</b>	<b>F</b>	<b>56.9</b>	P	2.62
OBA-01-WC-101		WC	Water fountain with cooler	100	7/6/2016	0903	P	< 1.00	P	< 1.00
OBA-01-WC-102		WC	Water fountain with cooler	100	7/6/2016	0915	P	< 1.00	P	< 1.00
OBA-01-WC-106		WC	Water fountain with cooler	100B	7/6/2016	0916	P	1.62	P	1.07
OBA-01-WC-107		WC	Water fountain with cooler	100B	7/6/2016	0917	P	< 1.00	P	< 1.00
OBA-01-CF-108		CF	Classroom faucets	163	7/6/2016	0925	P	9.07	P	< 1.00
OBA-01-CF-109		CF	Classroom faucets	163	7/6/2016	0926	P	9.97	P	< 1.00
OBA-01-CF-110		CF	Classroom faucets	163	7/6/2016	0923	P	12.2	P	3.93
OBA-01-CF-111		CF	Classroom faucets	153	7/6/2016	0930	P	3.84	P	< 1.00
OBA-01-KF-112		KF	Kitchen faucets	138	7/6/2016	0833	P	6.59	P	1.52
<b>OBA-02-CF-119</b>		<b>CF</b>	<b>Classroom faucets</b>	<b>238</b>	<b>7/6/2016</b>	<b>0940</b>	<b>F</b>	<b>37.5</b>	P	3.46
OBA-02-CF-120		CF	Classroom faucets	224	7/6/2016	0942	P	1.27	P	< 1.00
OBA-02-CF-121		CF	Classroom faucets	224	7/6/2016	0943	P	< 1.00	P	< 1.00
OBA-02-CF-122		CF	Classroom faucets	224	7/6/2016	0945	P	2.86	P	< 1.00
OBA-02-CF-123		CF	Classroom faucets	224	7/6/2016	0945	P	1.17	P	< 1.00
OBA-02-TF-129		TF	Teacher's lounge sinks	205	7/6/2016	0951	P	2.06	P	< 1.00
OBA-02-WC-137		WC	Water fountain with cooler	200B	7/6/2016	0953	P	1.28	P	< 1.00
OBA-02-WC-138		WC	Water fountain with cooler	200B	7/6/2016	0955	P	1.22	P	1.09
OBA-03-WC-166		WC	Water fountain with cooler	3008	7/6/2016	1002	P	< 1.00	P	< 1.00
OBA-03-WC-167		WC	Water fountain with cooler	3008	7/6/2016	1003	P	< 1.00	P	< 1.00
OBA-03-CF-193		CF	Classroom faucets	305	7/6/2016	1001	P	6.98	P	< 1.00

**Oliver Field House**

# Lead in Drinking Water Sample Results

School: Pittsburgh Oliver Fieldhouse

Address: 2323 Brighton Road Pittsburgh, PA 15212

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
OFH-GF-WM-00	GF	WM	Water Main	Heater Room	7/1/2016		P	<1.00		
OFH-GF-SL-00	GF	SL	Service Line	Heater Room	7/1/2016		P	<1.00		
OFH-GF-WO-263	GF	WO	Water fountain without cooler	Outside	7/1/2016		P	2.33	P	<1.00
OFH-GF-FF-270	GF	FF	Field House sink faucets	Storage	7/1/2016		P	1.59	P	1.04
OFH-GF-FF-271	GF	FF	Field House sink faucets	Men's restroom	7/1/2016		P	2.16	P	<1.00
OFH-GF-IM-272	GF	IM	Ice machines	Men's restroom	7/1/2016		P	<1.00	P	1.03

**Oliver**

## Lead in Drinking Water Sample Results

School: Pittsburgh Oliver

Address: 2323 Brighton Road Pittsburgh, PA 15212

Total fixtures tested #:

Total samples collected:

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
OLI-GF-WM-00	GF	WM	Water Main	Under stair I	7/1/2016	0651	P	1.47		
OLI-GF-SL-00	GF	SL	Service Line	Under stair I	7/1/2016	0649	P	7.25		
OLI-BS-WB-07	BS	WB	Water fountain bubbler (Ceramic or Porcelain)	P17	7/1/2016	0658	F	41.6	P	7.51
OLI-BS-WB-14	BS	WB	Water fountain bubbler (Ceramic or Porcelain)	P48	7/1/2016	0703	F	43.0	F	23.3
OLI-BS-MS-15	BS	MS	Miscellaneous sinks	P26	7/1/2016	0710	F	141	F	46.4
OLI-BS-WB-16	BS	WB	Water fountain bubbler (Ceramic or Porcelain)	P55	7/1/2016	0715	P	9.75	F	23.5
OLI-BS-WB-24	BS	WB	Water fountain bubbler (Ceramic or Porcelain)	P30	7/1/2016	0722	F	31.7	F	38.1
OLI-BS-WO-28	BS	WO	Water fountain without cooler	P44	7/1/2016	0854	F	30.7	P	8.40
OLI-BS-WC-29	BS	WC	Water fountain with cooler	B91	7/1/2016	0731	P	8.27	F	35.9
OLI-BS-IM-32	BS	IM	Ice machines		7/1/2016	Non Func.				
OLI-GF-WB-35	GF	WB	Water fountain bubbler (Ceramic or Porcelain)		7/1/2016	0741	P	3.70	P	1.14
OLI-GF-WB-36	GF	WB	Water fountain bubbler (Ceramic or Porcelain)		7/1/2016	0742	P	4.68	P	1.26
OLI-GF-CF-38	GF	CF	Classroom faucets	G64	7/1/2016	0747	P	5.39	P	1.31
OLI-GF-CF-41	GF	CF	Classroom faucets	G66	7/1/2016	Non Func.				
OLI-GF-WC-42	GF	WC	Water fountain with cooler	G68	7/1/2016	Non Func.				
OLI-02-KF-43	O2	KF	Kitchen faucets	202	7/1/2016	1109	P	17.4	P	4.09
OLI-GF-KF-44	GF	KF	Kitchen faucets	G01	7/1/2016	0756	P	9.80	P	2.00
OLI-GF-CF-47	GF	CF	Classroom faucets	G04	7/1/2016	0759	P	2.59	P	<1.00
OLI-GF-WC-48	GF	WC	Water fountain with cooler	G04	7/1/2016	Non Func.				
OLI-GF-OF-49	GF	OF	Office sink faucets	G02	7/1/2016	0803	F	22.8	F	38.2
OLI-GF-WO-57	GF	WO	Water fountain without cooler		7/1/2016	0807	P	2.15	P	1.32
OLI-GF-WO-58	GF	WO	Water fountain without cooler		7/1/2016	0809	P	2.57	P	1.46
OLI-GF-OF-59	GF	OF	Office sink faucets	G12	7/1/2016	Non Func.				
OLI-GF-CF-61	GF	CF	Classroom faucets	G15	7/1/2016	0813	P	4.47	P	1.41
OLI-GF-CF-62	GF	CF	Classroom faucets	G15	7/1/2016	0814	P	2.75	P	1.35
OLI-GF-WB-63	GF	WB	Water fountain bubbler (Ceramic or Porcelain)	G14	7/1/2016	0811	P	19.0	P	4.62
OLI-GF-HF-64	GF	HF	Home economics faucets (with cooking)	G14	7/1/2016	0815	P	5.98	P	3.24
OLI-GF-HF-65	GF	HF	Home economics faucets (with cooking)	G14A	7/1/2016	0817	P	4.34	P	3.37
OLI-GF-CF-67	GF	CF	Classroom faucets	G15	7/1/2016	0818	P	14.2	P	5.82
OLI-GF-CF-68	GF	CF	Classroom faucets	G15	7/1/2016	0819	P	8.07	P	5.27
OLI-GF-CF-69	GF	CF	Classroom faucets	G16	7/1/2016	0822	P	6.51	P	6.16
OLI-GF-CF-70	GF	CF	Classroom faucets	G16	7/1/2016	0823	P	6.71	P	4.85
OLI-GF-MS-72	GF	MS	Miscellaneous sinks	G19	7/1/2016	0824	F	103	P	9.21
OLI-GF-CF-73	GF	CF	Classroom faucets	G21	7/1/2016	0837	F	58.9	P	10.2
OLI-GF-CF-74	GF	CF	Classroom faucets	G21	7/1/2016	0838	P	14.5	P	10.0

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
OLI-GF-CF-75	GF	CF	Classroom faucets	G18	7/1/2016	0838	F	42.1	P	9.06
OLI-GF-CF-76	GF	CF	Classroom faucets	G18	7/1/2016	0840	F	41.5	P	8.10
OLI-GF-CF-77	GF	CF	Classroom faucets	G18	7/1/2016	0842	F	117	P	6.52
OLI-GF-WO-80	GF	WO	Water fountain without cooler	Outside G24	7/1/2016	Non Func.				
OLI-GF-WO-81	GF	WO	Water fountain without cooler	Outside G24	7/1/2016	0850	P	11.3	P	7.98
OLI-GF-WO-97	GF	WO	Water fountain without cooler	Outside G30	7/1/2016	0907	P	14.2	P	3.84
OLI-GF-WO-98	GF	WO	Water fountain without cooler	Outside G30	7/1/2016	0908	P	13.6	P	4.07
OLI-GF-MS-99	GF	MS	Miscellaneous sinks	G28	7/1/2016	Non Func.				
OLI-GF-WB-108	GF	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside G40	7/1/2016	Non Func.				
OLI-GF-WB-109	GF	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside G40	7/1/2016	0915	P	4.25	P	2.12
OLI-GF-WB-110	GF	WB	Water fountain bubbler (Ceramic or Porcelain)	G44	7/1/2016	0916	P	2.60	P	2.00
OLI-GF-WB-111	GF	WB	Water fountain bubbler (Ceramic or Porcelain)	G44	7/1/2016	0918	P	2.93	P	1.44
OLI-GF-KF-112	GF	KF	Kitchen faucets	G30	7/1/2016	0920	F	244	P	6.34
OLI-GF-KF-120	GF	KF	Kitchen faucets	G58D	7/1/2016	0928	P	2.87	P	1.72
OLI-GF-RF-121	GF	RF	Restroom lavatory faucets	G58	7/1/2016	No Access				
OLI-GF-OF-122	GF	OF	Office sink faucets	G58	7/1/2016	No Access				
OLI-GF-WB-123	GF	WB	Water fountain bubbler (Ceramic or Porcelain)	G17	7/1/2016	0929	P	6.26	P	2.23
OLI-GF-WB-125	GF	WB	Water fountain bubbler (Ceramic or Porcelain)	G17	7/1/2016	0931	P	8.59	P	8.14
OLI-GF-KF-126	GF	KF	Kitchen faucets	G01C	7/1/2016	0931	P	8.87	P	2.00
OLI-GF-KF-127	GF	KF	Kitchen faucets	G01C	7/1/2016	0933	P	4.60	P	1.27
OLI-GF-KF-128	GF	KF	Kitchen faucets	G01C	7/1/2016	0934	P	9.60	P	1.29
OLI-01-CF-130	01	CF	Classroom faucets	152	7/1/2016	0945	P	8.81	P	2.14
OLI-01-WB-131	01	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 143A	7/1/2016	0945	P	3.80	P	1.54
OLI-01-WB-132	01	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 143A	7/1/2016	0947	P	3.32	P	1.30
OLI-01-NF-134	01	NF	Nurse's office sink faucets	154A	7/1/2016	0948	P	7.14	P	1.91
OLI-01-TF-136	01	TF	Teacher's lounge sinks	100C	7/1/2016	0949	P	2.71	P	<1.00
OLI-01-CF-137	01	CF	Classroom faucets	103	7/1/2016	0952	P	5.79	P	1.93
OLI-01-WB-144	01	WB	Water fountain bubbler (Ceramic or Porcelain)	111	7/1/2016	0954	P	3.82	P	2.13
OLI-01-WB-145	01	WB	Water fountain bubbler (Ceramic or Porcelain)	111	7/1/2016	0956	P	4.15	P	1.64
OLI-01-CF-149	01	CF	Classroom faucets	108	7/1/2016	0958	P	15.0	P	6.88
OLI-01-CF-150	01	CF	Classroom faucets	108A	7/1/2016	1003	P	19.1	P	3.02
OLI-01-CF-151	01	CF	Classroom faucets	110	7/1/2016	Non Func.				
OLI-01-CF-152	01	CF	Classroom faucets	123A	7/1/2016	1005	P	12.2	P	9.47
OLI-01-CF-153	01	CF	Classroom faucets	123	7/1/2016	Non Func.				
OLI-01-CF-154	01	CF	Classroom faucets	114	7/1/2016	Non Func.				
OLI-01-CF-155	01	CF	Classroom faucets	114	7/1/2016	Non Func.				
OLI-01-CF-156	01	CF	Classroom faucets	114	7/1/2016	Non Func.				
OLI-01-CF-157	01	CF	Classroom faucets	114	7/1/2016	Non Func.				
OLI-01-CF-158	01	CF	Classroom faucets	123	7/1/2016	Non Func.				
OLI-01-CF-159	01	CF	Classroom faucets	125	7/1/2016	1020	P	18.7	P	8.76
OLI-01-WB-162	01	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 122	7/1/2016	1018	P	6.84	P	5.31
OLI-01-WB-163	01	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 122	7/1/2016	1020	P	5.96	P	4.13
OLI-01-CF-164	01	CF	Classroom faucets	124	7/1/2016	1026	P	11.2	P	6.98
OLI-01-CF-185	01	CF	Classroom faucets	124A	7/1/2016	1027	F	58.9	P	6.81
OLI-01-CF-206	01	CF	Classroom faucets	126	7/1/2016	1034	F	21.0	P	6.35

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
<b>OLI-01-CF-207</b>	<b>01</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>126</b>	<b>7/1/2016</b>	<b>1036</b>	<b>F</b>	<b>21.0</b>	P	4.02
OLI-01-WB-210	01	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 128	7/1/2016	Non Func.				
OLI-01-WB-211	01	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 128	7/1/2016	1032	P	4.16	P	2.57
OLI-01-CF-214	01	CF	Classroom faucets	136	7/1/2016	1038	P	14.5	P	2.56
OLI-01-OF-218	01	OF	Office sink faucets	121C	7/1/2016	1009	P	13.1	P	5.65
OLI-02-WB-222	02	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside A	7/1/2016	1102	P	6.54	P	4.87
OLI-02-WB-223	02	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside A	7/1/2016	Non Func.				
OLI-02-CF-224	02	CF	Classroom faucets	253	7/1/2016	Non Func.				
OLI-02-MC-225	02	MC	Multi-Purpose Room/Cafeteria faucets	200B	7/1/2016	1104	P	18.5	P	5.00
<b>OLI-02-HF-226</b>	<b>02</b>	<b>HF</b>	<b>Home economics faucets (with cooking)</b>	<b>203</b>	<b>7/1/2016</b>	<b>1111</b>	<b>P</b>	<b>11.2</b>	<b>F</b>	<b>27.7</b>
<b>OLI-02-HF-227</b>	<b>02</b>	<b>HF</b>	<b>Home economics faucets (with cooking)</b>	<b>203</b>	<b>7/1/2016</b>	<b>1113</b>	<b>F</b>	<b>110</b>	P	12.5
<b>OLI-02-HF-228</b>	<b>02</b>	<b>HF</b>	<b>Home economics faucets (with cooking)</b>	<b>203</b>	<b>7/1/2016</b>	<b>1117</b>	<b>F</b>	<b>53.6</b>	P	9.90
<b>OLI-02-HF-229</b>	<b>02</b>	<b>HF</b>	<b>Home economics faucets (with cooking)</b>	<b>203</b>	<b>7/1/2016</b>	<b>1119</b>	<b>F</b>	<b>85.7</b>	P	6.14
OLI-02-HF-230	02	HF	Home economics faucets (with cooking)	203	7/1/2016	1124	P	9.37	P	3.03
OLI-02-KF-231	02	KF	Kitchen faucets	202	7/1/2016	1111	P	19.8	P	2.13
<b>OLI-02-KF-232</b>	<b>02</b>	<b>KF</b>	<b>Kitchen faucets</b>	<b>202</b>	<b>7/1/2016</b>	<b>1114</b>	<b>F</b>	<b>36.3</b>	P	6.67
<b>OLI-02-KF-233</b>	<b>02</b>	<b>KF</b>	<b>Kitchen faucets</b>	<b>202</b>	<b>7/1/2016</b>	<b>1119</b>	P	10.4	<b>F</b>	<b>20.2</b>
OLI-02-MC-235	02	MC	Multi-Purpose Room/Cafeteria faucets	202	7/1/2016	Non Func.				
OLI-02-MC-236	02	MC	Multi-Purpose Room/Cafeteria faucets	202	7/1/2016	Non Func.				
OLI-02-KF-237	02	KF	Kitchen faucets	202	7/1/2016	1123	P	17.9	P	5.51
<b>OLI-02-OF-243</b>	<b>02</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>208</b>	<b>7/1/2016</b>	<b>1127</b>	<b>F</b>	<b>30.7</b>	P	5.86
OLI-02-WO-244	02	WO	Water fountain without cooler	209	7/1/2016	1129	P	1.11	P	<1.00
OLI-02-WO-245	02	WO	Water fountain without cooler	209	7/1/2016	1131	P	1.38	P	1.55
<b>OLI-02-OF-246</b>	<b>02</b>	<b>OF</b>	<b>Office sink faucets</b>	<b>209A</b>	<b>7/1/2016</b>	<b>1130</b>	<b>F</b>	<b>99.8</b>	P	7.02
OLI-02-CF-250	02	CF	Classroom faucets	227	7/1/2016	1139	P	5.87	P	6.44
OLI-02-WB-251	02	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 232	7/1/2016	Non Func.				
OLI-02-WB-252	02	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside 232	7/1/2016	Non Func.				
OLI-02-CF-255	02	CF	Classroom faucets	234	7/1/2016	Non Func.				
OLI-02-WO-256	02	WO	Water fountain without cooler	Outside 244	7/1/2016	1142	P	2.40	P	2.43
OLI-02-WO-257	02	WO	Water fountain without cooler	Outside 244	7/1/2016	1142	P	<1.00	P	1.16
OLI-02-TF-261	02	TF	Teacher's lounge sinks	246	7/1/2016	1143	P	4.81	P	2.68



**Phillips K-5**

# Lead in Drinking Water Sample Results

School: Pittsburgh Phillips K-5

Address: 1901 Sarah Street Pittsburgh, PA 15203

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
PHI-01-SL-00	SL	Service Line	112B	6/29/2016	0656	P	<1.00		
PHI-01-WM-00	WM	Water Main	112B	6/29/2016	0659	P	<1.00		
PHI-01-WC-07	WC	Water fountain with cooler	Corridor 100	6/29/2016	0710	P	<1.00	P	<1.00
PHI-01-WC-08	WC	Water fountain with cooler	Corridor 100	6/29/2016	0713	P	<1.00	P	<1.00
PHI-01-CF-10	CF	Classroom faucets	106	6/29/2016	0717	P	2.83	P	1.21
PHI-01-CF-12	CF	Classroom faucets	108	6/29/2016	0721	P	3.88	P	<1.00
PHI-01-NF-13	NF	Nurse's office sink faucets	Doc 101	6/29/2016	0726	P	4.26	P	<1.00
PHI-02-WC-17	WC	Water fountain with cooler	Corridor 200	6/29/2016	0730	P	<1.00	P	<1.00
PHI-02-WC-18	WC	Water fountain with cooler	Corridor 200	6/29/2016	0735	P	<1.00	P	<1.00
PHI-02-TF-20	TF	Teacher's lounge sinks	202	6/29/2016	0737	P	<1.00	P	<1.00
PHI-02-CF-23	CF	Classroom faucets	206	6/29/2016	0744	P	4.11	P	1.11
PHI-02-CF-24	CF	Classroom faucets	208	6/29/2016	0748	P	<1.00	P	<1.00
PHI-02-CF-25	CF	Classroom faucets	205	6/29/2016	0753	P	8.81	P	1.39
PHI-02-CF-26	CF	Classroom faucets	203	6/29/2016	0758	P	7.47	P	1.65

**Roosevelt PreK-1**

# Lead in Drinking Water Sample Results

School: Roosevelt PreK-1

Address: 200 The Boulevard, Pittsburgh, PA 15210

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly)	First Draw Lead Concentration (ppb)	Second Draw (plumbing)	Second Draw Lead Concentration (ppb)
ROS-01-SL-00	SL	Service Line	Outside - Adjacent Rm 105	6/14/2016	7:36am	P	2.87		
ROS-01-WM-00	WM	Water Main	Outside - Adjacent Rm 105	6/14/2016	7:44am	P	<1.00		
ROS-01-KF-02	KF	Kitchen faucets	Teacher's Room 106	6/14/2016	7:49am	P	<1.00	P	<1.00
ROS-01-CF-11	CF	Classroom faucets	Classroom 105	6/14/2016	7:55am	P	1.42	P	<1.00
ROS-01-WC-12	WC	Water fountain with cooler	Outside Room 103/130	6/14/2016	7:59am	P	1.19	P	<1.00
ROS-01-WB-13	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside Room 103/130	6/14/2016	8:03am	P	<1.00	P	<1.00
ROS-01-WO-14	WO	Water fountain without cooler	Outside Room 114	6/14/2016	8:09am	P	<1.00	P	<1.00
ROS-01-WC-15	WC	Water fountain with cooler	Outside Room 114	6/14/2016	8:12am	P	<1.00	P	<1.00
ROS-01-MC-16	MC	Multi- Purpose Room/Cafeteria faucets	Multi-Purpose 101	6/14/2016	8:17am	P	1.71	P	<1.00
ROS-01-WB-17	WB	Water fountain bubbler (Ceramic or Porcelain)	Multi-Purpose 101	6/14/2016	8:20am	P	1.02	P	<1.00
ROS-01-MC-18	MC	Multi- Purpose Room/Cafeteria faucets	Multi-Purpose 101	6/14/2016	8:22am	P	1.92	P	<1.00
ROS-01-NF-19	NF	Nurse's office sink faucets	Auxiliary 112-C	6/14/2016	8:27am	P	<1.00	P	<1.00
ROS-01-CF-20	CF	Classroom faucets	Kindergarten 102	6/14/2016	8:31am	P	<1.00	P	<1.00

**Schiller 6-8**

# Lead in Drinking Water Sample Results

School: Pittsburgh Schiller

Address: 1018 Peralta Street, Pittsburgh, PA

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
SCH-01-WM-00	WM	Water Main	STORAGE 115-A	7/6/2016	0701	P	12.0		
SCH-01-SL-00	SL	Service Line	STORAGE 115-A	7/6/2016	0702	P	3.10		
SCH-01-KF-02	KF	Kitchen faucets	119-A	7/6/2016	0707	P	1.05	P	<1.00
SCH-01-KF-03	KF	Kitchen faucets	119-A	7/6/2016	0709	P	<1.00	P	<1.00
SCH-GF-WB-05	WB	Water fountain bubbler	004	7/6/2016	Not Functional				
SCH-GF-CF-06	CF	Classroom faucets	004	7/6/2016	0713	P	7.68	P	2.17
SCH-02-CF-10	CF	Classroom faucets	216	7/6/2016	0720	P	3.98	P	2.58
SCH-02-CF-14	CF	Classroom faucets	213	7/6/2016	0749	P	1.90	P	1.00
SCH-02-CF-15	CF	Classroom faucets	213	7/6/2016	0751	P	2.09	P	<1.00
SCH-02-CF-16	CF	Classroom faucets	213	7/6/2016	0753	P	1.40	P	<1.00
SCH-02-CF-17	CF	Classroom faucets	211	7/6/2016	0728	P	12.2	P	2.24
SCH-02-WB-19	WB	Water fountain bubbler	CORRIDOR 200	7/6/2016	0731	P	3.17	P	3.06
SCH-02-WO-20	WO	Water fountain without cooler	CORRIDOR 200	7/6/2016	0735	P	2.69	P	3.10
SCH-02-CF-23	CF	Classroom faucets	209	7/6/2016	0738	P	8.30	P	3.03
<b>SCH-02-CF-24</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>202</b>	<b>7/6/2016</b>	<b>0741</b>	<b>P</b>	<b>39.5</b>	P	8.60
SCH-02-WO-25	WO	Water fountain without cooler	CORRIDOR 200	7/6/2016	Not Functional				
SCH-02-WB-26	WB	Water fountain bubbler	CORRIDOR 200	7/6/2016	0745	P	4.54	P	2.73
SCH-01-WB-31	WB	Water fountain bubbler	CORRIDOR 100	7/6/2016	0759	P	4.51	P	1.41
SCH-01-WO-32	WO	Water fountain without cooler	CORRIDOR 100	7/6/2016	0802	P	1.51	P	<1.00
SCH-01-WO-36	WO	Water fountain without cooler	Hallway	7/6/2016	Not Functional				
SCH-01-WB-37	WB	Water fountain bubbler	Hallway	7/6/2016	0806	P	3.00	P	2.10
SCH-01-OF-39	OF	Office sink faucets	111	7/6/2016	0811	P	5.78	P	<1.00
SCH-01-TF-43	TF	Teacher's lounge sinks	103	7/6/2016	0815	P	2.41	P	2.25
SCH-01-OF-46	OF	Office sink faucets	101	7/6/2016	0819	P	11.6	P	5.43
<b>SCH-01-CF-47</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>123</b>	<b>7/6/2016</b>	<b>0822</b>	<b>F</b>	<b>97.3</b>	P	7.68
SCH-01-NF-48	NF	Nurse's office sink faucets	122-B	7/6/2016	0825	P	15.3	P	1.99
SCH-01-KF-49	KF	Kitchen faucets	120	7/6/2016	0828	P	6.38	P	1.92

**Spring Garden Early Childhood Center**

# Lead in Drinking Water Sample Results

School: Pittsburgh Spring Garden Early Childhood Center

Address: 1501 Spring Garden Avenue, Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
SPG-BS-SL-00	SL	Service Line	B-8	6/14/2016	0712	P	1.12		
SPG-BS-WM-00	WM	Water Main	B-8	6/14/2016	0716	P	<1.00		
SPG-01-WB-02	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside Boys Toilet (106)	6/14/2016	0725	P	<1.00	P	<1.00
SPG-01-WB-03	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside Boys Toilet (106)	6/14/2016	0726	P	4.54	P	2.49
SPG-01-CF-06	CF	Classroom faucets	Room 110-A	6/14/2016	0735	P	1.31	P	<1.00
SPG-01-KF-09	KF	Kitchen faucets	Room 103-A	6/14/2016	0740	P	3.28	P	<1.00
SPG-01-WB-10	WB	Water fountain bubbler (Ceramic or Porcelain)	Room 110	6/14/2016	0742	P	1.54	P	2.44
SPG-01-WB-14	WB	Drinking Water Bubbler	Outside Girls Toilet (101)	6/14/2016	0746	P	2.89	P	<1.00
SPG-01-WB-15	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside Girls Toilet (101)	6/14/2016	0747	P	2.45	P	<1.00
SPG-01-KF-18	KF	Kitchen faucets	Stage 112-A	6/14/2016	0750	P	2.93	P	<1.00
SPG-02-WB-23	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside Boys Toilet (204)	6/14/2016	Non-Func.	P	2.70	P	<1.00
SPG-02-WB-24	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside Boys Toilet (204)	6/14/2016	0756	P	3.53	P	<1.00
SPG-02-CF-27	CF	Classroom faucets	Art Room 207	6/14/2016	0800	P	4.59	P	2.38
SPG-02-CF-28	CF	Classroom faucets	Library Room 208	6/14/2016	0803	P	6.72	P	<1.00
SPG-02-WB-29	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside Girls Toilet (201)	6/14/2016	0805	P	3.06	P	<1.00
SPG-02-WB-30	WB	Water fountain bubbler (Ceramic or Porcelain)	Outside Girls Toilet (201)	6/14/2016	0810	P	2.3	P	<1.00



**Spring Hill K-5**

# Lead in Drinking Water Sample Results

School: Pittsburgh Spring Hill K-5

Address: 1351 Damas Street Pittsburgh, PA 15212

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
SRG-BS-WM-00	WM	Water Main	006	6/24/2016	7:20am	P	7.89		
SRG-BS-SL-01	SL	Service Line	006	7/6/2016	6:31am	P	<1.00		
SRG-BS-CF-04	CF	Classroom faucets	007	6/24/2016	7:23am	P	2.38	P	<1.00
SRG-BS-KF-05	KF	Kitchen faucets	001	6/24/2016	7:29am	P	5.47	P	<1.00
SRG-BS-CF-07	CF	Classroom faucets	010	6/24/2016	7:34am	P	2.13	P	<1.00
SRG-BS-CF-08	CF	Classroom faucets	011	6/24/2016	7:40am	P	<1.00	P	<1.00
SRG-BS-CF-09	CF	Classroom faucets	011	6/24/2016	7:42am	P	<1.00	P	<1.00
SRG-BS-WC-12	WC	Water fountain with cooler	008	6/24/2016	7:47am	P	<1.00	P	<1.00
SRG-BS-WC-13	WC	Water fountain with cooler	008	6/24/2016	7:49am	P	<1.00	P	<1.00
SRG-01-WC-20	WC	Water fountain with cooler	129	6/24/2016	8:01am	P	<1.00	P	<1.00
SRG-01-WC-21	WC	Water fountain with cooler	129	6/24/2016	8:04am	P	<1.00	P	<1.00
SRG-01-TF-22	TF	Teacher's lounge sinks	135	6/24/2016	8:11am	P	<1.00	P	<1.00
SRG-01-NF-31	NF	Nurse's office sink faucets	104	6/24/2016	8:27am	P	<1.00	P	<1.00
SRG-01-WC-33	WC	Water fountain with cooler	Hallway	6/24/2016	8:32am	P	<1.00	P	<1.00
SRG-01-WC-34	WC	Water fountain with cooler	Hallway	6/24/2016	8:36am	P	<1.00	P	<1.00
<b>SRG-02-CF-35</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>219</b>	<b>6/24/2016</b>	<b>8:43am</b>	<b>F</b>	<b>36.4</b>	P	3.57
SRG-02-CF-36	CF	Classroom faucets	219	6/24/2016	8:45am	P	6.25	P	1.60
SRG-02-CF-37	CF	Classroom faucets	201	6/24/2016	8:50am	P	12.6	P	1.65
SRG-02-CF-38	CF	Classroom faucets	210	6/24/2016	8:55am	P	7.11	P	1.28
<b>SRG-02-CF-39</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>210</b>	<b>6/24/2016</b>	<b>8:56am</b>	<b>F</b>	<b>27.3</b>	P	1.92
SRG-02-WC-40	WC	Water fountain with cooler	208	6/24/2016	8:59am	P	<1.00	P	<1.00
SRG-02-WC-41	WC	Water fountain with cooler	208	6/24/2016	9:01am	P	<1.00	P	<1.00

**Student Achievement Center**

# Lead in Drinking Water Sample Results

School: Pittsburgh Student Achievement Center

Address: 925 Brushton Ave., Pittsburgh, PA 15208

Fixture ID	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
SAC-BS-WM-00	WM	Water Main	21	7/8/2016	0626	P	1.31		
SAC-SB-SL-00	SL	Service Line	B-1	7/8/2016	0622	P	2.47		
SAC-BS-KF-03	KF	Kitchen faucets	27	7/8/2016	0638	P	10.0	P	8.61
SAC-BS-KF-04	KF	Kitchen faucets	27	7/8/2016	0641	P	10.9	P	8.57
SAC-BS-WC-07	WC	Water fountain with cooler	23	7/8/2016	0630	P	<1.00	P	<1.00
SAC-BS-WB-12	WB	Water fountain bubbler (Ceramic or Porcelain	29	7/8/2016	Not Used				
SAC-01-WC-13	WC	Water fountain with cooler	120	7/8/2016	0656	P	9.24	P	4.31
SAC-01-WC-14	WC	Water fountain with cooler	120	7/8/2016	0305	P	4.78	P	2.81
SAC-01-NF-21	NF	Nurse's office sink faucets	119A	7/8/2016	0710	P	3.74	P	1.33
SAC-01-WC-22	WC	Water fountain with cooler	120	7/8/2016	0725	P	3.29	P	4.88
SAC-01-WC-23	WC	Water fountain with cooler	121	7/8/2016	0730	P	2.72	P	5.04
SAC-02-WC-29	WC	Water fountain with cooler	CORRIDOR 200	7/8/2016	07388	P	2.21	P	1.86
SAC-02-WC-30	WC	Water fountain with cooler	CORRIDOR 200	7/8/2016	0747	P	1.80	P	1.50
SAC-02-TF-33	TF	Teacher's lounge sinks	206	7/8/2016	0750	P	1.84	P	2.59
SAC-02-OF-34	OF	Office sink faucets	205	7/8/2016	0753	P	5.13	P	7.77
SAC-02-CF-35	CF	Classroom faucets	204	7/8/2016	Not Used				
SAC-02-CF-36	CF	Classroom faucets	203	7/8/2016	0758	P	12.0	P	1.43
SAC-02-CF-38	CF	Classroom faucets	211	7/8/2016	Not Used				
SAC-02-CF-40	CF	Classroom faucets	210B	7/8/2016	Not Used				
SAC-02-CF-42	CF	Classroom faucets	210	7/8/2016	0806	P	3.41	P	1.89
<b>SAC-02-CF-43</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>210</b>	<b>7/8/2016</b>	<b>0808</b>	<b>F</b>	<b>34.4</b>	P	1.55
SAC-02-WC-45	WC	Water fountain with cooler	220	7/8/2016	0813	P	1.42	P	1.89
SAC-02-WC-46	WC	Water fountain with cooler	221	7/8/2016	0815	P	1.34	P	1.34
SAC-03-WC-51	WC	Water fountain with cooler	320	7/8/2016	0850	P	5.99	P	7.52
SAC-03-WC-54	WC	Water fountain with cooler	332	7/8/2016	0853	P	7.46	P	6.67
SAC-03-WC-59	WC	Water fountain with cooler	300	7/8/2016	0823	P	3.11	P	2.47
SAC-03-WC-60	WC	Water fountain with cooler	300	7/8/2016	0825	P	2.34	P	1.56
SAC-03-HF-61	HF	Home economics faucets (with cooking)	303	7/8/2016	0832	P	1.68	P	<1.00
SAC-03-HF-62	HF	Home economics faucets (with cooking)	303	7/8/2016	0835	P	1.24	P	<1.00
SAC-03-HF-63	HF	Home economics faucets (with cooking)	303	7/8/2016	0837	P	3.90	P	1.40
SAC-03-TF-64	TF	Teacher's lounge sinks	301	7/8/2016	0843	P	12.4	P	1.91
SAC-BS-KF-65	KF	Kitchen faucets	27	7/8/2016	0645	P	3.76	P	5.95

**Westwood PreK-5**

# Lead in Drinking Water Sample Results

School: Pittsburgh Westwood K-5

Address: 508 Shadyhill Road Pittsburgh, PA 15205

Total fixtures tested<sup>#</sup>: 32

Total samples collected: 62

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
WWD-GF-SL-00	GF	SL	Service Line	115	6/22/2016	0637	P	4.89		
WWD-GF-WM-00	GF	WM	Water Main	115	6/22/2016	0638	P	3.39		
WWD-GF-CF-04	GF	CF	Classroom faucets	106	6/22/2016	0642	P	2.84	P	1.41
WWD-GF-WC-06	GF	WC	Water fountain with cooler	110C	6/22/2016	0648	P	< 1.00	P	< 1.00
WWD-GF-WC-07	GF	WC	Water fountain with cooler	110C	6/22/2016	0649	P	< 1.00	P	< 1.00
WWD-GF-TF-11	GF	TF	Teacher's lounge sinks	109	6/22/2016	0655	P	1.65	P	< 1.00
WWD-GF-CF-13	GF	CF	Classroom faucets	104	6/22/2016	0658	P	3.36	P	< 1.00
WWD-GF-CF-14	GF	CF	Classroom faucets	120	6/22/2016	0703	P	1.55	P	< 1.00
WWD-GF-WO-15	GF	WO	Water fountain without cooler	120	6/22/2016	0704	P	3.39	P	< 1.00
WWD-GF-WC-16	GF	WC	Water fountain with cooler	110	6/22/2016	0710	P	< 1.00	P	< 1.00
WWD-GF-WC-17	GF	WC	Water fountain with cooler	110	6/22/2016	0711	P	< 1.00	P	< 1.00
WWD-GF-CF-27	GF	CF	Classroom faucets	102	6/22/2016	0719	P	7.31	P	< 1.00
WWD-GF-CF-31	GF	CF	Classroom faucets	100	6/22/2016	0722	P	3.95	P	< 1.00
WWD-GF-CF-32	GF	CF	Classroom faucets	127	6/22/2016	0726	P	1.22	P	< 1.00
WWD-GF-CF-33	GF	CF	Classroom faucets	127	6/22/2016	0727	P	3.11	P	< 1.00
WWD-01-WC-34	01	WC	Water fountain with cooler		6/22/2016	0736	P	< 1.00	P	< 1.00
WWD-01-WC-35	01	WC	Water fountain with cooler		6/22/2016	0737	P	< 1.00	P	< 1.00
WWD-01-CF-36	01	CF	Classroom faucets	208	6/22/2016	0743	P	5.50	P	< 1.00
WWD-01-CF-37	01	CF	Classroom faucets	206	6/22/2016	0745	P	7.63	P	< 1.00
WWD-01-CF-38	01	CF	Classroom faucets	209	6/22/2016	0747	P	3.17	P	1.58
WWD-01-CF-40	01	CF	Classroom faucets	212	6/22/2016	0754	P	8.61	P	< 1.00
WWD-01-WO-41	01	WO	Water fountain without cooler	212	6/22/2016	Non-Operational				

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
WWD-01-CF-42	01	CF	Classroom faucets	204	6/22/2016	0758	P	8.91	P	< 1.00
WWD-01-WC-50	01	WC	Water fountain with cooler		6/22/2016	0802	P	< 1.00	P	< 1.00
WWD-01-WC-51	01	WC	Water fountain with cooler		6/22/2016	0803	P	< 1.00	P	< 1.00
WWD-01-KF-57	01	KF	Kitchen faucets	221	6/22/2016	0807	P	< 1.00	P	< 1.00
WWD-01-KF-58	01	KF	Kitchen faucets	221	6/22/2016	0808	P	1.23	P	1.81
WWD-01-CF-59	01	CF	Classroom faucets	202	6/22/2016	0818	P	3.03	P	< 1.00
WWD-01-CF-60	01	CF	Classroom faucets	201	6/22/2016	0824	P	1.04	P	< 1.00
WWD-01-WO-61	01	WO	Water fountain without cooler	201	6/22/2016	0825	P	< 1.00	P	< 1.00
WWD-01-CF-62	01	CF	Classroom faucets	201A	6/22/2016	0827	P	< 1.00	P	< 1.00
WWD-01-WO-63	01	WO	Water fountain without cooler	201A	6/22/2016	0829	P	< 1.00	P	< 1.00
WWD-01-OF-64	01	OF	Office sink faucets	222-A	6/22/2016	0837	P	5.17	P	< 1.00

**Whittier K-5**



## Lead in Drinking Water Sample Results

School: Pittsburgh Whittier K-5

Address: 150 Meridan Street Pittsburgh, PA 15211

Total fixtures tested #: 27

Total samples collected: 52

Fixture ID	School Code	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
WHI-SB-SL-00	WHI	SB	SL	Service Line	B-1	6/29/2016	0625	P	2.54		
WHI-SB-WM-00	WHI	SB	WM	Water Main	B-1	6/29/2016	0626	P	1.21		
WHI-BS-OF-02	WHI	BS	OF	Office sink faucets	10	6/29/2016	0628	P	1.71	P	<1.00
WHI-BS-CF-03	WHI	BS	CF	Classroom faucets	9	6/29/2016	0631	P	1.86	P	<1.00
WHI-BS-WB-05	WHI	BS	WB	Water fountain bubbler (Ceramic or Porcelain)	Bottom of	6/29/2016	0635	P	1.27	P	<1.00
WHI-01-WC-09	WHI	01	WC	Water fountain with cooler	Outside Boys	6/29/2016	0647	P	<1.00	P	<1.00
WHI-01-WC-12	WHI	01	WC	Water fountain with cooler	Boys	6/29/2016	0649	P	1.70	P	1.17
WHI-01-IM-15	WHI	01	IM	Ice machines	114	6/29/2016	0654	P	2.97	P	1.45
WHI-01-NF-16	WHI	01	NF	Nurse's office sink faucets	114	6/29/2016	0656	P	1.68	P	1.12
WHI-01-OF-19	WHI	01	OF	Office sink faucets	107	6/29/2016	0702	P	2.27	P	<1.00
WHI-01-KF-20	WHI	01	KF	Kitchen faucets	Kitchen	6/29/2016	0705	P	2.99	P	1.01
WHI-01-CF-22	WHI	01	CF	Classroom faucets	103	6/29/2016	0710	P	4.93	P	1.26
WHI-01-WC-23	WHI	01	WC	Water fountain with cooler	Girls	6/29/2016	0715	P	<1.00	P	1.19
WHI-01-WC-25	WHI	01	WC	Water fountain with cooler	Outside Girls	6/29/2016	0717	P	1.39	P	<1.00
WHI-01-CF-29	WHI	01	CF	Classroom faucets	102	6/29/2016	0723	P	11.9	P	2.77
WHI-01-CF-30	WHI	01	CF	Classroom faucets	102	6/29/2016	0726	P	7.54	P	2.35
WHI-01-WB-32	WHI	01	WB	Water fountain bubbler (Ceramic or Porcelain)	101A	6/29/2016	0730	P	1.52	P	<1.00
WHI-01-OF-33	WHI	01	OF	Office sink faucets	101B	6/29/2016	0735	P	2.24	P	1.14
WHI-02-CF-34	WHI	02	CF	Classroom faucets	205	6/29/2016	0742	P	8.08	P	1.32
WHI-02-CF-35	WHI	02	CF	Classroom faucets	205	6/29/2016	0744	P	4.91	P	<1.00
WHI-02-WC-36	WHI	02	WC	Water fountain with cooler	Outside Boys	6/29/2016	0748	P	1.47	P	1.40
WHI-02-WC-39	WHI	02	WC	Water fountain with cooler	200BT	6/29/2016	0752	P	1.60	P	<1.00
WHI-02-CF-41	WHI	02	CF	Classroom faucets	208	6/29/2016	0755	P	1.80	P	2.54
WHI-02-TF-43	WHI	02	TF	Teacher's lounge sinks	209	6/29/2016	0759	P	1.86	P	1.15
WHI-02-WC-44	WHI	02	WC	Water fountain with cooler	200GT	6/29/2016	0805	P	1.24	P	1.61
WHI-02-WC-46	WHI	02	WC	Water fountain with cooler	Outside Girls	6/29/2016	0808	P	<1.00	P	1.29
WHI-02-CF-50	WHI	02	CF	Classroom faucets	202	6/29/2016	0812	P	1.21	P	<1.00

**Woolslair K-5**

# Lead in Drinking Water Sample Results

School: Pittsburgh Woolslair K-5

Address: 501 40th Street Pittsburgh, PA 15224

Total fixtures tested<sup>#</sup>: 28

Total samples collected: 58

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
WOL-BS-SL-00	BS	SL	Service Line	G1C	6/21/2016	0609	P	1.14		
WOL-BS-WM-00	BS	WM	Water Main	G1C	6/21/2016	0610	P	1.37		
WOL-BS-WO-01	BS	WO	Water fountain without cooler	B1A	6/21/2016	0613	P	<1.00	P	1.37
WOL-BS-WO-02	BS	WO	Water fountain without cooler	B1A	6/21/2016	0614	P	1.21	P	1.25
WOL-BS-NF-03	BS	NF	Nurse's office sink faucets	G14	6/21/2016	0617	P	3.87	P	1.03
WOL-BS-KF-04	BS	KF	Kitchen faucets	G10	6/21/2016	0620	P	2.14	P	<1.00
WOL-BS-KF-05	BS	KF	Kitchen faucets	G10	6/21/2016	0621	P	13.7	P	2.46
WOL-BS-CF-11	BS	CF	Classroom faucets	G3	6/21/2016	0625	P	6.15	P	2.11
WOL-BS-CF-14	BS	CF	Classroom faucets	G7	6/21/2016	0633	P	1.11	P	2.54
WOL-BS-CF-15	BS	CF	Classroom faucets	G6	6/21/2016	0635	P	1.21	P	<1.00
WOL-BS-WO-16	BS	WO	Water fountain without cooler	B1B	6/21/2016	0638	P	1.33	P	1.19
WOL-BS-WO-17	BS	WO	Water fountain without cooler	B1B	6/21/2016	0640	P	1.2	P	1.21
WOL-BS-CF-19	BS	CF	Classroom faucets	G5	6/21/2016	0643	P	6.66	P	2.27
WOL-01-WO-20	01	WO	Water fountain without cooler	100A	6/21/2016	0648	P	2.16	P	2.16
WOL-01-WO-21	01	WO	Water fountain without cooler	100A	6/21/2016	0649	P	1.66	P	1.85
WOL-01-CF-23	01	CF	Classroom faucets	103	6/21/2016	0654	P	3.69	P	1.34
WOL-01-CF-24	01	CF	Classroom faucets	103	6/21/2016	0655	P	1.58	P	1.29
WOL-01-OF-27	01	OF	Office sink faucets	110	6/21/2016	0700	P	10.5	P	2.21
WOL-01-WO-31	01	WO	Water fountain without cooler		6/21/2016	0705	P	1.62	P	2.41
WOL-01-WO-32	01	WO	Water fountain without cooler		6/21/2016	0706	P	1.72	P	1.55
WOL-01-OF-33	01	OF	Office sink faucets	104D	6/21/2016	0709	F	40.7	P	4.95
WOL-02-CF-34	02	CF	Classroom faucets	201B	6/21/2016	0714	P	10.5	P	4.63

Fixture ID	Building Level	Fixture Symbol	Fixture Type	Plan Room Location	Sample Date	Sample Time	First Draw (fixture assembly) (A)	First Draw Lead Concentration (ppb)	Second Draw (plumbing) (B)	Second Draw Lead Concentration (ppb)
WOL-02-WO-36	02	WO	Water fountain without cooler	200A	6/21/2016	0716	P	10.1	P	4.14
WOL-02-WO-37	02	WO	Water fountain without cooler	200A	6/21/2016	0717	P	7.67	P	3.50
WOL-02-CF-38	02	CF	Classroom faucets	203	6/21/2016	0722	P	2.64	P	1.58
<b>WOL-02-TF-45</b>	<b>02</b>	<b>TF</b>	<b>Teacher's lounge sinks</b>	<b>208</b>	<b>6/21/2016</b>	<b>0726</b>	<b>F</b>	<b>22.3</b>	P	9.75
<b>WOL-02-CF-46</b>	<b>02</b>	<b>CF</b>	<b>Classroom faucets</b>	<b>207A</b>	<b>6/21/2016</b>	<b>0730</b>	<b>F</b>	<b>40.8</b>	P	18.3
WOL-02-CF-47	02	CF	Classroom faucets	207B	6/21/2016	0732	P	1.64	P	1.12
WOL-02-WO-48	02	WO	Water fountain without cooler	200B	6/21/2016	0735	P	2.69	P	1.68
WOL-02-WO-49	02	WO	Water fountain without cooler	200B	6/21/2016	0736	P	1.89	P	1.33