

November 30, 2020

Mr. Gerhard Leuer
Director of Facilities
Medina Central School District
1 Mustang Drive
Medina, NY 14103

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Leuer:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Medina Central School District, including:

- Oak Orchard Elementary School – 335 West Oak Street, Medina, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on October 14, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 5 sources of potable water in Oak Orchard Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Medina Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

Medina Central School District

Prepared by:



**3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM**

Conditions as of October 14, 2020

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Medina Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Oak Orchard Elementary School – 335 West Oak Street, Medina, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Oak Orchard Elementary School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Oak Orchard Elementary School	10/14/2020	118	113	5	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
155.3-1	Boiler Room Ice Machine	IM	22.3
155.3-10	Girls Locker Room Middle	Sink	27.3
155.3-20	Room 152	Sink	50.7
155.3-93	2 nd Floor Right Bathroom	Sink	30.7
155.3-98	Art Storage Room	Sink	15.2

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 20-10-04932

Received Date: 10/22/2020
Reported Date: 11/10/2020
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020L-155.3; Oak Orchard Elementary; 335 West Oak St; Medina, NY 14103

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04932-001	155.3-1	10/14/2020	BOILER ROOM IM	22.3	11/05/2020	
20-10-04932-002	155.3-2	10/14/2020	TEAM LOCKER	<1.00	11/05/2020	
20-10-04932-003	155.3-3	10/14/2020	BOYS LOCKER ROOM	1.95	11/05/2020	
20-10-04932-004	155.3-4	10/14/2020	BOYS LOCKER ROOM	3.92	11/05/2020	
20-10-04932-005	155.3-5	10/14/2020	BOYS LOCKER ROOM DF	<1.00	11/05/2020	
20-10-04932-006	155.3-6	10/14/2020	COACHES OFFICE	<1.00	11/06/2020	
20-10-04932-007	155.3-7	10/14/2020	COACHES OFFICE	1.26	11/06/2020	
20-10-04932-008	155.3-8	10/14/2020	GIRLS LOCKER ROOM	11.8	11/06/2020	
20-10-04932-009	155.3-9	10/14/2020	GIRLS LOCKER ROOM DF	<1.00	11/06/2020	
20-10-04932-010	155.3-10	10/14/2020	GIRLS LOCKER ROOM	27.3	11/06/2020	
20-10-04932-011	155.3-11	10/14/2020	KITCHEN SINK	3.05	11/06/2020	
20-10-04932-012	155.3-12	10/14/2020	KITCHEN SPRAYER	<1.00	11/06/2020	
20-10-04932-013	155.3-13	10/14/2020	DOUBLE SINK	1.32	11/06/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04932

Project/Test Address: 2020L-155.3; Oak Orchard Elementary; 335 West Oak St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04932-014	155.3-14	10/14/2020	DOUBLE SINK	4.26	11/06/2020	
20-10-04932-015	155.3-15	10/14/2020	POT FILL	12.4	11/06/2020	
20-10-04932-016	155.3-16	10/14/2020	FACULTY BR	2.05	11/06/2020	
20-10-04932-017	155.3-17B	10/14/2020	CAFE DFB	<1.00	11/06/2020	
20-10-04932-018	155.3-18B	10/14/2020	CAFE DFB	<1.00	11/06/2020	
20-10-04932-019	155.3-19	10/14/2020	ROOM 151	1.21	11/06/2020	
20-10-04932-020	155.3-20	10/14/2020	ROOM 152	50.7	11/06/2020	
20-10-04932-021	155.3-21	10/14/2020	ROOM 153	2.47	11/06/2020	
20-10-04932-022	155.3-22	10/14/2020	ROOM 154	5.46	11/06/2020	
20-10-04932-023	155.3-23	10/14/2020	ROOM 155	<1.00	11/06/2020	
20-10-04932-024	155.3-24	10/14/2020	ROOM 156	5.56	11/06/2020	
20-10-04932-025	155.3-25	10/14/2020	ROOM 157	2.38	11/06/2020	
20-10-04932-026	155.3-26	10/14/2020	BOYS BR	1.64	11/06/2020	
20-10-04932-027	155.3-27	10/14/2020	BOYS BR	3.36	11/06/2020	
20-10-04932-028	155.3-28	10/14/2020	BOYS BR	<1.00	11/06/2020	
20-10-04932-029	155.3-29B	10/14/2020	DFB NEAR BATHROOMS	<1.00	11/06/2020	
20-10-04932-030	155.3-30	10/14/2020	GIRLS BR	6.31	11/06/2020	
20-10-04932-031	155.3-31	10/14/2020	GIRLS BR	2.75	11/06/2020	
20-10-04932-032	155.3-32	10/14/2020	GIRLS BR	4.53	11/06/2020	
20-10-04932-033	155.3-33	10/14/2020	ROOM 159	12.1	11/06/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04932

Project/Test Address: 2020L-155.3; Oak Orchard Elementary; 335 West Oak St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04932-034	155.3-34	10/14/2020	ROOM 160	4.51	11/06/2020	
20-10-04932-035	155.3-35	10/14/2020	ROOM 161	1.73	11/06/2020	
20-10-04932-036	155.3-36	10/14/2020	ROOM 162	1.94	11/06/2020	
20-10-04932-037	155.3-37	10/14/2020	ROOM 163	<1.00	11/06/2020	
20-10-04932-038	155.3-38	10/14/2020	ROOM 164	<1.00	11/06/2020	
20-10-04932-039	155.3-39	10/14/2020	PRINCIPLE BR	<1.00	11/06/2020	
20-10-04932-040	155.3-40	10/14/2020	PRINCIPLE OFFICE	1.87	11/06/2020	
20-10-04932-041	155.3-41B	10/14/2020	DFB NEAR PRINCIPLE	<1.00	11/06/2020	
20-10-04932-042	155.3-42	10/14/2020	BR NEAR HALLWAY	2.13	11/06/2020	
20-10-04932-043	155.3-43	10/14/2020	BR NEAR VESTIBULE	1.23	11/06/2020	
20-10-04932-044	155.3-44	10/14/2020	NURSES	<1.00	11/06/2020	
20-10-04932-045	155.3-45	10/14/2020	NURSES	1.18	11/06/2020	
20-10-04932-046	155.3-46	10/14/2020	NURSES	2.53	11/06/2020	
20-10-04932-047	155.3-47	10/14/2020	PRINTING ROOM	2.34	11/06/2020	
20-10-04932-048	155.3-48	10/14/2020	BR LEFT OF PRINTING	1.38	11/06/2020	
20-10-04932-049	155.3-49	10/14/2020	BR RIGHT OF PRINTING	<1.00	11/06/2020	
20-10-04932-050	155.3-50B	10/14/2020	DFB IN PLAY ROOM	<1.00	11/06/2020	
20-10-04932-051	155.3-51	10/14/2020	LIBRARY BR	<1.00	11/06/2020	
20-10-04932-052	155.3-52	10/14/2020	LIBRARY BR	<1.00	11/06/2020	
20-10-04932-053	155.3-53	10/14/2020	LIBRARY BACKROOM	<1.00	11/06/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04932

Project/Test Address: 2020L-155.3; Oak Orchard Elementary; 335 West Oak St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04932-054	155.3-54	10/14/2020	LIBRARY DF	3.86	11/06/2020	
20-10-04932-055	155.3-55	10/14/2020	LIBRARY DF	3.29	11/06/2020	
20-10-04932-056	155.3-56	10/14/2020	ROOM 115	1.28	11/06/2020	
20-10-04932-057	155.3-57	10/14/2020	ROOM 115	1.62	11/06/2020	
20-10-04932-058	155.3-58	10/14/2020	ROOM 115	<1.00	11/06/2020	
20-10-04932-059	155.3-59	10/14/2020	ROOM 116	<1.00	11/06/2020	
20-10-04932-060	155.3-60	10/14/2020	ROOM 116	<1.00	11/06/2020	
20-10-04932-061	155.3-61	10/14/2020	ROOM 116	<1.00	11/06/2020	
20-10-04932-062	155.3-62	10/14/2020	ROOM 117	<1.00	11/06/2020	
20-10-04932-063	155.3-63	10/14/2020	ROOM 117	<1.00	11/06/2020	
20-10-04932-064	155.3-64	10/14/2020	ROOM 117	1.50	11/06/2020	
20-10-04932-065	155.3-65	10/14/2020	ROOM 118	2.74	11/09/2020	
20-10-04932-066	155.3-66	10/14/2020	ROOM 118	2.05	11/09/2020	
20-10-04932-067	155.3-67	10/14/2020	ROOM 118	<1.00	11/09/2020	
20-10-04932-068	155.3-68	10/14/2020	ROOM 119	1.94	11/09/2020	
20-10-04932-069	155.3-69	10/14/2020	ROOM 119	<1.00	11/09/2020	
20-10-04932-070	155.3-70	10/14/2020	ROOM 119	3.30	11/09/2020	
20-10-04932-071	155.3-71	10/14/2020	ROOM 120	<1.00	11/09/2020	
20-10-04932-072	155.3-72	10/14/2020	ROOM 120	1.04	11/09/2020	
20-10-04932-073	155.3-73	10/14/2020	ROOM 120	1.44	10/30/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04932

Project/Test Address: 2020L-155.3; Oak Orchard Elementary; 335 West Oak St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04932-074	155.3-74	10/14/2020	ROOM 121	<1.00	11/09/2020	
20-10-04932-075	155.3-75	10/14/2020	ROOM 121	2.06	11/09/2020	
20-10-04932-076	155.3-76	10/14/2020	ROOM 121	2.37	10/30/2020	
20-10-04932-077	155.3-77	10/14/2020	ROOM 122	1.34	11/09/2020	
20-10-04932-078	155.3-78	10/14/2020	ROOM 122	1.92	11/09/2020	
20-10-04932-079	155.3-79	10/14/2020	ROOM 122	<1.00	11/09/2020	
20-10-04932-080	155.3-80	10/14/2020	ROOM 123	1.03	11/09/2020	
20-10-04932-081	155.3-81	10/14/2020	ROOM 123	1.83	11/09/2020	
20-10-04932-082	155.3-82	10/14/2020	ROOM 123	<1.00	11/09/2020	
20-10-04932-083	155.3-83	10/14/2020	ROOM 124	<1.00	11/09/2020	
20-10-04932-084	155.3-84	10/14/2020	ROOM 124	1.50	11/09/2020	
20-10-04932-085	155.3-85	10/14/2020	ROOM 124	1.18	11/09/2020	
20-10-04932-086	155.3-86	10/14/2020	ROOM 125	<1.00	11/09/2020	
20-10-04932-087	155.3-87	10/14/2020	ROOM 125	1.96	11/09/2020	
20-10-04932-088	155.3-88	10/14/2020	ROOM 125	1.91	11/09/2020	
20-10-04932-089	155.3-89	10/14/2020	ROOM 126	<1.00	11/09/2020	
20-10-04932-090	155.3-90	10/14/2020	ROOM 126	<1.00	11/09/2020	
20-10-04932-091	155.3-91	10/14/2020	ROOM 126	<1.00	11/09/2020	
20-10-04932-092	155.3-92	10/14/2020	2ND FLOOR BR	2.38	11/09/2020	
20-10-04932-093	155.3-93	10/14/2020	2ND FLOOR BR	30.7	11/09/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04932

Project/Test Address: 2020L-155.3; Oak Orchard Elementary; 335 West Oak St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04932-094	155.3-94	10/14/2020	ROOM 202	4.12	11/09/2020	
20-10-04932-095	155.3-95	10/14/2020	2ND FLOOR OFFICE	<1.00	11/09/2020	
20-10-04932-096	155.3-96	10/14/2020	2ND FLOOR OFFICE	1.36	11/09/2020	
20-10-04932-097	155.3-97	10/14/2020	ART ROOM	1.38	11/09/2020	
20-10-04932-098	155.3-98	10/14/2020	ART ROOM	15.2	11/09/2020	
20-10-04932-099	155.3-99	10/14/2020	OFFICE 211	3.31	11/09/2020	
20-10-04932-100	155.3-100	10/14/2020	ROOM 213	3.52	11/09/2020	
20-10-04932-101	155.3-101	10/14/2020	ROOM 212	2.11	11/09/2020	
20-10-04932-102	155.3-102	10/14/2020	ROOM 215	3.83	11/09/2020	
20-10-04932-103	155.3-103	10/14/2020	ROOM 214	3.48	11/09/2020	
20-10-04932-104	155.3-104	10/14/2020	ROOM 217	4.42	11/09/2020	
20-10-04932-105	155.3-105	10/14/2020	ROOM 216	1.15	11/09/2020	
20-10-04932-106	155.3-106	10/14/2020	2ND FLOOR BOYS RR	<1.00	11/09/2020	
20-10-04932-107	155.3-107	10/14/2020	2ND FLOOR BOYS RR	1.49	11/09/2020	
20-10-04932-108	155.3-108	10/14/2020	2ND FLOOR BOYS RR	<1.00	11/09/2020	
20-10-04932-109	155.3-109B	10/14/2020	DFB NEAR BRS	<1.00	11/09/2020	
20-10-04932-110	155.3-110	10/14/2020	2ND FLOOR GIRLS RR	1.28	11/09/2020	
20-10-04932-111	155.3-111	10/14/2020	2ND FLOOR GIRLS RR	2.21	11/09/2020	
20-10-04932-112	155.3-112	10/14/2020	2ND FLOOR GIRLS RR	<1.00	11/09/2020	
20-10-04932-113	155.3-113	10/14/2020	ROOM 219	4.20	11/09/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04932

Project/Test Address: 2020L-155.3; Oak Orchard Elementary; 335 West Oak St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04932-114	155.3-114	10/14/2020	ROOM 220	5.57	11/09/2020	
20-10-04932-115	155.3-115	10/14/2020	ROOM 221	1.52	11/09/2020	
20-10-04932-116	155.3-116	10/14/2020	ROOM 222	2.59	11/09/2020	
20-10-04932-117	155.3-117	10/14/2020	ROOM 223	2.02	11/09/2020	
20-10-04932-118	155.3-118	10/14/2020	ROOM 224	1.46	11/09/2020	

Method: SM 3113B-2010

Analyst: Jennalee Hertzler

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2021
Issued April 01, 2020

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Copper, Total	SM 19, 21-23 3113B (-04,-10)
Lead, Total	SM 19, 21-23 3113B (-04,-10)



Department
of Health

Serial No.: 61514

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.3

Client: Medina CSD Contact: Gerhard Leur

Building: Oak Orchard Elementary Location: 335 West Oak St. Medina, NY 14103

LEAD

Water by SM 19, 21-23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.3-1	Boiler Room IM	IM	23:00			
155.3-2	Team Locker	Sink	23:01			
155.3-3	Boys Locker Room	Sink	23:02			
155.3-4	Boys Locker Room	Sink	23:03			
155.3-5	Boys Locker Room DF	DF	23:04			
155.3-6	Coaches Office	Sink	23:05			
155.3-7	Coaches Office	Sink	23:06			
155.3-8	Girls Locker Room	Sink	23:07			
155.3-9	Girls Locker Room DF	DF	23:08			
155.3-10	Girls Locker Room	Sink	23:09			
155.3-11	Kitchen Sink	Sink	23:10			
155.3-12	Kitchen Sprayer	Sink	23:11			
155.3-13	Double Sink	Sink	23:12			
155.3-14	Double Sink	Sink	23:13			
155.3-15	Pot Fill	Sink	23:14			
155.3-16	Faculty BR	Sink	23:15			
155.3-17B	Cafe DFB	DFB	23:16			
155.3-18B	Cafe DFB	DFB	23:17			

20-10-04932



Due Date:
11/19/2020
(Thursday)
AE

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 10/14/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): Eric Henderson Jr. Date: 10-22-20 Time: 2:49 pm

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.3

Client: Medina CSD

Contact: Gerhard Leur

Building: Oak Orchard Elementary

Location: 335 West Oak St. Medina, NY 14103

LEAD

Water by SM 19, 21-23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.3-19	Room 151	Sink	23:18			
155.3-20	Room 152	Sink	23:19			
155.3-21	Room 153	Sink	23:20			
155.3-22	Room 154	Sink	23:21			
155.3-23	Room 155	Sink	23:22			
155.3-24	Room 156	Sink	23:23			
155.3-25	Room 157	Sink	23:24			
155.3-26	Boys BR	Sink	23:25			
155.3-27	Boys BR	Sink	23:26			
155.3-28	Boys BR	Sink	23:27			
155.3-29B	DFB Near Bathrooms	DFB	23:28			
155.3-30	Girls BR	Sink	23:29			
155.3-31	Girls BR	Sink	23:30			
155.3-32	Girls BR	Sink	23:31			
155.3-33	Room 159	Sink	23:32			
155.3-34	Room 160	Sink	23:33			
155.3-35	Room 161	Sink	23:34			
155.3-36	Room 162	Sink	23:35			

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 10/14/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): KTHARRIS Date: 10-22-20 Time: 2:49pm

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.3

Client: Medina CSD

Contact: Gerhard Leur

Building: Oak Orchard Elementary

Location: 335 West Oak St. Medina, NY 14103

LEAD

Water by SM 19, 21-23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.3-37	Room 163	Sink	23:36			
155.3-38	Room 164	Sink	23:37			
155.3-39	Principle BR	Sink	23:38			
155.3-40	Principle Office	Sink	23:39			
155.3-41B	DFB Near Principle	DFB	23:40			
155.3-42	BR Near Hallway	Sink	23:41			
155.3-43	BR Near Vestibule	Sink	23:42			
155.3-44	Nurses	Sink	23:43			
155.3-45	Nurses	Sink	23:44			
155.3-46	Nurses	Sink	23:45			
155.3-47	Printing Room	Sink	23:46			
155.3-48	BR Left of Printing	Sink	23:47			
155.3-49	BR Right of Printing	Sink	23:48			
155.3-50B	DFB in Play Room	DFB	23:49			
155.3-51	Library BR	Sink	23:50			
155.3-52	Library BR	Sink	23:51			
155.3-53	Library Backroom	Sink	23:52			
155.3-54	Library DF	DF	23:53			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 10/14/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): KTHARRIS Date: 10-22-20 Time: 2:49 pm

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.3

Client: Medina CSD

Contact: Gerhard Leur

Building: Oak Orchard Elementary

Location: 335 West Oak St. Medina, NY 14103

LEAD

Water by SM 19, 21-23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.3-55	Library DF	DF	23:54			
155.3-56	Room 115	Sink	23:55			
155.3-57	Room 115	Bubbler	23:56			
155.3-58	Room 115	Sink	23:57			
155.3-59	Room 116	Bubbler	23:58			
155.3-60	Room 116	Sink	23:59			
155.3-61	Room 116	Sink	0:00			
155.3-62	Room 117	Sink	0:01			
155.3-63	Room 117	Sink	0:02			
155.3-64	Room 117	Bubbler	0:03			
155.3-65	Room 118	Sink	0:04			
155.3-66	Room 118	Bubbler	0:05			
155.3-67	Room 118	Sink	0:06			
155.3-68	Room 119	Sink	0:07			
155.3-69	Room 119	Bubbler	0:08			
155.3-70	Room 119	Sink	0:09			
155.3-71	Room 120	Sink	0:10			
155.3-72	Room 120	Sink	0:11			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 10/14/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): K. HARRIS Date: 10.22.20 Time: 2:49 pm

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.3

Client: Medina CSD

Contact: Gerhard Leur

Building: Oak Orchard Elementary

Location: 335 West Oak St. Medina, NY 14103

LEAD

Water by SM 19, 21-23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.3-73	Room 120	Bubbler	0:12			
155.3-74	Room 121	Sink	0:13			
155.3-75	Room 121	Sink	0:14			
155.3-76	Room 121	Bubbler	0:15			
155.3-77	Room 122	Sink	0:16			
155.3-78	Room 122	Bubbler	0:17			
155.3-79	Room 122	Sink	0:18			
155.3-80	Room 123	Sink	0:19			
155.3-81	Room 123	Bubbler	0:20			
155.3-82	Room 123	Sink	0:21			
155.3-83	Room 124	Sink	0:22			
155.3-84	Room 124	Sink	0:23			
155.3-85	Room 124	Bubbler	0:24			
155.3-86	Room 125	Sink	0:25			
155.3-87	Room 125	Sink	0:26			
155.3-88	Room 125	Bubbler	0:27			
155.3-89	Room 126	Sink	0:28			
155.3-90	Room 126	Bubbler	0:29			

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 10/14/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): K. Harris Date: 10-22-20 Time: 2:49 pm

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name/Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.3

Client: Medina CSD

Contact: Gerhard Leur

Building: Oak Orchard Elementary

Location: 335 West Oak St. Medina, NY 14103

LEAD

Water by SM 19, 21-23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.3-91	Room 126	Sink	0:30			
155.3-92	2nd Floor BR	Sink	0:31			
155.3-93	2nd Floor BR	Sink	0:32			
155.3-94	Room 202	Sink	0:33			
155.3-95	2nd Floor Office	Bottle Fill	0:34			
155.3-96	2nd Floor Office	Sink	0:35			
155.3-97	Art Room	Sink	0:36			
155.3-98	Art Room	Sink	0:37			
155.3-99	Office 211	Sink	0:38			
155.3-100	Room 213	Sink	0:39			
155.3-101	Room 212	Sink	0:40			
155.3-102	Room 215	Sink	0:41			
155.3-103	Room 214	Sink	0:42			
155.3-104	Room 217	Sink	0:43			
155.3-105	Room 216	Sink	0:44			
155.3-106	2nd Floor Boys BR	Sink	0:45			
155.3-107	2nd Floor Boys BR	Sink	0:46			
155.3-108	2nd Floor Boys BR	Sink	0:47			

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 10/14/2020

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/15/2020

Received (Name / Lab): KTHARRIS Date: 10.22.20 Time: 2:49 pm

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

