

November 30, 2020

Mr. Gerhard Leuer
Director of Facilities
Medina Central School District
1 Mustang Drive
Medina, NY 14103

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Leuer:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Medina Central School District, including:

- Clifford H. Wise Intermediate School – 1016 Gwinn Street, Medina, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on October 14, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 2 sources of potable water in Clifford H. Wise Intermediate School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Medina Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

Medina Central School District

Prepared by:



**3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM**

Conditions as of October 14, 2020

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Medina Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Clifford H. Wise Intermediate School – 1016 Gwinn Street, Medina, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Clifford H. Wise Intermediate School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Clifford H. Wise Intermediate School	10/14/2020	81	79	2	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
155.2-51	Drinking Fountain Near Room 201	DF	80.9
155.2-79	Shop Room Storage	Sink	22.2

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 20-10-04919

Received Date: 10/22/2020
Reported Date: 11/13/2020
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020L-155.2; Clifford Wise Intermediate School; 1016 Gwinn St; Medina, NY
14103

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04919-001	155.2-1	10/14/2020	DF IN POOL	1.02	11/11/2020	
20-10-04919-002	155.2-2	10/14/2020	DF IN BOYS LOCKER	4.21	11/11/2020	
20-10-04919-003	155.2-3	10/14/2020	BOYS LOCKER	<1.00	11/11/2020	
20-10-04919-004	155.2-4	10/14/2020	DF IN GIRLS LOCKER	<1.00	11/11/2020	
20-10-04919-005	155.2-5	10/14/2020	GIRLS LOCKER	2.03	11/11/2020	
20-10-04919-006	155.2-6	10/14/2020	HOME EC	3.71	11/11/2020	
20-10-04919-007	155.2-7	10/14/2020	HOME EC	<1.00	11/11/2020	
20-10-04919-008	155.2-8	10/14/2020	HOME EC	<1.00	11/11/2020	
20-10-04919-009	155.2-9	10/14/2020	HOME EC	<1.00	11/11/2020	
20-10-04919-010	155.2-10	10/14/2020	HOME EC	3.44	11/11/2020	
20-10-04919-011	155.2-11	10/14/2020	HOME EC	<1.00	11/11/2020	
20-10-04919-012	155.2-12B	10/14/2020	DF NEAR 302	<1.00	11/11/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04919

Project/Test Address: 2020L-155.2; Clifford Wise Intermediate School; 1016
Gwinn St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04919-013	155.2-13	10/14/2020	COACHES OFFICE BR	5.37	11/11/2020	
20-10-04919-014	155.2-14	10/14/2020	DF LOCKER ROOM	1.58	11/11/2020	
20-10-04919-015	155.2-15	10/14/2020	LOCKER ROOM	<1.00	11/11/2020	
20-10-04919-016	155.2-16	10/14/2020	ROOM 300	4.38	11/11/2020	
20-10-04919-017	155.2-17	10/14/2020	BR	<1.00	11/11/2020	
20-10-04919-018	155.2-18	10/14/2020	BR	<1.00	11/11/2020	
20-10-04919-019	155.2-19	10/14/2020	KITCHEN POT FILL	4.06	11/11/2020	
20-10-04919-020	155.2-20	10/14/2020	KITCHEN SPRAYER	2.86	11/11/2020	
20-10-04919-021	155.2-21	10/14/2020	HANDWASH	1.87	11/11/2020	
20-10-04919-022	155.2-22	10/14/2020	KITCHEN BR	4.18	11/11/2020	
20-10-04919-023	155.2-23	10/14/2020	LEFT HANDWASH	2.11	11/11/2020	
20-10-04919-024	155.2-24	10/14/2020	RIGHT HANDWASH	3.51	11/11/2020	
20-10-04919-025	155.2-25	10/14/2020	SPRAYER	<1.00	11/11/2020	
20-10-04919-026	155.2-26	10/14/2020	CAFE B DF	<1.00	11/11/2020	
20-10-04919-027	155.2-27B	10/14/2020	CAFE B DFB	<1.00	11/11/2020	
20-10-04919-028	155.2-28	10/14/2020	CAFE A DF	7.00	11/11/2020	
20-10-04919-029	155.2-29	10/14/2020	CAFE A DF	7.40	11/11/2020	
20-10-04919-030	155.2-30	10/14/2020	DF NEAR CAFE A	<1.00	11/11/2020	
20-10-04919-031	155.2-31	10/14/2020	MENS BR	<1.00	11/11/2020	
20-10-04919-032	155.2-32	10/14/2020	WOMENS BR	<1.00	11/11/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04919

Project/Test Address: 2020L-155.2; Clifford Wise Intermediate School; 1016
Gwinn St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04919-033	155.2-33	10/14/2020	ROOM 124	4.76	11/11/2020	
20-10-04919-034	155.2-34	10/14/2020	ROOM 118	6.46	11/11/2020	
20-10-04919-035	155.2-35	10/14/2020	BOYS BR	<1.00	11/11/2020	
20-10-04919-036	155.2-36	10/14/2020	GIRLS BR	<1.00	11/11/2020	
20-10-04919-037	155.2-37B	10/14/2020	DFB NEAR AUDITORIUM	<1.00	11/11/2020	
20-10-04919-038	155.2-38	10/14/2020	ROOM 200	5.74	11/11/2020	
20-10-04919-039	155.2-39	10/14/2020	ROOM 200	1.60	11/11/2020	
20-10-04919-040	155.2-40	10/14/2020	DF NEAR ROOM 202	11.6	11/11/2020	
20-10-04919-041	155.2-41	10/14/2020	ROOM 202	4.39	11/11/2020	
20-10-04919-042	155.2-42	10/14/2020	BAND ROOM	10.6	11/11/2020	
20-10-04919-043	155.2-43	10/14/2020	BOYS BR	<1.00	11/11/2020	
20-10-04919-044	155.2-44	10/14/2020	BOYS BR	<1.00	11/11/2020	
20-10-04919-045	155.2-45	10/14/2020	BOYS BR	<1.00	11/11/2020	
20-10-04919-046	155.2-46	10/14/2020	GIRLS BR	<1.00	11/11/2020	
20-10-04919-047	155.2-47	10/14/2020	GIRLS BR	<1.00	11/11/2020	
20-10-04919-048	155.2-48	10/14/2020	GIRLS BR	<1.00	11/11/2020	
20-10-04919-049	155.2-49	10/14/2020	DF NEAR BRS	1.79	11/11/2020	
20-10-04919-050	155.2-50	10/14/2020	ROOM 203	1.45	11/11/2020	
20-10-04919-051	155.2-51	10/14/2020	DF NEAR ROOM 201	80.9	11/11/2020	
20-10-04919-052	155.2-52	10/14/2020	ROOM 201	3.98	11/11/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04919

Project/Test Address: 2020L-155.2; Clifford Wise Intermediate School; 1016
Gwinn St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04919-053	155.2-53	10/14/2020	BOYS BR	<1.00	11/11/2020	
20-10-04919-054	155.2-54	10/14/2020	BOYS BR	<1.00	11/11/2020	
20-10-04919-055	155.2-55	10/14/2020	BOYS BR	<1.00	11/11/2020	
20-10-04919-056	155.2-56	10/14/2020	BOYS BR	<1.00	11/11/2020	
20-10-04919-057	155.2-57	10/14/2020	GIRLS BR	<1.00	11/11/2020	
20-10-04919-058	155.2-8	10/14/2020	GIRLS BR	<1.00	11/11/2020	
20-10-04919-059	155.2-59	10/14/2020	GIRLS BR	<1.00	11/11/2020	
20-10-04919-060	155.2-60	10/14/2020	GIRLS BR	<1.00	11/11/2020	
20-10-04919-061	155.2-61B	10/14/2020	DFB NEAR BRS	<1.00	11/11/2020	
20-10-04919-062	155.2-62	10/14/2020	MENS BR	1.62	11/11/2020	
20-10-04919-063	155.2-63	10/14/2020	WOMENS BR	2.35	11/11/2020	
20-10-04919-064	155.2-64	10/14/2020	LOUNGE	1.87	11/11/2020	
20-10-04919-065	155.2-65	10/14/2020	SCIENCE STORAGE	<1.00	11/11/2020	
20-10-04919-066	155.2-66	10/14/2020	NURSES	<1.00	11/11/2020	
20-10-04919-067	155.2-67	10/14/2020	NURSES	<1.00	11/11/2020	
20-10-04919-068	155.2-68	10/14/2020	DF NEAR NURSES	2.40	11/11/2020	
20-10-04919-069	155.2-69	10/14/2020	LIBRARY	<1.00	11/11/2020	
20-10-04919-070	155.2-70	10/14/2020	COUNSELERS OFFICE	<1.00	11/11/2020	
20-10-04919-071	155.2-71	10/14/2020	ART ROOM 305	3.10	11/11/2020	
20-10-04919-072	155.2-72	10/14/2020	ART ROOM 305	3.16	11/11/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 20-10-04919

Project/Test Address: 2020L-155.2; Clifford Wise Intermediate School; 1016
Gwinn St; Medina, NY 14103

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04919-073	155.2-73	10/14/2020	HALLWAY BR	<1.00	11/11/2020	
20-10-04919-074	155.2-74B	10/14/2020	DFB NEAR ROOM 307	<1.00	11/11/2020	
20-10-04919-075	155.2-75	10/14/2020	DF LOCKER ROOM	<1.00	11/11/2020	
20-10-04919-076	155.2-76	10/14/2020	LOCKER ROOM	<1.00	11/11/2020	
20-10-04919-077	155.2-77	10/14/2020	COACHES OFFICE BR	3.37	11/11/2020	
20-10-04919-078	155.2-78	10/14/2020	SHOP ROOM	13.8	11/11/2020	
20-10-04919-079	155.2-79	10/14/2020	SHOP ROOM	22.2	11/11/2020	
20-10-04919-080	155.2-80	10/14/2020	BR NEAR BOYS LOCKER	2.29	11/11/2020	
20-10-04919-081	155.2-81	10/14/2020	BR NEAR GIRLS LOCKER	3.65	11/11/2020	

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2021
Issued April 01, 2020

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Copper, Total SM 19, 21-23 3113B (-04,-10)

Lead, Total SM 19, 21-23 3113B (-04,-10)



Department
of Health

Serial No.: 61514

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.2

Client: Medina CSD

Contact: Gerhard Leuer

Building: Clifford Wise Intermediate School

Location: 1016 Gwinn St. Medina, NY 14103

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.2-1	DF in Pool	DF	1:30			
155.2-2	DF in Boys Locker	DF	1:31			
155.2-3	Boys Locker	Sink	1:32			
155.2-4	DF in Girls Locker	DF	1:33			
155.2-5	Girls Locker	Sink	1:34			
155.2-6	Home Ec	Sink	1:35			
155.2-7	Home Ec	Sink	1:36			
155.2-8	Home Ec	Sink	1:37			
155.2-9	Home Ec	Sink	1:38			
155.2-10	Home Ec	Sink	1:39			
155.2-11	Home Ec	Sink	1:40			
155.2-12B	DF Near 302	DFB	1:41			
155.2-13	Coaches Office BR	Sink	1:42			
155.2-14	DF Locker Room	DF	1:43			
155.2-15	Locker Room	Sink	1:44			
155.2-16	Room 300	Sink	1:45			
155.2-17	BR	Sink	1:46			
155.2-18	BR	Sink	1:47			

20-10-04919



Due Date:
11/19/2020
(Thursday)
AE

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name

Stohl Env: Paul Nichols

Date: 10/14/2020

Relinquished By: Eric Henderson Jr. Print Name

Stohl Env: Eric Henderson Jr.

Date: 10/16/2020

Received (Name / Lab): KT HARRIS

Date: 10-22-20

Time: 2:15 pm

Sample Login (Name / Lab): Tina Brown Tina Brown

Date: 11/6/20

Time: 1258 PM

Analysis (Name / Lab): Dr. Henderson

Date: 11/11/20

Time: 8 pm

QA/QC Review (Name / Lab): Michael

Date: 11/13/20

Time: None

Archived / Released: QA/QC InterLAB Use:

Date:

Time:



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.2

Client: Medina CSD

Contact: Gerhard Leuer

Building: Clifford Wise Intermediate School

Location: 1016 Gwinn St. Medina, NY 14103

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.2-19	Kitchen Pot Fill	Sink	1:48			
155.2-20	Kitchen Sprayer	Sink	1:49			
155.2-21	Handwash	Sink	1:50			
155.2-22	Kitchen BR	Sink	1:51			
155.2-23	Left Handwash	Sink	1:52			
155.2-24	Right Handwash	Sink	1:53			
155.2-25	Sprayer	Sink	1:54			
155.2-26	Cafe B DF	DF	1:55			
155.2-27B	Cafe B DFB	DFB	1:56			
155.2-28	Cafe A DF	DF	1:57			
155.2-29	Cafe A DF	DF	1:58			
155.2-30	DF Near Cafe A	DF	1:59			
155.2-31	Mens BR	Sink	2:00			
155.2-32	Womens BR	Sink	2:01			
155.2-33	Room 124	Sink	2:02			
155.2-34	Room 118	Sink	2:03			
155.2-35	Boys BR	Sink	2:04			
155.2-36	Girls BR	Sink	2:05			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Paul Nichols Date: 10/14/2020

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 10/16/2020

Received (Name / Lab): KT HARRIS Date: 10/22/20 Time: 2:15pm

Sample Login (Name / Lab): Travis Brown Date: 11/6/20 Time: 10:1PM

Analysis (Name / Lab): G. Hertzler Date: 11/11/20 Time: 8 pm

QA/QC Review (Name / Lab): M. Hertzler Date: 11/13/20 Time: run

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.2

Client: Medina CSD

Contact: Gerhard Leuer

Building: Clifford Wise Intermediate School

Location: 1016 Gwinn St. Medina, NY 14103

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.2-37B	DFB Near Auditorium	DFB	2:06			
155.2-38	Room 200	Sink	2:07			
155.2-39	Room 200	Sink	2:08			
155.2-40	DF Near Room 202	DF	2:09			
155.2-41	Room 202	Sink	2:10			
155.2-42	Band Room	Sink	2:11			
155.2-43	Boys BR	Sink	2:12			
155.2-44	Boys BR	Sink	2:13			
155.2-45	Boys BR	Sink	2:14			
155.2-46	Girls BR	Sink	2:15			
155.2-47	Girls BR	Sink	2:16			
155.2-48	Girls BR	Sink	2:17			
155.2-49	DF Near BRs	DF	2:18			
155.2-50	Room 203	Sink	2:19			
155.2-51	DF Near Room 201	DF	2:20			
155.2-52	Room 201	Sink	2:21			
155.2-53	Boys BR	Sink	2:22			
155.2-54	Boys BR	Sink	2:23			

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 10/14/2020

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 10/16/2020

Received (Name / Lab): KTHARRIS Date: 10.22.20 Time: 2:15 PM

Sample Login (Name / Lab): Travis Boone Date: 11/6/20 Time: 102 PM

Analysis (Name / Lab): G. Vertigler Date: 11/11/20 Time: 8 pm

QA/QC Review (Name / Lab): McLachlan Date: 11/13/20 Time: nan

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.2

Client: Medina CSD

Contact: Gerhard Leuer

Building: Clifford Wise Intermediate School

Location: 1016 Gwinn St. Medina, NY 14103

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
155.2-55	Boys BR	Sink	2:24			
155.2-56	Boys BR	Sink	2:25			
155.2-57	Girls BR	Sink	2:26			
155.2-58	Girls BR	Sink	2:27			
155.2-59	Girls BR	Sink	2:28			
155.2-60	Girls BR	Sink	2:29			
155.2-61B	DFB Near BRs	DFB	2:30			
155.2-62	Mens BR	Sink	2:31			
155.2-63	Womens BR	Sink	2:32			
155.2-64	Lounge	Sink	2:33			
155.2-65	Science Storage	Sink	2:34			
155.2-66	Nurses	Sink	2:35			
155.2-67	Nurses	Sink	2:36			
155.2-68	DF Near Nurses	DF	2:37			
155.2-69	Library	Sink	2:38			
155.2-70	Counselors Office	Sink	2:39			
155.2-71	Art Room 305	Sink	2:40			
155.2-72	Art Room 305	Sink	2:41			

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 10/14/2020

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 10/16/2020

Received (Name / Lab): KTHARRIS Date: 10-22-20 Time: 2:15 pm

Sample Login (Name / Lab): Travis Boone Date: 11/16/20 Time: 10:40 AM

Analysis (Name / Lab): J. Hertzler Date: 11/11/20 Time: 8 pm

QA/QC Review (Name / Lab): M. Schmitt Date: 11/13/20 Time: noon

Archived / Released: QA/QC InterLAB Use: Date: Time:



Submitted to: (Lab Name) EHS

STOHL Job # 2020L-155.2

Client: Medina CSD

Contact: Gerhard Leuer

Building: Clifford Wise Intermediate School

Location: 1016 Gwinn St. Medina, NY 14103

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Paul Nichols Print Name

Stohl Env: Paul Nichols Date: 10/14/2020

Relinquished By: E. H. O. Print Name

Stohl Env: Eric Henderson Jr. Date: 10/16/2020

Received (Name / Lab):

Date: 10.22.20 Time: 2:15 pm

Sample Login (Name / Lab): Traci Horn / Lab 2

Date: 11/10/20 Time: 1:55PM

Analysis (Name / Lab): A. Hertenberg

Date: 11/11/20 Time: 8 am

QA/QC Review (Name/Lab): M. J. J. J.

Date: 1/13/20 Time: 1:00

Archived / Released: QA/QC InterLAB Use: Date: Time: