

July 17th, 2024

Dear Parents and Guardians,

We are writing to let you know that **Tuftonboro Central School** recently completed testing for lead in drinking water. This is part of an ongoing effort related to New Hampshire's House Bill 1421, which requires school and child care facilities to test for lead in drinking water and to act when lead is found at levels at or above 5 parts per billion (ppb).

Lead is a toxic heavy metal that has a range of adverse health effects if inhaled or swallowed. Lead typically enters drinking water due to the wearing away of piping, faucets, fixtures and other plumbing materials. Lead rarely occurs naturally in New Hampshire's drinking water sources (groundwater or surface water).

Because lead is tasteless, odorless and colorless in drinking water, testing is a way to learn whether lead is present. It is important to sample each faucet or water fountain that is used for drinking or food prep because test results can vary between locations.

During recent testing, we collected samples from **10** drinking water outlets (e.g., drinking fountains, classroom faucets, kitchen sinks), with **3** samples testing at or above 5 ppb, the level where action must be taken.

We have removed access to these outlets until the problem can be corrected. The table below shows a list of all of the tested outlets, their locations, sample results and our planned remediation.

All sample results and additional resources from the New Hampshire Department of Environmental Services (NHDES) can be viewed at gettheleadoutnh.org.

Sincerely,



Richard Laughton
Certified Public Water Systems Operator
Secondwind Water Systems
735 East Industrial Park Drive
Manchester, NH 03109
603-641-5767

TUFTONBORO CENTRAL SCHOOL

Outlet Number	Location	Sample Result (ppb)	Planned Remediation
12	Kitchen 2 Bay	14.4	Plumbing Corrections & Resampling
15	Kitchen Prep Sink	<1	No remediation necessary
28	Room 126 Bathroom	1.6	No remediation necessary
29	Room 126 Bubbler	5.0	No remediation necessary
38	Room 138 Boys Right	<1	No remediation necessary
55	Room 162	<1	No remediation necessary
58	161 Bottle Filler	<1	No remediation necessary
59	Maintenance Laundry	15.1	Permanently Post Non-Potable/ Hand Wash Only
60	120 Health BR	3.1	No remediation necessary
61	Kitchen Sprayer	11.4	Plumbing Corrections & Resampling