**Bessemer Academy**

| Sample ID | Sample Date | Sample Time | Fixture Type | Cadmium (ppb) | Copper (ppb) | Iron (ppb) | Lead (ppb) | Zinc (ppb) | Location | Action |
|---|---|---|---|---|---|---|---|---|---|---|
| BSM3 | 9/19/2017 | 6:11 AM | DFS | <1.00 | 460 | <500 | 2.07 | 363 | First Floor South Near Restrooms | No Action Required |
| BSM4 | 9/19/2017 | 6:12 AM | DFS | <1.00 | 358 | <500 | 1.61 | 317 | First Floor South Near Restrooms | No Action Required |
| BSM5 | 9/19/2017 | 6:13 AM | TLF | 3.85 | 831 | <500 | <1.00 | 1673 | Staff Work Room | No Action Required |
| BSM6 | 9/19/2017 | 6:14 AM | TLF | <1.00 | 183 | <500 | <1.00 | 17.1 | Staff Lounge | No Action Required |
| BSM7 | 9/19/2017 | 6:16 AM | KSF | <1.00 | 230 | <500 | 6.23 | 482 | Kitchen | No Action Required |
| BSM8 | 9/19/2017 | 6:17 AM | DFS | <1.00 | 277 | <500 | 1.39 | 118 | First Floor Near Gym | No Action Required |
| BSM9-L | 9/19/2017 | 6:18 AM | DFS | <1.00 | 119 | <500 | <1.00 | 27.3 | First Floor Near Gym Storage | No Action Required |
| BSM10-R | 9/19/2017 | 6:19 AM | DFS | <1.00 | 158 | <500 | <1.00 | 35.7 | First Floor Near Gym Storage | No Action Required |
| BSM11-L | 9/19/2017 | 6:20 AM | DFS | <1.00 | 158 | <500 | <1.00 | 5.43 | Second Floor New Wing | No Action Required |
| BSM12-R | 9/19/2017 | 6:21 AM | DFS | <1.00 | 214 | <500 | <1.00 | 7.66 | Second Floor New Wing | No Action Required |
| BSM13 | 9/19/2017 | 6:23 AM | DFS | <1.00 | 353 | <500 | <1.00 | 151 | Second Floor South Hallway Near Rm 203 | No Action Required |
| BSM14 | 9/19/2017 | 6:24 AM | DFS | <1.00 | 834 | <500 | 1.45 | 618 | Second Floor North Hallway Near Rm 205 | No Action Required |
| BSM15-L | 9/19/2017 | 6:25 AM | DFS | <1.00 | 185 | <500 | <1.00 | 17.6 | Second Floor North Hallway Near Music Rm | No Action Required |
| BSM16-R | 9/19/2017 | 6:26 AM | DFS | <1.00 | 141 | <500 | <1.00 | 13.2 | Second Floor North Hallway Near Music Rm | No Action Required |

**Fixture Type: DFS - Drinking Fountain with single faucet, DFD - Drinking Fountain with double faucet, SC - Service Connection; KS - Kitchen Sink; TL - Teachers Lounge Sink**