

Carlile Elementary School

Sample ID	Sample Date	Sample Time	Fixture Type	Cadmium (ppb)	Copper (ppb)	Iron (ppb)	Lead (ppb)	Zinc (ppb)	Location	Action
CRL1-L	9/13/2017	6:23 AM	DFD	<1.00	275	<500	<1.00	293	Cafeteria Drinking Fountain (left)	No Action Required
CRL1-R	9/13/2017	6:24 AM	DFD	<1.00	400	<500	1.90	403	Cafeteria Drinking Fountain (right)	No Action Required
CRL2	9/13/2017	6:27 AM	KSF	<1.00	541	<500	15.6	1378	Kitchen Sink Faucet	Replacing Faucet, Pipe & Shut Off Valves
CRL3	9/13/2017	6:30 AM	TLF	<1.00	572	<500	<1.00	245	Teacher Lounge Sink Faucet	No Action Required
CRL4-L	9/13/2017	6:32 AM	DFD	<1.00	25.7	<500	<1.00	548	1st Floor North Hall Drinking Fountain (left)	No Action Required
CRL4-R	9/13/2017	6:33 AM	DFD	<1.00	174	<500	1.36	298	1st Floor North Hall Drinking Fountain (right)	No Action Required
CRL5-L	9/13/2017	6:34 AM	DFD	<1.00	303	<500	2.04	457	1st Floor Mid-Hall Drinking Fountain (left)	No Action Required
CRL5-R	9/13/2017	6:36 AM	DFD	<1.00	144	<500	<1.00	360	1st Floor Mid-Hall Drinking Fountain (right)	No Action Required
CRL6-L	9/13/2017	6:37 AM	DFD	<1.00	205	<500	<1.00	328	1st Floor South Hall Drinking Fountain (left)	No Action Required
CRL6-R	9/13/2017	6:38 AM	DFD	<1.00	105	580	<1.00	141	1st Floor South Hall Drinking Fountain (right)	No Action Required
CRL7-L	9/13/2017	6:40 AM	DFD	1.00	373	<500	2.10	716	2nd Floor North Hall Drinking Fountain (left)	No Action Required
CRL7-R	9/13/2017	6:42 AM	DFD	<1.00	263	<500	1.39	330	2nd Floor North Hall Drinking Fountain (right)	No Action Required
CRL8-L	9/13/2017	6:45 AM	DFD	<1.00	230	<500	<1.00	505	2nd Floor South Hall Drinking Fountain (left)	No Action Required
CRL8-R	9/13/2017	6:46 AM	DFD	<1.00	127	<500	<1.00	341	2nd Floor South Hall Drinking Fountain (right)	No Action Required
CRL9	9/13/2017	6:48 AM	DFS	<1.00	285	<500	<1.00	495	Gym Drinking Fountain (left)	No Action Required
CRL10	9/13/2017	6:49 AM	DFS	<1.00	198	<500	4.16	482	Gym Drinking Fountain (mid)	No Action Required
CRL11	9/13/2017	6:50 AM	DFS	<1.00	155	<500	<1.00	108	Gym Drinking Fountain (right)	No Action Required
CRL12-L	9/13/2017	6:51 AM	DFD	8.47	54.0	<500	1.37	2905	Pre-K Hall Drinking Fountain (left)	Disabled
CRL12-R	9/13/2017	6:52 AM	DFD	7.98	71.8	<500	<1.00	1626	Pre-K Hall Drinking Fountain (right)	Disabled
CRL13-L	9/13/2017	6:53 AM	DFD	11.1	14.7	<500	<1.00	2562	Kinder Hall Drinking Fountain (left)	Disabled
CRL13-R	9/13/2017	6:54 AM	DFD	5.67	11.3	<500	<1.00	1656	Kinder Hall Drinking Fountain (right)	Disabled
CRL14	9/13/2017	6:56 AM	DFS	<1.00	851	<500	<1.00	303	Music Room Hall Drinking Fountain	No Action Required

Fixture Type: DFS - Drinking Fountain with single faucet, DFD - Drinking Fountain with double faucet, SC - Service Connection; KS - Kitchen Sink; TL - Teachers Lounge Sink